

Technical Site Visit Report

Prepared for: Bhaskar_Kasturi Nagar_4.375kWp_Optimizer - 4C-149

PROJECT INFORMATION

Report Number	ESV-2026-0185
Project ID	B362140B
Project Name	Bhaskar_Kasturi Nagar_4.375kWp_Optimizer
Building Name	4C-149
Billing Name	Bhaskar
Project Sector	Commercial
Project Type	With Subsidy
Sales Lead	Hariom
Site Address	4C-149, Kasturinagar, Kalyananagar- post, Bangalore- 560043
GPS Coordinates	13.00565, 77.65823
Google Maps	https://www.google.com/maps?q=13.00565,77.65823
Visit Date	2026-08-12
Visited By	K Naveen
Revision	Rev 0

CLIENT INFORMATION

Client Name	Bhaskar
Contact	+91 90084 69387

PROJECT DETAILS

Solar Rooftop System Type	On-Grid
System Capacity (kWp)	4.375
Sanction Load (kW)	4
Module Make & Capacity	Adani Topcon DCR 625 Wp

Module Length (mm)	2382
Module Width (mm)	1133
Number of Panels	7
Inverter Type	SolarEdge
Inverter Brand	Solar Edge 4 kW 1phase Optimizer
Number of Inverters	1
Number of Optimizers	7
Mounting Structure Type	RCC Flat Roof

SITE INSPECTION CHECKLIST

General

#	Question	Answer	Notes
1	Can the delivery van/truck reach the material unloading point?	Yes	-
2	Are there any obstacles at the site that could hinder material lifting?	No	-
3	Where will the Inverter, DCDB, ACDB, Battery, etc. be located?	The Inverter,DCDB,ACDB will be located near the headroom wall which is near to the proposed area	-
4	Is a canopy required for protecting the Inverters/ACDB/DCDB?	No	-
5	Did you discuss the location of the earth pits with the customer?	The earth pits are located near the corridor which is near to the north east corner	-
6	Where is the Internet Router located?	Customer scope	-
7	What's the Wi-Fi strength of the router near to the String inverter/Envoy?	Not Available / Under Construction	-
8	Did you pin the site location in your WhatsApp when you were at the site?	Yes	-

Roof Details

#	Question	Answer	Notes
1	What type of roof is present at the site?	RCC Flat Roof	-
2	Are there any obstructions on the roof that could affect the solar installation?	No	-
3	What is the angle of the panels? (in degrees)	10	-
4	In case of sloped roof, what is the slope angle of the roof? (in degrees)	N/A	-

#	Question	Answer	Notes
5	On how many roofs at the site are we installing solar?	1	-
6	If it is a Tiled roof, what is underneath the tiles?	N/A	-
7	If it is a Tiled roof with MS or Wooden rafters, is it Single-tiled or Double-tiled?	N/A	-
8	What type of mounting structure is planned?	Elevated	HDGI - Elevated
9	What is the orientation of the solar panels?	["South"]	-
10	How can the roof be accessed?	Staircase	-
11	Is the building currently under construction?	Yes	-
12	In an under-construction building, are existing conduit pipes available for AC, DC cables, and earthing?	No	-
13	What is the height of the building and how many floors does it have?	The height of the building is G+3+headroom is approximately 15 meters	-
14	Is the site photo matching with the building description?	Yes	-
15	Is there an overhead HT line passing within a 10-meter radius of the site?	No	-

Residential / Electrical

#	Question	Answer	Notes
1	What type of energy meter is currently installed?	Phase: Single, Type: Digital	-
2	Is the Meter cubicle photo matching with the previous answer?	Yes	-
3	Has the termination point in the Main meter panel been identified?	Yes	-
4	Is the Termination Point easily visible or sealed?	Visible	-
5	Is a Lightning Arrestor (LA) already available at the site?	No	-
6	Is space available for CT within Energy meter panel?	N/A	-
7	In case of an Enphase system, is the distance between the farthest micro-inverter and IQ Gateway > 50m?	N/A	-
8	Provide details of the existing CT ratings (if applicable).	N/A	-
9	In Main meter panel, is empty space available for solar meter?	No	Not Available
10	In Main meter panel, is empty space available to house the Enphase accessories or ACDB components?	N/A	-
11	Is there space available to dig DC, AC and LA earth pits?	Yes	-
12	In case of elevated structures, is an LA extension provided at the far end?	Yes	-
13	In case of elevated structures, is it with or without grouting?	With Grouting	-
14	Are there any challenges with respect to Installation and Maintenance activities?	No	-
15	Are there any safety risks associated with accessing the roof for installation?	No	-
16	Is space present in rooftop to store the panels?	Horizontally sleeping	-
17	In case of sloped roof MS structure, provide the dimension of rafter to rafter, purlin to purlin.	N/A	-

#	Question	Answer	Notes
18	Is ventilation available in the battery location?	N/A	-
19	Should the Inverters/ACDB/DCDB be installed on a metal grill or wall mount?	Wall Mount	-
20	Provide the dimensions for solar meter cubicle placement (L x W of wall).	length: 350, width: 400	-
21	Provide the dimension for earth pits location (L x W of available space).	length: 1500, width: 1500	-
22	Is LAN cable under customer scope?	No	-
23	Is there any shadow that affects the solar installation?	Yes	-
24	Is there any trench work to be done to carry the AC cable to the meter location?	No	-

PHOTO DOCUMENTATION

Cable Routing Legend

Legend	Description
	Proposed PV Module Array
	Main Meter Location
	Solar Meter
	Battery
	Inverter
	Other Equipment
	DC Cable
	AC Cable
	Material Shifting
	DC Earthing Cable
	AC Earthing Cable
	LA Cable
	DC Earth Pit
	AC Earth Pit
	LA Pit
	LA

Material Delivery Route



This route (using lifting) will be followed to carry large items (like Panels).





This route (using Staircase) will be followed to carry Small items.






Staircase Details



Meter Box



Material Storage



Proposed PV Area



Cable Routing



From the inverter location to the parapet wall, the client will provide a conduit pipe, through which the AC cable will be routed.








Make a hole to run the AC,DC,LA earthing routing till the earthing location













Equipment Location









Earth Pit Location




Site Layout - Top View







Shadow Analysis




1. From January to March, between 09:00 and 12:30 Pm, the west side headroom wall will cast a shadow on the solar panels



2. From March to November, between 01:00 and 04:30 Pm, the west side headroom wall will cast a shadow on the solar panels



3. From September to December, between 02:00 and 04:30 Pm, the west side headroom wall will cast a shadow on the solar panels



Building Exterior



OBSERVATIONS & RECOMMENDATIONS

Customer Scope

#	Observation
1	Wi-Fi up to the inverter location is under customer scope.
2	As per the customer scope only the panel layout, earthing, cable routing has been considered.
3	As per the customer suggestions only the inverter location has been considered.
4	From the inverter location to the parapet wall, the client will provide a conduit pipe, through which the AC cable will be routed.

THANK YOU

Dear Bhaskar,

Thank you for choosing EcoSoch Solar for your solar installation. We appreciate your trust in us and your commitment to sustainable energy. Our team is dedicated to ensuring a seamless installation experience and long-term performance of your solar system.

Should you have any questions or require further assistance, please do not hesitate to reach out to us.

Warm Regards,
Team EcoSoch

& Did You Know?

The Sun burns 600 million tonnes of hydrogen per second — and your panels get a share.

EcoSoch Solar Pvt. Ltd.

#940, Sha Arcade, 2nd Phase, NTI Layout, Kodigehalli, Bengaluru 560097

www.ecosoch.com | info@ecosoch.com