



District Water Testing Laboratory
Public Health Engineering Division Sarangarh-Bilaigarh (C.G.)
 Nagar Palika, Pin Code — 496445
 E-mail -: phelabsrgh@gmail.com

Test Report

Group- Drinking Water

Report Number- DL/PHED/SRGH/092	URL-FC13342240000001031F	Sampled by	Mr. Suresh
Sender's Name and Address:	Sender's letter No.	Q	Sender's Letter Date:
Principal Guru Dronacharya Adarsh Vidya	DL Receipt No:	083	DL Receipt Date:
Mandir, Sarangarh-Bilaigarh	Date of Analysis started	18-02-2026	Date of Analysis Completed:
			18-02-2026

Sample Details

Sl.no	Block	Sample ID	Village	Location / Source
1	Baramkela	083/2133/Feb26	Baramkela	Baramkela/Guru Dronacharya Adarsh Vidya Mandir

Details of parameters, their test method, units and specification as per IS 3025/APHA

Results

Sl.No.	Characteristics	Unit of Measurement	Test Method					
1	Turbidity	NTU	IS 3025 Part No-10 (2023)	1.3				
2	Colour	Hazen	IS 3025 Part No-04 (2023)	5				
3	Odour		IS 3025 Part No-05 (2023)	Agreeable				
4	pH	pH Scale	IS 3025 Part No-11 (2023)	7.06				
5	Total Alkalinity as CaCO ₃	mg/L	IS 3025 Part No-23 (2023)	30.29				
6	Total Dissolved Solid at 180°C±2°C	mg/L	IS 3025 Part No-16 (2023)	60				
7	Chloride as Ca ²⁺	mg/L	IS 3025 Part No-32 (2023)	10.34				
8	Total Hardness as CaCO ₃	mg/L	IS 3025 Part No-21 (2023)	45.31				
9	Calcium as Ca ²⁺	mg/L	IS 3025 Part No-40 (2023)	15.00				
10	Magnesium as Mg ²⁺	mg/L	APHA 24th 3500-Mg-B (2023)	1.91				
11	Fluoride as F ⁻	mg/L	APHA 24th 4500-F- C (2023)	0.17				

1. The report should not be produced partly or full without approval of signatory authority of legal purpose.
2. It is recommended that acceptable limit is to be implemented. Value in excess of these mentioned under "Acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source in column 7. above which the sources will have to be rejected.
3. The results refer only to tested samples and parameters.
4. This Lab does not hold any responsibility for variation in results for samples kept on hold for wants of clarification.
5. Samples will be stored a period of 10 days from date of issue of report.

Remark:- 1. Results apply to the sample as received.

2. Sampling not done by Laboratory's Staff.

Laboratory Issue No. 092/Lab/Date: 21-02-2026

Chemist/Authorized Signatory (NABL)

Page no .

Digitally signed by ASD
 Date: 2026.09.29 23:45:30 +05:30
 Reason: reason
 Location: location

District Water Testing Laboratory
Public Health Engineering Division Sarangarh-Bilaigarh (C.G.)

Nagar Palika, Pin Code — 496445

E-mail phelabsrgh@gmail.com

Test Report

Group- Drinking Water

Report No. - DL/PHED/SRGH/092	Sender's letter No.	Q	Sender's Letter Date	16-02-2026
Sender's Name and Address :- Principal Guru Dronacharya Adarsh Vidya Mandir, Sarangarh-Bilaigarh	DL Receipt No.	083	DL Receipt Date	17-02-2026
	Date of Analysis started	18-02-2026	Date of Analysis Completed	18-02-2026

Sample Details

Sl-no	Block	Sample ID	Village	Location / Source
1	Baramkela	083/2133/Feb26	Baramkela	Baramkela / Guru Dronacharya Adarsh Vidya Mandir

Details of parameters, their test method. units and specification as per IS 3025/APHA

Results

Sr.No	Characteristics	Unit of Measurement	Test Method	1					
1	Spec. Conductivity	μS/cm	IS 3025 Part No -14	100					
2	Nitrate as NO ₃ (Screening Method)	mg/L	APHA 24 th 4500-NO ₂ -B	-					
3	Iron as Fe	mg/L	APHA 24 th 3500-Fe-B	0.2					
4	Manganese as Mn ⁺	mg/L	APHA 24 th 3500-MN-B	-					
5	Sulphate as SO ₄ ²⁻	mg/L	IS 3025 Part No 24	-					
6	Residual Chlorine	mg/L	IS 3025 Part No -26	-					
7	E. Coli	CFU/ 100ml	APHA 24 th 9222 B	-					
8	Total Coliform Bacteria	CFC/ 100ml	1APHA 24 th 9222 B	-					

1. The report should not be produced partly or full without approval of signatory authority of legal purpose.

2. It is recommended that acceptable limit is to be implemented. Value in excess of these mentioned under "Acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source in column 7. above which the sources will have to be rejected.

6. The results refer only to tested samples and parameters.

7. This Lab does not hold any responsibility for variation in results for samples kept on hold for wants of clarification.

8. Samples will be stored a period of 10 days from date of issue of report.

Remark:- 1. Results apply to the sample as received.

2. Sampling not done by Laboratory's Staff.

Laboratory Issue No. 092/Lab/Date: 21-02-2026


 Chemist/Authorized Signatory (NABL)

NABL Report Limit

Details of parameters, their test method, units and specification as per IS 3025/APHA				As Per IS - 10500-2012 (Second Revision) For Drinking Water	
Sr. No.	Characteristics	Unit of Measurement	Test method	Acceptable Limit	Permissible Limit in the absence of alternate source
1	Turbidity	NTU	IS 3025 Part No-10 (2023)	1	5
2	Colour	Hazen	IS 3025 Part No -04 (2021)	5-15	No Relaxation
3	Odour		IS 3025 Part No -05 (2018)	Agreeable	Agreeable
4	pH	pH Scale	IS 3025 Part No -11 (2022)	6.5-8.5	No Relaxation
5	Total Alkalinity as CaCO ₃	mg/L	IS 3025 Part No-23 (2023)	200	600
6	Total Dissolved Solid at 180°C±2°C	mg/L	IS 3025 Part No.-16 (2023)	500	2000
7	Chloride as Cl ⁻	mg/L	IS 3025 Part No.-32 (2019)	250	1000
8	Total Hardness as CaCO ₂	mg/L	IS 3025 Part No.-21 (2019)	200	600
9	Calcium as Ca ²⁺	mg/L	IS 3025 Part No -40 (2023)	75	200
10	Magnesium as Mg ²⁺	mg/L	APHA 24 th 3500-MgB (2023)	30	100
11	Fluoride as F	mg/L	APHA 24 th 4500-F- C (2023)	1.0	1.5

Non - NABL Report Limit

Details of parameters, their test method, units and specification as per IS 3025/APHA				As Per IS - 10500-2012 (Second Revision) For Drinking Water	
Sr. No.	Characteristics	Unit of Measurement	Test method	Acceptable Limit	Permissible Limit in the absence of alternate source
1	Spec. Conductivity	μS/cm	IS 3025 Part No-14	500	2000
2	Nitrate as NO ⁻ (Screening Method)	mg/L	APHA 24 th .4500-NO2-B	45	No Relaxation
3	Iron as Fe	mg/L	APHA 24 th .3500-Fe-B	1.0	No Relaxation
4	Manganese as Mn ⁺	mg/L	APHA 24 th .3500-Mn-B	0.1	0.3
5	Sulphate as SO ₄ ²⁻	mg/L	IS 3025 Part No-24	200	400
6	Residual Chlorine	mg/L	IS 3025 Part No -26	0.2	1
7	E. Coli	CFU/ 100ml	APHA 24 th 9222 B	Ni	Ni
8	Total Coliform Bacteria	CPU/ 100ml	APHA 24 th 9222 B	Ni	Ni

D:\Report Acceptable & Permissible Limit Report.docx

