

DISTRICT WATER TESTING LABORATORY

RWS&S DIVISION, CUTTACK

Email.rwssdilctc@gmail.com



TEST REPORT



MC-4440

Test Report No. DWTL – TR-182 /2026

Date of Issue :- 18.03.2026

ULR – TC112009200009300G

Sample Particulars

Details of Sampling

Name of Customer :-

PETALS INTERNATIONAL
SCHOOL, KURANGA,
CUTTACK, ODISHA

Type of Source:-

Drinking Water

Date of Sampling:-

06.02.2026

Sample Package Condition:-

Sample receive date/Time:-

07.02.2026 (11.32 AM)

a)Quality of Sample Received – 1000ml

Sample Registration Date:-

07.02.2026

b)Type of Container :-

Sampling Protocol:-

Samples are not collected by this
Laboratory.

c)Sealed / Unsealed : Sealed

Sample Collected by:-

BHUSHAN MANGARAJ

Sample Location:-

Cuttack, Odisha

Test Start Date :

07.02.2026

Test End Date : 07.02.2026

Testing Protocol :

As per APHA


TEST RESULT

Sl. No.	Test Parameters	Units	Results	Requirements		Test Method
				Acceptable Limit	Permissible Limit in absence of alternate source	
1	Temperture*	°C	25.1	25.0	23 - 27	Instrumental Method
2	Colour*	CU	1	5 CU	15 CU	Visual Comparison Method (APHA,23rd Ed – 2120 B)
3	Odour*		Agreeabl e	Agreeable	Agreeable	Observation Method (APHA,23rd Ed – 2150 B)
4	Taste*		Agreeabl e	Agreeable	Agreeable	Observation Method (APHA,23rd Ed – 2160 B)
5	pH	pH Unit	6.83	6.5 to 8.5	No relaxation	Electrometric Method (APHA 23 rd Ed 4500-H+B)
6	Turbidity	NTU	0.57	1.0	5	Nephelometric Method,(APHA 23rd Ed – 2130 B)
7	Conductivity	µS/cm	78		1000	Laboratory Method(APHA 23rd Ed – 2510 B)
8	TDS*	Mg/L	50.7	500.0	2000	Calculation Method,

9	Chloride	Mg/L	18	250.0	1000	Argentometric Method (APHA 23rd Ed 4500 – Cl- B)
10	Total Alkalinity (as Ca CO ₃)	Mg/L	32	200.0	600	Titration Method (APHA 23rd Ed - 2320 B)
11	Iron	Mg/L	0.183	1.0	No relaxation	Phenanthroline Method (APHA 23rd Ed 3500-Fe B)
12	Fluoride*	Mg/L	0.158	1.0	1.5	SPADNS Method (APHA 23rd Ed 4500-F—D)
13	Total Hardness (as CaCO ₃)	Mg/L	38	200.0	600	EDTA Titrimetric Method (APHA 23rd Ed 2340 C)
14	Calcium *(as Ca)	Mg/L	7.2	75.0	200	EDTA Titrimetric Method (APHA 23rd Ed – 3500)
15	Magnesium* (as Mg)	Mg/L	4.86	30.0	100	Calculation Method (APHA 23rd Ed - 3500 Mg B)
16	Bacteriological* (Total Coliform)	MPN / 100ml	0	0.0	No relaxation	Enzyme Substrate Method
17	Free Residual Chlorine*	Mg/L	0	0.2	No relaxation	Iodometric Method (APHA 23rd Ed - 4500 Cl B)

*Note:- Unless otherwise stated the results shown in this test report refer only to the samples tested and such samples are retain for 30 days from date of issue of report. This report shall not be reported except in full without prior written approval of the District water testing laboratory, Cuttack.
This Certificate is valid for 1 year from the date of issue.*

*The parameters are not accredited by NANL


Laboratory Chemist
 Sub- Division Water Testing Laboratory
 RWS&S, Sub- Division, Cuttack

Declaration:- Results are based on the given Sample.

.....End of Report