

DISTRICT WATER TESTING LABORATORY R.W.S.&S. DIVISION.

TEL NO. 06815-279502, E-MAIL : distwtlabgjp@gmail.com

WATER ANALYSIS REPORT

No. 0114, Date. 12.02.2026

Type of Source:- Bore Well

Sampling Protocol:- Sample is not collected by this laboratory.

Sample Collected By:- Staff of the School

Sample Location:- Vikash vidya Niketan, Paralakhemundi, Gajapati


<u>TEST REPORT</u>					
Sl. No.	Name of the Parameters	Units	Results obtained	Requirements IS 10500 : 2012	
				Acceptable Limit	Permissible Limit in absence of alternate source
1	Temperature	°C	26.5		
2	Colour		Nil	Agreeable	Agreeable
3	Odour		Nil	Agreeable	Agreeable
4	pH		6.87	6.5-8.5	No relaxation
5	Turbidity	NTU	0.62	1.0	5.0
6	Conductivity	uS/cm	378.0		
7	TDS	mg/l	246.0	500	2000
8	Iron	mg/l	0.086	0.3	1.0
9	Fluoride	mg/l	0.982	1.0	1.5
10	Chloride	mg/l	24.0	250	1000
11	Alkalinity as CaCo3	mg/l	134.0	200	600
12	Hardness as CaCo3	mg/l	204.0	200	600
13	Residual* Chlorine	mg/l	0.00	0.2	1.0
14	Residual* Chlorine	MPN/100ml	<1 (0.0)	Shall not be detectable in any 100ml samples	Shall not be detectable in any 100ml samples
15	E Coli*	MPN/100ml	<1 (0.0)	Shall not be detectable in any 100ml samples	Shall not be detectable in any 100ml samples

Note- As per above parameters tested water sample is potable.

Information on Test Report:

Results relates only to samples received in the Laboratory

The test report shall not be reproduced except in full without written approval of DWTL


Laboratory Chemist

Sub- Division Water Testing Laboratory

RWS&S, Sub- Division, Paralakhemundi

Laboratory Chemist

Sub- Division Water Testing Laboratory

RWS&S, Sub- Division, Paralakhemundi