GRID CONTROLLER OF INDIA (GRID-INDIA)
NORTHERN REGIONAL LOAD DESPATCH CENTRE
DAILY OPERATION REPORT OF NORTHERN REGION

Power Supply Position in Northern Region For 02-Jun-2026

Date of Reporting:03-Jun-2026

1. Regional Availability/Demand:

Evening Peak (20:00) MW				Off-Peak (03:00) MW				Day Energy(Net MU)	
Demand Met	Shortage	Requirement	Freq (Hz)	Demand Met	Shortage	Requirement	Freq (Hz)	Demand Met	Shortage
75,060	80	75,140	49.906	60,668	0	60,668	50.042	1,601	0.75

2(A)State's Load Deails (At State Periphery) in MU:

State	State's Control Area Generation (Net MU)							Drawal Sch	Act Drawal	UI	Requirement	Shortage	Consumption
	Thermal	Hydro	Gas/Naptha/ Diesel	Solar	Wind	OthersBiomass/Co-gen etc.)	Total	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)
PUNJAB	89.53	12.99	0	4.99	0	2.47	109.98	143.59	133.74	-9.85	243.72	0	243.72
HARYANA	58.96	0.56	0	1.49	0	1.3	62.3	170.36	168.59	-1.77	230.89	0	230.89
RAJASTHAN	168.79	0.17	0.97	55.64	12.17	5.65	243.39	42.09	33.76	-8.33	277.15	0	277.15
DELHI	0	0	12.36	0	0	1.59	13.95	122.95	121.18	-1.77	135.13	0	135.13
UTTAR PRADESH	322.36	9.2	0	16.5	0	1.2	349.26	215.77	211.72	-4.05	560.98	0	560.98
UTTARAKHAND	0	13.26	0	0.63	0	0	13.89	36.99	36.6	-0.39	51.24	0.75	50.49
HIMACHAL PRADESH	0	26.33	0	0.54	0	0	26.87	9.67	11.32	1.65	38.19	0	38.19
J&K(UT) & Ladakh(UT)	0	22	0	0	0	0	22	30.97	29.03	-1.94	51.03	0	51.03
CHANDIGARH	0	0	0	0	0	0	0	6.17	6.25	0.08	6.25	0	6.25
RAILWAYS_NR ISTS	0	0	0	0	0	0	0	3.87	4.37	0.5	4.37	0	4.37
BULK CONSUMER_NR ISTS	0	0	0	0	0	0	0	1.84	2.44	0.6	2.44	0	2.44
Region	**639.64**	**84.51**	**13.33**	**79.79**	**12.17**	**12.21**	**841.64**	**784.27**	**759**	**-25.27**	**1,601.39**	**0.75**	**1,600.64**

2(B)State Demand Met (Peak and off-peak Hrs)

State	Evening Peak (20:00) MW				AVG DEMAND	Off-Peak (03:00) MW			
	Demand Met	Shortage	UI	STOA/PX/RTM Transaction	MW	Demand Met	Shortage	UI	STOA/PX/RTM Transaction
PUNJAB	10,700	0	-516	506	10,109	8,292	0	-541	-639
HARYANA	10,530	0	-315	-782	9,681	9,045	0	-60	-631
RAJASTHAN	14,017	0	36	-664	11,596	10,174	0	-372	-2,407
DELHI	5,848	0	-18	891	5,614	5,121	0	270	890
UTTAR PRADESH	27,147	0	-181	300	23,356	22,560	0	-137	1,071
UTTARAKHAND	2,460	80	37	502	2,102	2,004	0	-18	198
HIMACHAL PRADESH	1,680	0	167	-639	1,572	1,260	0	104	-56
J&K(UT) & Ladakh(UT)	2,184	0	65	-110	2,127	1,818	0	5	233
CHANDIGARH	305	0	4	-57	260	202	0	10	-95
RAILWAYS_NR ISTS	191	0	53	68	182	191	0	-1	91
BULK CONSUMER_NR ISTS	0	0	0	38	102	0	0	0	60
Region	75,062	80	-668	53	66,701	60,667	0	-740	-1,285

2(C)State's Demand Met in MWs (Maximum Demand Met and Maximum requirement of the day details)

State	Maximum Demand, corresponding shortage and requirement details for the day				Maximum requirement, corresponding shortage and demand details for the day						ACE			
	Maximum Demand Met of the day	Time	Shortage during at maximum demand	Requirement at the max demand met of the day	Maximum Requirement of the day	Time	Shortage during at maximum Requirement	Demand Met at maximum requiremnet	Min Demand Met	Time	ACE_MAX	Time	ACE_MIN	Time
PUNJAB	11,565	22:00	0	11,565	11,565	22:00	0	11,565	8,292	3:00	1,516.16	08:31:00	-266.09	15:25:00
HARYANA	11,117	22:00	0	11,117	11,117	22:00	0	11,117	8,111	7:00	496.16	18:28:00	-433.65	14:28:00
RAJASTHAN	15,034	22:00	0	15,034	15,034	22:00	0	15,034	9,962	11:00	2,308.12	19:01:00	-977.8	18:29:00
DELHI	6,630	23:00	0	6,630	6,630	23:00	0	6,630	4,410	7:00	631.11	09:31:00	-176.33	09:27:00
UP	27,331	23:00	0	27,331	27,331	23:00	0	27,331	18,376	6:00	1,619.31	18:04:00	-703.3	13:48:00
UTTARAKHA ..	2,460	20:00	80	2,540	2,540	20:00	80	2,460	1,792	11:00	427.93	18:19:00	-156.88	15:22:00
HP	1,765	7:00	0	1,765	1,765	7:00	0	1,765	1,260	3:00	222.19	19:09:00	-149.74	21:44:00
J&K(UT)&Lad ..	2,476	6:00	0	2,476	2,476	6:00	0	2,476	1,818	3:00	749.82	01:59:00	-335.13	20:04:00
CHANDIGARH	317	16:00	0	317	317	16:00	0	317	190	6:00	147.11	19:07:00	-16.84	00:17:00
RAILWAYS_NR ISTS	213	22:00	0	213	213	22:00	0	213	140	14:00	0	-	0	-
BULK CONSUMER_NR ISTS	113	21:00	0	113	113	21:00	0	113	94	7:00	-	-	-	-
NR	77,847	22:00	215	78,062	78,062	22:00	215	77,847	58,001	6:00	0	-	0	-

3(A) State Entities Generation:

CHANDIGARH

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
NIL										
Total	0	0	0					0	0	0
Total	0	0	0					0	0	0

DELHI

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
BAWANA GPS(2 * 253 + 4 * 216)	1,370	298	284	470.09	23:00	0		7.49	7.21	300
DELHI GAS TURBINES(3 * 34 + 6 * 30)	282	67	71	72.3	05:00	0		1.68	1.58	66
PRAGATI GAS TURBINES(1 * 121.2 + 2 * 104.6)	331	147	148	149.85	12:00	0		3.66	3.57	149
RITHALA GPS(3 * 36)	108	0	0	0		0				
Total GAS/NAPTHA/DIESEL	2,091	512	503					12.83	12.36	515
WIND	0	0	0	0		0				
BIOMASS(52)	52	58	60	0		0		1.61	1.59	66
SOLAR(2)	2	0	0	0		0				
Total DELHI	2,145	570	563					14.44	13.95	581

HARYANA

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
DCRTPP (YAMUNA NAGAR)(2 * 300)	600	216	245	250	01:00	168	14:00	5.08	4.62	193
JHAJJAR(CLP)(2 * 660)	1,320	1,219	1,172	1,238	00:00	742	09:00	25.48	23.85	994
MAGNUM DIESEL (IPP)(4 * 6.3)	25	0	0	0		0				
PANIPAT TPS(1 * 210 + 2 * 250)	710	657	632	664	21:00	534	12:00	14.81	13.4	558
RGTPP(KHEDAR)(2 * 600)	1,200	808	799	816	22:00	575	15:00	17.68	17.09	712
Total THERMAL	3,855	2,900	2,848					63.05	58.96	2,457
FARIDABAD GPS(1 * 156.07 + 2 * 137.75)	432	0	0	0		0				
Total GAS/NAPTHA/DIESEL	432	0	0					0	0	0
TOTAL HYDRO HARYANA(64.8)	65	20	34	35	02:00	10	13:00	0.56	0.56	23
Total HYDEL	65	20	34					0.56	0.56	23
WIND	0	0	0	0		0				
BIOMASS(106)	106	0	0	0		0		1.3	1.3	54
SOLAR(196)	196	0	0	0		0		1.49	1.49	62
Total HARYANA	4,654	2,920	2,882					66.4	62.31	2,596

HIMACHAL PRADESH

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
BAJOLI HOLI(3*60)	180	185	131	194	23:30	0		3.3	3.29	137
BASPA (IPP) HPS(3 * 100)	300	95	199	224	21:00	0		2.78	2.77	115
KUTEHAR(3 * 80)	240	215	82	242	21:00	0		3.94	3.94	164
MALANA (IPP) HPS(2 * 43)	86	51	44	51	20:00	0		0.63	0.63	26
MALANA2(2 * 50)	100	61	50	61.61	23:00	0		0.73	0.73	30
NAITWAR MORI(2 * 30)	60	40	31	41	21:00	0		0.74	0.74	31
SAWARA KUDDU(3 * 37)	111	39	0	111	08:00	0		0.61	0.61	25
OTHER HYDRO HP(503.75)	504	315	204	0		0		7.17	7.13	297
Total HYDEL	1,581	1,001	741					19.9	19.84	825
WIND	0	0	0	0		0				
BIOMASS	0	0	0	0		0				
SOLAR	198	0	0	0		0		0.54	0.54	23
SMALL HYDRO(765.25)	765	301	294	0		0		6.52	6.51	271
Total SMALL HYDRO	765	301	294					6.52	6.51	271
Total HP	2,544	1,302	1,035					26.96	26.89	1,119

J&K(UT) & LADAKH(UT)

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
GAS/DIESEL/OTHERS J&K(1 * 190)	190	0	0	0		0				
Total GAS/NAPTHA/DIESEL	190	0	0					0	0	0
BAGLIHAR (IPP) HPS(6 * 150)	900	745	745	746		0		17.9	17.9	746
OTHER HYDRO/IPP J&K(308)	308	188	174	188		0		4.11	4.11	171
Total HYDEL	1,208	933	919					22.01	22.01	917
WIND	0	0	0	0		0				
BIOMASS	0	0	0	0		0				
SOLAR	0	0	0	0		0				
SMALL HYDRO(98)	98	0	0	0		0				
Total SMALL HYDRO	98	0	0					0	0	0
Total J&K(UT)&Ladakh(UT)	1,496	933	919					22.01	22.01	917

PUNJAB

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
GOINDWAL(GVK)(2 * 270)	540	320	491	491	01:00	270	05:00	9.23	8.24	343
GURU GOBIND SINGH TPS (ROPAR)(4 * 210)	840	407	420	420	03:00	398	05:00	10.75	9.66	403
GURU HARGOBIND SINGH TPS (LEHRA MOHABBAT)(2 * 210 + 2 * 250)	920	589	805	805	01:00	570	04:00	17.05	15.69	654
RAJPURA(NPL) TPS(2 * 700)	1,400	1,320	1,320	1,320	01:00	660	09:00	27.4	26.14	1,089
TALWANDI SABO TPS(3 * 660)	1,980	1,475	1,590	1,680	22:00	924	08:00	31.99	29.81	1,242
Total THERMAL	5,680	4,111	4,626					96.42	89.54	3,731
ANANADPUR SAHIB HYDRO PLANT(2 * 33.5 + 2 * 33.5)	134	26	13	26	07:00	13	01:00	0.76	0.76	32
MUKERIAN HYDRO PLANT(6 * 15 + 6 * 19.5 + 2 * 9)	225	61	87	89	21:00	48	18:00	1.77	1.77	74
RANJIT SAGAR POWER PLANT (4 * 150)	600	600	600	600	01:00	0	07:00	7.79	7.77	324
SHANAN(4 * 15 + 1 * 50)	110	80	70	80	20:00	70	01:00	1.75	1.75	73
UBDC(3 * 15 + 3 * 15.5)	92	27	26	27	12:00	26	01:00	0.64	0.64	27
OTHER HYDRO PUNJAB	0	0	0	0		0		0.32	0.32	13
Total HYDEL	1,161	794	796					13.03	13.01	543
WIND	0	0	0	0		0				
BIOMASS(303)	303	0	0	0		0		2.47	2.47	103
SOLAR(942)	942	53	42	529	12:00	42	01:00	4.99	4.99	208
Total PUNJAB	8,086	4,958	5,464					116.91	110.01	4,585

RAJASTHAN

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
BARSINGSAR (IPP) LTPS(2 * 125)	250	110	111	111	03:00	107	10:00	2.96	2.47	103
CHHABRA TPS(2 * 660 + 4 * 250)	2,320	1,906	1,848	1,940	22:00	1,308	16:00	42.88	41.67	1,736
GIRAL (IPP) LTPS(2 * 125)	250	0	0	0		0				
KALISINDH TPS(2 * 600)	1,200	981	984	1,037	00:00	634	09:00	21.95	20.25	844
KAWAI TPS(2 * 660)	1,320	1,249	1,247	1,250	21:00	775	10:00	27.54	25.98	1,083
KOTA TPS(2 * 110 + 2 * 195 + 3 * 210)	1,240	1,002	972	1,003	21:00	736	07:00	23.34	20.63	860
RAJWEST (IPP) LTPS(8 * 135)	1,080	616	2	616	20:00	177	06:00	9.83	8.32	347
SURATGARH TPS (6 * 250 + 2 * 660(SSCTPS))	2,820	2,414	2,398	2,497	22:00	1,526	13:00	50.78	46.67	1,945
VSLPP (IPP)(1 * 135)	135	118	118	118	01:00	117.64	14:00	3.17	2.79	116
Total THERMAL	10,615	8,396	7,680					182.45	168.78	7,034
DHOLPUR GPS(3 * 110)	330	0	0	0		0				
RAMGARH GPS(1 * 110 + 1 * 35.5 + 1 * 50 + 2 * 37.5)	271	52	53	53	02:00	51	17:00	1.02	0.97	40
Total GAS/NAPTHA/DIESEL	601	52	53					1.02	0.97	40
RAPS-A(1 * 100 + 1 * 200)	300	148	149	150	06:00	147	18:00	3.92	3.67	153
Total NUCLEAR	300	148	149					3.92	3.67	153
TOTAL HYDRO RAJASTHAN(550)	550	20	0	43	00:00	0	15:00	0.18	0.17	7
Total HYDEL	550	20	0					0.18	0.17	7
WIND(1 * 4328)	4,328	200	244	1,127	07:00	144	18:00	12.17	12.17	507
BIOMASS(180)	180	82	82	82	01:00	82	06:00	1.98	1.98	83
SOLAR(8269)	8,269	45	0	6,919	13:00	2	06:00	55.64	55.64	2,318
Total RAJASTHAN	24,843	8,943	8,208					257.36	243.38	10,142

UTTAR PRADESH

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
ANPARA TPS(2 * 500 + 3 * 210)	1,630	1,349	1,344	1,354	15:00	1,077	17:00	33.3	30.9	1,288
ANPARA-C TPS(2 * 600)	1,200	887	1,112	1,116	02:00	703	08:00	24	22.4	933
ANPARA-D TPS(2 * 500)	1,000	899	934	941	01:00	672	18:00	22.8	21.4	892
BAJAJ ENERGY PVT LTD (IPP) TPS(10 * 45)	450	365	259	365	01:00	202	02:00	6.6	5.9	246
BARA PPGCL TPS(3 * 660)	1,980	1,695	1,634	1,743	23:59	1,031	08:00	38.6	35.7	1,488
GHATAMPUR TPS (2*660)	1,320	608	326	617	23:00	323	02:00	12.1	11.4	475
HARDUAGANJ TPS(1 * 110 + 2 * 250 + 1*660)	1,270	990	778	1,104	22:00	515	10:00	20.8	19	792
INFIRM POWER	660	0	0	0		0				
JAWAHARPUR TPS(2*660)	1,320	917	19	917	20:00	0	01:00	10	9.4	392
JP CHURK(3 * 60)	180	0	0	0		0				
KHURJA TPS(2 * 660)	1,320	1,363	1,286	1,392	18:18	907	14:04	29.37	27.66	1,153
LALITPUR TPS(3 * 660)	1,980	1,809	1,795	1,865	22:00	1,008	08:00	37.3	35	1,458
MEJA TPS(2 * 660)	1,320	943	781	1,223	23:00	668	08:00	24.2	22.5	938
OBRA TPS (5 * 200+2*660)	2,320	1,667	1,631	1,711	21:00	1,098	08:00	39.3	36.4	1,517
PANKI_I TPS(1 * 660)	660	615	556	629	15:00	352	10:00	13.8	13	542
PARICHA TPS(2 * 210 + 2 * 250)	920	609	488	666	23:00	478	07:00	14.1	12.8	533
ROSA TPS(4 * 300)	1,200	1,008	874	1,101	23:00	587	08:00	20.6	18.9	788
Total THERMAL	20,730	15,724	13,817					346.87	322.36	13,435
ALAKHANANDA HEP(4 * 82.5)	330	166	83	166	20:00	82	09:00	2.4	2.4	100
RIHAND HPS(6 * 50)	300	125	0	295	21:00	0	02:00	1.9	1.9	79
VISHNUPARYAG HPS(4 * 110)	440	178	150	198	22:00	123	11:00	3.5	3.5	146
OTHER HYDRO UP(227)	227	91	78	126	23:59	3	15:00	1.4	1.4	58
Total HYDEL	1,297	560	311					9.2	9.2	383
WIND	0	0	0	0		0				
BIOMASS(26)	26	0	0	0		0				
SOLAR(2729)	2,729	0	0	2,139	12:00	0	01:00	16.5	16.5	688
CO-GENERATION(1360)	1,360	50	50	50	01:00	0		1.2	1.2	50
Total OTHERs	1,360	50	50					1.2	1.2	50
Total UP	26,142	16,334	14,178					373.77	349.26	14,556

UTTARAKHAND

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
GAMMA	225	0	0	0		0				
SARAVANTI	450	0	0	0		0				
Total GAS/NAPTHA/DIESEL	675	0	0					0	0	0
OTHER HYDRO UK(1250)	1,250	821	702	821	20:00	322	15:00	13.31	13.26	553
Total HYDEL	1,250	821	702					13.31	13.26	553
WIND	0	0	0	0		0				
BIOMASS(127)	127	0	0	0		0				
SOLAR(278)	278	0	0	84	13:00	13	18:00	0.63	0.63	26
SMALL HYDRO(180)	180	0	0	0		0				
Total SMALL HYDRO	180	0	0					0	0	0
Total UTTARAKHAND	2,510	821	702					13.94	13.89	579

3(B) Regional Entities Generation

Station/Constituents	Inst. Capacity	Declared Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy				AVG. MW	UI(Actual-Schedule-(+- AGC))
	(MW)	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	Gross Gen ACT (MU)	Net Gen ACT MU)	AGC(MU)		
Aravali Power Company Private Ltd														
ISTPP (JHAJJAR)(3 * 500)	1,500	1,406	1,354	713	1,506	19:45	578	03:30	22.81932	23.7	21.96	-0.08	915	-0.77932
Sub-Total	1,500	1,406	1,354	713	-	-	-	-	22.81932	23.7	21.96	-0.08	915	-0.77932
BBMB														
BHAKRA HPS(5 * 126 + 5 * 157)	1,415	1,049	1,066	538	1,072	22:00	419	14:00	14.29775	14.73	14.52	0	605	0.22225
DEHAR HPS(6 * 165)	990	480	495	330	495	22:00	165	14:00	7.96	8.29	8.07	0	336	0.11
PONG HPS(6 * 66)	396	246	250	124	250	22:00	0	14:00	2.0735	2.14	2.1	0	88	0.0265
Sub-Total	2,801	1,775	1,811	992	-	-	-	-	24.33125	25.16	24.69	0	1,029	0.35875
NHPC														
BAIRASIUL HPS(3 * 60)	180	186	183	58	187	21:00	0	12:00	1.692	1.76	1.74	0	73	0.048
CHAMERA I HPS(3 * 180)	540	545	543	357	545	22:00	0	07:00	4.99993	5	5	-0.05	208	0.05007
CHAMERA II HPS(3 * 100)	300	208	202	199	202	20:00	198	09:00	4.7736	4.78	4.76	0	198	-0.0136
CHAMERA III HPS(3 * 77)	231	240	230	181	232	23:59	121.3	19:00	4.15741	4.18	4.13	0	172	-0.02741
DHAULIGANGA HPS(4 * 70)	280	277	282	71	283	22:00	0	13:00	2.10938	2.22	2.21	0.01	92	0.09062
DULHASTI HPS(3 * 130)	390	385	380	379	381	17:00	359.7	08:00	8.92596	9.01	8.93	0	372	0.00404
KISHANGANGA(3 * 110)	330	340	340	332	341	23:00	331.5	05:00	7.95	8.02	7.99	0	333	0.04
PARBATI III HEP(4 * 130)	520	520	518	114	518	20:00	28.3	06:00	3.413	3.51	3.48	0	145	0.067
PARBATI-II(4 * 200)	800	600	604	115	604	20:00	105.8	05:00	5.555	5.89	5.64	0	235	0.085
SALAL HPS(6 * 115)	690	590	601	601	602	12:00	558	07:00	13.885	14.12	13.98	0	583	0.095
SEWA-II HPS(3 * 40)	120	130	127	0	128	21:00	0	-	0.67778	0.71	0.7	0	29	0.02222
TANAKPUR HPS(1 * 31.42 + 2 * 31.4)	94	35	38	37	93	01:00	36.31	11:00	1.0052	1.11	1.09	0	45	0.0848
URI HPS(4 * 120)	480	494	485	484	499	20:45	487	08:00	11.667	11.89	11.81	0	492	0.143
URI-II HPS(4 * 60)	240	250	246	246	247	21:00	244.85	19:00	5.72952	5.91	5.87	0	245	0.14048
Sub-Total	5,195	4,800	4,779	3,174	-	-	-	-	76.54078	78.11	77.33	-0.04	3,222	0.82922
NPCL														
NAPS(2 * 220)	440	399	433	439	443	07:00	0	-	9.576	10.35	9.37	0	390	-0.206
RAPP-D	700	615	0	0	0	-	0	-	14.76	16.21	14.9	0	621	0.14
RAPS-B(2 * 220)	440	358	390	416	420	07:00	0	-	8.60304	9.8	8.67	0	361	0.06696
RAPS-C(2 * 220)	440	417	455	462	464	08:00	0	-	10.008	11.06	10.01	0	417	0.002
Sub-Total	2,020	1,789	1,278	1,317	-	-	-	-	42.94704	47.42	42.95	0	1,789	0.00296
NTPC														
ANTA GPS(1 * 153.2 + 3 * 88.71)	419	380	0	0	0	-	0	-	0	0	-0.03	0	-1	-0.03
AURAIYA GPS(2 * 109.3 + 4 * 111.19)	663	639	0	0	0	-	0	-	0	0	-0.03	0	-1	-0.03
DADRI GPS(2 * 154.51 + 4 * 130.19)	830	800	0	0	0	-	0	-	1.58278	1.69	1.55	0	65	-0.03278
DADRI-I TPS(4 * 210)	840	560	614	0	614	20:00	0	-	4.03288	4.51	3.65	0	152	-0.38288
DADRI-II TPS(2 * 490)	1,000	469	448	358	448	20:00	0	-	8.30976	8.66	7.76	0	323	-0.54976
KOLDAM HPS(4 * 200)	800	871	872	0	872	20:00	0	-	6	6.07	6.03	0	251	0.03
RIHAND-I STPS(2 * 500)	1,000	920	1,002	985	1,007	23:00	577	09:00	20.04404	21.66	19.68	0	820	-0.36404
RIHAND-II STPS(2 * 500)	1,000	943	981	950	999	20:00	557	10:00	20.49067	21.42	20.1	-0.09	838	-0.30067
RIHAND-III STPS(2 * 500)	1,000	943	974	967	1,003	20:00	544	11:00	20.49067	21.61	20.4	-0.14	850	0.04933
SINGRAULI HYDRO(1 * 8)	8	6	6	6	6	20:00	0	-	0.1371	0.14	0.14	0	6	0.0029
SINGRAULI STPS(2 * 500 + 5 * 200)	2,000	1,853	2,025	1,893	2,025	20:00	0	-	39.75218	43.46	39.94	0	1,664	0.18782
TANDA TPS(4 * 110)	440	-	0	0	0	-	0	-	-	-	-	-	-	-
TANDA TPS STAGE-II(2 * 660)	1,320	1,238	1,239	1,208	1,239	20:00	0	-	25.17305	26.66	24.86	0	1,036	-0.31305
UNCHAHAR II TPS(2 * 210)	420	375	419	400	430	19:30	239	16:00	7.11138	7.94	7.07	0	295	-0.04138
UNCHAHAR III TPS(1 * 210)	210	189	203	212	212	03:00	116	15:00	3.55439	3.95	3.58	0.02	149	0.00561
UNCHAHAR IV TPS(1 * 500)	500	466	489	492	500	21:30	262	15:00	8.81474	9.41	8.82	0.01	368	-0.00474
UNCHAHAR TPS(2 * 210)	420	378	418	419	432	23:00	239	08:30	7.12151	7.93	6.86	0	286	-0.26151
Sub-Total	12,870	11,030	9,690	7,890	-	-	-	-	172.61515	185.11	170.38	-0.2	7,101	-2.03515
SJVNL														
NATHPA-JHAKRI HPS(6 * 250)	1,500	1,630	1,638	440	1,638	20:00	0	11:00	14.48985	14.68	14.56	-0.07	607	0.14015
RAMPUR HEP(6 * 68.67)	412	449	438	126	440	22:00	0	11:00	3.99067	4.13	4.09	0	170	0.09933
Sub-Total	1,912	2,079	2,076	566	-	-	-	-	18.48052	18.81	18.65	-0.07	777	0.23948
THDC														
KOTESHWAR HPS(4 * 100)	400	90	98	65	101	21:00	63	11:00	1.5175	1.55	1.54	0	64	0.0225
TEHRI HPS(4 * 250)	1,000	354	380	121	380	20:00	0	07:00	2.6515	2.79	2.78	0.01	116	0.1185
Sub-Total	1,400	444	478	186	-	-	-	-	4.169	4.34	4.32	0.01	180	0.141
Total	27,698	23,323	21,466	14,838					361.90306	382.65	360.28	-0.38	15,013	-1.24306

IPP/JV

Station/Constituents	Inst. Capacity	Declared Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW	UI
	(MW)	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	Gross Gen(MU)	Net Gen(MU)		
IPP													
ADHPL(IPP) HPS(2 * 96)	192	99	102	93	178	23:00	0	-	1.7192	1.76	1.75	73	0.0308
BUDHIL HPS (IPP)(2 * 35)	70	69	72	35	72	20:00	25.79	02:00	0.93775	0.97	0.96	40	0.02225
KARCHAM WANGTOO HPS(4 * 261.25)	1,045	988	1,000	300	1,000	20:00	150	21:20	7.49097	7.7	7.65	319	0.15903
SHREE CEMENT (IPP) TPS(2 * 150 + 2 * 19 + 1 * 6)	344	330	0	0	0	-	0	-	4.13688	3.81	3.49	145	-0.64688
SAINJ HEP(2 * 50)	100	49	50	30	105	21:00	0	-	1.0148	1.05	1.03	43	0.0152
SINGOLI BHATWARI HEP(3 * 33)	99	98	60	50	60	19:15	0	-	0.95124	0.88	0.86	36	-0.09124
SORANG HYDROELECTRIC PROJECT(2 * 50)	100	98	44	30	47	22:00	0	-	0.8768	0.79	0.79	33	-0.0868
Sub-Total	1,950	1,731	1,328	538	-	-	-	-	17.12764	16.96	16.53	689	-0.59764
SOLAR IPP													
ADANI GREEN ENERGY TWENTY FIVE LIMITED	500	0	0	0	0	-	0	-	4.32423	4.12	4.12	172	-0.20423
ABC RENEWABLE ENERGY(1 * 300)	300	0	0	0	0	-	0	-	2.16294	2.06	2.06	86	-0.10294
ABC RENEWABLE ENERGY_2	550	0	0	0	0	-	0	-	0.96074	0.96	0.96	40	-0.00074
ACME CHITTORGARH SOLAR ENERGY PVT LTD(1 * 250)	250	0	0	0	203	13:12	0	-	1.55391	1.63	1.63	68	0.07609
ACME DEOGHAR SOLAR POWER PRIVATE LIMITED(ADSPPL)	300	0	0	0	315	12:55	0	-	2.31884	2.33	2.33	97	0.01116
ACME HEERGARH POWERTECH PRIVATE LIMITED(1*300)	300	0	0	0	0	-	0	-	2.28536	2.19	2.19	91	-0.09536
ACME PHALODI SOLAR ENERGY PRIVATE LIMITED(APSEPL)	300	0	0	0	312	12:24	0	-	2.26883	2.34	2.33	97	0.06117
ACME RAISAR SOLAR ENERGY PRIVATE LIMITED(ARSEPL)	300	0	0	0	293	14:04	0	-	2.32634	2.36	2.32	97	-0.00634
ACME SIKAR SOLAR PRIVATE LIMITED	300	0	0	0	0	-	0	-	2.29387	2.19	2.19	91	-0.10387
ACMEDHAULPUR POWERTECH PRIVATE LIMITED(ADPPL)	300	0	0	0	310	12:22	0	-	2.29508	2.34	2.34	98	0.04492
AMP ENERGY GREEN SIX PRIVATE LIMITED	100	0	0	0	0	-	0	-	0.35975	0.36	0.36	15	0.00025
AMP GREEN ENERGY FIVE PRIVATE LIMITED	100	0	0	0	0	-	0	-	0.86154	0.86	0.86	36	-0.00154
ADANI GREEN ENERGY TWENTY FIVE B	138	0	0	0	0	-	0	-	0.31586	0.32	0.32	13	0.00414
ADANI GREEN ENERGY TWENTY FOUR LIMITED	500	0	0	0	0	-	0	-	3.75513	3.54	3.54	148	-0.21513
ADANI RENEWABLE ENERGY RJ LIMITED (ARERJL)(1 * 200)	200	0	0	0	172	12:18	0	-	1.31054	1.34	1.34	56	0.02946
ADANI SOLAR ENERGY BARMER ONE LIMITED_FTG3	251	0	0	0	254	12:38	0	-	2.10649	1.95	1.94	81	-0.16649
ADANI SOLAR ENERGY JAISALMER TWO PRIVATE LIMITED(1*150)	150	0	0	0	149	12:15	0	-	1.06843	1.09	1.09	45	0.02157
ADANI SOLAR ENERGY JAISALMER TWO PRIVATE LIMITED (PROJECT-2)(1*150)	150	0	0	0	133	12:00	0	-	1.05097	1.08	1.08	45	0.02903
ADANI SOLAR ENERGY JODHPUR SIX PRIVATE LIMITED	50	0	0	0	0	-	0	-	0.1767	0.18	0.18	8	0.0033
ADANI SOLAR ENERGY RJ TWO PVT LTD_BHADLA(1*150)	150	0	0	0	150	10:31	0	-	1.07217	1.15	1.15	48	0.07783
ADANI SOLAR ENERGY RJ TWO PVT LTD_FATEGARH 2(1*180)	180	0	0	0	183	12:08	0	-	1.74941	1.71	1.7	71	-0.04941
ADEPT RENEWABLE TECHNOLOGIES PVT LTD(1*110)	110	0	0	0	111	14:06	0	-	0.96008	1.02	1.02	43	0.05992
ALTRA XERGI POWER PRIVATE LIMITED	380	0	0	0	371	12:48	0	-	2.8814	2.85	2.84	118	-0.0414
AMBUJA CEMENTS LIMITED	150	0	0	0	0	-	0	-	2.2831	2.18	2.18	91	-0.1031
AMP ENERGY GREEN FOUR PRIVATE LIMITED	100	0	0	0	0	-	0	-	0.31579	0.32	0.32	13	0.00421
AMPLUS AGES PRIVATE LIMITED(1*100)	100	0	0	0	79	16:02	0	-	0.64072	0.73	0.73	30	0.08928
AURAIYA SOLAR(1 * 40)	40	0	0	0	0	-	0	-	0.2402	0.27	0.26	11	0.0198
AVAADA RJHN PRIVATE LIMITED(1*240)	240	0	0	0	222	12:21	0	-	1.64187	1.7	1.7	71	0.05813
AVAADA SUNCE ENERGY PRIVATE LIMITED, BIKANER(1 * 350)	350	0	0	0	326	13:01	0	-	2.39497	2.51	2.51	105	0.11503
AVAADA SUNRAYS ENERGY PRIVATE LTD(1*320)	320	0	0	0	318	12:39	0	-	2.37731	2.43	2.43	101	0.05269
AVAADA SUSTAINABLE RJPROJECT PVT LTD(1*300)	300	0	0	0	281	12:33	0	-	2.13162	2.12	2.12	88	-0.01162
AYANA RENEWABLE POWER ONE PRIVATE LIMITED, BIKANER(300)	300	0	0	0	282	12:06	0	-	1.96848	2.23	2.23	93	0.26152
AZURE POWER FORTY THREE PRIVATE LIMITED(1 * 150 + 1 * 150 + 1 * 300)	600	0	0	0	560	12:15	0	-	4.09284	4.26	4.26	178	0.16716
AZURE POWER INDIA PVT LTD.(4 * 50)	200	0	0	0	163	12:25	0	-	1.1564	1.21	1.21	50	0.0536
AZURE POWER MAPLE PVT LTD(1*300)	300	0	0	0	256	12:30	0	-	1.98848	2.02	2.02	84	0.03152
AZURE POWER THIRTY FOUR PRIVATE LTD(1 * 130)	130	0	0	0	121	12:35	0	-	0.90351	0.91	0.91	38	0.00649
BBMB SOLAR BHIWANI	9	0	0	0	0	-	0	-	0.03431	0.03	0.05	2	0.01569

BBMB SOLAR HISSAR	2	0	0	0	0	-	0	-	0.00803	0.01	0.01	0	0.00197
BANDERWALA SOLAR PLANT LTD(1*300)	300	0	0	0	0	-	0	-	0.74995	0.75	0.75	31	0.00005
CLEAN SOLAR POWER (BHADLA) PVT LTD(1 * 300)	300	0	0	0	280	13:14	0	-	2.06325	2.23	2.23	93	0.16675
CLEAN SOLAR POWER(JODHPUR) PRIVATE LIMITED(1*250)	250	0	0	0	0	-	0	-	1.75167	1.65	1.65	69	-0.10167
DADRI SOLAR(5)	5	0	0	0	3	-	0	-	0.01968	0.02	0.02	1	0.00032
DEVIKOT SOLAR POWER NTPC	240	0	0	0	0	-	0	-	1.52486	1.42	1.42	59	-0.10486
EDEN RENEWABLE ALMA PRIVATE LIMITED	300	0	0	0	0	-	0	-	0.6872	0.68	0.68	28	-0.0072
EDEN RENEWABLE CITE PRIVATE LIMITED(1 * 300)	300	0	0	0	304	12:37	0	-	2.25369	2.34	2.34	98	0.08631
ENERGIZENT POWER PRIVATE LIMITED	69	0	0	0	0	-	0	-	0.2107	0.21	0.21	9	-0.0007
GORBEA SOLAR PRIVATE LIMITED	300	0	0	0	0	-	0	-	0.72456	0.72	0.72	30	-0.00456
GRIAN ENERGY PRIVATE LIMITED(1*100)	100	0	0	0	78	09:58	0	-	0.66768	0.73	0.73	30	0.06232
HRP GREEN POWER PRIVATE LIMITED_BHD3	244	0	0	0	0	-	0	-	0.70672	0.71	0.71	30	0.00328
IB VOGT SOLAR SEVEN PRIVATE LIMITED	300	0	0	0	0	-	0	-	0.35147	0.35	0.35	15	-0.00147
JUNIPER GREEN COSMIC PRIVATE LIMITED	100	0	0	0	98	13:05	0	-	0.76042	0.77	0.77	32	0.00958
JUNA RENEWABLE ENERGY PRIVATE LIMITED	335	0	0	0	0	-	0	-	2.5031	2.4	2.4	100	-0.1031
JUNIPER NIRJARA ENERGY PRIVATE LIMITED	50	0	0	0	31	09:29	0	-	0.20768	0.23	0.23	10	0.02232
KARNISAR SOLAR PLANT NHPC LIMITED	300	0	0	0	295	12:12	0	-	2.06414	2.34	2.33	97	0.26586
KHABA RENEWABLE ENERGY PRIVATE LIMITED_FTG3	250	0	0	0	0	-	0	-	0.39175	0.39	0.39	16	-0.00175
KHIDRAT RENEWABLE ENERGY PRIVATE LIMITED	300	0	0	0	0	-	0	-	0.75962	0.76	0.76	32	0.00038
KOLAYAT SOLAR POWER PLANT NTPC LIMITED(1*550)	550	0	0	0	0	-	0	-	3.86196	3.66	3.66	153	-0.20196
M/S ADANI SOLAR ENERGY FOUR PRIVATE LIMITED(1 * 50)	50	0	0	0	46	12:16	0	-	0.33225	0.37	0.37	15	0.03775
M/S ADANI SOLAR ENERGY JODHPUR TWO LIMITED(1 * 50)	50	0	0	0	47	12:15	0	-	0.3415	0.37	0.37	15	0.0285
M/S AZURE POWER FORTY ONE PRIVATE LIMITED(1 * 300)	300	0	0	0	0	-	0	-	2.05551	1.96	1.96	82	-0.09551
M/S. ONEVOLT ENERGY PRIVATE LIMITED(1*100)	100	0	0	0	73	15:51	0	-	0.6512	0.72	0.71	30	0.0588
MEGA SOILS RENEWABLE PRIVATE LIMITED(1 * 250)	250	0	0	0	0	-	0	-	1.48241	1.38	1.38	58	-0.10241
MEGA SURYAURJA PVT LTD(1*250)	250	0	0	0	0	-	0	-	1.8136	1.71	1.71	71	-0.1036
NTPC ANTA SOLAR PV STATION	90	0	0	0	0	-	0	-	0.65605	0.65	0.65	27	-0.00605
NTPC NOKH SOLAR PROJECT	735	0	0	0	0	-	0	-	5.88755	5.59	5.59	233	-0.29755
NTPC NIDAN SOLAR(1*296)	296	0	0	0	0	-	0	-	2.07514	1.65	1.65	69	-0.42514
NEEMBA RENEW SURYA VIHAAN PRIVATE LIMITED	200	0	0	0	0	-	0	-	0.50718	0.5	0.5	21	-0.00718
NOKHRA SOLAR POWER NTPC	300	0	0	0	0	-	0	-	2.08925	1.99	1.99	83	-0.09925
PROJECT ELEVEN RENEWABLE POWER PL_BHDL2	150	0	0	0	0	-	0	-	0.3175	0.32	0.32	13	0.0025
PROJECT SIXTEEN RENEWABLE POWER_BHDL2	150	0	0	0	0	-	0	-	0.58575	0.59	0.59	25	0.00425
RENEW DINKAR URJA PRIVATE LIMITED_BKN2	300	0	0	0	0	-	0	-	1.17435	1.17	1.17	49	-0.00435
RENEW SAMIR SHAKTI PRIVATE LIMITED_FTG3	300	0	0	0	0	-	0	-	0	-	-	-	-
RENEW SOLAR SHAKTI THREE PRIVATE LIMITED_FTG3	300	0	0	0	0	-	0	-	0	-	-	-	-
RENEW SUN BRIGHT PRIVATE LIMITED (RSBPL)(1 * 300)	300	0	0	0	275	12:34	0	-	2.12895	2.16	2.16	90	0.03105
RENEW SURYA RAVI PVT LTD(1*300)	300	0	0	0	255	12:10	0	-	1.86776	2.05	2.05	85	0.18224
RENEW SOLAR (SHAKTI FIVE) PRIVATE LIMITED_FTG3	211	0	0	0	0	-	0	-	0.15383	0.15	0.15	6	-0.00383
RENEW SOLAR ENERGY (JHARKHAND THREE) PVT LTD(300)	300	0	0	0	272	11:57	0	-	2.17158	2.17	2.17	90	-0.00158
RENEW SOLAR POWER PVT LTD(50)	50	0	0	0	227	12:11	0	-	0.37694	1.76	1.76	73	1.38306
RENEW SOLAR POWER PVT LTD. BIKANER(1 * 250)	250	0	0	0	227	12:11	0	-	1.59779	1.76	1.75	73	0.15221
RENEW SOLAR URJA PVT LIMITED(300)	300	0	0	0	271	12:33	0	-	2.11519	2.12	2.12	88	0.00481
RENEW SURYA AAYAN PRIVATE LIMITED	300	0	0	0	291	12:01	0	-	2.14894	2.2	2.19	91	0.04106
RENEW SURYA JYOTI PRIVATE LIMITED	210	0	0	0	0	-	0	-	0.52581	0.53	0.53	22	0.00419
RENEW SURYA PRATAP PRIVATE LIMITED(1*200)	200	0	0	0	198	13:04	0	-	1.49865	1.54	1.54	64	0.04135
RENEW SURYA ROSHNI PVT LTD_SOLAR(1*400)	400	0	0	0	0	-	0	-	3.05589	2.96	2.96	123	-0.09589
RENEW SURYA VIHAAN PRIVATE LIMITED	100	0	0	0	95	13:04	0	-	0.72353	0.73	0.72	30	-0.00353
RISING SUN ENERGY (K) PVT LTD(1*164)	190	0	0	0	176	12:32	0	-	1.3653	1.33	1.32	55	-0.0453
SB ENERGY FOUR PVT LTD(2 * 100)	200	0	0	0	0	-	0	-	1.17313	1.17	1.17	49	-0.00313
SB ENERGY SIX PRIVATE LIMITED(1 * 300)	300	0	0	0	290	13:00	0	-	2.08788	2.24	2.24	93	0.15212

SJVN GREEN ENERGY LIMITED	888	0	0	0	814	11:28	0	-	5.65383	7.05	6.64	277	0.98617
SERENTICA RENEWABLES INDIA 4 PRIVATE LIMITED_BKN2	168	0	0	0	0	-	0	-	1.62318	1.52	1.52	63	-0.10318
SERENTICA RENEWABLES INDIA 5 PRIVATE LIMITED	220	0	0	0	0	-	0	-	0.90952	0.91	0.91	38	0.00048
SINGRAULI SOLAR(15)	15	0	0	0	0	-	0	-	0.0666	0.05	0.05	2	-0.0166
SOLZEN URJA PRIVATE LIMITED(1 * 300)	300	0	0	0	288	12:58	0	-	2.15404	2.13	2.13	89	-0.02404
TRANSITION CLEANTECH SERVICES PRIVATE LIMITED	24	0	0	0	69	09:14	0	-	0.21062	0.57	0.57	24	0.35938
TATA POWER GREEN ENERGY LIMITED	225	0	0	0	191	11:25	0	-	1.52756	1.47	1.47	61	-0.05756
TATA POWER RENEWABLE ENERGY LTD(1 * 300)	300	0	0	0	288	12:36	0	-	2.03517	2.13	2.09	87	0.05483
TATA POWER SAURYA LIMITED	110	0	0	0	92	10:53	0	-	0.72762	0.69	0.69	29	-0.03762
THAR SURYA 1PRIVATE LIMITED(1*300)	300	0	0	0	191	13:29	0	-	1.42638	1.45	1.45	60	0.02362
TRANSITION ENERGY SERVICES PRIVATE LIMITED	60	0	0	0	0	-	0	-	0.32184	0.32	0.32	13	-0.00184
TRANSITION GREEN ENERGY PRIVATE LIMITED	100	0	0	0	83	09:14	0	-	0.2946	0.37	0.37	15	0.0754
TRANSITION SUSTAINABLE ENERGY SERVICES PVT. LTD.	50	0	0	0	52	14:13	0	-	0.43366	0.46	0.46	19	0.02634
TRANSITION SUSTAINABLE ENERGY SERVICES ONE PVT LTD	56	0	0	0	0	-	0	-	0.28404	0.28	0.28	12	-0.00404
UNCHAHAR SOLAR(10)	10	0	0	0	5	12:00	0.16	18:00	0.04303	0.04	0.04	2	-0.00303
XL XERGI POWER PRIVATE LIMITED	400	0	0	0	226	09:33	0	-	0.92883	0.94	0.93	39	0.00117
Sub-Total	**24,251**	**0**	**0**	**0**	**-**	**-**	**-**	**-**	**146.49727**	**149.48**	**148.89**	**6,205**	**2.39273**
HYBRID IPP													
AMPIN ENERGY GREEN EIGHT PRIVATE LIMITED_SOLAR	113	0	0	0	0	-	0	-	0.0065	0.01	0.01	0	0.0035
AMPIN ENERGY GREEN EIGHT PRIVATE LIMITED_WIND	44	0	0	0	0	-	0	-	0.1815	0.18	0.18	8	-0.0015
AMPIN ENERGY GREEN TEN PRIVATE LIMITED_SOLAR	110	0	0	0	0	-	0	-	0.33418	0.33	0.33	14	-0.00418
AMPIN ENERGY GREEN TEN PRIVATE LIMITED_WIND	41	0	0	0	0	-	0	-	0.18202	0.18	0.18	8	-0.00202
AMPIN ENERGY GREEN THREE PRIVATE LIMITED_SOLAR	50	0	0	0	0	-	0	-	0.14625	0.15	0.15	6	0.00375
AMPIN ENERGY GREEN THREE PRIVATE LIMITED_WIND	19	0	0	0	0	-	0	-	0.08582	0.09	0.09	4	0.00418
ADANI HYBRID ENERGY JAISALMER FOUR LIMITED SOLAR(1*600)	600	0	0	0	0	-	0	-	5.78845	5.59	5.59	233	-0.19845
ADANI HYBRID ENERGY JAISALMER FOUR LIMITED WIND(1*510)	510	0	0	0	0	-	0	-	2.37834	2.28	2.28	95	-0.09834
ADANI HYBRID ENERGY JAISALMER ONE LIMITED SOLAR(1 * 235.1 + 1 * 124.8)	360	0	0	0	351	13:25	0	-	2.83686	2.67	2.67	111	-0.16686
ADANI HYBRID ENERGY JAISALMER ONE LIMITED WIND(1 * 101)	101	0	16	54	91	07:45	0	-	0.71474	0.08	0.08	3	-0.63474
ADANI HYBRID ENERGY JAISALMER THREE LIMITED SOLAR(1*300)	300	0	0	0	0	-	0	-	2.70066	2.5	2.5	104	-0.20066
ADANI HYBRID ENERGY JAISALMER THREE LIMITED WIND(1*75)	75	0	15	24	60	08:00	0	-	0.41352	0.41	0.41	17	-0.00352
ADANI HYBRID ENERGY JAISALMER TWO LIMITED SOLAR(1*299)	300	0	0	0	300	11:45	0	-	2.77124	2.88	2.88	120	0.10876
ADANI HYBRID ENERGY JAISALMER TWO LIMITED WIND(1*75)	75	0	13	21	68	07:30	0	-	0.48125	0.05	0.05	2	-0.43125
ADANI JAISALMER ONE SEPL SOLAR(1*420)	420	0	0	0	400	12:23	0	-	3.29568	3.12	3.12	130	-0.17568
ADANI JAISALMER ONE SEPL WIND(1*105)	105	0	4	0	72	06:15	0	-	0.78852	0.44	0.44	18	-0.34852
AYANA RENEWABLE THREE PVT LTD (1*300)	300	0	0	0	301	12:10	0	-	2.14737	2.31	2.31	96	0.16263
JUNIPER GREEN STELLAR PRIVATE LIMITED_S_FTG3	185	0	0	0	0	-	0	-	0	-	-	-	-
Sub-Total	**3,708**	**0**	**48**	**99**	**-**	**-**	**-**	**-**	**25.2529**	**23.27**	**23.27**	**969**	**-1.9829**
Total	**29,909**	**1,731**	**1,376**	**637**					**188.87781**	**189.71**	**188.69**	**7,863**	**-0.18781**

STORAGE

Station/Constituents	Inst. Capacity	Declared Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW	UI
	(MW)	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	Gross Gen(MU)	Net Gen(MU)		
PUMP STORAGE													
TEHRI PSP(4 * 250)	1,000	480	508	0	508	20:00	0	-	-1.61896	3.84	-1.42	-59	0.19896
Sub-Total	1,000	480	508	0	-	-	-	-	-1.61896	3.84	-1.42	-59	0.19896
BESS													
ACME SUN POWER PRIVATE LIMITED_BESS	167	0	0	0	0	-	0	-	0.10185	0.1	0.1	4	-0.00185
ACME SURYA POWER PRIVATE LIMITED_BESS	107	0	0	0	0	-	0	-	0.02314	0.02	0.02	1	-0.00314
ACME SURYODAYA PRIVATE LIMITED_BESS	247	0	0	0	0	-	0	-	0.02392	0.02	0.02	1	-0.00392
JUNIPER GREEN STELLAR PRIVATE LIMITED_BESS_FTG4	180	0	0	0	0	-	0	-	0.1815	0.18	0.18	8	-0.0015
JUNIPER GREEN COSMIC PRIVATE LIMITED_BESS	41	0	0	0	0	-	0	-	0.09112	0.09	0.09	4	-0.00112
RENEW SURYA ROSHNI PVT LTD_BESS	23	0	0	0	0	-	0	-	0.1035	0.1	0.1	4	-0.0035
Sub-Total	765	0	0	0	-	-	-	-	0.52503	0.51	0.51	22	-0.01503
Total	1,765	480	508	0					-1.09393	4.35	-0.91	-37	0.18393

Summary Section

	Inst. Capacity	PEAK	OFF-PEAK	Day Energy		Day AVG.
				Gross Gen	Net Gen	
Total State Control Area Generation	72,420	36,781	33,951	891.79	841.7	35,075
J. Net Inter Regional Exchange [Import (+ve)/Export (-ve)]		2,720	5,589	237.29	237.29	10,612
Inter National Exchange with Nepal[Import (+ve)/Export (-ve)]		58	38	-2.16	-2.16	-71
Total Regional Availability(Gross)	131,792	62,909	55,053	1,703.63	1,624.89	68,455

Total Hydro Generation

	Inst. Capacity	PEAK	OFF-PEAK	Day Energy		Day AVG.
				Gross Gen	Net Gen	
Regional Entities Hydro	14,722	11,858	5,462	149.62	142.78	5,950
State Control Area Hydro	8,155	4,450	3,797	84.71	84.56	3,522
Total Regional Hydro	22,877	16,308	9,259	234.33	227.34	9,472

Total Renewable Generation

	Inst. Capacity	PEAK	OFF-PEAK	Day Energy		Day AVG.
				Gross Gen	Net Gen	
Regional Entities Renewable	27,959	48	99	172.75	172.16	7,174
State Control Area Renewable	17,736	438	428	99.32	99.3	4,138
Total Regional Renewable	45,695	486	527	272.07	271.46	11,312

Total Solar Generation

	Inst. Capacity	PEAK	OFF-PEAK	Day Energy		Day AVG.
				Gross Gen	Net Gen	
Regional Entities Solar	26,989	0	0	169.04	168.45	7,019
State Control Area Solar	12,614	98	42	79.79	79.79	3,325
Total Solar	39,603	98	42	248.83	248.24	10,344

Total Wind Generation

	Inst. Capacity	PEAK	OFF-PEAK	Day Energy		Day AVG.
				Gross Gen	Net Gen	
Regional Entities Wind	970	48	99	3.71	3.71	155
State Control Area Wind	4,328	200	244	12.17	12.17	507
Total Wind	5,298	248	343	15.88	15.88	662

4(A) INTER-REGIONAL EXCHANGES (Import=(+ve) /Export =(-ve))

SL.No.	Element	20:00	03:00	Maximum Interchange (MW)		Import in MU	Export in MU	NET
		(MW)	MW	Import (MW)	Export (MW)			
Import/Export between EAST REGION and NORTH REGION								
1	132KV Rihand - Nagar Untari	-	-	-	-	-	-	-
2	132KV-Chandauli (UP)-Karmnasa(PG)	-	-	-	-	-	-	-
3	132KV-Rihand (UP)-Garhwa(CG)	-	-	-	-	0	0.65	-0.65
4	132KV-Sahupuri (UP)-Karamnasa(PG)	-	-	-	-	-	-	-
5	220KV-Sahupuri (UP)-Karamnasa(PG)	-	-	-	-	1.77	0	1.77
6	400KV-Allahabad (PG)-Sasaram(PG)	-	-	-	-	0	0.03	-0.03
7	400KV-Balia (PG)-Biharsharif(PG)	-	-	-	-	0	10.2	-10.2
8	400KV-Balia (PG)-Naubatpur(Bihar)	-	-	-	-	0	0.68	-0.68
9	400KV-Balia (PG)-Patna(PG)	-	-	-	-	3.56	0	3.56
10	400KV-Gorakhpur (UP)-Motihari(DMT)	236	214	296	438	1.39	0	1.39
11	400KV-Gorakhpur (UP)-Muzaffarpur(PG)	139	72	244	764	0	3.87	-3.87
12	400KV-Sahupuri (UP)-Biharsharif(PG)	-	-	-	-	0	1.35	-1.35
13	400KV-Varanasi (PG)-Sasaram(PG)	-89	-72	144	0	2.38	0	2.38
14	765KV-Balia (PG)-Gaya(PG)	-	-	-	-	11.2	0	11.2

Import/Export between EAST REGION and NORTH REGION								
15	765KV-Sasaram (PG)-Fatehpur(PG)	-	-	-	-	0	0.68	-0.68
16	765KV-Varanasi (PG)-Gaya(PG)	-196	-367	478	924	0	2.08	-2.08
17	HVDC800KV-Agra (PG)-Alipurduar(PG)	-	-	-	-	-	-	-
Sub-Total EAST REGION		90	-153	1,162	2,126	20.3	19.54	0.76
Import/Export between NORTH_EAST REGION and NORTH REGION								
1	HVDC800KV-Agra (PG)-Biswanath Charialli(PG)	-	-	-	-	13.47	0	13.47
Sub-Total NORTH_EAST REGION		0	0	0	0	13.47	0	13.47
Import/Export between WEST REGION and NORTH REGION								
1	132KV-Lalitpur (UP)-Rajghat(MP)	-	-	-	-	-	-	-
2	132KV-Sawai Madhopur (RJ)-Gwalior(MP)	-	-	-	-	-	-	-
3	220KV-Auraiya (NT)-Malanpur(PG)	-47	-5	-	58	0	0.54	-0.54
4	220KV-Auraiya (NT)-Mehgaon(PG)	-	-	-	-	-	-	-
5	220KV-Modak (RJ)-Bhanpura(MP)	48	41	55	34	1.06	0	1.06
6	220KV-Ranpur (RS)-Bhanpura(MP)	91	77	108	53	1.88	0	1.88
7	400KV-Bhinmal (PG)-Zerda(PG)	-	-	-	-	-	-	-
8	400KV-Chittorgarh 765 (PG)-Neemuch (WR)	-104	-257	399	491	0	0.45	-0.45
9	400KV-Kankroli (RJ)-Zerda(PG)	-	-	-	-	0	1.73	-1.73
10	400KV-RAPS C (NP)-Sujalpur	-	-	-	-	0	6.92	-6.92
11	400KV-Rihand (NT)-Vindhyachal(PG)	-	-	-	-	-	-	-
12	765KV-0rai-Gwalior (PG)	-572	-559	0	-710	0	9.62	-9.62
13	765KV-0rai-Jabalpur	1,253	1,687	1,993	0	24.79	0	24.79
14	765KV-0rai-Satna	852	905	942	0	17.24	0	17.24
15	765KV-Agra (PG)-Gwalior(PG)	-	-	-	-	25.32	0	25.32
16	765KV-Chittorgarh-Banaskata D/C	55	505	436	777	0	2.88	-2.88
17	765KV-Dausa (PG)-Gwalior(PG)	-	-	-	-	10.3	0	10.3
18	765KV-Varanasi (PG)-Vindhyachal(PG)	-2,347	-2,054	2,942	0	59.83	0	59.83
19	HVDC500KV-Mohindergarh (JH)-Mundra(JH)	1,501	1,502	1,504	0	35.5	0	35.5
20	HVDC500KV-Vindhyachal (PG)-Vindhaychal B/B	-100	-100	0	100	0	2.44	-2.44
21	HVDC800KV-Kurukshetra (PG)(PG)-Champa(PG)	2,000	4,000	4,000	0	71.72	0	71.72
Sub-Total WEST REGION		2,630	5,742	12,379	803	247.64	24.58	223.06
TOTAL IR EXCHANGE		2,720	5,589	13,541	2,929	281.41	44.12	237.29

4(B) Inter Regional Schedule & Actual Exchange (Import=(+ve) /Export =(-ve)) in MU

	ISGS+GNA+URS schedule	T-GNA Bilateral (MW)	GDAM Schedule	DAM Schedule	RTM Schedule	Total IR Schedule	Total IR Actual	NET IR UI
NR-ER	114.52	5.82	0	-3.61	0	97.85	0.76	-97.09
NR-NORTH_EAST REGION	0	0	0	0	0	0	13.47	13.47
NR-WR	232.86	66.91	0	-111.25	0	167.02	223.06	56.04
Total	347.38	72.73	0	-114.86	0	264.87	237.29	-27.58

5.Inter National Exchange with Nepal [Import (+ve)/Export(-ve)] [Linkwise]

Element	Peak	Off-Peak	Maximum Interchange(MW)		Energy (MU)		Net Energy	Schedule Energy
	MW	MW	Import	Export	Import	Export	(MU)	(MU)
132KV-Tanakpur(NH)-Mahendranagar(PG)	58	38	0	71	0	1.18	-1.18	0
132KV-Nautanwa (UP)-Mainhiya (Nepal)						0.98	-0.98	0

5.Frequency Profile

RANGE(Hz)	< 49.2	< 49.7	< 49.8	< 49.9	< 50.0	>= 49.9 - <= 50.05	> 50.05 - <= 50.1	> 50.1 - <= 50.2	> 50.2	> 50.05
%	0	7.37	13.77	23.8	50.71	56.46	15.01	4.47	.27	19.75

<----------Frequency (Hz)---------->

Maximum		Minimum		Average	Freq Variation	Standard	Freq. in 15 mnt blk		Freq Dev Index
Frequency	Time	Frequency	Time	Frequency	Index	Deviation	Max.	Min.	(% of Time)
50.229	08:02:20	49.458	22:16:50	49.956	0.205	0.136	50.18	49.538	99.99

6.Voltage Profile: 400kV

	Maximum		Minimum		Voltage (in %)				Voltage Deviation Index
					< 380	< 390	> 420	> 430	(% of time)
Abdullapur(PG) - 400KV	418	03:55	399	22:15	0	0	0	0	0
Amritsar(PG) - 400KV	410	03:45	391	14:40	0	0	0	0	0
Ballabgarh(PG) - 400KV	413	03:55	392	22:15	0	0	0	0	0
Bareilly II(PG) - 400KV	410	03:55	393	22:15	0	0	0	0	0
Bareilly(UP) - 400KV	411	03:55	394	22:15	0	0	0	0	0

Baspa(HP) - 400KV	**411**	**01:10**	**395**	**22:10**	**0**	**0**	**0**	**0**	**0**
Bassi(PG) - 400KV	**420**	**03:55**	**398**	**22:15**	**0**	**0**	**0**	**0**	**0**
Bawana(DTL) - 400KV	**414**	**03:55**	**397**	**11:55**	**0**	**0**	**0**	**0**	**0**
Dadri HVDC(PG). - 400KV	**413**	**03:55**	**401**	**00:05**	**0**	**0**	**0**	**0**	**0**
Gorakhpur(PG) - 400KV	**411**	**07:25**	**388**	**11:55**	**0**	**3.13**	**0**	**0**	**0**
Hisar(PG) - 400KV	**419**	**18:00**	**398**	**11:55**	**0**	**0**	**0**	**0**	**0**
Kanpur(PG) - 400KV	**415**	**08:00**	**396**	**23:30**	**0**	**0**	**0**	**0**	**0**
Kashipur(UT) - 400KV	**415**	**03:55**	**407**	**22:15**	**0**	**0**	**0**	**0**	**0**
Kishenpur(PG) - 400KV	**413**	**05:00**	**400**	**11:55**	**0**	**0**	**0**	**0**	**0**
Moga(PG) - 400KV	**415**	**05:00**	**397**	**12:45**	**0**	**0**	**0**	**0**	**0**
Nallagarh(PG) - 400KV	**411**	**01:10**	**395**	**22:10**	**0**	**0**	**0**	**0**	**0**
Rihand HVDC(PG) - 400KV	**401**	**08:55**	**391**	**23:55**	**0**	**0**	**0**	**0**	**0**
Rihand(NT) - 400KV	**402**	**08:55**	**395**	**22:10**	**0**	**0**	**0**	**0**	**0**

6.1 Voltage Profile: 765kV

	Maximum		**Minimum**		**Voltage (in %)**				**Voltage Deviation Index**
					< 728	**< 742**	**> 800**	**> 820**	
Anta RS(RJ) - 765KV	**790**	**08:10**	**766**	**23:40**	**0**	**0**	**0**	**0**	**0**
Balia(PG) - 765KV	**780**	**08:00**	**751**	**23:35**	**0**	**0**	**0**	**0**	**0**
Bareilly II(PG) - 765KV	**774**	**08:00**	**741**	**22:15**	**0**	**.35**	**0**	**0**	**0**
Bhiwani(PG) - 765KV	**793**	**01:20**	**763**	**22:25**	**0**	**0**	**0**	**0**	**0**
Fatehpur(PG) - 765KV	**792**	**08:00**	**760**	**23:30**	**0**	**0**	**0**	**0**	**0**
Jhatikara(PG) - 765KV	**788**	**04:00**	**751**	**11:55**	**0**	**0**	**0**	**0**	**0**
Lucknow II(PG) - 765KV	**786**	**08:00**	**749**	**22:15**	**0**	**0**	**0**	**0**	**0**
Meerut(PG) - 765KV	**793**	**03:55**	**757**	**11:55**	**0**	**0**	**0**	**0**	**0**
Moga(PG) - 765KV	**797**	**03:45**	**754**	**08:50**	**0**	**0**	**0**	**0**	**0**
Phagi(RJ) - 765KV	**797**	**01:55**	**766**	**22:15**	**0**	**0**	**0**	**0**	**0**
Unnao(UP) - 765KV	**782**	**08:00**	**749**	**23:30**	**0**	**0**	**0**	**0**	**0**

7(A). Short-Term Open Access Details:

State	**Off- Peak Hours (03:00)**										**Peak Hours (20:00)**									
	T-GNA Bilateral(MW)	**IEX GDAM (MW)**	**IEX DAM (MW)**	**IEX RTM (MW)**	**PXIL GDAM (MW)**	**PXIL DAM (MW)**	**PXI RTM (MW)**	**HPX GDAM (MW)**	**HPX DAM (MW)**	**HPX RTM (MW)**	**Bilateral (MW)**	**IEX GDAM (MW)**	**IEX DAM (MW)**	**IEX RMT (MW)**	**PXIL GDAM (MW)**	**PXIL DAM (MW)**	**PXIL RMT (MW)**	**HPX GDAM (MW)**	**HPX DAM (MW)**	**HPX RTM (MW)**
PUNJAB	2,561.21	0	0	-3,200	0	0	0	0	0	0	2,298.73	0.99	2.61	-1,796.04	0	0	0	0	0	0
HARYANA	391.66	0	-1,022.39	0	0	0	0	0	0	0	-790.2	1.09	2.87	3.8	0	0	0	0	0	0
RAJASTHAN	210.67	-25.2	-681.74	-1,911.22	0	0	0	0	0	0	389.21	-5.73	-1,070.37	22.51	0	0	0	0	0	0
DELHI	915.88	2.22	-638	609.74	0	0	0	0	0	0	1,628.41	0.14	-319.65	-418.02	0	0	0	0	0	0
UTTAR PRADESH	623.72	-12.12	227.24	232.6	0	0	0	0	0	0	131.34	7.97	59.29	101.12	0	0	0	0	0	0
UTTARAKHAND	126.84	-6.2	0	77.27	0	0	0	0	0	0	266.17	-9.2	92.65	152.29	0	0	0	0	0	0
HIMACHAL PRADESH	-38.37	-32.2	-83.24	97.88	0	0	0	0	0	0	-81.37	-40.8	-421.91	-95.12	0	0	0	0	0	0
J&K(UT) & LADAKH(UT)	-16	-25.8	129.88	144.88	0	0	0	0	0	0	-16	-25.8	131.59	-199.99	0	0	0	0	0	0
CHANDIGARH	0	0	-105	9.66	0	0	0	0	0	0	81.95	0	-130	-9	0	0	0	0	0	0
RAILWAYS_NR ISTS	0	0	90.6	0	0	0	0	0	0	0	0	8.97	23.75	35.33	0	0	0	0	0	0
BULK CONSUMER_NR ISTS	0	0	0	59.98	0	0	0	0	0	0	0	0	0	37.83	0	0	0	0	0	0
TOTAL	4,775.61	-99.3	-2,082.65	-3,879.21	0	0	0	0	0	0	3,908.24	-62.37	-1,629.17	-2,165.29	0	0	0	0	0	0

State	Day Energy (MU)					
	GNA schedule	T-GNA Bilateral (MW)	GDAM Schedule	DAM Schedule	RTM Schedule	Total (MU)
PUNJAB	106.2	59.46	0.02	0.08	-22.17	143.59
HARYANA	167.73	5.93	0.81	-6.12	2	170.36
RAJASTHAN	97.93	5.36	0.13	-27.35	-33.98	42.09
DELHI	95.82	32.7	0.07	-7.48	1.85	122.95
UTTAR PRADESH	209.96	3.27	0.26	-1.5	3.55	215.77
UTTARAKHAND	27.44	3.22	-0.11	3.3	3.14	36.99
HIMACHAL PRADESH	11.52	-0.55	-0.09	-3.27	2.06	9.67
J&K(UT) & LADAKH(UT)	28.21	-0.28	-0.43	1.81	1.67	30.97
CHANDIGARH	6.29	0.45	0	-0.96	0.4	6.17
RAILWAYS_NR ISTS	2.53	0	0.15	0.97	0.22	3.87
BULK CONSUMER_NR ISTS	1.32	0.06	0	0	0.46	1.84
TOTAL	754.95	109.62	0.81	-40.52	-40.8	784.27

7(B). Short-Term Open Access Details

State	GNA schedule		T-GNA Bilateral (MW)		IEX GDAM (MW)		PXI GDAM (MW)		HPX GDAM(MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
PUNJAB	4,967.61	3,784.78	2,575.74	2,298.73	11.59	0	0	0	0	0
HARYANA	8,209.43	5,709.51	401.64	-939.89	83.55	0	0	0	0	0
RAJASTHAN	5,400	2,175.73	454.39	87.73	61.68	-25.8	0	0	0	0
DELHI	4,721.34	3,334.75	2,088.66	703.26	8.21	0	0	0	0	0
UTTAR PRADESH	10,783.11	6,855.07	623.72	-48.25	230.58	-28.62	0	0	0	0
UTTARAKHAND	1,355.89	948.76	266.18	39.07	0	-13.2	0	0	0	0
HIMACHAL PRADESH	804.72	156.71	29.71	-81.37	46.47	-40.8	0	0	0	0
J&K(UT) & Ladakh(UT)	1,591.06	631.08	-8	-16	0	-25.8	0	0	0	0
CHANDIGARH	374.01	150.92	81.95	0	8.7	0	0	0	0	0
RAILWAYS_NR ISTS	120.95	89.44	0	0	71.38	0	0	0	0	0
BULK CONSUMER_NR ISTS	-	-	-	-	-	-	-	-	-	-

State	IEX DAM (MW)		PXI DAM(MW)		HPX DAM (MW)		IEX RTM (MW)		PXI RTM (MW)		HPX RTM (MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
PUNJAB	13.52	0	0	0	0	0	878	-3,200	0	0	0	-25
HARYANA	14.11	-1,128.33	0	0	0	0	772.72	-420	0	0	0	-200
RAJASTHAN	69.99	-2,868.24	0	0	0	0	34.36	-4,402.03	0	0	0	0
DELHI	173.86	-889	0	0	0	0	609.74	-464.3	0	0	0	0
UTTAR PRADESH	378.63	-2,181.91	0	0	0	0	930.15	-897.18	151.66	151.66	151.66	0
UTTARAKHAND	520.62	0	0	0	0	0	341.35	-34.11	0	0	0	0
HIMACHAL PRADESH	344.26	-482.69	0	0	0	0	363.17	-227.25	0	0	0	0
J&K(UT) & LADAKH(UT)	274.77	-15	0	0	0	0	864.79	-250	0	0	0	0
CHANDIGARH	82.1	-160	0	0	0	0	61.82	-28	0	0	0	0
RAILWAYS_NR ISTS	93.6	0	0	0	0	0	76.31	0	0	0	0	0
BULK CONSUMER_NR ISTS	-	-	-	-	-	-	-	-	-	-	-	-

8.Major Reservoir Particulars

RESERVOIR	Parameters			Present Parameters		LAST YEAR		LAST DAY	
	MDDL (Mts)	FRL (Mts)	Energy Content at FRL	Level (Mts)	Energy (MU)	Level (Mts)	Energy (MU)	Inflow (m3/s)	Usage (m3/s)
Bhakra	445.62	513.59	1,728.8	481.78	503	476.52	381	298.18	424.75
Chamera-I	748.75	760	753.95	-	-	-	-	-	0
Gandhisagar	381	399.9	725	-	-	-	-	-	0
Jawahar Sagar	295.96	298.7	2.01	-	-	-	-	-	0
Koteshwar	598.5	612.5	610.73	610.7	5	611.15	5	97.95	100.25
Pong	384.05	426.72	1,084	405.57	361	395.11	126	58.62	141.7
RPS	343.81	352.81	175.66	-	-	-	-	-	0
RSD	487.91	527.91	390.3	513.14	250	508.41	197	101.54	302.27
Rihand	252.98	268.22	860.5	-	-	-	-	-	0
Tehri	740.04	830	1,164.11	741.13	6	742.43	14	119.1	102
TOTAL	-	-	-	-	1,125	-	723	675.39	1,070.97

9. System Reliability Indices(Violation of TTC and ATC):

(i)%age of times N-1 Criteria was violated in the inter and intra regional corridors	
WR	0
ER	0
Simultaneous	0
Delhi	0
Rajasthan	0
UP	0
Punjab	0
Haryana	0

ii)%age of times ATC violated on the inter and intra regional corridors

WR	0
ER	0
Simultaneous	0
Delhi	0
Rajasthan	0
UP	0
Punjab	0
Haryana	0

iii)%age of times Angular Difference on Important Buses was beyond permissible limits(40 deg.)

Rihand-Dadri	0

10. Zero Crossing Violations

State	No. of violations(Maximum 15 in a day)	Maximum number of continuous blocks without sign change
CHANDIGARH	0	2
DELHI	9	29
HARYANA	8	21
HIMACHAL PRADESH	0	6
J&K(UT) & Ladakh(UT)	8	32
PUNJAB	13	43
RAJASTHAN	12	41
UTTAR PRADESH	5	14
UTTARAKHAND	9	38

11. NCR's and Ladakh Power Supply Position(based on SCADA data)

	Inst Capacity	20:00	03:00	Day Peak			
Station/Constituents	(MW)	Peak MW	Off Peak MW	MW	HRS	Net MU	AVG MW
NCR_GENERATION	9225	5,430	3,626	5986	23:30:00	95.94	3,997
NCR_DRAWAL	-	12,902	11,677	13717	22:30:00	271.25	11,302
NCR_DEMAND	-	18,332	15,303	19625	22:30:00	367.19	15,300
LADAKH_DEMAND	-	23	10	29	07:00:00	0.31	13

12. RE/Load Curtailment details

State	Load Curtailment (Shortage)			RE Curtailment				
	Energy	Maximum	At the time of maximum demand	Wind		Solar		Reason
	MU	MW	MW	Max MW	Energy(MU)	Max MW	Energy(MU)	
PUNJAB	0	0	0	0	0	0	0	
HARYANA	0	0	0	0	0	0	0	
RAJASTHAN	0	0	0	0	0	0	0	
DELHI	0	0	0	0	0	0	0	
UTTAR PRADESH	0	0	0	0	0	0	0	
UTTARAKHAND	0.745	295	80	0	0	0	0	
HIMACHAL PRADESH	0	0	0	0	0	0	0	
J&K(UT) & Ladakh(UT)	0	0	0	0	0	0	0	
CHANDIGARH	0	0	0	0	0	0	0	
RAILWAYS_NR ISTS	0	0	0	0	0	0	0	
BULK CONSUMER_NR ISTS	0	0	0	0	0	0	0	

13.Grid Disturbance / Any Other Significant Event:

14.Weather Conditions :

15.Synchronisation of new generating units :

16.Synchronisation of new 220 / 400 / 765 KV lines and energising of bus / /substation :

1. 400/220 KV 500 MVA ICT 2 AT AJMER(RS) FIRST TIME CHARGED AT 02-Jun-26 15:35 HRS
2. 412 MAIN BAY - 400/220 KV 500 MVA ICT 2 AT AJMER(RS) (RRVPNL) AT 400 KV AJMER(RS) FIRST TIME CHARGED AT 02-Jun-26 15:35 HRS

17.Instances of persistent/significant non-complaint with the grid code

18.Constraints and instances of congestion in the transmission system

19.Remarks :

No Records Found

Note: Data(regarding drawal,generation, shortage , inter-regional flows and reservoir levels)of the constituents filled in the report are as per last furnished data by the respective state/constituent to NRLDC.
***Unscheduled Load Shedding carried out by Uttar Pradesh.**

Shift In Charge