GRID CONTROLLER OF INDIA (GRID-INDIA)
NORTHERN REGIONAL LOAD DESPATCH CENTRE
DAILY OPERATION REPORT OF NORTHERN REGION

Power Supply Position in Northern Region For 03-Jun-2026

Date of Reporting:04-Jun-2026

1. Regional Availability/Demand:

Evening Peak (20:00) MW				Off-Peak (03:00) MW				Day Energy(Net MU)	
Demand Met	Shortage	Requirement	Freq (Hz)	Demand Met	Shortage	Requirement	Freq (Hz)	Demand Met	Shortage
79,275	0	79,275	50.057	67,374	0	67,374	50.047	1,731	2.09

2(A)State's Load Deails (At State Periphery) in MU:

State	State's Control Area Generation (Net MU)							Drawal Sch	Act Drawal	UI	Requirement	Shortage	Consumption
	Thermal	Hydro	Gas/Naptha/ Diesel	Solar	Wind	OthersBiomass/Co-gen etc.)	Total	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)
PUNJAB	96.15	13.84	0	5.36	0	2.47	117.82	137.47	130.33	-7.14	248.15	0	248.15
HARYANA	61.62	0.61	1.92	1.44	0	1.4	66.99	183.07	180.6	-2.47	248.74	1.15	247.59
RAJASTHAN	176.4	0	1.42	53.71	19.29	6.06	256.88	70.42	65.25	-5.17	322.13	0	322.13
DELHI	0	0	16.61	0	0	1.63	18.24	128.51	126.36	-2.15	144.6	0	144.6
UTTAR PRADESH	346.04	10.4	0	16.6	0	1.2	374.24	233.98	233.36	-0.62	607.6	0	607.6
UTTARAKHAND	0	13.4	0	0.7	0	0	14.1	39.82	40.36	0.54	54.9	0.44	54.46
HIMACHAL PRADESH	0	31.47	0	0.42	0	0	31.89	7.93	7.51	-0.42	39.4	0	39.4
J&K(UT) & Ladakh(UT)	0	22.22	0	0	0	0	22.22	30.25	31.46	1.21	54.18	0.5	53.68
CHANDIGARH	0	0	0	0	0	0	0	6.77	6.91	0.14	6.91	0	6.91
RAILWAYS_NR ISTS	0	0	0	0	0	0	0	3.73	4.48	0.75	4.48	0	4.48
BULK CONSUMER_NR ISTS	0	0	0	0	0	0	0	1.69	2.06	0.37	2.06	0	2.06
Region	**680.21**	**91.94**	**19.95**	**78.23**	**19.29**	**12.76**	**902.38**	**843.64**	**828.68**	**-14.96**	**1,733.15**	**2.09**	**1,731.06**

2(B)State Demand Met (Peak and off-peak Hrs)

State	Evening Peak (20:00) MW				AVG DEMAND	Off-Peak (03:00) MW			
	Demand Met	Shortage	UI	STOA/PX/RTM Transaction	MW	Demand Met	Shortage	UI	STOA/PX/RTM Transaction
PUNJAB	11,080	0	-541	60	10,342	7,926	0	-958	-729
HARYANA	11,119	0	-305	-262	10,404	9,955	0	97	-196
RAJASTHAN	14,134	0	-136	-696	13,273	12,950	0	-91	-327
DELHI	6,201	0	-257	1,079	6,019	5,456	0	214	835
UTTAR PRADESH	29,401	0	-55	516	25,201	25,329	0	-331	505
UTTARAKHAND	2,736	0	-109	811	2,270	2,142	0	57	260
HIMACHAL PRADESH	1,682	0	26	-696	1,624	1,363	0	-82	-125
J&K(UT) & Ladakh(UT)	2,417	0	91	478	2,236	1,804	0	-5	145
CHANDIGARH	316	0	6	-47	288	242	0	27	-59
RAILWAYS_NR ISTS	190	0	32	75	186	208	0	7	91
BULK CONSUMER_NR ISTS	0	0	0	0	86	0	0	0	39
Region	79,276	0	-1,248	1,318	71,929	67,375	0	-1,065	439

2(C)State's Demand Met in MWs (Maximum Demand Met and Maximum requirement of the day details)

State	Maximum Demand, corresponding shortage and requirement details for the day				Maximum requirement, corresponding shortage and demand details for the day						ACE			
	Maximum Demand Met of the day	Time	Shortage during at maximum demand	Requirement at the max demand met of the day	Maximum Requirement of the day	Time	Shortage during at maximum Requirement	Demand Met at maximum requiremnet	Min Demand Met	Time	ACE_MAX	Time	ACE_MIN	Time
PUNJAB	12,022	22:00	0	12,022	12,022	22:00	0	12,022	7,926	3:00	1,528.21	02:59:00	-693.21	11:48:00
HARYANA	11,788	15:00	0	11,788	11,788	15:00	0	11,788	8,688	7:00	442.66	06:04:00	-448.84	23:37:00
RAJASTHAN	15,133	22:00	0	15,133	15,133	22:00	0	15,133	12,110	10:00	1,261.22	10:29:00	-599.72	22:32:00
DELHI	7,270	23:00	0	7,270	7,270	23:00	0	7,270	4,780	6:00	295.96	17:29:00	-150.22	09:13:00
UP	29,400	20:00	0	29,400	29,400	20:00	0	29,400	20,023	6:00	1,395.04	19:01:00	-1,057.87	06:01:00
UTTARAKHA ..	2,736	20:00	0	2,736	2,736	20:00	0	2,736	1,906	12:00	261.53	20:33:00	-212.25	14:59:00
HP	1,800	9:00	0	1,800	1,800	9:00	0	1,800	1,363	3:00	244.45	14:35:00	-211.23	19:31:00
J&K(UT)&Lad ..	2,561	17:00	0	2,561	2,561	17:00	0	2,561	1,657	1:00	377.23	08:59:00	-593.75	23:02:00
CHANDIGARH	346	15:00	0	346	346	15:00	0	346	214	6:00	14.98	07:31:00	-27.01	01:02:00
RAILWAYS_NR ISTS	216	0:00	0	216	216	0:00	0	216	154	14:00	0	-	0	-
BULK CONSUMER_NR ISTS	109	3:00	0	109	109	3:00	0	109	30	21:00	-	-	-	-
NR	81,730	22:00	375	82,105	82,105	22:00	375	81,730	63,097	6:00	0	-	0	-

3(A) State Entities Generation:

CHANDIGARH

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
NIL										
Total	0	0	0					0	0	0
Total	0	0	0					0	0	0

DELHI

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
BAWANA GPS(2 * 253 + 4 * 216)	1,370	463	467	544.17	01:00	0		11.84	11.5	479
DELHI GAS TURBINES(3 * 34 + 6 * 30)	282	66	72	71.52	03:00	0		1.64	1.53	64
PRAGATI GAS TURBINES(1 * 121.2 + 2 * 104.6)	331	151	150	153.31	13:00	0		3.7	3.59	150
RITHALA GPS(3 * 36)	108	0	0	0		0				
Total GAS/NAPTHA/DIESEL	2,091	680	689					17.18	16.62	693
WIND	0	0	0	0		0				
BIOMASS(52)	52	59	59	0		0		1.65	1.63	68
SOLAR(2)	2	0	0	0		0				
Total DELHI	2,145	739	748					18.83	18.25	761

HARYANA

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
DCRTPP (YAMUNA NAGAR)(2 * 300)	600	247	236	249	22:00	170	08:00	5.37	4.85	202
JHAJJAR(CLP)(2 * 660)	1,320	1,222	1,227	1,234	00:00	751	09:00	27.31	25.55	1,065
MAGNUM DIESEL (IPP)(4 * 6.3)	25	0	0	0		0				
PANIPAT TPS(1 * 210 + 2 * 250)	710	657	658	666	06:00	532	17:00	15.17	13.71	571
RGTPP(KHEDAR)(2 * 600)	1,200	763	799	817	01:00	690	15:00	18.1	17.51	730
Total THERMAL	3,855	2,889	2,920					65.95	61.62	2,568
FARIDABAD GPS(1 * 156.07 + 2 * 137.75)	432	271	0	348	23:00	0	12:00	1.92	1.92	80
Total GAS/NAPTHA/DIESEL	432	271	0					1.92	1.92	80
TOTAL HYDRO HARYANA(64.8)	65	13	37	40	04:00	12	18:00	0.62	0.61	25
Total HYDEL	65	13	37					0.62	0.61	25
WIND	0	0	0	0		0				
BIOMASS(106)	106	0	0	0		0		1.4	1.4	58
SOLAR(196)	196	0	0	0		0		1.44	1.44	60
Total HARYANA	4,654	3,173	2,957					71.33	66.99	2,791

HIMACHAL PRADESH

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
BAJOLI HOLI(3*60)	180	190	184	191	01:00	0		3.69	3.69	154
BASPA (IPP) HPS(3 * 100)	300	157	179	181	21:00	0		2.76	2.75	115
KUTEHAR(3 * 80)	240	216	162	242	01:00	0		4.55	4.54	189
MALANA (IPP) HPS(2 * 43)	86	33	32	43	23:00	0		0.79	0.78	33
MALANA2(2 * 50)	100	36	36	50.52	23:00	0		0.9	0.89	37
NAITWAR MORI(2 * 30)	60	40	32	40	20:00	0		0.81	0.8	33
SAWARA KUDDU(3 * 37)	111	31	0	111	08:00	0		0.64	0.64	27
OTHER HYDRO HP(503.75)	504	230	376	0		0		8.48	8.44	352
Total HYDEL	1,581	933	1,001					22.62	22.53	940
WIND	0	0	0	0		0				
BIOMASS	0	0	0	0		0				
SOLAR	198	0	0	0		0		0.42	0.42	18
SMALL HYDRO(765.25)	765	379	391	0		0		8.96	8.95	373
Total SMALL HYDRO	765	379	391					8.96	8.95	373
Total HP	2,544	1,312	1,392					32	31.9	1,331

J&K(UT) & LADAKH(UT)

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
GAS/DIESEL/OTHERS J&K(1 * 190)	190	0	0	0		0				
Total GAS/NAPTHA/DIESEL	190	0	0					0	0	0
BAGLIHAR (IPP) HPS(6 * 150)	900	0	0	0		0		17.88	17.88	745
OTHER HYDRO/IPP J&K(308)	308	0	0	0		0		4.34	4.34	181
Total HYDEL	1,208	0	0					22.22	22.22	926
WIND	0	0	0	0		0				
BIOMASS	0	0	0	0		0				
SOLAR	0	0	0	0		0				
SMALL HYDRO(98)	98	0	0	0		0				
Total SMALL HYDRO	98	0	0					0	0	0
Total J&K(UT)&Ladakh(UT)	1,496	0	0					22.22	22.22	926

PUNJAB

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
GOINDWAL(GVK)(2 * 270)	540	451	469	491	01:00	270	09:00	10.16	8.96	373
GURU GOBIND SINGH TPS (ROPAR)(4 * 210)	840	407	403	416	01:00	398	12:00	10.69	9.49	395
GURU HARGOBIND SINGH TPS (LEHRA MOHABBAT)(2 * 210 + 2 * 250)	920	810	796	810	07:00	570	14:00	18.2	16.66	694
RAJPURA(NPL) TPS(2 * 700)	1,400	1,320	1,245	1,320	01:00	675	11:00	30.02	28.65	1,194
TALWANDI SABO TPS(3 * 660)	1,980	1,640	1,540	1,680	21:00	924	11:00	34.69	32.39	1,350
Total THERMAL	5,680	4,628	4,453					103.76	96.15	4,006
ANANADPUR SAHIB HYDRO PLANT(2 * 33.5 + 2 * 33.5)	134	38	26	38	17:00	26	01:00	0.88	0.88	37
MUKERIAN HYDRO PLANT(6 * 15 + 6 * 19.5 + 2 * 9)	225	48	87	87	01:00	48	16:00	1.66	1.65	69
RANJIT SAGAR POWER PLANT (4 * 150)	600	600	600	600	01:00	0	07:00	8.28	8.26	344
SHANAN(4 * 15 + 1 * 50)	110	95	70	95	05:00	70	01:00	2.14	2.14	89
UBDC(3 * 15 + 3 * 15.5)	92	24	27	27	01:00	24	09:00	0.6	0.6	25
OTHER HYDRO PUNJAB	0	0	0	0		0		0.32	0.32	13
Total HYDEL	1,161	805	810					13.88	13.85	577
WIND	0	0	0	0		0				
BIOMASS(303)	303	0	0	0		0		2.47	2.47	103
SOLAR(942)	942	53	53	525	12:00	53	01:00	5.36	5.36	223
Total PUNJAB	8,086	5,486	5,316					125.47	117.83	4,909

RAJASTHAN

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
BARSINGSAR (IPP) LTPS(2 * 125)	250	110	111	111	08:00	103	13:00	2.95	2.49	104
CHHABRA TPS(2 * 660 + 4 * 250)	2,320	1,866	1,904	1,942	07:00	1,347	14:00	46.17	42.92	1,788
GIRAL (IPP) LTPS(2 * 125)	250	0	0	0		0				
KALISINDH TPS(2 * 600)	1,200	1,020	1,011	1,048	23:00	641	10:00	22.84	21.02	876
KAWAI TPS(2 * 660)	1,320	1,231	1,246	1,253	22:00	769	10:00	27.91	26.34	1,098
KOTA TPS(2 * 110 + 2 * 195 + 3 * 210)	1,240	802	975	991	01:00	623	09:00	21	18.52	772
RAJWEST (IPP) LTPS(8 * 135)	1,080	720	595	720	20:00	519	14:00	16.89	14.75	615
SURATGARH TPS (6 * 250 + 2 * 660(SSCTPS))	2,820	2,358	2,461	2,524	00:00	1,372	11:00	51.71	47.58	1,983
VSLPP (IPP)(1 * 135)	135	118	117	118	22:00	116.87	08:00	3.17	2.78	116
Total THERMAL	10,615	8,225	8,420					192.64	176.4	7,352
DHOLPUR GPS(3 * 110)	330	0	0	0		0				
RAMGARH GPS(1 * 110 + 1 * 35.5 + 1 * 50 + 2 * 37.5)	271	68	53	69	10:00	53	07:00	1.49	1.42	59
Total GAS/NAPTHA/DIESEL	601	68	53					1.49	1.42	59
RAPS-A(1 * 100 + 1 * 200)	300	149	146	150	15:00	145	13:00	3.95	3.69	154
Total NUCLEAR	300	149	146					3.95	3.69	154
TOTAL HYDRO RAJASTHAN(550)	550	0	0	0		0				
Total HYDEL	550	0	0					0	0	0
WIND(1 * 4328)	4,328	857	323	1,344	22:00	237	09:00	19.29	19.29	804
BIOMASS(180)	180	99	99	99	01:00	99	06:00	2.37	2.37	99
SOLAR(8269)	8,269	37	0	6,737	13:00	1	06:00	53.71	53.71	2,238
Total RAJASTHAN	24,843	9,435	9,041					273.45	256.88	10,706

UTTAR PRADESH

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
ANPARA TPS(2 * 500 + 3 * 210)	1,630	1,340	1,349	1,353	10:00	1,133	08:00	34.1	31.6	1,317
ANPARA-C TPS(2 * 600)	1,200	934	944	958	01:00	747	07:00	23.9	22.4	933
ANPARA-D TPS(2 * 500)	1,000	938	877	938	19:00	809	08:00	23.2	21.8	908
BAJAJ ENERGY PVT LTD (IPP) TPS(10 * 45)	450	405	405	405	03:00	225	04:00	7.7	6.9	288
BARA PPGCL TPS(3 * 660)	1,980	1,725	1,665	1,734	01:00	1,046	13:00	40.5	37.5	1,563
GHATAMPUR TPS (2*660)	1,320	571	583	608	01:00	320	14:00	12.4	11.7	488
HARDUAGANJ TPS(1 * 110 + 2 * 250 + 1*660)	1,270	1,109	1,047	1,109	20:00	630	18:00	22.5	20.6	858
INFIRM POWER	660	0	0	0		0				
JAWAHARPUR TPS(2*660)	1,320	835	944	980	02:00	665	16:00	20.4	19.2	800
JP CHURK(3 * 60)	180	0	0	0		0				
KHURJA TPS(2 * 660)	1,320	1,315	1,253	1,367	12:54	921	09:53	29.45	27.74	1,156
LALITPUR TPS(3 * 660)	1,980	1,819	1,844	1,865	01:00	1,014	13:00	39.5	37.1	1,546
MEJA TPS(2 * 660)	1,320	1,145	1,217	1,241	01:00	670	18:00	25.4	23.7	988
OBRA TPS (5 * 200+2*660)	2,320	1,734	1,668	1,742	23:00	1,378	13:00	42	38.9	1,621
PANKI_I TPS(1 * 660)	660	607	611	643	11:00	353	14:00	13.6	12.8	533
PARICHA TPS(2 * 210 + 2 * 250)	920	648	669	669	03:00	472	08:00	14.9	13.6	567
ROSA TPS(4 * 300)	1,200	1,076	1,086	1,095	02:00	590	09:00	22.4	20.5	854
Total THERMAL	20,730	16,201	16,162					371.95	346.04	14,420
ALAKHANANDA HEP(4 * 82.5)	330	82	82	166	01:00	81	10:00	2.4	2.4	100
RIHAND HPS(6 * 50)	300	295	0	295	20:00	0	02:00	1.8	1.8	75
VISHNUPARYAG HPS(4 * 110)	440	257	198	307	22:00	153	13:00	4.8	4.8	200
OTHER HYDRO UP(227)	227	75	122	137	22:00	3	16:00	1.4	1.4	58
Total HYDEL	1,297	709	402					10.4	10.4	433
WIND	0	0	0	0		0				
BIOMASS(26)	26	0	0	0		0				
SOLAR(2729)	2,729	0	0	2,209	12:00	0	01:00	16.6	16.6	692
CO-GENERATION(1360)	1,360	50	50	50	01:00	0		1.2	1.2	50
Total OTHERs	1,360	50	50					1.2	1.2	50
Total UP	26,142	16,960	16,614					400.15	374.24	15,595

UTTARAKHAND

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
GAMMA	225	0	0	0		0				
SARAVANTI	450	0	0	0		0				
Total GAS/NAPTHA/DIESEL	675	0	0					0	0	0
OTHER HYDRO UK(1250)	1,250	875	775	875	20:00	378	14:00	13.45	13.4	558
Total HYDEL	1,250	875	775					13.45	13.4	558
WIND	0	0	0	0		0				
BIOMASS(127)	127	0	0	0		0				
SOLAR(278)	278	0	0	97	12:00	10	18:00	0.7	0.7	29
SMALL HYDRO(180)	180	0	0	0		0				
Total SMALL HYDRO	180	0	0					0	0	0
Total UTTARAKHAND	2,510	875	775					14.15	14.1	587

3(B) Regional Entities Generation

Station/Constituents	Inst. Capacity	Declared Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy				AVG. MW	UI(Actual-Schedule-(+- AGC))
	(MW)	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	Gross Gen ACT (MU)	Net Gen ACT MU)	AGC(MU)		
Aravali Power Company Private Ltd														
ISTPP (JHAJJAR)(3 * 500)	1,500	1,406	930	1,430	1,507	21:00	820	08:45	23.92586	25.35	23.62	0.07	984	-0.37586
Sub-Total	1,500	1,406	930	1,430	-	-	-	-	23.92586	25.35	23.62	0.07	984	-0.37586
BBMB														
BHAKRA HPS(5 * 126 + 5 * 157)	1,415	1,049	1,066	535	1,066	20:00	419	11:00	14.6405	15.09	14.89	0	620	0.2495
DEHAR HPS(6 * 165)	990	480	495	330	495	20:00	145	11:00	7.74	7.99	7.85	0	327	0.11
PONG HPS(6 * 66)	396	246	250	124	250	20:00	0	11:00	2.0735	2.14	2.08	0	87	0.0065
Sub-Total	2,801	1,775	1,811	989	-	-	-	-	24.454	25.22	24.82	0	1,034	0.366
NHPC														
BAIRASIUL HPS(3 * 60)	180	186	183	59	184	21:00	0	13:30	1.82538	1.91	1.88	0.05	78	0.00462
CHAMERA I HPS(3 * 180)	540	545	518	168	540	23:00	0	04:00	5	4.91	4.88	-0.9	203	0.78
CHAMERA II HPS(3 * 100)	300	208	198	202	202	03:00	196	07:00	4.7736	4.77	4.76	0	198	-0.0136
CHAMERA III HPS(3 * 77)	231	240	222	230	232	01:00	119.6	18:00	4.80653	4.81	4.76	0	198	-0.04653
DHAULIGANGA HPS(4 * 70)	280	277	259	69	285	19:00	0	15:00	2.40331	2.44	2.42	-0.02	101	0.03669
DULHASTI HPS(3 * 130)	390	385	382	379	383	21:00	372.3	09:00	8.92596	9.11	9	0	375	0.07404
KISHANGANGA(3 * 110)	330	340	342	333	342	21:00	331.8	06:00	7.95	8.03	7.99	0	333	0.04
PARBATI III HEP(4 * 130)	520	390	386	132	393	21:00	30.16	12:00	4.26275	4.41	4.38	0	183	0.11725
PARBATI-II(4 * 200)	800	600	600	111	601	22:00	110.6	03:00	6.555	6.95	6.64	0	277	0.085
SALAL HPS(6 * 115)	690	590	603	601	604	11:00	596	23:59	14.19	14.43	14.3	0	596	0.11
SEWA-II HPS(3 * 40)	120	130	127	0	127	20:00	0	-	0.6679	0.68	0.66	0	28	-0.0079
TANAKPUR HPS(1 * 31.42 + 2 * 31.4)	94	35	36	37	95	10:59	24.38	08:00	0.92843	0.98	0.95	0	40	0.02157
URI HPS(4 * 120)	480	494	485	484	498	01:30	70	00:45	11.37075	11.66	11.58	0	483	0.20925
URI-II HPS(4 * 60)	240	250	246	245	247	02:00	244.72	18:00	5.72952	5.89	5.85	0	244	0.12048
Sub-Total	5,195	4,670	4,587	3,050	-	-	-	-	79.38913	80.98	80.05	-0.87	3,337	1.53087
NPCL														
NAPS(2 * 220)	440	395	427	437	439	08:00	0	-	9.48	10.25	9.27	0	386	-0.21
RAPP-D	700	615	0	0	0	-	0	-	14.76	16.03	14.71	0	613	-0.05
RAPS-B(2 * 220)	440	350	364	395	406	07:00	0	-	8.40096	9.17	8.05	0	335	-0.35096
RAPS-C(2 * 220)	440	415	455	455	456	08:00	0	-	9.96	10.96	9.88	0	412	-0.08
Sub-Total	2,020	1,775	1,246	1,287	-	-	-	-	42.60096	46.41	41.91	0	1,746	-0.69096
NTPC														
ANTA GPS(1 * 153.2 + 3 * 88.71)	419	380	210	0	368	23:04	0	-	1.9289	1.87	1.77	0	74	-0.1589
AURAIYA GPS(2 * 109.3 + 4 * 111.19)	663	639	0	0	580	22:45	0	-	2.52299	2.59	2.47	0	103	-0.05299
DADRI GPS(2 * 154.51 + 4 * 130.19)	830	800	0	0	0	-	0	-	3.53285	3.69	3.54	0	148	0.00715
DADRI-I TPS(4 * 210)	840	769	437	716	437	20:00	0	-	12.08277	13.91	12.65	0	527	0.56723
DADRI-II TPS(2 * 490)	1,000	938	500	448	500	20:00	0	-	13.41421	14.06	12.91	0	538	-0.50421
KOLDAM HPS(4 * 200)	800	871	872	0	872	20:00	0	-	4.9977	5.04	5	0	208	0.0023
RIHAND-I STPS(2 * 500)	1,000	920	980	993	1,017	01:00	572	11:00	19.84534	21.6	19.63	0	818	-0.21534
RIHAND-II STPS(2 * 500)	1,000	450	478	984	1,001	01:00	543	12:00	15.54641	16.65	15.39	-0.01	641	-0.14641
RIHAND-III STPS(2 * 500)	1,000	943	938	981	1,011	02:00	530	09:00	20.16752	21.13	19.97	-0.13	832	-0.06752
SINGRAULI HYDRO(1 * 8)	8	6	6	6	6	20:00	0	-	0.13665	0.14	0.14	0	6	0.00335
SINGRAULI STPS(2 * 500 + 5 * 200)	2,000	1,853	1,904	2,010	1,904	20:00	0	-	39.35824	42.74	39.23	0	1,635	-0.12824
TANDA TPS(4 * 110)	440	-	0	0	0	-	0	-	-	-	-	-	-	-
TANDA TPS STAGE-II(2 * 660)	1,320	1,238	1,170	1,204	1,170	20:00	0	-	24.48339	25.84	24.07	0	1,003	-0.41339
UNCHAHAR II TPS(2 * 210)	420	375	359	402	418	02:00	236	18:00	6.89793	7.71	6.86	0.05	286	-0.08793
UNCHAHAR III TPS(1 * 210)	210	189	149	194	209	21:30	116	18:00	3.45073	3.85	3.47	0.06	145	-0.04073
UNCHAHAR IV TPS(1 * 500)	500	466	471	473	500	02:00	276	17:00	8.68462	9.34	8.77	0.14	365	-0.05462
UNCHAHAR TPS(2 * 210)	420	330	370	413	424	02:00	234	13:00	6.85808	7.74	6.73	0	280	-0.12808
Sub-Total	12,870	11,167	8,844	8,824	-	-	-	-	183.90833	197.9	182.6	0.11	7,609	-1.41833
SJVNL														
NATHPA-JHAKRI HPS(6 * 250)	1,500	1,630	1,621	441	1,632	23:00	0	11:00	15.5816	15.75	15.63	-0.03	651	0.0784
RAMPUR HEP(6 * 68.67)	412	449	439	126	440	21:00	0	11:00	4.29123	4.42	4.38	0	183	0.08877
Sub-Total	1,912	2,079	2,060	567	-	-	-	-	19.87283	20.17	20.01	-0.03	834	0.16717
THDC														
KOTESHWAR HPS(4 * 100)	400	90	90	64	92	22:00	0	01:00	1.538	1.57	1.56	0	65	0.022
TEHRI HPS(4 * 250)	1,000	354	348	118	374	21:00	0	07:00	2.5925	2.64	2.64	0	110	0.0475
Sub-Total	1,400	444	438	182	-	-	-	-	4.1305	4.21	4.2	0	175	0.0695
Total	27,698	23,316	19,916	16,329					378.28161	400.24	377.21	-0.72	15,719	-0.35161

IPP/JV

Station/Constituents	Inst. Capacity	Declared Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW	UI
	(MW)	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	Gross Gen(MU)	Net Gen(MU)		
IPP													
ADHPL(IPP) HPS(2 * 96)	192	99	98	98	193	02:00	0	-	1.8387	1.86	1.85	77	0.0113
BUDHIL HPS (IPP)(2 * 35)	70	69	72	25	72	20:00	25.25	02:00	1.00138	1.03	1.03	43	0.02862
KARCHAM WANGTOO HPS(4 * 261.25)	1,045	988	1,000	300	1,000	19:15	150	10:00	8.15283	8.41	8.33	347	0.17717
SHREE CEMENT (IPP) TPS(2 * 150 + 2 * 19 + 1 * 6)	344	330	0	0	0	-	0	-	4.2521	3.84	3.49	145	-0.7621
SAINJ HEP(2 * 50)	100	49	50	55	105	21:00	0	-	1.3258	1.35	1.34	56	0.0142
SINGOLI BHATWARI HEP(3 * 33)	99	98	60	54	60	20:00	0	-	0.942	0.88	0.87	36	-0.072
SORANG HYDROELECTRIC PROJECT(2 * 50)	100	98	50	50	53	00:00	0	-	0.9183	0.97	0.96	40	0.0417
Sub-Total	**1,950**	**1,731**	**1,330**	**582**	-	-	-	-	**18.43111**	**18.34**	**17.87**	**744**	**-0.56111**
SOLAR IPP													
ADANI GREEN ENERGY TWENTY FIVE LIMITED	500	0	0	0	0	-	0	-	4.30956	4.36	4.36	182	0.05044
ABC RENEWABLE ENERGY(1 * 300)	300	0	0	0	0	-	0	-	2.19704	2.11	2.11	88	-0.08704
ABC RENEWABLE ENERGY_2	550	0	0	0	0	-	0	-	0.85549	0.77	0.77	32	-0.08549
ACME CHITTORGARH SOLAR ENERGY PVT LTD(1 * 250)	250	0	0	0	201	11:40	0	-	1.59418	1.62	1.62	68	0.02582
ACME DEOGHAR SOLAR POWER PRIVATE LIMITED(ADSPPL)	300	0	0	0	307	13:05	0	-	2.34033	2.36	2.36	98	0.01967
ACME HEERGARH POWERTECH PRIVATE LIMITED(1*300)	300	0	0	0	0	-	0	-	2.17385	1.96	1.96	82	-0.21385
ACME PHALODI SOLAR ENERGY PRIVATE LIMITED(APSEPL)	300	0	0	0	310	13:12	0	-	2.36216	2.4	2.4	100	0.03784
ACME RAISAR SOLAR ENERGY PRIVATE LIMITED(ARSEPL)	300	0	0	0	292	14:00	0	-	2.3519	2.4	2.34	98	-0.0119
ACME SIKAR SOLAR PRIVATE LIMITED	300	0	0	0	0	-	0	-	2.27224	2.22	2.22	93	-0.05224
ACMEDHAULPUR POWERTECH PRIVATE LIMITED(ADPPL)	300	0	0	0	306	13:02	0	-	2.37109	2.37	2.36	98	-0.01109
AMP ENERGY GREEN SIX PRIVATE LIMITED	100	0	0	0	0	-	0	-	0.36275	0.35	0.35	15	-0.01275
AMP GREEN ENERGY FIVE PRIVATE LIMITED	100	0	0	0	0	-	0	-	0.8375	0.78	0.78	33	-0.0575
ADANI GREEN ENERGY TWENTY FIVE B	138	0	0	0	0	-	0	-	0.15537	0.15	0.15	6	-0.00537
ADANI GREEN ENERGY TWENTY FOUR LIMITED	500	0	0	0	0	-	0	-	3.8892	3.85	3.85	160	-0.0392
ADANI RENEWABLE ENERGY RJ LIMITED (ARERJL)(1 * 200)	200	0	0	0	165	14:03	0	-	1.22842	1.27	1.27	53	0.04158
ADANI SOLAR ENERGY BARMER ONE LIMITED_FTG3	251	0	0	0	242	13:02	0	-	1.82974	1.83	1.82	76	-0.00974
ADANI SOLAR ENERGY JAISALMER TWO PRIVATE LIMITED(1*150)	150	0	0	0	138	12:15	0	-	0.99882	1.07	1.07	45	0.07118
ADANI SOLAR ENERGY JAISALMER TWO PRIVATE LIMITED (PROJECT-2)(1*150)	150	0	0	0	132	12:15	0	-	0.85764	1.09	1.09	45	0.23236
ADANI SOLAR ENERGY JODHPUR SIX PRIVATE LIMITED	50	0	0	0	0	-	0	-	0.17296	0.16	0.16	7	-0.01296
ADANI SOLAR ENERGY RJ TWO PVT LTD_BHADLA(1*150)	150	0	0	0	150	10:48	0	-	1.05256	1.15	1.15	48	0.09744
ADANI SOLAR ENERGY RJ TWO PVT LTD_FATEGARH 2(1*180)	180	0	0	0	181	12:56	0	-	1.73711	1.72	1.71	71	-0.02711
ADEPT RENEWABLE TECHNOLOGIES PVT LTD(1*110)	110	0	0	0	111	12:37	0	-	0.98785	0.93	0.93	39	-0.05785
ALTRA XERGI POWER PRIVATE LIMITED	380	0	0	0	0	-	0	-	2.8004	2.83	2.83	118	0.0296
AMBUJA CEMENTS LIMITED	150	0	0	0	0	-	0	-	2.00182	1.99	1.99	83	-0.01182
AMP ENERGY GREEN FOUR PRIVATE LIMITED	100	0	0	0	0	-	0	-	0.30479	0.3	0.3	13	-0.00479
AMPLUS AGES PRIVATE LIMITED(1*100)	100	0	0	0	80	09:34	0	-	0.63916	0.72	0.71	30	0.07084
AURAIYA SOLAR(1 * 40)	40	0	0	0	0	-	0	-	0.23152	0.28	0.27	11	0.03848
AVAADA RJHN PRIVATE LIMITED(1*240)	240	0	0	0	223	15:35	0	-	1.59848	1.72	1.72	72	0.12152
AVAADA SUNCE ENERGY PRIVATE LIMITED, BIKANER(1 * 350)	350	0	0	0	320	12:19	0	-	2.3315	2.48	2.48	103	0.1485
AVAADA SUNRAYS ENERGY PRIVATE LTD(1*320)	320	0	0	0	305	12:50	0	-	2.30847	2.3	2.29	95	-0.01847
AVAADA SUSTAINABLE RJPROJECT PVT LTD(1*300)	300	0	0	0	282	12:29	0	-	2.04592	2.15	2.15	90	0.10408
AYANA RENEWABLE POWER ONE PRIVATE LIMITED, BIKANER(300)	300	0	0	0	282	11:07	0	-	2.00246	2.25	2.25	94	0.24754
AZURE POWER FORTY THREE PRIVATE LIMITED(1 * 150 + 1 * 150 + 1 * 300)	600	0	0	0	548	12:30	0	-	3.96718	4.26	4.26	178	0.29282
AZURE POWER INDIA PVT LTD.(4 * 50)	200	0	0	0	158	12:07	0	-	1.124	1.19	1.19	50	0.066
AZURE POWER MAPLE PVT LTD(1*300)	300	0	0	0	245	12:57	0	-	1.93414	1.95	1.95	81	0.01586
AZURE POWER THIRTY FOUR PRIVATE LTD(1 * 130)	130	0	0	0	117	12:38	0	-	0.8719	0.88	0.88	37	0.0081
BBMB SOLAR BHIWANI	9	0	0	0	0	-	0	-	0.03338	0.03	0.05	2	0.01662

BBMB SOLAR HISSAR	2	0	0	0	0	-	0	-	0.00764	0.01	0.01	0	0.00236
BANDERWALA SOLAR PLANT LTD(1*300)	300	0	0	0	0	-	0	-	0.73803	0.74	0.74	31	0.00197
CLEAN SOLAR POWER (BHADLA) PVT LTD(1 * 300)	300	0	0	0	283	13:20	0	-	2.09647	2.18	2.18	91	0.08353
CLEAN SOLAR POWER(JODHPUR) PRIVATE LIMITED(1*250)	250	0	0	0	0	-	0	-	1.75419	1.81	1.81	75	0.05581
DADRI SOLAR(5)	5	0	0	0	3	-	0	-	0.02008	0.02	0.02	1	-0.00008
DEVIKOT SOLAR POWER NTPC	240	0	0	0	0	-	0	-	1.53601	1.55	1.55	65	0.01399
EDEN RENEWABLE ALMA PRIVATE LIMITED	300	0	0	0	0	-	0	-	0.68872	0.75	0.75	31	0.06128
EDEN RENEWABLE CITE PRIVATE LIMITED(1 * 300)	300	0	0	0	304	12:22	0	-	2.25046	2.27	2.27	95	0.01954
ENERGIZENT POWER PRIVATE LIMITED	69	0	0	0	0	-	0	-	0.16898	0.14	0.14	6	-0.02898
GORBEA SOLAR PRIVATE LIMITED	300	0	0	0	210	09:35	0	-	0.72675	0.83	0.83	35	0.10325
GRIAN ENERGY PRIVATE LIMITED(1*100)	100	0	0	0	80	09:34	0	-	0.66015	0.72	0.71	30	0.04985
HRP GREEN POWER PRIVATE LIMITED_BHD3	244	0	0	0	0	-	0	-	0.7333	0.72	0.72	30	-0.0133
IB VOGT SOLAR SEVEN PRIVATE LIMITED	300	0	0	0	0	-	0	-	0.34892	0.5	0.5	21	0.15108
JUNIPER GREEN COSMIC PRIVATE LIMITED	100	0	0	0	96	12:20	0	-	0.73357	0.75	0.75	31	0.01643
JUNA RENEWABLE ENERGY PRIVATE LIMITED	335	0	0	0	0	-	0	-	2.79427	2.83	2.83	118	0.03573
JUNIPER NIRJARA ENERGY PRIVATE LIMITED	50	0	0	0	31	09:29	0	-	0.2192	0.22	0.22	9	0.0008
KARNISAR SOLAR PLANT NHPC LIMITED	300	0	0	0	288	12:11	0	-	1.99225	2.22	2.21	92	0.21775
KHABA RENEWABLE ENERGY PRIVATE LIMITED_FTG3	250	0	0	0	0	-	0	-	0.38942	0.41	0.41	17	0.02058
KHIDRAT RENEWABLE ENERGY PRIVATE LIMITED	300	0	0	0	0	-	0	-	0.76548	0.78	0.78	33	0.01452
KOLAYAT SOLAR POWER PLANT NTPC LIMITED(1*550)	550	0	0	0	0	-	0	-	3.84629	3.4	3.4	142	-0.44629
M/S ADANI SOLAR ENERGY FOUR PRIVATE LIMITED(1 * 50)	50	0	0	0	46	14:03	0	-	0.3325	0.36	0.36	15	0.0275
M/S ADANI SOLAR ENERGY JODHPUR TWO LIMITED(1 * 50)	50	0	0	0	46	14:03	0	-	0.32925	0.35	0.35	15	0.02075
M/S AZURE POWER FORTY ONE PRIVATE LIMITED(1 * 300)	300	0	0	0	271	13:30	0	-	2.08626	2.09	2.09	87	0.00374
M/S. ONEVOLT ENERGY PRIVATE LIMITED(1*100)	100	0	0	0	78	09:46	0	-	0.64503	0.7	0.69	29	0.04497
MEGA SOILS RENEWABLE PRIVATE LIMITED(1 * 250)	250	0	0	0	0	-	0	-	1.54474	1.51	1.51	63	-0.03474
MEGA SURYAURJA PVT LTD(1*250)	250	0	0	0	0	-	0	-	1.7481	1.68	1.68	70	-0.0681
NTPC ANTA SOLAR PV STATION	90	0	0	0	0	-	0	-	0.67422	0.66	0.66	28	-0.01422
NTPC NOKH SOLAR PROJECT	735	0	0	0	0	-	0	-	5.15409	5.01	5.01	209	-0.14409
NTPC NIDAN SOLAR(1*296)	296	0	0	0	0	-	0	-	2.12325	2.08	2.08	87	-0.04325
NEEMBA RENEW SURYA VIHAAN PRIVATE LIMITED	200	0	0	0	125	09:30	0	-	0.52014	0.49	0.49	20	-0.03014
NOKHRA SOLAR POWER NTPC	300	0	0	0	0	-	0	-	2.09925	1.96	1.96	82	-0.13925
PROJECT ELEVEN RENEWABLE POWER PL_BHDL2	150	0	0	0	0	-	0	-	0.31075	0.3	0.3	13	-0.01075
PROJECT SIXTEEN RENEWABLE POWER_BHDL2	150	0	0	0	0	-	0	-	0.58575	0.58	0.58	24	-0.00575
RENEW DINKAR URJA PRIVATE LIMITED_BKN2	300	0	0	0	0	-	0	-	1.17035	1.06	1.06	44	-0.11035
RENEW SAMIR SHAKTI PRIVATE LIMITED_FTG3	300	0	0	0	0	-	0	-	0	-	-	-	-
RENEW SOLAR SHAKTI THREE PRIVATE LIMITED_FTG3	300	0	0	0	0	-	0	-	0	-	-	-	-
RENEW SUN BRIGHT PRIVATE LIMITED (RSBPL)(1 * 300)	300	0	0	0	274	12:53	0	-	2.11044	2.04	2.04	85	-0.07044
RENEW SURYA RAVI PVT LTD(1*300)	300	0	0	0	256	11:16	0	-	1.95446	2.05	2.05	85	0.09554
RENEW SOLAR (SHAKTI FIVE) PRIVATE LIMITED_FTG3	211	0	0	0	0	-	0	-	0	-	-	-	-
RENEW SOLAR ENERGY (JHARKHAND THREE) PVT LTD(300)	300	0	0	0	269	12:02	0	-	2.10631	2.09	2.09	87	-0.01631
RENEW SOLAR POWER PVT LTD(50)	50	0	0	0	176	12:36	0	-	0.38962	0.36	0.36	15	-0.02962
RENEW SOLAR POWER PVT LTD. BIKANER(1 * 250)	250	0	0	0	176	12:36	0	-	1.07461	1.33	1.32	55	0.24539
RENEW SOLAR URJA PVT LIMITED(300)	300	0	0	0	265	12:21	0	-	2.07825	2.06	2.06	86	-0.01825
RENEW SURYA AAYAN PRIVATE LIMITED	300	0	0	0	281	11:59	0	-	2.12593	2.09	2.09	87	-0.03593
RENEW SURYA JYOTI PRIVATE LIMITED	210	0	0	0	0	-	0	-	0.54125	0.08	0.08	3	-0.46125
RENEW SURYA PRATAP PRIVATE LIMITED(1*200)	200	0	0	0	0	-	0	-	1.50285	1.44	1.44	60	-0.06285
RENEW SURYA ROSHNI PVT LTD_SOLAR(1*400)	400	0	0	0	0	-	0	-	3.03824	2.96	2.96	123	-0.07824
RENEW SURYA VIHAAN PRIVATE LIMITED	100	0	0	0	0	-	0	-	0.71896	0.68	0.68	28	-0.03896
RISING SUN ENERGY (K) PVT LTD(1*164)	190	0	0	0	168	12:39	0	-	1.27064	1.27	1.27	53	-0.00064
SB ENERGY FOUR PVT LTD(2 * 100)	200	0	0	0	0	-	0	-	1.18047	1.17	1.17	49	-0.01047
SB ENERGY SIX PRIVATE LIMITED(1 * 300)	300	0	0	0	284	12:44	0	-	1.98923	2.19	2.19	91	0.20077

SJVN GREEN ENERGY LIMITED	888	0	0	0	770	11:09	0	-	5.46349	5.48	5.47	228	0.00651
SERENTICA RENEWABLES INDIA 4 PRIVATE LIMITED_BKN2	168	0	0	0	0	-	0	-	1.63717	1.63	1.63	68	-0.00717
SERENTICA RENEWABLES INDIA 5 PRIVATE LIMITED	220	0	0	0	0	-	0	-	0.94053	0.95	0.95	40	0.00947
SINGRAULI SOLAR(15)	15	0	0	0	0	-	0	-	0.06642	0.06	0.06	3	-0.00642
SOLZEN URJA PRIVATE LIMITED(1 * 300)	300	0	0	0	299	12:25	0	-	2.19532	2.22	2.22	93	0.02468
TRANSITION CLEANTECH SERVICES PRIVATE LIMITED	24	0	0	0	72	09:20	0	-	0.2156	0.51	0.51	21	0.2944
TATA POWER GREEN ENERGY LIMITED	225	0	0	0	191	12:26	0	-	1.50092	1.46	1.46	61	-0.04092
TATA POWER RENEWABLE ENERGY LTD(1 * 300)	300	0	0	0	273	12:43	0	-	2.02436	2.09	2.05	85	0.02564
TATA POWER SAURYA LIMITED	110	0	0	0	92	12:06	0	-	0.7001	0.68	0.68	28	-0.0201
THAR SURYA 1PRIVATE LIMITED(1*300)	300	0	0	0	210	13:38	0	-	1.3824	1.52	1.52	63	0.1376
TRANSITION ENERGY SERVICES PRIVATE LIMITED	60	0	0	0	0	-	0	-	0.33052	0.5	0.5	21	0.16948
TRANSITION GREEN ENERGY PRIVATE LIMITED	100	0	0	0	86	09:24	0	-	0.33608	0.34	0.34	14	0.00392
TRANSITION SUSTAINABLE ENERGY SERVICES PVT. LTD.	50	0	0	0	51	13:29	0	-	0.45226	0.43	0.43	18	-0.02226
TRANSITION SUSTAINABLE ENERGY SERVICES ONE PVT LTD	56	0	0	0	0	-	0	-	0.29824	0.27	0.27	11	-0.02824
UNCHAHAR SOLAR(10)	10	0	0	0	0	-	0	-	0.04225	0.04	0.04	2	-0.00225
XL XERGI POWER PRIVATE LIMITED	400	0	0	0	217	09:32	0	-	0.89535	0.9	0.9	38	0.00465
Sub-Total	**24,251**	**0**	**0**	**0**	**-**	**-**	**-**	**-**	**143.48901**	**144.82**	**144.63**	**6,034**	**1.14099**
HYBRID IPP													
AMPIN ENERGY GREEN EIGHT PRIVATE LIMITED_SOLAR	113	0	0	0	0	-	0	-	0	-	-	-	-
AMPIN ENERGY GREEN EIGHT PRIVATE LIMITED_WIND	44	0	0	0	0	-	0	-	0.0605	0.06	0.06	3	-0.0005
AMPIN ENERGY GREEN TEN PRIVATE LIMITED_SOLAR	110	0	0	0	0	-	0	-	0.31135	0.3	0.3	13	-0.01135
AMPIN ENERGY GREEN TEN PRIVATE LIMITED_WIND	41	0	0	0	0	-	0	-	0.21695	0.21	0.21	9	-0.00695
AMPIN ENERGY GREEN THREE PRIVATE LIMITED_SOLAR	50	0	0	0	0	-	0	-	0.1385	0.13	0.13	5	-0.0085
AMPIN ENERGY GREEN THREE PRIVATE LIMITED_WIND	19	0	0	0	0	-	0	-	0.09408	0.09	0.09	4	-0.00408
ADANI HYBRID ENERGY JAISALMER FOUR LIMITED SOLAR(1*600)	600	0	0	0	0	-	0	-	5.71782	5.77	5.77	240	0.05218
ADANI HYBRID ENERGY JAISALMER FOUR LIMITED WIND(1*510)	510	0	0	0	0	-	0	-	3.2381	3.58	3.58	149	0.3419
ADANI HYBRID ENERGY JAISALMER ONE LIMITED SOLAR(1 * 235.1 + 1 * 124.8)	360	0	0	0	354	11:38	0	-	2.94292	2.78	2.78	116	-0.16292
ADANI HYBRID ENERGY JAISALMER ONE LIMITED WIND(1 * 101)	101	0	54	11	89	10:00	0	-	0.8925	0.07	0.07	3	-0.8225
ADANI HYBRID ENERGY JAISALMER THREE LIMITED SOLAR(1*300)	300	0	0	0	280	-	0	-	2.66757	2.7	2.7	113	0.03243
ADANI HYBRID ENERGY JAISALMER THREE LIMITED WIND(1*75)	75	0	17	4	63	10:00	0	-	0.56228	0.04	0.04	2	-0.52228
ADANI HYBRID ENERGY JAISALMER TWO LIMITED SOLAR(1*299)	300	0	0	0	295	11:15	0	-	2.90407	2.9	2.9	121	-0.00407
ADANI HYBRID ENERGY JAISALMER TWO LIMITED WIND(1*75)	75	0	61	7	68	09:30	0	-	0.575	0.06	0.06	3	-0.515
ADANI JAISALMER ONE SEPL SOLAR(1*420)	420	0	0	0	389	11:59	0	-	3.28922	3	3	125	-0.28922
ADANI JAISALMER ONE SEPL WIND(1*105)	105	0	96	14	104	22:00	0	-	0.93328	1.11	1.11	46	0.17672
AYANA RENEWABLE THREE PVT LTD (1*300)	300	0	0	0	296	12:58	0	-	2.09215	2.22	2.22	93	0.12785
JUNIPER GREEN STELLAR PRIVATE LIMITED_S_FTG3	185	0	0	0	0	-	0	-	0	-	-	-	-
Sub-Total	**3,708**	**0**	**228**	**36**	**-**	**-**	**-**	**-**	**26.63629**	**25.02**	**25.02**	**1,045**	**-1.61629**
Total	**29,909**	**1,731**	**1,558**	**618**					**188.55641**	**188.18**	**187.52**	**7,823**	**-1.03641**

STORAGE

Station/Constituents	Inst. Capacity	Declared Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW	UI
	(MW)	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	Gross Gen(MU)	Net Gen(MU)		
PUMP STORAGE													
TEHRI PSP(4 * 250)	1,000	480	447	0	495	21:00	0	-	-1.39296	3.88	-1.39	-58	0.00296
Sub-Total	1,000	480	447	0	-	-	-	-	-1.39296	3.88	-1.39	-58	0.00296
BESS													
ACME SUN POWER PRIVATE LIMITED_BESS	167	0	0	0	0	-	0	-	0.05773	0.05	0.05	2	-0.00773
ACME SURYA POWER PRIVATE LIMITED_BESS	107	0	0	0	0	-	0	-	0.07934	0.07	0.07	3	-0.00934
ACME SURYODAYA PRIVATE LIMITED_BESS	247	0	0	0	0	-	0	-	0.04488	0.04	0.04	2	-0.00488
JUNIPER GREEN STELLAR PRIVATE LIMITED_BESS_FTG4	180	0	0	0	0	-	0	-	0.051	0.04	0.04	2	-0.011
JUNIPER GREEN COSMIC PRIVATE LIMITED_BESS	41	0	0	0	0	-	0	-	0.09012	0.06	0.06	3	-0.03012
RENEW SURYA ROSHNI PVT LTD_BESS	23	0	0	0	0	-	0	-	0.0805	0.02	0.02	1	-0.0605
Sub-Total	765	0	0	0	-	-	-	-	0.40357	0.28	0.28	13	-0.12357
Total	1,765	480	447	0					-0.98939	4.16	-1.11	-45	-0.12061

Summary Section

	Inst. Capacity	PEAK	OFF-PEAK	Day Energy		Day AVG.
				Gross Gen	Net Gen	
Total State Control Area Generation	72,420	37,980	36,843	957.6	902.41	37,606
J. Net Inter Regional Exchange [Import (+ve)/Export (-ve)]		4,651	5,125	287.17	287.17	12,662
Inter National Exchange with Nepal[Import (+ve)/Export (-ve)]		37	20	-2.04	-2.04	-69
Total Regional Availability(Gross)	131,792	64,589	58,935	1,835.31	1,751.16	73,696

Total Hydro Generation

	Inst. Capacity	PEAK	OFF-PEAK	Day Energy		Day AVG.
				Gross Gen	Net Gen	
Regional Entities Hydro	14,722	11,551	5,376	154.14	147.21	6,135
State Control Area Hydro	8,155	3,714	3,416	92.15	91.96	3,832
Total Regional Hydro	22,877	15,265	8,792	246.29	239.17	9,967

Total Renewable Generation

	Inst. Capacity	PEAK	OFF-PEAK	Day Energy		Day AVG.
				Gross Gen	Net Gen	
Regional Entities Renewable	27,959	228	36	169.84	169.65	7,079
State Control Area Renewable	17,736	1,105	534	105.41	105.39	4,392
Total Regional Renewable	45,695	1,333	570	275.25	275.04	11,471

Total Solar Generation

	Inst. Capacity	PEAK	OFF-PEAK	Day Energy		Day AVG.
				Gross Gen	Net Gen	
Regional Entities Solar	26,989	0	0	164.62	164.43	6,860
State Control Area Solar	12,614	90	53	78.23	78.23	3,260
Total Solar	39,603	90	53	242.85	242.66	10,120

Total Wind Generation

	Inst. Capacity	PEAK	OFF-PEAK	Day Energy		Day AVG.
				Gross Gen	Net Gen	
Regional Entities Wind	970	228	36	5.22	5.22	219
State Control Area Wind	4,328	857	323	19.29	19.29	804
Total Wind	5,298	1,085	359	24.51	24.51	1,023

4(A) INTER-REGIONAL EXCHANGES (Import=(+ve) /Export =(-ve))

SL.No.	Element	20:00	03:00	Maximum Interchange (MW)		Import in MU	Export in MU	NET
		(MW)	MW	Import (MW)	Export (MW)			
Import/Export between EAST REGION and NORTH REGION								
1	132KV Rihand - Nagar Untari	-	-	-	-	-	-	-
2	132KV-Chandauli (UP)-Karmnasa(PG)	-	-	-	-	-	-	-
3	132KV-Rihand (UP)-Garhwa(CG)	-	-	-	-	0	0.73	-0.73
4	132KV-Sahupuri (UP)-Karamnasa(PG)	-	-	-	-	-	-	-
5	220KV-Sahupuri (UP)-Karamnasa(PG)	-	-	-	-	1.89	0	1.89
6	400KV-Allahabad (PG)-Sasaram(PG)	-	-	-	-	0.07	0	0.07
7	400KV-Balia (PG)-Biharsharif(PG)	-	-	-	-	0	9.93	-9.93
8	400KV-Balia (PG)-Naubatpur(Bihar)	-	-	-	-	0	1.33	-1.33
9	400KV-Balia (PG)-Patna(PG)	-	-	-	-	2.18	0	2.18
10	400KV-Gorakhpur (UP)-Motihari(DMT)	158	176	304	229	1.59	0	1.59
11	400KV-Gorakhpur (UP)-Muzaffarpur(PG)	8	43	214	627	0	3.69	-3.69
12	400KV-Sahupuri (UP)-Biharsharif(PG)	-	-	-	-	0	0.84	-0.84
13	400KV-Varanasi (PG)-Sasaram(PG)	-76	-72	125	0	2.28	0	2.28
14	765KV-Balia (PG)-Gaya(PG)	-	-	-	-	11.4	0	11.4

Import/Export between EAST REGION and NORTH REGION								
15	765KV-Sasaram (PG)-Fatehpur(PG)	-	-	-	-	0	0.88	-0.88
16	765KV-Varanasi (PG)-Gaya(PG)	-223	-388	493	860	0	1.93	-1.93
17	HVDC800KV-Agra (PG)-Alipurduar(PG)	-	-	-	-	-	-	-
Sub-Total EAST REGION		-133	-241	1,136	1,716	19.41	19.33	0.08
Import/Export between NORTH_EAST REGION and NORTH REGION								
1	HVDC800KV-Agra (PG)-Biswanath Charialli(PG)	-	-	-	-	13.52	0	13.52
Sub-Total NORTH_EAST REGION		0	0	0	0	13.52	0	13.52
Import/Export between WEST REGION and NORTH REGION								
1	132KV-Lalitpur (UP)-Rajghat(MP)	-	-	-	-	-	-	-
2	132KV-Sawai Madhopur (RJ)-Gwalior(MP)	-	-	-	-	-	-	-
3	220KV-Auraiya (NT)-Malanpur(PG)	-102	-34	-	87	0	0.9	-0.9
4	220KV-Auraiya (NT)-Mehgaon(PG)	-	-	-	-	-	-	-
5	220KV-Modak (RJ)-Bhanpura(MP)	44	52	57	39	1.15	0	1.15
6	220KV-Ranpur (RS)-Bhanpura(MP)	65	94	100	65	2.03	0	2.03
7	400KV-Bhinmal (PG)-Zerda(PG)	-	-	-	-	-	-	-
8	400KV-Chittorgarh 765 (PG)-Neemuch (WR)	-44	-317	439	377	0.68	0	0.68
9	400KV-Kankroli (RJ)-Zerda(PG)	-	-	-	-	0.03	0	0.03
10	400KV-RAPS C (NP)-Sujalpur	-	-	-	-	0	5.19	-5.19
11	400KV-Rihand (NT)-Vindhyachal(PG)	-	-	-	-	-	-	-
12	765KV-0rai-Gwalior (PG)	-573	-636	0	-692	0	11.35	-11.35
13	765KV-0rai-Jabalpur	1,418	1,575	1,965	0	27.34	0	27.34
14	765KV-0rai-Satna	788	873	957	0	16.95	0	16.95
15	765KV-Agra (PG)-Gwalior(PG)	-	-	-	-	26.99	0	26.99
16	765KV-Chittorgarh-Banaskata D/C	-210	494	899	964	2.75	0	2.75
17	765KV-Dausa (PG)-Gwalior(PG)	-	-	-	-	14.03	0	14.03
18	765KV-Varanasi (PG)-Vindhyachal(PG)	-2,802	-2,336	3,562	0	62.28	0	62.28
19	HVDC500KV-Mohindergarh (JH)-Mundra(JH)	1,500	1,501	1,503	0	36.35	0	36.35
20	HVDC500KV-Vindhyachal (PG)-Vindhaychal B/B	200	100	200	100	2.26	1.28	0.98
21	HVDC800KV-Kurukshetra (PG)(PG)-Champa(PG)	4,500	4,000	4,500	0	99.45	0	99.45
Sub-Total WEST REGION		4,784	5,366	14,182	940	292.29	18.72	273.57
TOTAL IR EXCHANGE		4,651	5,125	15,318	2,656	325.22	38.05	287.17

4(B) Inter Regional Schedule & Actual Exchange (Import=(+ve) /Export =(-ve)) in MU

	ISGS+GNA+URS schedule	T-GNA Bilateral (MW)	GDAM Schedule	DAM Schedule	RTM Schedule	Total IR Schedule	Total IR Actual	NET IR UI
NR-ER	117.79	4.12	0	-1.42	0	97.43	0.08	-97.35
NR-NORTH_EAST REGION	0	0	0	0	0	0	13.52	13.52
NR-WR	232.13	66.67	0	-78	0	209.08	273.57	64.49
Total	349.92	70.79	0	-79.42	0	306.51	287.17	-19.34

5.Inter National Exchange with Nepal [Import (+ve)/Export(-ve)] [Linkwise]

Element	Peak	Off-Peak	Maximum Interchange(MW)		Energy (MU)		Net Energy	Schedule Energy
	MW	MW	Import	Export	Import	Export	(MU)	(MU)
132KV-Tanakpur(NH)-Mahendranagar(PG)	37	20	0	69	0	1.04	-1.04	0
132KV-Nautanwa (UP)-Mainhiya (Nepal)						1	-1	0

5.Frequency Profile

RANGE(Hz)	< 49.2	< 49.7	< 49.8	< 49.9	< 50.0	>= 49.9 - <= 50.05	> 50.05 - <= 50.1	> 50.1 - <= 50.2	> 50.2	> 50.05
%	0	4.64	6.85	10.31	47.47	70.31	14.42	4.57	.38	19.38

<----------Frequency (Hz)---------->

Maximum		Minimum		Average	Freq Variation	Standard	Freq. in 15 mnt blk		Freq Dev Index
Frequency	Time	Frequency	Time	Frequency	Index	Deviation	Max.	Min.	(% of Time)
50.279	18:02:30	49.451	00:36:00	49.985	0.12	0.108	50.156	49.515	29.69

6.Voltage Profile: 400kV

	Maximum		Minimum		Voltage (in %)				Voltage Deviation Index
					< 380	< 390	> 420	> 430	(% of time)
Abdullapur(PG) - 400KV	413	02:10	397	12:05	0	0	0	0	0
Amritsar(PG) - 400KV	411	02:55	391	12:15	0	0	0	0	0
Ballabgarh(PG) - 400KV	411	07:40	388	12:15	0	4.17	0	0	0
Bareilly II(PG) - 400KV	408	07:40	393	22:30	0	0	0	0	0
Bareilly(UP) - 400KV	409	07:40	394	22:30	0	0	0	0	0

Baspa(HP) - 400KV	**411**	**02:15**	**395**	**22:20**	**0**	**0**	**0**	**0**	**0**
Bassi(PG) - 400KV	**416**	**04:00**	**394**	**12:20**	**0**	**0**	**0**	**0**	**0**
Bawana(DTL) - 400KV	**411**	**03:55**	**394**	**12:15**	**0**	**0**	**0**	**0**	**0**
Dadri HVDC(PG). - 400KV	**412**	**00:00**	**412**	**00:00**	**0**	**0**	**0**	**0**	**0**
Gorakhpur(PG) - 400KV	**411**	**07:50**	**391**	**19:45**	**0**	**0**	**0**	**0**	**0**
Hisar(PG) - 400KV	**418**	**02:20**	**391**	**12:15**	**0**	**0**	**0**	**0**	**0**
Kanpur(PG) - 400KV	**413**	**07:40**	**396**	**00:30**	**0**	**0**	**0**	**0**	**0**
Kashipur(UT) - 400KV	**414**	**06:50**	**407**	**20:40**	**0**	**0**	**0**	**0**	**0**
Kishenpur(PG) - 400KV	**413**	**03:55**	**399**	**12:20**	**0**	**0**	**0**	**0**	**0**
Moga(PG) - 400KV	**415**	**02:55**	**395**	**12:15**	**0**	**0**	**0**	**0**	**0**
Nallagarh(PG) - 400KV	**411**	**02:15**	**395**	**22:20**	**0**	**0**	**0**	**0**	**0**
Rihand HVDC(PG) - 400KV	**400**	**13:00**	**391**	**00:15**	**0**	**0**	**0**	**0**	**0**
Rihand(NT) - 400KV	**401**	**09:55**	**394**	**21:15**	**0**	**0**	**0**	**0**	**0**

6.1 Voltage Profile: 765kV

	Maximum		**Minimum**		**Voltage (in %)**				**Voltage Deviation Index**
					< 728	**< 742**	**> 800**	**> 820**	
Anta RS(RJ) - 765KV	**790**	**08:10**	**762**	**22:55**	**0**	**0**	**0**	**0**	**0**
Balia(PG) - 765KV	**779**	**07:40**	**750**	**00:05**	**0**	**0**	**0**	**0**	**0**
Bareilly II(PG) - 765KV	**771**	**07:40**	**741**	**22:30**	**0**	**.35**	**0**	**0**	**0**
Bhiwani(PG) - 765KV	**790**	**03:40**	**756**	**12:05**	**0**	**0**	**0**	**0**	**0**
Fatehpur(PG) - 765KV	**790**	**07:40**	**760**	**00:00**	**0**	**0**	**0**	**0**	**0**
Jhatikara(PG) - 765KV	**785**	**04:00**	**743**	**12:05**	**0**	**0**	**0**	**0**	**0**
Lucknow II(PG) - 765KV	**782**	**07:40**	**746**	**00:30**	**0**	**0**	**0**	**0**	**0**
Meerut(PG) - 765KV	**789**	**03:55**	**747**	**12:15**	**0**	**0**	**0**	**0**	**0**
Moga(PG) - 765KV	**794**	**03:55**	**746**	**12:05**	**0**	**0**	**0**	**0**	**0**
Phagi(RJ) - 765KV	**793**	**07:40**	**760**	**12:20**	**0**	**0**	**0**	**0**	**0**
Unnao(UP) - 765KV	**778**	**07:40**	**747**	**00:30**	**0**	**0**	**0**	**0**	**0**

7(A). Short-Term Open Access Details:

State	**Off- Peak Hours (03:00)**										**Peak Hours (20:00)**									
	T-GNA Bilateral(MW)	**IEX GDAM (MW)**	**IEX DAM (MW)**	**IEX RTM (MW)**	**PXIL GDAM (MW)**	**PXIL DAM (MW)**	**PXI RTM (MW)**	**HPX GDAM (MW)**	**HPX DAM (MW)**	**HPX RTM (MW)**	**Bilateral (MW)**	**IEX GDAM (MW)**	**IEX DAM (MW)**	**IEX RMT (MW)**	**PXIL GDAM (MW)**	**PXIL DAM (MW)**	**PXIL RMT (MW)**	**HPX GDAM (MW)**	**HPX DAM (MW)**	**HPX RTM (MW)**
PUNJAB	2,570.87	0	0	-3,300	0	0	0	0	0	0	2,452.17	0.44	3.11	-2,395.77	0	0	0	0	0	0
HARYANA	392.05	0	-587.88	0	0	0	0	0	0	0	-177.81	0.93	6.53	-92.03	0	0	0	0	0	0
RAJASTHAN	-89.33	-32.7	-1,137.38	932.4	0	0	0	0	0	0	-16.03	-35.04	-1,097.93	453.18	0	0	0	0	0	0
DELHI	996.07	0	-409	248.07	0	0	0	0	0	0	1,744.15	0.02	-629.92	-34.86	0	0	0	0	0	0
UTTAR PRADESH	296.68	-16.52	206.12	18.76	0	0	0	0	0	0	267.78	0	139.32	108.94	0	0	0	0	0	0
UTTARAKHAND	121.67	-11.6	250.17	-100	0	0	0	0	0	0	604.9	-12.6	49.55	169.14	0	0	0	0	0	0
HIMACHAL PRADESH	-150.37	-32.4	-22.29	79.9	0	0	0	0	0	0	-153.37	-34.5	-414.17	-93.9	0	0	0	0	0	0
J&K(UT) & LADAKH(UT)	-16	-31.8	-15	207.63	0	0	0	0	0	0	-16	-31.8	102.98	422.85	0	0	0	0	0	0
CHANDIGARH	0	0	-70	10.63	0	0	0	0	0	0	75.4	0	-130	7.61	0	0	0	0	0	0
RAILWAYS_NR ISTS	0	0	90.6	0	0	0	0	0	0	0	0	4.39	31.19	39.75	0	0	0	0	0	0
BULK CONSUMER_NR ISTS	0	0	0	38.84	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOTAL	4,121.64	-125.02	-1,694.66	-1,863.77	0	0	0	0	0	0	4,781.19	-108.16	-1,939.34	-1,415.09	0	0	0	0	0	0

State	Day Energy (MU)					
	GNA schedule	T-GNA Bilateral (MW)	GDAM Schedule	DAM Schedule	RTM Schedule	Total (MU)
PUNJAB	107.76	60.52	0.01	0.08	-30.89	137.47
HARYANA	176.94	8.38	0.79	-3.86	2.94	183.2
RAJASTHAN	104.69	1.41	-0.58	-37.49	2.38	70.42
DELHI	97.51	37.89	0.2	-7.55	0.45	128.51
UTTAR PRADESH	222.57	2.22	0.07	3.95	4.83	233.98
UTTARAKHAND	28.56	6.33	-0.16	3.43	1.67	39.82
HIMACHAL PRADESH	12.51	-2.46	-0.22	-2.91	1	7.93
J&K(UT) & LADAKH(UT)	27.87	-0.28	-0.5	1.54	1.63	30.25
CHANDIGARH	6.51	0.41	0.01	-0.51	0.36	6.77
RAILWAYS_NR ISTS	2.56	0	0.04	0.94	0.18	3.73
BULK CONSUMER_NR ISTS	1.4	0.06	0	0	0.23	1.69
TOTAL	788.88	114.48	-0.34	-42.38	-15.22	843.77

7(B). Short-Term Open Access Details

State	GNA schedule		T-GNA Bilateral (MW)		IEX GDAM (MW)		PXI GDAM (MW)		HPX GDAM(MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
PUNJAB	5,120.58	4,004.41	2,585.4	2,449.16	8.4	0	0	0	0	0
HARYANA	8,155.61	6,045	621.27	-543.17	82.29	0	0	0	0	0
RAJASTHAN	5,294.45	2,902.61	290.89	-209.32	33.97	-55.96	0	0	0	0
DELHI	4,589.92	3,156.96	2,183.36	985.72	130.3	0	0	0	0	0
UTTAR PRADESH	11,389.48	7,020.77	386.34	-46.88	229.08	-28.32	0	0	0	0
UTTARAKHAND	1,374.82	1,005.01	605.2	28.13	0	-19.2	0	0	0	0
HIMACHAL PRADESH	862.69	159.11	-0.63	-153.37	31.89	-34.5	0	0	0	0
J&K(UT) & Ladakh(UT)	1,617.36	533.14	-8	-16	0	-31.8	0	0	0	0
CHANDIGARH	375.87	157.93	75.4	0	35.34	0	0	0	0	0
RAILWAYS_NR ISTS	121.77	100.76	0	0	70.61	0	0	0	0	0
BULK CONSUMER_NR ISTS	-	-	-	-	-	-	-	-	-	-

State	IEX DAM (MW)		PXI DAM(MW)		HPX DAM (MW)		IEX RTM (MW)		PXI RTM (MW)		HPX RTM (MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
PUNJAB	13.52	0	0	0	0	0	579.54	-4,600	0	0	0	-25
HARYANA	21.25	-828.17	0	0	0	0	869.31	-450	196.98	196.98	196.98	0
RAJASTHAN	-203.39	-3,341.02	0	0	0	0	1,056.85	-699.52	1.36	1.36	1.36	0
DELHI	181.59	-894	0	0	0	0	283.97	-141.2	0	0	0	0
UTTAR PRADESH	554.79	-1,759.2	0	0	0	0	722.94	-566	41.23	41.23	41.23	0
UTTARAKHAND	528.35	0	0	0	0	0	309.32	-150	0	0	0	0
HIMACHAL PRADESH	162.89	-463.86	0	0	0	0	457.1	-241.33	0	0	0	0
J&K(UT) & LADAKH(UT)	274.77	-15	0	0	0	0	471.84	-257.5	0	0	0	0
CHANDIGARH	106.25	-135	0	0	0	0	72.44	-17	0	0	0	0
RAILWAYS_NR ISTS	99.97	0	0	0	0	0	64.72	0	0	0	0	0
BULK CONSUMER_NR ISTS	-	-	-	-	-	-	-	-	-	-	-	-

8.Major Reservoir Particulars

RESERVOIR	Parameters			Present Parameters		LAST YEAR		LAST DAY	
	MDDL (Mts)	FRL (Mts)	Energy Content at FRL	Level (Mts)	Energy (MU)	Level (Mts)	Energy (MU)	Inflow (m3/s)	Usage (m3/s)
Bhakra	445.62	513.59	1,728.8	481.69	495	476.17	375	335.47	435.37
Chamera-I	748.75	760	753.95	-	-	-	-	-	0
Gandhisagar	381	399.9	725	-	-	-	-	-	0
Jawahar Sagar	295.96	298.7	2.01	-	-	-	-	-	0
Koteshwar	598.5	612.5	610.73	610.3	5	611.35	5	93.53	102.2
Pong	384.05	426.72	1,084	405.53	352	395.04	126	53.66	142.69
RPS	343.81	352.81	175.66	-	-	-	-	-	0
RSD	487.91	527.91	390.3	512.75	250	508.23	197	77.93	327.84
Rihand	252.98	268.22	860.5	-	-	-	-	-	0
Tehri	740.04	830	1,164.11	741.26	7	742.03	11	114.91	97
TOTAL	-	-	-	-	1,109	-	714	675.5	1,105.1

9. System Reliability Indices(Violation of TTC and ATC):

(i)%age of times N-1 Criteria was violated in the inter and intra regional corridors	
WR	0
ER	0
Simultaneous	0
Delhi	0
Rajasthan	0
UP	0
Punjab	0
Haryana	0

ii)%age of times ATC violated on the inter and intra regional corridors

WR	0
ER	0
Simultaneous	0
Delhi	0
Rajasthan	0
UP	0
Punjab	0
Haryana	0

iii)%age of times Angular Difference on Important Buses was beyond permissible limits(40 deg.)

Rihand-Dadri	0

10. Zero Crossing Violations

State	No. of violations(Maximum 15 in a day)	Maximum number of continuous blocks without sign change
CHANDIGARH	0	3
DELHI	10	31
HARYANA	7	28
HIMACHAL PRADESH	2	10
J&K(UT) & Ladakh(UT)	7	17
PUNJAB	11	23
RAJASTHAN	11	56
UTTAR PRADESH	4	21
UTTARAKHAND	7	32

11. NCR's and Ladakh Power Supply Position(based on SCADA data)

	Inst Capacity	20:00	03:00	Day Peak			
Station/Constituents	(MW)	Peak MW	Off Peak MW	MW	HRS	Net MU	AVG MW
NCR_GENERATION	9225	5,799	5,496	7242	22:30:00	121.84	5,077
NCR_DRAWAL	-	13,952	11,641	14136	19:45:00	283.94	11,831
NCR_DEMAND	-	19,751	17,138	21284	22:45:00	405.79	16,908
LADAKH_DEMAND	-	22	-1	23	20:15:00	0.22	9

12. RE/Load Curtailment details

State	Load Curtailment (Shortage)			RE Curtailment				
	Energy	Maximum	At the time of maximum demand	Wind		Solar		Reason
	MU	MW	MW	Max MW	Energy(MU)	Max MW	Energy(MU)	
PUNJAB	0	0	0	0	0	0	0	
HARYANA	1.15	468.75	0	0	0	0	0	
RAJASTHAN	0	0	0	0	0	0	0	
DELHI	0	0	0	0	0	0	0	
UTTAR PRADESH	0	0	0	0	0	0	0	
UTTARAKHAND	0.44	285	0	0	0	0	0	
HIMACHAL PRADESH	0	0	0	0	0	0	0	
J&K(UT) & Ladakh(UT)	0.495	495	0	0	0	0	0	
CHANDIGARH	0	0	0	0	0	0	0	
RAILWAYS_NR ISTS	0	0	0	0	0	0	0	
BULK CONSUMER_NR ISTS	0	0	0	0	0	0	0	

13.Grid Disturbance / Any Other Significant Event:

14.Weather Conditions :

15.Synchronisation of new generating units :

16.Synchronisation of new 220 / 400 / 765 KV lines and energising of bus / /substation :

1.427(RENEW SHAKTI SIX) MAIN BAY - 400 KV BHADLA_3(PB3TL) - BUS 1 (PB3TL) AT 400 KV BHADLA_3(PB3TL) first time charged at 03-Jun-26 00:00
2.428(RENEW SHAKTI SIX) TIE BAY - 400 KV BHADLA_3(PB3TL) - BUS 1 (PB3TL) AND 400 KV BHADLA_3(PB3TL) - BUS 2 AT 400 KV BHADLA_3(PB3TL) (PB3TL) first time charged at 03-Jun-26 00:00
3.410(FARRUKHABAD CKT1) MAIN BAY - 400 KV MAHEBA(UP) - BUS 1 (UPPTCL) AT 400 KV MAHEBA(UP) first time charged at 03-Jun-26 00:51
4.407(FARRUKHABAD CKT2) MAIN BAY - 400 KV MAHEBA(UP) - BUS 1 (UPPTCL) AT 400 KV MAHEBA(UP) first time charged at 03-Jun-26 05:13
5.226(ALF CKT1) MAIN BAY - 220 KV BIKANER_2 (PBTSL) - BUS 1 (PBTSL) AT 220 KV BIKANER_2 (PBTSL) first time charged at 03-Jun-26 01:00

17.Instances of persistent/significant non-complaint with the grid code

18.Constraints and instances of congestion in the transmission system

19.Remarks :

No Records Found

Note: Data(regarding drawal,generation, shortage , inter-regional flows and reservoir levels)of the constituents filled in the report are as per last furnished data by the respective state/constituent to NRLDC.
***Unscheduled Load Shedding carried out by Uttar Pradesh.**

Shift In Charge