GRID CONTROLLER OF INDIA (GRID-INDIA)
NORTHERN REGIONAL LOAD DESPATCH CENTRE
DAILY OPERATION REPORT OF NORTHERN REGION

Power Supply Position in Northern Region For 04-Jun-2026

Date of Reporting:05-Jun-2026

1. Regional Availability/Demand:

Evening Peak (20:00) MW				Off-Peak (03:00) MW				Day Energy(Net MU)	
Demand Met	Shortage	Requirement	Freq (Hz)	Demand Met	Shortage	Requirement	Freq (Hz)	Demand Met	Shortage
69,866	0	69,866	50.201	72,114	0	72,114	49.988	1,699	0.05

2(A)State's Load Deails (At State Periphery) in MU:

State	State's Control Area Generation (Net MU)							Drawal Sch	Act Drawal	UI	Requirement	Shortage	Consumption
	Thermal	Hydro	Gas/Naptha/ Diesel	Solar	Wind	OthersBiomass/Co-gen etc.)	Total	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)
PUNJAB	90.91	13.9	0	5.23	0	2.47	112.5	133.15	125.97	-7.18	238.47	0	238.47
HARYANA	57.3	0.69	1.84	1.3	0	1.44	62.58	185.19	176.33	-8.86	238.91	0	238.91
RAJASTHAN	160.25	0.03	1.7	50.43	40.7	6.15	259.26	64.57	49.97	-14.6	309.23	0	309.23
DELHI	0	0	16.23	0	0	1.61	17.84	130.09	124.73	-5.36	142.57	0	142.57
UTTAR PRADESH	335.3	12.2	0	16.9	0	1.2	365.6	250.53	246.21	-4.32	611.81	0	611.81
UTTARAKHAND	0	14.91	0	0.66	0	0	15.57	40.61	40.91	0.3	56.53	0.05	56.48
HIMACHAL PRADESH	0	33.31	0	0.46	0	0	33.76	4.87	4.61	-0.26	38.37	0	38.37
J&K(UT) & Ladakh(UT)	0	22.41	0	0	0	0	22.41	29.07	27.72	-1.35	50.13	0	50.13
CHANDIGARH	0	0	0	0	0	0	0	7.03	6.86	-0.17	6.86	0	6.86
RAILWAYS_NR ISTS	0	0	0	0	0	0	0	4.05	4.49	0.44	4.49	0	4.49
BULK CONSUMER_NR ISTS	0	0	0	0	0	0	0	1.43	1.47	0.04	1.47	0	1.47
Region	643.76	97.45	19.77	74.98	40.7	12.87	889.52	850.59	809.27	-41.32	1,698.84	0.05	1,698.79

2(B)State Demand Met (Peak and off-peak Hrs)

State	Evening Peak (20:00) MW				AVG DEMAND	Off-Peak (03:00) MW			
	Demand Met	Shortage	UI	STOA/PX/RTM Transaction	MW	Demand Met	Shortage	UI	STOA/PX/RTM Transaction
PUNJAB	7,940	0	-227	-1,749	9,919	9,547	0	-93	549
HARYANA	8,947	0	-1,285	-684	10,010	10,629	0	-142	408
RAJASTHAN	12,320	0	-1,647	12	12,774	12,686	0	107	-1,493
DELHI	5,501	0	-325	1,530	5,934	5,963	0	179	1,120
UTTAR PRADESH	28,087	0	-637	1,609	25,413	27,391	0	-261	1,267
UTTARAKHAND	2,717	0	-34	595	2,357	2,225	0	26	260
HIMACHAL PRADESH	1,508	0	21	-811	1,580	1,374	0	-22	-109
J&K(UT) & Ladakh(UT)	2,383	0	-178	382	2,089	1,848	0	129	265
CHANDIGARH	264	0	-53	-48	286	251	0	2	-73
RAILWAYS_NR ISTS	200	0	20	95	187	199	0	1	88
BULK CONSUMER_NR ISTS	0	0	0	0	61	0	0	0	0
Region	69,867	0	-4,345	931	70,610	72,113	0	-74	2,282

2(C)State's Demand Met in MWs (Maximum Demand Met and Maximum requirement of the day details)

State	Maximum Demand, corresponding shortage and requirement details for the day				Maximum requirement, corresponding shortage and demand details for the day						ACE			
	Maximum Demand Met of the day	Time	Shortage during at maximum demand	Requirement at the max demand met of the day	Maximum Requirement of the day	Time	Shortage during at maximum Requirement	Demand Met at maximum requiremnet	Min Demand Met	Time	ACE_MAX	Time	ACE_MIN	Time
PUNJAB	12,811	14:00	0	12,811	12,811	14:00	0	12,811	5,916	18:00	3,344.28	17:59:00	-2,322.79	15:14:00
HARYANA	11,275	12:00	0	11,275	11,275	12:00	0	11,275	8,775	19:00	1,416.13	14:27:00	-385.42	00:31:00
RAJASTHAN	13,719	0:00	0	13,719	13,719	0:00	0	13,719	11,690	19:00	4,566.54	15:15:00	-860.41	11:06:00
DELHI	7,195	0:00	0	7,195	7,195	0:00	0	7,195	5,025	7:00	2,318	14:55:00	-208.68	18:17:00
UP	29,054	1:00	0	29,054	29,054	1:00	0	29,054	20,234	6:00	2,164.99	15:25:00	-1,095.14	07:31:00
UTTARAKHA ..	2,717	20:00	0	2,717	2,717	20:00	0	2,717	2,053	12:00	466.98	19:17:00	-119.72	13:29:00
HP	1,849	9:00	0	1,849	1,849	9:00	0	1,849	1,315	23:00	238.89	18:16:00	-502.14	15:15:00
J&K(UT)&Lad ..	2,503	6:00	0	2,503	2,503	6:00	0	2,503	1,553	16:00	917.39	15:15:00	-640.87	00:04:00
CHANDIGARH	371	15:00	0	371	371	15:00	0	371	219	6:00	66.07	20:59:00	-14.21	23:46:00
RAILWAYS_NR ISTS	211	0:00	0	211	211	0:00	0	211	146	13:00	0	-	0	-
BULK CONSUMER_NR ISTS	103	11:00	0	103	103	11:00	0	103	23	1:00	-	-	-	-
NR	78,551	0:00	0	78,551	78,551	0:00	0	78,551	62,440	18:00	0	-	0	-

3(A) State Entities Generation:

CHANDIGARH

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
NIL										
Total	0	0	0					0	0	0
Total	0	0	0					0	0	0

DELHI

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
BAWANA GPS(2 * 253 + 4 * 216)	1,370	464	464	477.27	14:00	0		11.52	11.17	465
DELHI GAS TURBINES(3 * 34 + 6 * 30)	282	69	67	72.82	15:00	0		1.57	1.48	62
PRAGATI GAS TURBINES(1 * 121.2 + 2 * 104.6)	331	148	152	152.35		0		3.7	3.58	149
RITHALA GPS(3 * 36)	108	0	0	0		0				
Total GAS/NAPTHA/DIESEL	2,091	681	683					16.79	16.23	676
WIND	0	0	0	0		0				
BIOMASS(52)	52	60	56	0		0		1.63	1.61	67
SOLAR(2)	2	0	0	0		0				
Total DELHI	2,145	741	739					18.42	17.84	743

HARYANA

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
DCRTPP (YAMUNA NAGAR)(2 * 300)	600	337	229	348	21:00	172	08:00	5.88	5.25	219
JHAJJAR(CLP)(2 * 660)	1,320	754	1,237	1,241	06:00	737	15:00	23.49	21.95	915
MAGNUM DIESEL (IPP)(4 * 6.3)	25	0	0	0		0				
PANIPAT TPS(1 * 210 + 2 * 250)	710	539	650	664	06:00	522	18:00	14.52	13.18	549
RGTPP(KHEDAR)(2 * 600)	1,200	702	806	814	01:00	673	17:00	17.21	16.92	705
Total THERMAL	3,855	2,332	2,922					61.1	57.3	2,388
FARIDABAD GPS(1 * 156.07 + 2 * 137.75)	432	234	0	287	22:00	29	17:00	1.84	1.84	77
Total GAS/NAPTHA/DIESEL	432	234	0					1.84	1.84	77
TOTAL HYDRO HARYANA(64.8)	65	12	37	38	04:00	10	17:00	0.7	0.69	29
Total HYDEL	65	12	37					0.7	0.69	29
WIND	0	0	0	0		0				
BIOMASS(106)	106	0	0	0		0		1.44	1.44	60
SOLAR(196)	196	0	0	0		0		1.3	1.3	54
Total HARYANA	4,654	2,578	2,959					66.38	62.57	2,608

HIMACHAL PRADESH

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
BAJOLI HOLI(3*60)	180	161	183	191	23:00	0		3.83	3.82	159
BASPA (IPP) HPS(3 * 100)	300	140	217	291	23:30	0		3.65	3.65	152
KUTEHAR(3 * 80)	240	212	213	240	22:00	0		4.83	4.83	201
MALANA (IPP) HPS(2 * 43)	86	31	42	42	01:00	0		0.85	0.84	35
MALANA2(2 * 50)	100	36	50	50.56	22:00	0		0.99	0.98	41
NAITWAR MORI(2 * 30)	60	36	40	45	23:00	0		0.86	0.86	36
SAWARA KUDDU(3 * 37)	111	36	0	111	08:00	0		0.7	0.69	29
OTHER HYDRO HP(503.75)	504	288	395	0		0		9.1	9.06	378
Total HYDEL	1,581	940	1,140					24.81	24.73	1,031
WIND	0	0	0	0		0				
BIOMASS	0	0	0	0		0				
SOLAR	198	0	0	0		0		0.46	0.46	19
SMALL HYDRO(765.25)	765	385	372	0		0		8.58	8.58	358
Total SMALL HYDRO	765	385	372					8.58	8.58	358
Total HP	2,544	1,325	1,512					33.85	33.77	1,408

J&K(UT) & LADAKH(UT)

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
GAS/DIESEL/OTHERS J&K(1 * 190)	190	0	0	0		0				
Total GAS/NAPTHA/DIESEL	190	0	0					0	0	0
BAGLIHAR (IPP) HPS(6 * 150)	900	746	745	746		0		17.88	17.88	745
OTHER HYDRO/IPP J&K(308)	308	199	183	201		0		4.53	4.53	189
Total HYDEL	1,208	945	928					22.41	22.41	934
WIND	0	0	0	0		0				
BIOMASS	0	0	0	0		0				
SOLAR	0	0	0	0		0				
SMALL HYDRO(98)	98	0	0	0		0				
Total SMALL HYDRO	98	0	0					0	0	0
Total J&K(UT)&Ladakh(UT)	1,496	945	928					22.41	22.41	934

PUNJAB

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
GOINDWAL(GVK)(2 * 270)	540	451	453	491	01:00	270	09:00	9.33	8.41	350
GURU GOBIND SINGH TPS (ROPAR)(4 * 210)	840	389	402	421	06:00	389	20:00	10.75	9.58	399
GURU HARGOBIND SINGH TPS (LEHRA MOHABBAT)(2 * 210 + 2 * 250)	920	810	664	810	01:00	570	14:00	17.35	15.76	657
RAJPURA(NPL) TPS(2 * 700)	1,400	1,070	1,320	1,320	01:00	660	12:00	27.12	25.85	1,077
TALWANDI SABO TPS(3 * 660)	1,980	1,488	1,640	1,680	01:00	924	09:00	33.62	31.3	1,304
Total THERMAL	5,680	4,208	4,479					98.17	90.9	3,787
ANANADPUR SAHIB HYDRO PLANT(2 * 33.5 + 2 * 33.5)	134	66	38	66	16:00	38	01:00	1.43	1.43	60
MUKERIAN HYDRO PLANT(6 * 15 + 6 * 19.5 + 2 * 9)	225	78	87	173	23:45	43	17:00	1.96	1.95	81
RANJIT SAGAR POWER PLANT (4 * 150)	600	600	600	600	01:00	0	06:00	7.41	7.39	308
SHANAN(4 * 15 + 1 * 50)	110	95	104	108	22:00	76	16:00	2.25	2.25	94
UBDC(3 * 15 + 3 * 15.5)	92	22	24	24	01:00	22	18:00	0.57	0.57	24
OTHER HYDRO PUNJAB	0	0	0	0		0		0.32	0.32	13
Total HYDEL	1,161	861	853					13.94	13.91	580
WIND	0	0	0	0		0				
BIOMASS(303)	303	0	0	0		0		2.47	2.47	103
SOLAR(942)	942	54	53	519	12:00	53	01:00	5.23	5.23	218
Total PUNJAB	8,086	5,123	5,385					119.81	112.51	4,688

RAJASTHAN

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
BARSINGSAR (IPP) LTPS(2 * 125)	250	110	111	112	22:00	110	06:00	2.97	2.56	107
CHHABRA TPS(2 * 660 + 4 * 250)	2,320	1,751	1,917	1,928	06:00	1,243	11:00	43.4	40.24	1,677
GIRAL (IPP) LTPS(2 * 125)	250	0	0	0		0				
KALISINDH TPS(2 * 600)	1,200	996	1,016	1,020	02:00	641	09:00	20.86	19.1	796
KAWAI TPS(2 * 660)	1,320	1,249	1,246	1,252	04:00	770	15:00	27.25	25.68	1,070
KOTA TPS(2 * 110 + 2 * 195 + 3 * 210)	1,240	611	780	789	02:00	616	15:00	18.35	16.03	668
RAJWEST (IPP) LTPS(8 * 135)	1,080	647	725	725	03:00	445	12:00	16.54	14.49	604
SURATGARH TPS (6 * 250 + 2 * 660(SSCTPS))	2,820	1,535	2,506	2,523	01:00	1,528	13:00	44.42	39.49	1,645
VSLPP (IPP)(1 * 135)	135	118	117	118	21:00	116.16	14:00	3.02	2.66	111
Total THERMAL	10,615	7,017	8,418					176.81	160.25	6,678
DHOLPUR GPS(3 * 110)	330	0	0	0		0				
RAMGARH GPS(1 * 110 + 1 * 35.5 + 1 * 50 + 2 * 37.5)	271	69	69	70	08:00	68	13:00	1.77	1.7	71
Total GAS/NAPTHA/DIESEL	601	69	69					1.77	1.7	71
RAPS-A(1 * 100 + 1 * 200)	300	145	148	149	08:00	144	15:00	3.86	3.57	149
Total NUCLEAR	300	145	148					3.86	3.57	149
TOTAL HYDRO RAJASTHAN(550)	550	8	0	8	19:00	0	13:00	0.04	0.03	1
Total HYDEL	550	8	0					0.04	0.03	1
WIND(1 * 4328)	4,328	1,363	963	2,198	00:00	572	06:00	40.7	40.7	1,696
BIOMASS(180)	180	107	107	107	01:00	107	06:00	2.58	2.58	108
SOLAR(8269)	8,269	49	0	6,011	11:00	0	06:00	50.43	50.43	2,101
Total RAJASTHAN	24,843	8,758	9,705					276.19	259.26	10,804

UTTAR PRADESH

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
ANPARA TPS(2 * 500 + 3 * 210)	1,630	1,334	1,338	1,347	10:00	907	16:00	33.3	30.8	1,283
ANPARA-C TPS(2 * 600)	1,200	1,112	1,121	1,121	03:00	635	16:00	26.9	25.1	1,046
ANPARA-D TPS(2 * 500)	1,000	904	913	939	22:00	539	16:00	22.3	20.9	871
BAJAJ ENERGY PVT LTD (IPP) TPS(10 * 45)	450	281	286	405	01:00	225	07:00	7	6.3	263
BARA PPGCL TPS(3 * 660)	1,980	1,659	1,813	1,826	04:00	1,008	12:00	39.4	36.5	1,521
GHATAMPUR TPS (2*660)	1,320	0	595	603	02:00	0	18:00	9.3	8.8	367
HARDUAGANJ TPS(1 * 110 + 2 * 250 + 1*660)	1,270	761	843	1,085	01:00	628	16:00	20.7	19	792
INFIRM POWER	660	222	0	309	21:00	0	01:00	1.7	1.5	63
JAWAHARPUR TPS(2*660)	1,320	828	667	892	23:00	663	08:00	19.6	18.4	767
JP CHURK(3 * 60)	180	0	0	0		0				
KHURJA TPS(2 * 660)	1,320	1,231	1,237	1,263	05:00	751	17:00	28.5	26.9	1,121
LALITPUR TPS(3 * 660)	1,980	1,791	1,838	1,851	04:00	998	16:00	38.6	36.2	1,508
MEJA TPS(2 * 660)	1,320	1,082	1,236	1,236	03:00	661	08:00	26.3	24.5	1,021
OBRA TPS (5 * 200+2*660)	2,320	1,539	1,712	1,740	05:00	1,144	16:00	39.8	36.9	1,538
PANKI_I TPS(1 * 660)	660	514	610	621	01:00	353	23:59	12.5	11.7	488
PARICHA TPS(2 * 210 + 2 * 250)	920	517	626	2,293	09:00	470	17:00	14.2	12.9	538
ROSA TPS(4 * 300)	1,200	724	1,070	1,085	02:00	590	08:00	20.6	18.9	788
Total THERMAL	20,730	14,499	15,905					360.7	335.3	13,975
ALAKHANANDA HEP(4 * 82.5)	330	166	148	168	23:59	83	04:00	2.8	2.8	117
RIHAND HPS(6 * 50)	300	295	0	295	01:00	0	02:00	1.5	1.5	63
VISHNUPARYAG HPS(4 * 110)	440	287	287	337	23:00	198	13:00	6.1	6.1	254
OTHER HYDRO UP(227)	227	84	113	138	01:00	19	14:00	1.8	1.8	75
Total HYDEL	1,297	832	548					12.2	12.2	509
WIND	0	0	0	0		0				
BIOMASS(26)	26	0	0	0		0				
SOLAR(2729)	2,729	0	0	2,230	11:00	0	01:00	16.9	16.9	704
CO-GENERATION(1360)	1,360	50	50	50	01:00	0		1.2	1.2	50
Total OTHERs	1,360	50	50					1.2	1.2	50
Total UP	26,142	15,381	16,503					391	365.6	15,238

UTTARAKHAND

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
GAMMA	225	0	0	0		0				
SARAVANTI	450	0	0	0		0				
Total GAS/NAPTHA/DIESEL	675	0	0					0	0	0
OTHER HYDRO UK(1250)	1,250	853	717	853	20:00	413	14:00	14.96	14.91	621
Total HYDEL	1,250	853	717					14.96	14.91	621
WIND	0	0	0	0		0				
BIOMASS(127)	127	0	0	0		0				
SOLAR(278)	278	0	0	95	12:00	10	18:00	0.66	0.66	28
SMALL HYDRO(180)	180	0	0	0		0				
Total SMALL HYDRO	180	0	0					0	0	0
Total UTTARAKHAND	2,510	853	717					15.62	15.57	649

3(B) Regional Entities Generation

Station/Constituents	Inst. Capacity	Declared Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy				AVG. MW	UI(Actual-Schedule-(+- AGC))
	(MW)	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	Gross Gen ACT (MU)	Net Gen ACT MU)	AGC(MU)		
Aravali Power Company Private Ltd														
ISTPP (JHAJJAR)(3 * 500)	1,500	1,406	819	936	1,467	00:15	811	19:45	20.15428	22.38	20.62	0.48	859	-0.01428
Sub-Total	1,500	1,406	819	936	-	-	-	-	20.15428	22.38	20.62	0.48	859	-0.01428
BBMB														
BHAKRA HPS(5 * 126 + 5 * 157)	1,415	1,196	1,210	687	1,210	20:00	531	13:00	16.03275	16.5	16.22	0	676	0.18725
DEHAR HPS(6 * 165)	990	480	495	495	495	20:00	290	13:00	10.32	10.7	10.53	0	439	0.21
PONG HPS(6 * 66)	396	305	310	124	310	20:00	0	13:00	2.5085	2.59	2.55	0	106	0.0415
Sub-Total	2,801	1,981	2,015	1,306	-	-	-	-	28.86125	29.79	29.3	0	1,221	0.43875
NHPC														
BAIRASIUL HPS(3 * 60)	180	186	182	62	186	22:15	0	12:15	1.9143	2.01	1.99	0.06	83	0.0157
CHAMERA I HPS(3 * 180)	540	545	535	327	548	21:00	0	05:00	7.5	7.47	7.39	-0.15	308	0.04
CHAMERA II HPS(3 * 100)	300	208	200	198	201	19:00	98.5	01:00	4.7736	4.77	4.75	0	198	-0.0236
CHAMERA III HPS(3 * 77)	231	240	217	216	229	04:00	176.1	15:00	4.97317	5	4.94	0	206	-0.03317
DHAULIGANGA HPS(4 * 70)	280	277	241	72	273	22:00	64.2	08:00	2.81827	2.87	2.85	-0.01	119	0.04173
DULHASTI HPS(3 * 130)	390	385	376	380	383	21:00	0	-	8.35947	7.94	7.84	0	327	-0.51947
KISHANGANGA(3 * 110)	330	340	342	333	342	20:00	331.7	07:00	7.95	8.02	7.99	0	333	0.04
PARBATI III HEP(4 * 130)	520	390	392	229	496	23:59	30.25	12:00	4.7875	4.98	4.95	0	206	0.1625
PARBATI-II(4 * 200)	800	600	606	431	606	21:00	106.87	15:00	8.2825	8.86	8.47	0	353	0.1875
SALAL HPS(6 * 115)	690	700	710	678	715	05:00	603	02:00	16.35	16.61	16.47	0	686	0.12
SEWA-II HPS(3 * 40)	120	130	128	0	128	20:00	0	-	0.6679	0.7	0.69	0	29	0.0221
TANAKPUR HPS(1 * 31.42 + 2 * 31.4)	94	45	79	33	96	16:59	23.47	07:00	0.90743	0.96	0.94	0	39	0.03257
URI HPS(4 * 120)	480	494	486	487	489	21:00	484	16:00	11.667	11.87	11.79	0	491	0.123
URI-II HPS(4 * 60)	240	250	244	245	246	01:00	243.75	19:00	5.72952	5.87	5.83	0	243	0.10048
Sub-Total	5,195	4,790	4,738	3,691	-	-	-	-	86.68066	87.93	86.89	-0.1	3,621	0.30934
NPCL														
NAPS(2 * 220)	440	391	434	429	439	23:00	0	-	9.384	10.21	9.24	0	385	-0.144
RAPP-D	700	615	0	0	0	-	0	-	14.76	16.15	14.82	0	618	0.06
RAPS-B(2 * 220)	440	361	375	388	418	07:00	0	-	8.66808	9.28	8.17	0	340	-0.49808
RAPS-C(2 * 220)	440	417	452	457	458	08:00	0	-	10.008	11	9.94	0	414	-0.068
Sub-Total	2,020	1,784	1,261	1,274	-	-	-	-	42.82008	46.64	42.17	0	1,757	-0.65008
NTPC														
ANTA GPS(1 * 153.2 + 3 * 88.71)	419	380	130	0	292	00:05	0	-	1.8905	1.27	1.14	0	48	-0.7505
AURAIYA GPS(2 * 109.3 + 4 * 111.19)	663	627	352	0	436	00:15	0	-	3.01875	1.97	1.81	0	75	-1.20875
DADRI GPS(2 * 154.51 + 4 * 130.19)	830	800	0	0	618	00:15	0	-	3.69657	2.91	2.6	0	108	-1.09657
DADRI-I TPS(4 * 210)	840	769	0	0	0	-	0	-	10.66439	12.57	11.25	0	469	0.58561
DADRI-II TPS(2 * 490)	1,000	938	0	0	0	-	0	-	14.35354	15.58	14.41	0	600	0.05646
KOLDAM HPS(4 * 200)	800	871	845	0	869	22:00	0	-	4.9972	5.04	5.01	0	209	0.0128
RIHAND-I STPS(2 * 500)	1,000	920	988	1,012	1,012	03:00	554	10:00	19.50625	21.17	19.24	-0.04	802	-0.22625
RIHAND-II STPS(2 * 500)	1,000	450	490	492	508	05:00	272	10:00	9.5438	10.4	9.44	-0.03	393	-0.0738
RIHAND-III STPS(2 * 500)	1,000	943	987	991	1,004	18:00	561	10:00	19.9221	20.97	19.72	-0.1	822	-0.1021
SINGRAULI HYDRO(1 * 8)	8	6	0	0	0	-	0	-	0.13508	0.14	0.14	0	6	0.00492
SINGRAULI STPS(2 * 500 + 5 * 200)	2,000	1,853	1,966	1,956	1,966	20:00	0	-	38.68833	42.19	38.71	0	1,613	0.02167
TANDA TPS(4 * 110)	440	-	0	0	0	-	0	-	-	-	-	-	-	-
TANDA TPS STAGE-II(2 * 660)	1,320	1,238	1,159	1,326	1,159	20:00	0	-	23.34649	24.99	23.22	0	968	-0.12649
UNCHAHAR II TPS(2 * 210)	420	375	337	404	337	20:00	0	-	6.51912	7.4	6.56	0.08	273	-0.03912
UNCHAHAR III TPS(1 * 210)	210	189	121	199	121	20:00	0	-	3.17395	3.59	3.19	0.04	133	-0.02395
UNCHAHAR IV TPS(1 * 500)	500	466	423	470	423	20:00	0	-	8.251	8.86	8.3	0.04	346	0.009
UNCHAHAR TPS(2 * 210)	420	378	354	404	354	20:00	0	-	6.63652	7.44	6.5	0	271	-0.13652
Sub-Total	12,870	11,203	8,152	7,254	-	-	-	-	174.34359	186.49	171.24	-0.01	7,136	-3.09359
SJVNL														
NATHPA-JHAKRI HPS(6 * 250)	1,500	1,630	1,569	488	1,642	21:00	0	11:00	17.8841	18.05	17.9	0	746	0.0159
RAMPUR HEP(6 * 68.67)	412	449	436	139	439	22:00	0	11:00	4.92554	5.09	5.06	0	211	0.13446
Sub-Total	1,912	2,079	2,005	627	-	-	-	-	22.80964	23.14	22.96	0	957	0.15036
THDC														
KOTESHWAR HPS(4 * 100)	400	90	90	70	90	20:00	0	01:00	1.505	1.54	1.53	0	64	0.025
TEHRI HPS(4 * 250)	1,000	354	292	122	368	21:00	0	08:00	2.71	2.77	2.75	-0.01	115	0.05
Sub-Total	1,400	444	382	192	-	-	-	-	4.215	4.31	4.28	-0.01	179	0.075
Total	27,698	23,687	19,372	15,280					379.8845	400.68	377.46	0.36	15,730	-2.7845

IPP/JV

Station/Constituents	Inst. Capacity	Declared Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW	UI
	(MW)	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	Gross Gen(MU)	Net Gen(MU)		
IPP													
ADHPL(IPP) HPS(2 * 96)	192	99	101	105	164	23:55	0	-	2.0807	2.12	2.11	88	0.0293
BUDHIL HPS (IPP)(2 * 35)	70	69	70	25	71	23:00	25.35	03:00	1.0421	1.08	1.08	45	0.0379
KARCHAM WANGTOO HPS(4 * 261.25)	1,045	988	1,000	300	1,000	19:15	150	10:00	9.51054	9.75	9.68	403	0.16946
SHREE CEMENT (IPP) TPS(2 * 150 + 2 * 19 + 1 * 6)	344	330	0	0	0	-	0	-	3.56157	3.66	3.3	138	-0.26157
SAINJ HEP(2 * 50)	100	69	70	50	105	21:00	0	-	1.24092	1.33	1.31	55	0.06908
SINGOLI BHATWARI HEP(3 * 33)	99	98	54	59	64	03:30	0	-	0.96225	0.9	0.88	37	-0.08225
SORANG HYDROELECTRIC PROJECT(2 * 50)	100	98	55	47	57	21:00	0	-	1	1.05	1.04	43	0.04
Sub-Total	1,950	1,751	1,350	586	-	-	-	-	19.39808	19.89	19.4	809	0.00192
SOLAR IPP													
ADANI GREEN ENERGY TWENTY FIVE LIMITED	500	0	0	0	0	-	0	-	4.3034	4.1	4.1	171	-0.2034
ABC RENEWABLE ENERGY(1 * 300)	300	0	0	0	0	-	0	-	2.19766	2.1	2.1	88	-0.09766
ABC RENEWABLE ENERGY_2	550	0	0	0	0	-	0	-	0.84328	0.84	0.84	35	-0.00328
ACME CHITTORGARH SOLAR ENERGY PVT LTD(1 * 250)	250	0	0	0	211	11:48	0	-	1.54974	1.57	1.57	65	0.02026
ACME DEOGHAR SOLAR POWER PRIVATE LIMITED(ADSPPL)	300	0	0	0	316	11:56	0	-	2.2812	2.29	2.28	95	-0.0012
ACME HEERGARH POWERTECH PRIVATE LIMITED(1*300)	300	0	0	0	0	-	0	-	2.23428	2.13	2.13	89	-0.10428
ACME PHALODI SOLAR ENERGY PRIVATE LIMITED(APSEPL)	300	0	0	0	317	12:03	0	-	2.27399	2.31	2.3	96	0.02601
ACME RAISAR SOLAR ENERGY PRIVATE LIMITED(ARSEPL)	300	0	0	0	299	10:58	0	-	2.31415	2.32	2.18	91	-0.13415
ACME SIKAR SOLAR PRIVATE LIMITED	300	0	0	0	0	-	0	-	1.99846	1.9	1.9	79	-0.09846
ACMEDHAULPUR POWERTECH PRIVATE LIMITED(ADPPL)	300	0	0	0	315	11:53	0	-	2.25885	2.3	2.29	95	0.03115
AMP ENERGY GREEN SIX PRIVATE LIMITED	100	0	0	0	0	-	0	-	0.3647	0.36	0.36	15	-0.0047
AMP GREEN ENERGY FIVE PRIVATE LIMITED	100	0	0	0	0	-	0	-	0.84034	0.84	0.84	35	-0.00034
ADANI GREEN ENERGY TWENTY FIVE B	138	0	0	0	0	-	0	-	0.33228	0.33	0.33	14	-0.00228
ADANI GREEN ENERGY TWENTY FOUR LIMITED	500	0	0	0	0	-	0	-	3.93416	3.73	3.73	155	-0.20416
ADANI RENEWABLE ENERGY RJ LIMITED (ARERJL)(1 * 200)	200	0	0	0	168	12:18	0	-	1.26802	1.24	1.24	52	-0.02802
ADANI SOLAR ENERGY BARMER ONE LIMITED_FTG3	251	0	0	0	225	12:00	0	-	1.81396	1.76	1.75	73	-0.06396
ADANI SOLAR ENERGY JAISALMER TWO PRIVATE LIMITED(1*150)	150	0	0	0	132	12:45	0	-	1.01192	0.97	0.97	40	-0.04192
ADANI SOLAR ENERGY JAISALMER TWO PRIVATE LIMITED (PROJECT-2)(1*150)	150	0	0	0	131	12:45	0	-	0.94288	1.01	1.01	42	0.06712
ADANI SOLAR ENERGY JODHPUR SIX PRIVATE LIMITED	50	0	0	0	0	-	0	-	0.18203	0.18	0.18	8	-0.00203
ADANI SOLAR ENERGY RJ TWO PVT LTD_BHADLA(1*150)	150	0	0	0	150	10:43	0	-	1.08422	1.15	1.15	48	0.06578
ADANI SOLAR ENERGY RJ TWO PVT LTD_FATEGARH 2(1*180)	180	0	0	0	0	-	0	-	1.7675	1.67	1.67	70	-0.0975
ADEPT RENEWABLE TECHNOLOGIES PVT LTD(1*110)	110	0	0	0	0	-	0	-	0.97084	0.97	0.97	40	-0.00084
ALTRA XERGI POWER PRIVATE LIMITED	380	0	0	0	0	-	0	-	2.74978	2.67	2.67	111	-0.07978
AMBUJA CEMENTS LIMITED	150	0	0	0	0	-	0	-	2.26094	2.16	2.16	90	-0.10094
AMP ENERGY GREEN FOUR PRIVATE LIMITED	100	0	0	0	0	-	0	-	0.30614	0.31	0.31	13	0.00386
AMPLUS AGES PRIVATE LIMITED(1*100)	100	0	0	0	77	09:46	0	-	0.63194	0.64	0.64	27	0.00806
AURAIYA SOLAR(1 * 40)	40	0	0	0	0	-	0	-	0.23775	0.28	0.27	11	0.03225
AVAADA RJHN PRIVATE LIMITED(1*240)	240	0	0	0	223	12:44	0	-	1.60364	1.61	1.61	67	0.00636
AVAADA SUNCE ENERGY PRIVATE LIMITED, BIKANER(1 * 350)	350	0	0	0	325	13:02	0	-	2.3396	2.36	2.36	98	0.0204
AVAADA SUNRAYS ENERGY PRIVATE LTD(1*320)	320	0	0	0	319	12:33	0	-	2.31578	2.36	2.36	98	0.04422
AVAADA SUSTAINABLE RJPROJECT PVT LTD(1*300)	300	0	0	0	284	12:47	0	-	2.0631	2.05	2.05	85	-0.0131
AYANA RENEWABLE POWER ONE PRIVATE LIMITED, BIKANER(300)	300	0	0	0	28	12:26	0	-	1.97936	2.1	2.1	88	0.12064
AZURE POWER FORTY THREE PRIVATE LIMITED(1 * 150 + 1 * 150 + 1 * 300)	600	0	0	0	532	12:15	0	-	4.01614	4.07	4.07	170	0.05386
AZURE POWER INDIA PVT LTD.(4 * 50)	200	0	0	0	0	-	0	-	1.14658	1.15	1.15	48	0.00342
AZURE POWER MAPLE PVT LTD(1*300)	300	0	0	0	0	-	0	-	1.96057	1.86	1.86	78	-0.10057
AZURE POWER THIRTY FOUR PRIVATE LTD(1 * 130)	130	0	0	0	123	12:45	0	-	0.88486	0.86	0.86	36	-0.02486
BBMB SOLAR BHIWANI	9	0	0	0	0	-	0	-	0.03356	0.03	0.04	2	0.00644

BBMB SOLAR HISSAR	2	0	0	0	0	-	0	-	0.00717	0.01	0.01	0	0.00283
BANDERWALA SOLAR PLANT LTD(1*300)	300	0	0	0	0	-	0	-	0.74027	0.74	0.74	31	-0.00027
CLEAN SOLAR POWER (BHADLA) PVT LTD(1 * 300)	300	0	0	0	0	-	0	-	2.07436	1.97	1.97	82	-0.10436
CLEAN SOLAR POWER(JODHPUR) PRIVATE LIMITED(1*250)	250	0	0	0	0	-	0	-	1.75034	1.65	1.65	69	-0.10034
DADRI SOLAR(5)	5	0	0	0	3	-	0	-	0.0182	0.02	0.02	1	0.0018
DEVIKOT SOLAR POWER NTPC	240	0	0	0	0	-	0	-	1.51778	1.42	1.42	59	-0.09778
EDEN RENEWABLE ALMA PRIVATE LIMITED	300	0	0	0	0	-	0	-	0.7218	0.72	0.72	30	-0.0018
EDEN RENEWABLE CITE PRIVATE LIMITED(1 * 300)	300	0	0	0	301	12:09	0	-	2.19975	2.17	2.17	90	-0.02975
ENERGIZENT POWER PRIVATE LIMITED	69	0	0	0	0	-	0	-	0.18272	0.18	0.18	8	-0.00272
GORBEA SOLAR PRIVATE LIMITED	300	0	0	0	211	09:22	0	-	0.72921	0.81	0.81	34	0.08079
GRIAN ENERGY PRIVATE LIMITED(1*100)	100	0	0	0	77	09:47	0	-	0.65359	0.64	0.64	27	-0.01359
HRP GREEN POWER PRIVATE LIMITED_BHD3	244	0	0	0	0	-	0	-	0.72715	0.73	0.73	30	0.00285
IB VOGT SOLAR SEVEN PRIVATE LIMITED	300	0	0	0	0	-	0	-	0.32165	0.32	0.32	13	-0.00165
JUNIPER GREEN COSMIC PRIVATE LIMITED	100	0	0	0	0	-	0	-	0.74452	0.75	0.75	31	0.00548
JUNA RENEWABLE ENERGY PRIVATE LIMITED	335	0	0	0	0	-	0	-	2.63906	2.53	2.53	105	-0.10906
JUNIPER NIRJARA ENERGY PRIVATE LIMITED	50	0	0	0	0	-	0	-	0.21764	0.28	0.28	12	0.06236
KARNISAR SOLAR PLANT NHPC LIMITED	300	0	0	0	296	11:51	0	-	1.94304	2.2	2.2	92	0.25696
KHABA RENEWABLE ENERGY PRIVATE LIMITED_FTG3	250	0	0	0	0	-	0	-	0.36812	0.37	0.37	15	0.00188
KHIDRAT RENEWABLE ENERGY PRIVATE LIMITED	300	0	0	0	0	-	0	-	0.74983	0.75	0.75	31	0.00017
KOLAYAT SOLAR POWER PLANT NTPC LIMITED(1*550)	550	0	0	0	0	-	0	-	3.80405	3.7	3.7	154	-0.10405
M/S ADANI SOLAR ENERGY FOUR PRIVATE LIMITED(1 * 50)	50	0	0	0	46	12:16	0	-	0.33075	0.34	0.34	14	0.00925
M/S ADANI SOLAR ENERGY JODHPUR TWO LIMITED(1 * 50)	50	0	0	0	47	12:15	0	-	0.3505	0.34	0.34	14	-0.0105
M/S AZURE POWER FORTY ONE PRIVATE LIMITED(1 * 300)	300	0	0	0	0	-	0	-	2.07164	1.97	1.97	82	-0.10164
M/S. ONEVOLT ENERGY PRIVATE LIMITED(1*100)	100	0	0	0	76	09:48	0	-	0.63429	0.64	0.63	26	-0.00429
MEGA SOILS RENEWABLE PRIVATE LIMITED(1 * 250)	250	0	0	0	0	-	0	-	1.53978	1.44	1.44	60	-0.09978
MEGA SURYAURJA PVT LTD(1*250)	250	0	0	0	0	-	0	-	1.78288	1.68	1.68	70	-0.10288
NTPC ANTA SOLAR PV STATION	90	0	0	0	0	-	0	-	0.59976	0.6	0.6	25	0.00024
NTPC NOKH SOLAR PROJECT	735	0	0	0	0	-	0	-	5.06009	4.86	4.86	203	-0.20009
NTPC NIDAN SOLAR(1*296)	296	0	0	0	0	-	0	-	2.07572	2.08	2.08	87	0.00428
NEEMBA RENEW SURYA VIHAAN PRIVATE LIMITED	200	0	0	0	129	09:27	0	-	0.47192	0.5	0.5	21	0.02808
NOKHRA SOLAR POWER NTPC	300	0	0	0	0	-	0	-	2.0855	1.99	1.99	83	-0.0955
PROJECT ELEVEN RENEWABLE POWER PL_BHDL2	150	0	0	0	0	-	0	-	0.29325	0.29	0.29	12	-0.00325
PROJECT SIXTEEN RENEWABLE POWER_BHDL2	150	0	0	0	129	09:17	0	-	0.55075	0.53	0.52	22	-0.03075
RENEW DINKAR URJA PRIVATE LIMITED_BKN2	300	0	0	0	0	-	0	-	1.05095	0.95	0.95	40	-0.10095
RENEW SAMIR SHAKTI PRIVATE LIMITED_FTG3	300	0	0	0	0	-	0	-	0	-	-	-	-
RENEW SOLAR SHAKTI THREE PRIVATE LIMITED_FTG3	300	0	0	0	0	-	0	-	0	-	-	-	-
RENEW SUN BRIGHT PRIVATE LIMITED (RSBPL)(1 * 300)	300	0	0	0	266	11:45	0	-	2.0849	2.02	2.02	84	-0.0649
RENEW SURYA RAVI PVT LTD(1*300)	300	0	0	0	243	12:12	0	-	1.92991	1.92	1.92	80	-0.00991
RENEW SOLAR (SHAKTI FIVE) PRIVATE LIMITED_FTG3	211	0	0	0	0	-	0	-	0	-	-	-	-
RENEW SOLAR ENERGY (JHARKHAND THREE) PVT LTD(300)	300	0	0	0	269	12:01	0	-	2.03241	2.06	2.06	86	0.02759
RENEW SOLAR POWER PVT LTD(50)	50	0	0	0	195	12:46	0	-	0.38962	0.39	0.39	16	0.00038
RENEW SOLAR POWER PVT LTD. BIKANER(1 * 250)	250	0	0	0	195	12:46	0	-	1.41696	1.46	1.46	61	0.04304
RENEW SOLAR URJA PVT LIMITED(300)	300	0	0	0	266	11:43	0	-	1.94758	1.96	1.96	82	0.01242
RENEW SURYA AAYAN PRIVATE LIMITED	300	0	0	0	0	-	0	-	2.04105	1.94	1.94	81	-0.10105
RENEW SURYA JYOTI PRIVATE LIMITED	210	0	0	0	0	-	0	-	0.51935	0.59	0.59	25	0.07065
RENEW SURYA PRATAP PRIVATE LIMITED(1*200)	200	0	0	0	186	12:29	0	-	1.43723	1.39	1.38	58	-0.05723
RENEW SURYA ROSHNI PVT LTD_SOLAR(1*400)	400	0	0	0	0	-	0	-	2.94426	2.84	2.84	118	-0.10426
RENEW SURYA VIHAAN PRIVATE LIMITED	100	0	0	0	87	12:30	0	-	0.70384	0.65	0.65	27	-0.05384
RISING SUN ENERGY (K) PVT LTD(1*164)	190	0	0	0	178	12:55	0	-	1.32549	1.27	1.27	53	-0.05549
SB ENERGY FOUR PVT LTD(2 * 100)	200	0	0	0	0	-	0	-	1.18606	1.19	1.19	50	0.00394
SB ENERGY SIX PRIVATE LIMITED(1 * 300)	300	0	0	0	305	12:02	0	-	2.00133	2.18	2.18	91	0.17867

SJVN GREEN ENERGY LIMITED	888	0	0	0	815	12:13	0	-	5.5734	6.4	6.03	251	0.4566
SERENTICA RENEWABLES INDIA 4 PRIVATE LIMITED_BKN2	168	0	0	0	0	-	0	-	1.52205	1.42	1.42	59	-0.10205
SERENTICA RENEWABLES INDIA 5 PRIVATE LIMITED	220	0	0	0	0	-	0	-	0.85638	0.86	0.86	36	0.00362
SINGRAULI SOLAR(15)	15	0	0	0	0	-	0	-	0.04578	0.05	0.05	2	0.00422
SOLZEN URJA PRIVATE LIMITED(1 * 300)	300	0	0	0	0	-	0	-	2.06836	1.97	1.97	82	-0.09836
TRANSITION CLEANTECH SERVICES PRIVATE LIMITED	24	0	0	0	0	-	0	-	0.20898	0.21	0.21	9	0.00102
TATA POWER GREEN ENERGY LIMITED	225	0	0	0	206	12:23	0	-	1.46015	1.44	1.44	60	-0.02015
TATA POWER RENEWABLE ENERGY LTD(1 * 300)	300	0	0	0	293	12:42	0	-	2.01472	2.01	1.97	82	-0.04472
TATA POWER SAURYA LIMITED	110	0	0	0	101	12:19	0	-	0.72988	0.73	0.73	30	0.00012
THAR SURYA 1PRIVATE LIMITED(1*300)	300	0	0	0	225	13:13	0	-	1.44704	1.61	1.61	67	0.16296
TRANSITION ENERGY SERVICES PRIVATE LIMITED	60	0	0	0	0	-	0	-	0.32805	0.33	0.33	14	0.00195
TRANSITION GREEN ENERGY PRIVATE LIMITED	100	0	0	0	0	-	0	-	0.33101	0.33	0.33	14	-0.00101
TRANSITION SUSTAINABLE ENERGY SERVICES PVT. LTD.	50	0	0	0	0	-	0	-	0.43085	0.43	0.43	18	-0.00085
TRANSITION SUSTAINABLE ENERGY SERVICES ONE PVT LTD	56	0	0	0	0	-	0	-	0.30121	0.3	0.3	13	-0.00121
UNCHAHAR SOLAR(10)	10	0	0	0	0	-	0	-	0.04342	0.04	0.04	2	-0.00342
XL XERGI POWER PRIVATE LIMITED	400	0	0	0	225	09:30	0	-	0.85344	0.91	0.91	38	0.05656
Sub-Total	**24,251**	**0**	**0**	**0**	**-**	**-**	**-**	**-**	**142.48034**	**141.65**	**141.03**	**5,880**	**-1.45034**
HYBRID IPP													
AMPIN ENERGY GREEN EIGHT PRIVATE LIMITED_SOLAR	113	0	0	0	0	-	0	-	0.4505	0.45	0.45	19	-0.0005
AMPIN ENERGY GREEN EIGHT PRIVATE LIMITED_WIND	44	0	0	0	0	-	0	-	0.43783	0.44	0.44	18	0.00217
AMPIN ENERGY GREEN TEN PRIVATE LIMITED_SOLAR	110	0	0	0	0	-	0	-	0.404	0.4	0.4	17	-0.004
AMPIN ENERGY GREEN TEN PRIVATE LIMITED_WIND	41	0	0	0	0	-	0	-	0.4042	0.4	0.4	17	-0.0042
AMPIN ENERGY GREEN THREE PRIVATE LIMITED_SOLAR	50	0	0	0	0	-	0	-	0.1735	0.17	0.17	7	-0.0035
AMPIN ENERGY GREEN THREE PRIVATE LIMITED_WIND	19	0	0	0	0	-	0	-	0.20508	0.21	0.21	9	0.00492
ADANI HYBRID ENERGY JAISALMER FOUR LIMITED SOLAR(1*600)	600	0	0	0	622	11:37	0	-	5.58942	5.64	5.64	235	0.05058
ADANI HYBRID ENERGY JAISALMER FOUR LIMITED WIND(1*510)	510	0	0	0	0	-	0	-	5.6392	5.64	5.64	235	0.0008
ADANI HYBRID ENERGY JAISALMER ONE LIMITED SOLAR(1 * 235.1 + 1 * 124.8)	360	0	0	0	352	10:10	0	-	2.89853	2.65	2.65	110	-0.24853
ADANI HYBRID ENERGY JAISALMER ONE LIMITED WIND(1 * 101)	101	0	80	18	95	12:30	0	-	0.97297	0.13	0.13	5	-0.84297
ADANI HYBRID ENERGY JAISALMER THREE LIMITED SOLAR(1*300)	300	0	0	0	0	-	0	-	2.7505	2.65	2.65	110	-0.1005
ADANI HYBRID ENERGY JAISALMER THREE LIMITED WIND(1*75)	75	0	61	24	69	11:15	0	-	0.6213	0.07	0.07	3	-0.5513
ADANI HYBRID ENERGY JAISALMER TWO LIMITED SOLAR(1*299)	300	0	0	0	300	12:00	0	-	2.87339	2.72	2.72	113	-0.15339
ADANI HYBRID ENERGY JAISALMER TWO LIMITED WIND(1*75)	75	0	63	33	70	01:00	0	-	0.62142	0.08	0.08	3	-0.54142
ADANI JAISALMER ONE SEPL SOLAR(1*420)	420	0	0	0	399	11:48	0	-	3.31031	2.98	2.98	124	-0.33031
ADANI JAISALMER ONE SEPL WIND(1*105)	105	0	98	97	104	21:30	0	-	1.05066	1.82	1.82	76	0.76934
AYANA RENEWABLE THREE PVT LTD (1*300)	300	0	0	0	298	12:42	0	-	2.11074	2.12	2.12	88	0.00926
JUNIPER GREEN STELLAR PRIVATE LIMITED_S_FTG3	185	0	0	0	0	-	0	-	0.61476	0.61	0.61	25	-0.00476
Sub-Total	**3,708**	**0**	**302**	**172**	**-**	**-**	**-**	**-**	**31.12831**	**29.18**	**29.18**	**1,214**	**-1.94831**
Total	**29,909**	**1,751**	**1,652**	**758**					**193.00673**	**190.72**	**189.61**	**7,903**	**-3.39673**

STORAGE

Station/Constituents	Inst. Capacity	Declared Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW	UI
	(MW)	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	Gross Gen(MU)	Net Gen(MU)		
PUMP STORAGE													
TEHRI PSP(4 * 250)	1,000	360	307	0	307	20:00	0	-	-1.2317	3.18	-0.73	-30	0.5017
Sub-Total	1,000	360	307	0	-	-	-	-	-1.2317	3.18	-0.73	-30	0.5017
BESS													
ACME SUN POWER PRIVATE LIMITED_BESS	167	0	0	0	0	-	0	-	0.05461	0.06	0.06	3	0.00539
ACME SURYA POWER PRIVATE LIMITED_BESS	107	0	0	0	0	-	0	-	0.03012	0.03	0.03	1	-0.00012
ACME SURYODAYA PRIVATE LIMITED_BESS	247	0	0	0	0	-	0	-	0.01238	0.01	0.01	0	-0.00238
JUNIPER GREEN STELLAR PRIVATE LIMITED_BESS_FTG4	180	0	0	0	0	-	0	-	0.31819	0.61	0.61	25	0.29181
JUNIPER GREEN COSMIC PRIVATE LIMITED_BESS	41	0	0	0	0	-	0	-	0.14688	0.15	0.15	6	0.00312
RENEW SURYA ROSHNI PVT LTD_BESS	23	0	0	0	0	-	0	-	0.092	0.09	0.09	4	-0.002
Sub-Total	765	0	0	0	-	-	-	-	0.65418	0.95	0.95	39	0.29582
Total	1,765	360	307	0					-0.57752	4.13	0.22	9	0.79752

Summary Section

	Inst. Capacity	PEAK	OFF-PEAK	Day Energy		Day AVG.
				Gross Gen	Net Gen	
Total State Control Area Generation	72,420	35,704	38,448	943.68	889.53	37,072
J. Net Inter Regional Exchange [Import (+ve)/Export (-ve)]		7,046	5,791	265.12	265.12	6,091
Inter National Exchange with Nepal[Import (+ve)/Export (-ve)]		59	68	-2.28	-2.28	-69
Total Regional Availability(Gross)	131,792	64,140	60,345	1,802.05	1,719.66	66,736

Total Hydro Generation

	Inst. Capacity	PEAK	OFF-PEAK	Day Energy		Day AVG.
				Gross Gen	Net Gen	
Regional Entities Hydro	14,722	11,642	6,402	169.76	163.95	6,834
State Control Area Hydro	8,155	4,836	4,595	97.64	97.46	4,063
Total Regional Hydro	22,877	16,478	10,997	267.4	261.41	10,897

Total Renewable Generation

	Inst. Capacity	PEAK	OFF-PEAK	Day Energy		Day AVG.
				Gross Gen	Net Gen	
Regional Entities Renewable	27,959	302	172	170.83	170.21	7,094
State Control Area Renewable	17,736	1,633	1,179	123.8	123.78	5,158
Total Regional Renewable	45,695	1,935	1,351	294.63	293.99	12,252

Total Solar Generation

	Inst. Capacity	PEAK	OFF-PEAK	Day Energy		Day AVG.
				Gross Gen	Net Gen	
Regional Entities Solar	26,989	0	0	162.04	161.42	6,728
State Control Area Solar	12,614	103	53	74.98	74.98	3,124
Total Solar	39,603	103	53	237.02	236.4	9,852

Total Wind Generation

	Inst. Capacity	PEAK	OFF-PEAK	Day Energy		Day AVG.
				Gross Gen	Net Gen	
Regional Entities Wind	970	302	172	8.79	8.79	366
State Control Area Wind	4,328	1,363	963	40.7	40.7	1,696
Total Wind	5,298	1,665	1,135	49.49	49.49	2,062

4(A) INTER-REGIONAL EXCHANGES (Import=(+ve) /Export =(-ve))

SL.No.	Element	20:00	03:00	Maximum Interchange (MW)		Import in MU	Export in MU	NET
		(MW)	MW	Import (MW)	Export (MW)			
Import/Export between EAST REGION and NORTH REGION								
1	132KV Rihand - Nagar Untari	-	-	-	-	0	0.09	-0.09
2	132KV-Chandauli (UP)-Karmnasa(PG)	-	-	-	-	-	-	-
3	132KV-Rihand (UP)-Garhwa(CG)	-	-	-	-	0	0.76	-0.76
4	132KV-Sahupuri (UP)-Karamnasa(PG)	-	-	-	-	-	-	-
5	220KV-Sahupuri (UP)-Karamnasa(PG)	-	-	-	-	2.1	0	2.1
6	400KV-Allahabad (PG)-Sasaram(PG)	-	-	-	-	0	0.23	-0.23
7	400KV-Balia (PG)-Biharsharif(PG)	-	-	-	-	0	9.05	-9.05
8	400KV-Balia (PG)-Naubatpur(Bihar)	-	-	-	-	0	2.08	-2.08
9	400KV-Balia (PG)-Patna(PG)	-	-	-	-	0.9	0	0.9
10	400KV-Gorakhpur (UP)-Motihari(DMT)	164	284	350	316	1.89	0	1.89
11	400KV-Gorakhpur (UP)-Muzaffarpur(PG)	82	285	347	521	0	1.38	-1.38
12	400KV-Sahupuri (UP)-Biharsharif(PG)	-	-	-	-	0	1.31	-1.31
13	400KV-Varanasi (PG)-Sasaram(PG)	-	-	-	-	2.5	0	2.5
14	765KV-Balia (PG)-Gaya(PG)	-	-	-	-	10.54	0	10.54

Import/Export between EAST REGION and NORTH REGION								
15	765KV-Sasaram (PG)-Fatehpur(PG)	-	-	-	-	0	2.04	-2.04
16	765KV-Varanasi (PG)-Gaya(PG)	-	-	-	-	0	5.41	-5.41
17	HVDC800KV-Agra (PG)-Alipurduar(PG)	-	-	-	-	-	-	-
Sub-Total EAST REGION		246	569	697	837	17.93	22.35	-4.42
Import/Export between NORTH_EAST REGION and NORTH REGION								
1	HVDC800KV-Agra (PG)-Biswanath Charialli(PG)	-	-	-	-	13.06	0	13.06
Sub-Total NORTH_EAST REGION		0	0	0	0	13.06	0	13.06
Import/Export between WEST REGION and NORTH REGION								
1	132KV-Lalitpur (UP)-Rajghat(MP)	-	-	-	-	-	-	-
2	132KV-Sawai Madhopur (RJ)-Gwalior(MP)	-	-	-	-	-	-	-
3	220KV-Auraiya (NT)-Malanpur(PG)	-68	18	-	91	0	0.54	-0.54
4	220KV-Auraiya (NT)-Mehgaon(PG)	-	-	-	-	-	-	-
5	220KV-Modak (RJ)-Bhanpura(MP)	49	53	59	40	1.18	0	1.18
6	220KV-Ranpur (RS)-Bhanpura(MP)	83	86	94	52	1.75	0	1.75
7	400KV-Bhinmal (PG)-Zerda(PG)	-	-	-	-	-	-	-
8	400KV-Chittorgarh 765 (PG)-Neemuch (WR)	-78	-271	-342	544	0	1.38	-1.38
9	400KV-Kankroli (RJ)-Zerda(PG)	-	-	-	-	2.42	0	2.42
10	400KV-RAPS C (NP)-Sujalpur	146	-103	208	701	0	5.82	-5.82
11	400KV-Rihand (NT)-Vindhyachal(PG)	-	-	-	-	-	-	-
12	765KV-0rai-Gwalior (PG)	-501	-614	0	-646	0	9.6	-9.6
13	765KV-0rai-Jabalpur	1,186	1,889	2,102	0	26.29	0	26.29
14	765KV-0rai-Satna	637	886	892	0	14.04	0	14.04
15	765KV-Agra (PG)-Gwalior(PG)	-	-	-	-	26.57	0	26.57
16	765KV-Chittorgarh-Banaskata D/C	-355	-420	-1,450	754	13.9	0	13.9
17	765KV-Dausa (PG)-Gwalior(PG)	-	-	-	-	7.3	0	7.3
18	765KV-Varanasi (PG)-Vindhyachal(PG)	-	-	-	-	58.23	0	58.23
19	HVDC500KV-Mohindergarh (JH)-Mundra(JH)	1,001	1,498	1,504	0	32.76	0	32.76
20	HVDC500KV-Vindhyachal (PG)-Vindhaychal B/B	200	200	200	0	4.82	0	4.82
21	HVDC800KV-Kurukshetra (PG)(PG)-Champa(PG)	4,500	2,000	4,500	0	84.56	0	84.56
Sub-Total WEST REGION		6,800	5,222	7,767	1,536	273.82	17.34	256.48
TOTAL IR EXCHANGE		7,046	5,791	8,464	2,373	304.81	39.69	265.12

4(B) Inter Regional Schedule & Actual Exchange (Import=(+ve) /Export =(-ve)) in MU

	ISGS+GNA+URS schedule	T-GNA Bilateral (MW)	GDAM Schedule	DAM Schedule	RTM Schedule	Total IR Schedule	Total IR Actual	NET IR UI
NR-ER	112.2	4.64	0	-0.33	0	93.27	-4.42	-97.69
NR-NORTH_EAST REGION	0	0	0	0	0	0	13.06	13.06
NR-WR	215.54	69.94	0	-81.19	0	210.06	256.48	46.42
Total	327.74	74.58	0	-81.52	0	303.33	265.12	-38.21

5.Inter National Exchange with Nepal [Import (+ve)/Export(-ve)] [Linkwise]

Element	Peak	Off-Peak	Maximum Interchange(MW)		Energy (MU)		Net Energy	Schedule Energy
	MW	MW	Import	Export	Import	Export	(MU)	(MU)
132KV-Tanakpur(NH)-Mahendranagar(PG)	59	68	0	69	0	1.17	-1.17	0
132KV-Nautanwa (UP)-Mainhiya (Nepal)						1.11	-1.11	0

5.Frequency Profile

RANGE(Hz)	< 49.2	< 49.7	< 49.8	< 49.9	< 50.0	>= 49.9 - <= 50.05	> 50.05 - <= 50.1	> 50.1 - <= 50.2	> 50.2	> 50.05
%	0	0	0	4.19	49.32	71.53	17.31	5.67	1.3	24.28

<----------Frequency (Hz)---------->

Maximum		Minimum		Average	Freq Variation	Standard	Freq. in 15 mnt blk		Freq Dev Index
Frequency	Time	Frequency	Time	Frequency	Index	Deviation	Max.	Min.	(% of Time)
50.251	07:59:40	49.841	11:32:30	50.005	0.045	0.067	50.176	49.899	99.99

6.Voltage Profile: 400kV

	Maximum		Minimum		Voltage (in %)				Voltage Deviation Index
					< 380	< 390	> 420	> 430	(% of time)
Abdullapur(PG) - 400KV	415	16:50	398	11:50	0	0	0	0	0
Amritsar(PG) - 400KV	415	16:55	390	12:45	0	0	0	0	0
Ballabgarh(PG) - 400KV	415	15:10	386	11:50	0	6.6	0	0	0
Bareilly II(PG) - 400KV	410	16:30	392	11:50	0	0	0	0	0
Bareilly(UP) - 400KV	411	16:30	393	11:50	0	0	0	0	0

Baspa(HP) - 400KV	**411**	**16:50**	**398**	**22:15**	**0**	**0**	**0**	**0**	**0**
Bassi(PG) - 400KV	**419**	**18:00**	**396**	**11:50**	**0**	**0**	**0**	**0**	**0**
Bawana(DTL) - 400KV	**415**	**15:10**	**394**	**11:50**	**0**	**0**	**0**	**0**	**0**
Dadri HVDC(PG). - 400KV	**412**	**00:00**	**412**	**00:00**	**0**	**0**	**0**	**0**	**0**
Gorakhpur(PG) - 400KV	**410**	**07:55**	**389**	**22:20**	**0**	**8.33**	**0**	**0**	**0**
Hisar(PG) - 400KV	**423**	**16:50**	**393**	**11:50**	**0**	**0**	**3.82**	**0**	**3.82**
Kanpur(PG) - 400KV	**416**	**16:30**	**400**	**11:50**	**0**	**0**	**0**	**0**	**0**
Kashipur(UT) - 400KV	**415**	**15:10**	**406**	**11:50**	**0**	**0**	**0**	**0**	**0**
Kishenpur(PG) - 400KV	**416**	**16:50**	**399**	**11:50**	**0**	**0**	**0**	**0**	**0**
Moga(PG) - 400KV	**418**	**16:55**	**395**	**12:45**	**0**	**0**	**0**	**0**	**0**
Nallagarh(PG) - 400KV	**411**	**16:50**	**398**	**22:15**	**0**	**0**	**0**	**0**	**0**
Rihand HVDC(PG) - 400KV	**401**	**10:15**	**391**	**22:25**	**0**	**0**	**0**	**0**	**0**
Rihand(NT) - 400KV	**400**	**08:55**	**395**	**21:25**	**0**	**0**	**0**	**0**	**0**

6.1 Voltage Profile: 765kV

	Maximum		**Minimum**		**Voltage (in %)**				**Voltage Deviation Index**
					< 728	**< 742**	**> 800**	**> 820**	
Anta RS(RJ) - 765KV	**791**	**13:40**	**766**	**00:00**	**0**	**0**	**0**	**0**	**0**
Balia(PG) - 765KV	**784**	**07:55**	**755**	**21:05**	**0**	**0**	**0**	**0**	**0**
Bareilly II(PG) - 765KV	**776**	**16:30**	**744**	**11:50**	**0**	**0**	**0**	**0**	**0**
Bhiwani(PG) - 765KV	**806**	**15:10**	**760**	**11:50**	**0**	**0**	**2.08**	**0**	**2.08**
Fatehpur(PG) - 765KV	**792**	**16:30**	**763**	**21:25**	**0**	**0**	**0**	**0**	**0**
Jhatikara(PG) - 765KV	**798**	**15:10**	**747**	**11:50**	**0**	**0**	**0**	**0**	**0**
Lucknow II(PG) - 765KV	**785**	**16:30**	**751**	**21:00**	**0**	**0**	**0**	**0**	**0**
Meerut(PG) - 765KV	**802**	**15:10**	**750**	**11:50**	**0**	**0**	**.69**	**0**	**.69**
Moga(PG) - 765KV	**804**	**15:10**	**745**	**11:50**	**0**	**0**	**.69**	**0**	**.69**
Phagi(RJ) - 765KV	**798**	**16:50**	**768**	**10:30**	**0**	**0**	**0**	**0**	**0**
Unnao(UP) - 765KV	**782**	**16:30**	**751**	**21:25**	**0**	**0**	**0**	**0**	**0**

7(A). Short-Term Open Access Details:

State	**Off- Peak Hours (03:00)**										**Peak Hours (20:00)**									
	T-GNA Bilateral(MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX RTM (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXI RTM (MW)	HPX GDAM (MW)	HPX DAM (MW)	HPX RTM (MW)	Bilateral (MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX RMT (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXIL RMT (MW)	HPX GDAM (MW)	HPX DAM (MW)	HPX RTM (MW)
PUNJAB	2,249.09	0	0	-1,700	0	0	0	0	0	0	2,242.43	0.46	2.24	-3,994.59	0	0	0	0	0	0
HARYANA	307.59	0.21	2.06	98.43	0	0	0	0	0	0	-98.98	0.86	4.13	-590.24	0	0	0	0	0	0
RAJASTHAN	113.25	-48.56	-176.79	-1,380.51	0	0	0	0	0	0	33.91	-24.07	-37.48	39.73	0	0	0	0	0	0
DELHI	1,633.41	0	-583	69.92	0	0	0	0	0	0	2,464.42	0.06	-1,188.74	254.71	0	0	0	0	0	0
UTTAR PRADESH	626.6	-4.87	118.95	526.05	0	0	0	0	0	0	256.15	8.52	150.36	1,194.43	0	0	0	0	0	0
UTTARAKHAND	314.85	-14.6	0	-40	0	0	0	0	0	0	604.9	-11.6	0	1.42	0	0	0	0	0	0
HIMACHAL PRADESH	-190.37	-33.1	-51.75	165.75	0	0	0	0	0	0	-143.37	-35.7	-476.05	-155.92	0	0	0	0	0	0
J&K(UT) & LADAKH(UT)	-16	-59.1	-15	355.45	0	0	0	0	0	0	-16	-59.1	71.13	386.36	0	0	0	0	0	0
CHANDIGARH	0	0	-20	-53	0	0	0	0	0	0	77.97	0	-120	-6	0	0	0	0	0	0
RAILWAYS_NR ISTS	0	4.52	45.46	37.67	0	0	0	0	0	0	0	5.49	26.36	62.78	0	0	0	0	0	0
BULK CONSUMER_NR ISTS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOTAL	5,038.42	-155.5	-680.07	-1,920.24	0	0	0	0	0	0	5,421.43	-115.08	-1,568.05	-2,807.32	0	0	0	0	0	0

State	Day Energy (MU)					
	GNA schedule	T-GNA Bilateral (MW)	GDAM Schedule	DAM Schedule	RTM Schedule	Total (MU)
PUNJAB	108.8	57.26	0.05	0.03	-32.99	133.15
HARYANA	179.53	8.73	0.82	-1.19	-0.37	185.25
RAJASTHAN	101.05	1.98	-0.51	-17.56	-20.39	64.57
DELHI	95.6	44.54	0.06	-10.56	0.45	130.09
UTTAR PRADESH	226.41	3.76	0.45	6.03	13.52	250.53
UTTARAKHAND	30	8.11	-0.21	1.21	1.49	40.61
HIMACHAL PRADESH	11.88	-2.42	-0.15	-3.11	-1.32	4.87
J&K(UT) & LADAKH(UT)	27.94	-0.28	-0.93	1.29	1.05	29.07
CHANDIGARH	7.06	0.42	0.02	-0.24	-0.21	7.03
RAILWAYS_NR ISTS	2.56	0	0.13	0.79	0.57	4.05
BULK CONSUMER_NR ISTS	1.37	0.06	0	0	0	1.43
TOTAL	792.2	122.16	-0.27	-23.31	-38.2	850.65

7(B). Short-Term Open Access Details

State	GNA schedule		T-GNA Bilateral (MW)		IEX GDAM (MW)		PXI GDAM (MW)		HPX GDAM(MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
PUNJAB	5,095.73	3,478.51	2,585.4	2,242.43	13.52	0	0	0	0	0
HARYANA	8,286.89	6,293.82	700.86	-299.61	87.9	0	0	0	0	0
RAJASTHAN	5,205.61	2,404.05	336.05	-351.18	45.65	-51.6	0	0	0	0
DELHI	4,857.23	3,186.31	2,464.42	1,207.81	6.86	0	0	0	0	0
UTTAR PRADESH	11,460.22	7,006.18	626.61	-41.87	297.39	-28.1	0	0	0	0
UTTARAKHAND	1,342.27	1,038.49	605.39	36.3	0	-18.6	0	0	0	0
HIMACHAL PRADESH	843.1	221.71	1.22	-190.37	40.38	-35.7	0	0	0	0
J&K(UT) & Ladakh(UT)	1,605.54	610.38	-8	-16	0	-59.1	0	0	0	0
CHANDIGARH	384.71	182.91	77.97	0	43.47	0	0	0	0	0
RAILWAYS_NR ISTS	119.76	100.76	0	0	78.62	0	0	0	0	0
BULK CONSUMER_NR ISTS	-	-	-	-	-	-	-	-	-	-

State	IEX DAM (MW)		PXI DAM(MW)		HPX DAM (MW)		IEX RTM (MW)		PXI RTM (MW)		HPX RTM (MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
PUNJAB	12.56	0	0	0	0	0	936.92	-5,495.65	0	0	0	0
HARYANA	386.75	-759.95	0	0	0	0	1,014.2	-1,081.45	0	0	0	0
RAJASTHAN	54.1	-2,877.75	0	0	0	0	57.63	-2,700.79	0	0	0	0
DELHI	193.18	-1,274	0	0	0	0	599.82	-1,143	0	0	0	0
UTTAR PRADESH	628.12	-1,322.45	0	0	0	0	1,716.27	-346.15	0	0	0	0
UTTARAKHAND	236.16	0	0	0	0	0	286.39	-120.65	0	0	0	0
HIMACHAL PRADESH	162.59	-477.6	0	0	0	0	237.57	-575.92	0	0	0	0
J&K(UT) & LADAKH(UT)	274.77	-15	0	0	0	0	772.72	-650	0	0	0	0
CHANDIGARH	111.08	-140	0	0	0	0	51.19	-95	0	0	0	0
RAILWAYS_NR ISTS	77.66	0	0	0	0	0	100.45	0	0	0	0	0
BULK CONSUMER_NR ISTS	-	-	-	-	-	-	-	-	-	-	-	-

8.Major Reservoir Particulars

RESERVOIR	Parameters			Present Parameters		LAST YEAR		LAST DAY	
	MDDL (Mts)	FRL (Mts)	Energy Content at FRL	Level (Mts)	Energy (MU)	Level (Mts)	Energy (MU)	Inflow (m3/s)	Usage (m3/s)
Bhakra	445.62	513.59	1,728.8	481.53	495	475.91	368	324.96	485.18
Chamera-I	748.75	760	753.95	756.05	6	-	-	169.17	202.42
Gandhisagar	381	399.9	725	-	-	-	-	-	0
Jawahar Sagar	295.96	298.7	2.01	-	-	-	-	-	0
Koteshwar	598.5	612.5	610.73	610.45	5	611.7	5	109.87	100.03
Pong	384.05	426.72	1,084	405.47	352	394.89	126	61.14	173.87
RPS	343.81	352.81	175.66	-	-	-	-	-	0
RSD	487.91	527.91	390.3	512.5	250	508.1	197	69.98	349.57
Rihand	252.98	268.22	860.5	-	-	-	-	-	0
Tehri	740.04	830	1,164.11	740.98	5	742.15	12	138.77	102
TOTAL	-	-	-	-	1,113	-	708	873.89	1,413.07

9. System Reliability Indices(Violation of TTC and ATC):

(i)%age of times N-1 Criteria was violated in the inter and intra regional corridors	
WR	0
ER	0
Simultaneous	0
Delhi	0
Rajasthan	0
UP	0
Punjab	0
Haryana	0

ii)%age of times ATC violated on the inter and intra regional corridors

WR	0
ER	0
Simultaneous	0
Delhi	0
Rajasthan	0
UP	0
Punjab	0
Haryana	0

iii)%age of times Angular Difference on Important Buses was beyond permissible limits(40 deg.)

Rihand-Dadri	0

10. Zero Crossing Violations

State	No. of violations(Maximum 15 in a day)	Maximum number of continuous blocks without sign change
CHANDIGARH	1	8
DELHI	11	42
HARYANA	7	30
HIMACHAL PRADESH	4	16
J&K(UT) & Ladakh(UT)	9	24
PUNJAB	11	37
RAJASTHAN	13	48
UTTAR PRADESH	4	11
UTTARAKHAND	8	28

11. NCR's and Ladakh Power Supply Position(based on SCADA data)

	Inst Capacity	20:00	03:00	Day Peak			
Station/Constituents	(MW)	Peak MW	Off Peak MW	MW	HRS	Net MU	AVG MW
NCR_GENERATION	9225	4,720	4,935	6939	00:00:00	113.49	4,729
NCR_DRAWAL	-	11,840	13,208	14098	01:45:00	274.71	11,446
NCR_DEMAND	-	16,560	18,143	20589	00:00:00	388.19	16,175
LADAKH_DEMAND	-	23	-2	23	20:15:00	0.15	6

12. RE/Load Curtailment details

State	Load Curtailment (Shortage)			RE Curtailment				
	Energy	Maximum	At the time of maximum demand	Wind		Solar		Reason
	MU	MW	MW	Max MW	Energy(MU)	Max MW	Energy(MU)	
PUNJAB	0	0	0	0	0	0	0	
HARYANA	0	0	0	0	0	0	0	
RAJASTHAN	0	0	0	0	0	0	0	
DELHI	0	0	0	0	0	0	0	
UTTAR PRADESH	0	0	0	0	0	0	0	
UTTARAKHAND	0	0	0	0	0	0	0	
HIMACHAL PRADESH	0	0	0	0	0	0	0	
J&K(UT) & Ladakh(UT)	0	0	0	0	0	0	0	
CHANDIGARH	0	0	0	0	0	0	0	
RAILWAYS_NR ISTS	0	0	0	0	0	0	0	
BULK CONSUMER_NR ISTS	0	0	0	0	0	0	0	

13.Grid Disturbance / Any Other Significant Event:

14.Weather Conditions :

15.Synchronisation of new generating units :

16.Synchronisation of new 220 / 400 / 765 KV lines and energising of bus / /substation :

17.Instances of persistent/significant non-complaint with the grid code

18.Constraints and instances of congestion in the transmission system

19.Remarks :

No Records Found

Note: Data(regarding drawal,generation, shortage , inter-regional flows and reservoir levels)of the constituents filled in the report are as per last furnished data by the respective state/constituent to NRLDC.
***Unscheduled Load Shedding carried out by Uttar Pradesh.**

Shift In Charge