GRID CONTROLLER OF INDIA (GRID-INDIA)
WESTERN REGIONAL LOAD DESPATCH CENTRE
DAILY OPERATION REPORT OF WESTERN REGION

Power Supply Position in Western Region For 02-Jun-2026

Date of Reporting:03-Jun-2026

1. Regional Availability/Demand:

Evening Peak (20:00) MW				Off-Peak (03:00) MW				/Day Energy(Net MU)	
मांग पूरता/ Demand Met	अभाव/Shortage	आवश्यकता/ Requirement	आवृतता/Freq (Hz)	मांग पूरता/ Demand Met	अभाव/Shortage	आवश्यकता/ Requirement	आवृतता/Freq (Hz)	मांग पूरता/Demand Met	अभाव/Shortage
70,132	0	70,132	50.07	60,036	0	60,036	50.04	1,597.4	0.49

2(A) /Load Details (/in state periphery) in MU:

राज्य/STATE	State's Control Area Generation (Net MU)							/Net SCH	/Drawal	/UI	Availability	Requirement	/ Shortage	/ Consump -tion
	तापीय/ THERMAL	जलीय/ HYDRO	गैस/ Gas	पवन/ WIND	सौर/ SOLAR	अन्य/ OTHERS	कुल/TOTAL	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)
BALCO	-	0	0	0	0	0	0	17	16.9	-0.1	16.9	16.9	0	16.9
CHHATTISGARH	52	0.2	0	0	4.2	0.7	57.1	65.9	65.5	-0.4	122.6	122.8	0.18	122.6
DNHDDPDCL	-	0	0	0	0	0	0	30.5	30.6	0.1	30.6	30.6	0	30.6
AMNSIL	6.8	0	0	0	0	0	6.8	12.9	13	0.1	19.8	19.8	0	19.8
GOA	0.4	0	0	0	0	0	0.4	17.4	17.5	0.1	17.9	18	0.06	17.9
GUJARAT	182.3	2	12.5	45	70.1	0	311.9	166.5	155.7	-10.8	467.6	467.7	0.11	467.6
MADHYA PRADESH	85.3	9.1	0	9.3	11.8	1.6	117.1	151.8	151.8	0	268.9	268.9	0	268.9
MAHARASHTRA	333.3	15.3	9.9	23.8	37.5	0	419.8	233.1	227	-6.1	646.8	646.9	0.14	646.8
RIL JAMNAGAR	-	0	0	0	0	0	0	6.6	6.3	-0.3	6.3	6.3	0	6.3
Region	660.1	26.6	22.4	78.1	123.6	2.3	913.1	701.7	684.3	-17.4	1,597.4	1,597.9	0.49	1,597.4

2(B) / /State's Demand Met in MW and day energy forecast and deviation particulars

राज्य/State	Evening Peak (20:00) MW			Off-Peak (03:00) MW				/Day Energy(Net MU)	
	मांग पूरता/ Demand Met	अभाव/ Shortage	आवश्यकता/ Requirement at Evening peak	मांग पूरता/ Demand Met	अभाव/ Shortage	आवश्यकता/ Requirement at Off-Peak	AVG (MW)	पूर्वानुमान/ForeCast(MU)	विचलन/Deviation[Fore .. -Consumption] (MU)
BALCO	705	0	705	701	0	701	703	14	-2.9
CHHATTISGARH	5,131	0	5,131	5,293	0	5,293	5,121	122.61	0.01
DNHDDPDCL	1,292	0	1,292	1,218	0	1,218	1,268	30.73	0.13
AMNSIL	807	0	807	840	0	840	827	19	-0.8
GOA	813	0	813	710	0	710	746	17.4	-0.5
GUJARAT	21,698	0	21,698	15,794	0	15,794	19,482	539.31	71.71
MADHYA PRADESH	11,669	0	11,669	10,483	0	10,483	11,219	286.87	17.97
MAHARASHTRA	27,767	0	27,767	24,722	0	24,722	26,958	651.58	4.78
RIL JAMNAGAR	250	0	250	275	0	275	263	6	-0.3
Region	70,132	0	70,132	60,036	0	60,036	66,587	1,687.5	90.1

2(C) /State's Demand Met in MW (/maximum demand met and /Maximum requirement of the day details)

राज्य/State	Maximum Demand, corresponding shortage and requirement details for the day				ACE			
	अधिकतम मांग पूरता/Maximum Demand Met of the day	समय/Time	अभाव/Shortage at maximum demand	आवश्यकता/Requirement at the max demand met of the day	ACE_MAX	बजे/Time	ACE_MIN	बजे/Time
BALCO	706	17:00	0	706	-	-	-	-
CHHATTISGARH	5,542	23:15	0	5,542	380.46	01:47:00	-299.69	08:50:00
DNHDDPDCL	1,360	17:00	0	1,360	145.93	05:16:00	-96.76	23:38:00
AMNSIL	885	05:00	0	885	293.92	01:48:00	-305.4	12:25:00
GOA	824	21:45	0	824	63.74	19:18:00	-100.17	22:10:00
GUJARAT	23,031	16:00	0	23,031	3,629.77	08:16:00	-2,312.37	23:34:00
MADHYA PRADESH	12,490	23:45	0	12,490	886.42	04:56:00	-734.69	13:37:00
MAHARASHTRA	29,783	15:00	0	29,783	1,205.75	16:03:00	-1,569.11	18:56:00
RIL JAMNAGAR	275	10:00	0	275	-	-	-	-
WR	73,887	15:00	0	73,887	-	-	-	-

3(A) State Entities Generation:

CHHATTISGARH

स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
KORBA EAST EXT(DSPM)(2*250)	500	424	410	455	23:38	388	12:12	10.51	9.62	401
KORBA(W) CSETCL(4*210 + 1*500)	1,340	-179	731	746	08:27	-192	17:12	18.37	17.01	709
MARWA TPS(1*500 + 1*500)	1,000	969	970	985	23:19	767	11:00	23.59	22.45	935
OTHER CPP	50	0	0	0	-	0	-	2.95	2.95	123
TOTAL THERMAL	2,890	1,214	2,111	-	-	-	-	55.42	52.03	2,168
HASDEO BANGO(3*40)	120	1	1	40	21:04	1	00:01	0.12	0.12	5
KWB MINI MICRO(2*0.85)	1.7	0	0	0	-	0	-	0.01	0.01	0
SMALL HYDRO	50	0	0	0	-	0	-	0.05	0.05	2
TOTAL HYDEL	171.7	1	1	-	-	-	-	0.18	0.18	7
WIND	0	0	0	0	-	0	-	0	0	0
SOLAR	842	0	0	602	11:30	22	06:00	4.21	4.21	175
BIO MASS	50	0	0	0	-	0	-	0	0	0
TOTAL BIO MASS	50	0	0	-	-	-	-	0	0	0
TOTAL CHHATTISGARH	3,953.7	-	-	-	-	-	-	59.81	56.42	2,350

GUJARAT

स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
AECO(1*120 + 2*121)	362	357	362	364	21:50	228	10:35	7.48	6.81	284
ALTPS(2*125)	250	99	102	106	23:27	96	16:54	2.4	1.93	80
APL MUNDRA(4*330 + 2*660 + 3*660)	4,620	4,145	3,725	4,237	00:17	2,604	10:43	88	81.06	3,378
BLTPS(2*250)	500	324	319	326	23:33	264	12:15	7.76	6.55	273
GANDHINAGAR(GTPS)(3*210)	630	409	223	424	18:51	241	15:47	6.91	6.57	274
KLTPS(2*75)	150	64	59	66	17:48	56	00:21	1.51	1.32	55
OTHER CPP	1,000	0	0	0	-	0	-	4.22	5.5	229
SLPP(4*125)	500	394	397	399	03:25	260	14:40	9.49	8.21	342
STPS(2*250)	500	0	0	0	00:00	0	09:56	0	0	0
UKAI(2*200 + 1*210 + 1*500)	1,110	378	343	392	21:14	236	13:36	7.33	6.35	265
VADINAR(2*600)	1,200	1,117	952	1,141	22:50	577	14:57	21.4	20.07	836
WANAKBORI(7*210 + 1*800)	2,270	1,747	1,619	1,771	21:20	1,033	06:32	32.34	29.74	1,239
TOTAL THERMAL	13,092	9,034	8,101	-	-	-	-	188.84	174.11	7,255
DGBP(1*107 + 1*112 + 1*376)	594	0	0	0	00:00	0	00:00	1.02	0.97	40
ESSAR POWER GAS(3*110 + 1*185)	515	0	0	0	-	0	-	0	0	0
GIPCL STG(3*32 + 49)	145	0	0	0	00:00	0	00:00	0	0	0
GIPCL STG 2(111 + 54)	165	0	0	0	00:00	0	00:00	0	0	0
GPEC(3*138 +241)	654	0	0	0	-	0	-	0	0	0
GPPC(2*351.43)	702	0	0	0	00:00	0	00:00	0	0	0
GSEC(3*52)	156	0	170	298	00:17	0	03:25	0.82	0.77	32
SUGEN 1(3*382.5)	1,147.5	661	-3	988	23:15	-3	01:55	7.21	6.94	289
UNOSUGEN(1*382.5)	382.5	282	190	364	00:00	0	05:06	2.56	2.47	103
UTRAN STG II(1*229 + 1*146(ST))	375	0	0	193	02:25	0	00:00	1.34	1.3	54
TOTAL GAS	4,836	943	357	-	-	-	-	12.95	12.45	518
KADANA(4*60)	240	0	52	102	22:17	0	04:39	0.39	0.39	16
LBC PANAM HYDRO	5	0	0	0	-	0	-	0.08	0.08	3
PVT HYDRO	20.6	0	0	0	-	0	-	0.13	0.13	5
UKAI HYDRO(4*75)	300	65	65	129	00:00	65	00:07	1.63	1.61	67
TOTAL HYDEL	565.6	65	117	-	-	-	-	2.23	2.21	91
WIND	8,836	2,927	444	3,422	08:27	1,122	12:31	45	45	1,875
SOLAR	15,238	58	-20	8,628	14:26	1	06:00	70.1	70.1	2,921
BIO MASS	51.65	0	0	0	-	0	-	0	0	0
TOTAL GUJARAT	42,619.25	-	-	-	-	-	-	319.12	303.87	12,660

MADHYA PRADESH

स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
AMARKANTAK(1*210)	210	0	182	182	03:00	0	14:15	2.72	2.41	100
BLA IPP(2*45)	90	83	84	84	03:00	46	09:27	1.75	1.54	64
JP BINA(2*250)	500	240	42	243	04:56	141	15:22	4.03	3.56	148
SANJAY GANDHI TPS(4*210 + 1*500)	1,340	972	964	986	21:19	807	10:24	24.04	22.09	920
SATPURA IV(2*250)	500	470	470	479	16:31	261	13:03	11.01	10.08	420
SINGAJI(2*600 + 2*660)	2,520	2,346	2,315	2,387	18:37	1,336	13:33	51.3	48.54	2,023
TOTAL THERMAL	5,160	4,111	4,057	-	-	-	-	94.85	88.22	3,675
BANASAGAR TONS(3*105)	315	289	163	311	19:11	88	16:36	4.74	4.69	195
BARGI(2*45)	90	33	33	33	00:08	33	16:32	0.78	0.77	32
BIRSINGHPUR	20	0	0	0	-	0	-	0	0	0
BSGR(DEVLONE)(3*20)	60	0	0	0	00:00	0	00:00	0	0	0
BSGR(SILPARA)(2*15)	30	-24	-20	0	09:05	-21	07:36	0.33	0.33	14
INDIRASAGAR(8*125)	1,000	349	1	628	00:07	0	09:44	2.64	2.62	109
JHINNA(2*10)	20	16	16	16	08:42	16	15:47	0.39	0.39	16
MADIKHEADA(3*20)	60	60	60	60	00:00	60	00:00	0	0	0
MP CHAMBAL	386	0	0	0	-	0	-	0	0	0
OMKARESHWAR(8*65)	520	0	0	69	16:31	0	00:00	0.3	0.3	13
PENCH(2*80)	160	0	0	0	-	0	-	0	0	0
RAJGHAT HYDRO(3*15)	45	0	0	0	00:00	0	00:00	0	0	0
TOTAL HYDEL	2,706	723	253	-	-	-	-	9.18	9.1	379
WIND	2,670	317	318	676	05:08	34	09:43	9.29	9.29	387
SOLAR	2,370	0	0	1,611	12:14	52	06:00	11.8	11.8	492
BIO + SMALL HYDRO	100	0	0	0	-	0	-	1.56	1.56	65
TOTAL MADHYA PRADESH	13,006	-	-	-	-	-	-	126.68	119.97	4,998

MAHARASHTRA

स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
APML TIRODA(5*660)	3,300	3,116	3,069	3,133	20:19	1,710	14:05	63.67	60.02	2,501
BHUSAWAL(1*210 + 2*500+1*660)	1,870	1,549	1,691	1,707	01:06	1,016	14:10	36.09	34.19	1,425
CHANDRAPUR(2*210 + 5*500)	2,920	1,749	1,693	1,834	21:56	1,243	09:44	40.31	37.71	1,571
DAHANU(2*250)	500	501	498	505	17:15	280	08:00	10.2	9.16	382
IEPL(1*270)	270	271	267	286	17:55	148	11:02	5.63	5.01	209
JAIGAD(4*300)	1,200	1,006	929	1,025	22:27	718	15:39	23.09	21.13	880
JPL DHULE (SHIRPUR)(2*150)	300	280	268	281	16:50	151	13:00	5.88	5.82	243
KHAPARKHEDA(4*210 + 1*500)	1,340	957	1,027	1,052	03:43	727	12:37	24.43	22.66	944
KORADI(1*210 + 3*660)	4,170	1,025	1,084	1,093	00:19	745	11:14	24.34	22.55	940
NASIK(3*210)	630	290	278	300	18:41	213	10:28	6.53	6.08	253
OTHER CPP	3,305	0	0	0	-	0	-	38.95	38.95	1,623
PARAS(2*250)	500	419	250	445	23:09	250	03:35	8.73	7.95	331
PARLI(3*250)	750	663	586	675	22:36	380	09:35	14.34	12.83	535
RATTAN INDIA (AMARAVATI)(5*270)	1,350	1,233	1,202	1,258	23:58	688	12:38	30.16	27.59	1,150
SWPGL(4*135)	540	432	436	443	17:28	258	12:29	10.9	9.8	408
TROMBAY(250+1*500)	750	640	404	675	00:14	373	06:27	0	0	0
VIPL(2*300)	600	551	554	573	07:43	320	13:04	12.9	11.88	495
TOTAL THERMAL	24,295	14,682	14,236	-	-	-	-	356.15	333.33	13,890
TROMBAY_GAS(1*120+1*60)	180	166	164	174	00:00	103	08:44	3.42	3.4	142
URAN(4*108 + 2*120)	672	257	274	327	19:49	257	15:03	6.71	6.54	273
TOTAL GAS	852	423	438	-	-	-	-	10.13	9.94	415
BHIRA(6*25)	150	107	11	153	00:04	2	10:38	0	0	0
BHIRA PSS	150	163	160	163	20:00	-182	10:12	0	0	0
BHIRA TR(2*40)	80	0	0	0	-	0	-	0.33	0.32	13
BHIVPURI(3*24 + 2*1.5)	75	47	48	48	03:00	20	13:34	0	0	0
GHATGHAR(2*125)	250	122	0	123	19:08	0	02:01	0.91	0.89	37
HYDRO VTRNA(1*60)	60	0	0	0	00:00	0	00:00	0.56	0.55	23
HYDROSMLHY_PTN	350	0	0	0	-	0	-	5.01	4.91	205
KHOPOLI(3*24)	72	24	23	24	02:00	2	10:08	0	0	0
KOYNA I AND II(4*(65+5) + 4*(75+5))	600	40	41	524	22:16	35	08:24	2.63	2.59	108
KOYNA III(4*80)	320	78	0	157	23:23	0	00:00	0.53	0.53	22
KOYNA ST-IV(4*250)	1,000	-4	-4	1	09:36	-26	14:40	0	0	0
TILLARI(1*66)	66	0	0	55	14:47	-1	15:07	0	0	0
OTHER HYDRO	122	0	0	0	-	0	-	5.51	5.51	230
TOTAL HYDEL	3,295	577	279	-	-	-	-	15.48	15.3	638
WIND	5,321	853	654	1,334	00:07	51	11:12	23.83	23.83	993
SOLAR	6,028	85	99	4,944	12:15	133	06:00	37.46	37.46	1,561
TOTAL MAHARASHTRA	39,791	-	-	-	-	-	-	443.05	419.86	17,497

3(B) Regional Entities Generation

ISGS

स्टेशन/ Station/Constituents	स्थापित क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
GADARWARA(2*800)	1,600	1,508	1,477	1,570	23:20	749	08:22	29.6	31.42	29.5	1,229
GANDHAR(3*144.3 + 1*224.49)	657	2	0	263	23:02	-26	15:06	0.79	0.84	0.79	33
KAPS(2*220)	440	391	391	391	00:00	391	00:00	9.48	10.58	9.57	399
KAPS3&4(2*700)	1,400	588	604	611	06:55	580	15:20	27.6	30.75	28.16	1,173
KAWAS(4*106 + 2*116.1)	656.2	-4	-5	44	02:32	-10	12:02	0.02	0.01	0.01	0
KHARGONE(2*660)	1,320	1,260	1,176	1,275	22:50	645	15:16	23.34	24.84	23.53	980
KSTPS1&2(3*200 + 3*500)	2,100	1,367	1,337	1,394	00:02	755	09:04	32.87	35.06	32.36	1,348
KSTPS3(1*500)	500	482	471	490	21:45	282	10:15	10.29	10.78	10.08	420
LARA(2*800)	1,600	1,514	1,476	1,528	22:15	824	11:19	32.93	34.88	32.9	1,371
MOUDA I(2*500)	1,000	954	883	965	20:59	460	12:42	18.98	19.72	17.85	744
MOUDA II(2*660)	1,320	1,186	1,184	1,241	00:06	581	12:42	24.79	26.31	23.32	972
NSPCL(2*250)	500	459	412	476	22:10	237	08:12	9.56	10.35	9.44	393
RGPPL(2*320 + 4*331.75)	1,967	-21	-25	2	14:26	-35	07:12	0.09	0.11	0.11	5
SASAN(6*660)	3,960	3,747	3,757	3,800	17:01	2,706	10:42	87.73	93.52	87.98	3,666
SIPAT I(3*660)	1,980	1,932	1,871	1,972	22:50	1,027	11:09	40.72	43.3	40.85	1,702
SIPAT II(2*500)	1,000	959	936	977	23:54	527	11:19	20.75	21.93	20.64	860
SOLAPUR STPS(2*660)	1,320	1,231	941	1,281	23:33	653	17:50	21.56	23.39	21.75	906
SSP(RBPH+CHPH)(6*200 + 5*50)	1,450	600	-2	1,011	23:47	-2	10:06	5.59	5.82	5.7	238
TARAPUR I(2*160)	320	151	154	156	20:11	102	13:16	3.48	3.85	3.41	142
TARAPUR II(2*540)	1,080	784	791	811	07:12	734	13:20	18.72	20.94	18.67	778
VSTPS I(6*210)	1,260	916	906	943	17:20	510	08:18	19.82	21.99	19.39	808
VSTPS II(2*500)	1,000	908	896	949	00:27	517	08:57	19.26	20.31	18.74	781
VSTPS III(2*500)	1,000	955	900	965	20:16	493	08:16	19.56	20.4	19.41	809
VSTPS IV(2*500)	1,000	955	885	972	23:33	479	11:33	19.65	20.89	19.52	813
VSTPS V(1*500)	500	471	449	490	23:24	240	08:24	9.75	10.27	9.69	404
SUB-TOTAL	30,930.2	23,295	21,865	-	-	-	-	506.93	542.26	503.37	20,974
TOTAL	30,930.2	-	-					506.93	542.26	503.37	20,974

IPP/JV

स्टेशन/ Station/Constituents	स्थापित क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
ACBIL(2*135 + 2*50 + 2*30 + 1*63)	493	289	298	302	00:15	254	09:50	6.83	8.02	6.82	284
ADANI RAIPUR(2*685)	1,370	1,219	1,165	1,247	19:31	649	10:45	26.87	28.37	25.54	1,064
APL RAIGARH(1*600)	600	0	0	0	00:00	-7	13:14	0	0	0	0
BALCO(4*300)	1,200	836	860	884	06:45	601	10:23	19.82	19.82	19.3	804
DB POWER(2*600)	1,200	1,132	1,136	1,155	03:08	754	09:44	25.89	27.4	25.92	1,080
DCPP(2*135)	270	212	220	223	05:25	135	09:45	4.94	5.65	4.93	205
DGEN(3*400)	1,200	-2	-3	-2	11:09	-4	12:40	0	0.05	0.05	2
DHARIWAL CTU(2*300)	600	556	548	566	18:43	290	08:26	11.76	12.76	11.86	494
GMR WARORA(2*300)	600	567	577	592	19:41	341	09:32	12.56	13.66	12.62	526
JHABUA POWER(1*600)	600	547	516	556	23:45	307	08:41	11.53	12.2	11.45	477
JP NIGRIE(2*660)	1,320	1,266	1,260	1,285	21:30	698	09:49	25.53	27.36	25.98	1,083
JPL STG-I(4*250)	1,000	827	841	860	22:50	504	13:17	17.29	19.58	17.34	723
JPL STG-II(4*600)	2,400	2,313	2,330	2,352	22:24	1,608	12:03	49.68	53.89	51.04	2,127
JSW MAHANADI(3*600)	1,800	1,362	1,362	1,362	00:00	1,362	00:00	33.34	35.3	32.71	1,363
LANCO(2*300)	600	558	546	569	19:40	300	08:57	12.46	13.86	12.6	525
MAHAN ENERGEN(2*600)	1,200	1,126	1,128	1,141	21:02	626	09:37	25.31	27.19	25.44	1,060
MB POWER(2*600)	1,200	1,179	1,184	1,200	18:32	491	10:55	24.96	26.43	24.93	1,039
MCCPL(1*300)	300	263	269	278	03:15	215	10:15	6.14	6.75	6.12	255
RKM POWER(4*360)	1,440	1,305	1,317	1,325	21:31	737	09:43	27.72	30.86	27.99	1,166
SARDA ENERGY & MINERALS LTD(2*300)	600	522	520	532	23:59	404	09:37	12.29	13.62	12.36	515
TPCL(5*800)	4,000	3,825	2,986	3,827	22:21	2,054	08:40	66.73	72.37	66.59	2,775
TRN ENERGY(2*300)	600	517	542	542	03:00	496	17:39	12.33	13.37	12.2	508
VEDANTA_LIMITED_CG (1*600)	600	-1	-1	0	23:19	-2	17:18	0	0.05	0.05	2
SUB-TOTAL	25,193	20,418	19,601	-	-	-	-	433.98	468.56	433.84	18,077
TOTAL	25,193	-	-					433.98	468.56	433.84	18,077

RENEWABLE

स्टेशन/ Station/Constituents	स्थापित क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
AGE25BL_PSS9_KPS1_HS	100	0	0	0	-	0	-	0.37	0.58	0.58	24
AHEJ5L_PSS8_KPS3_HS	100	0	0	104	12:40	0	05:58	1.4	0.95	0.95	40
AYANARP4_DVSR_BHJ_HS	37.5	0	0	0	00:00	0	00:00	0.25	0.26	0.26	11
ACL_PSS3_KPS1_S	200	0	0	206	11:26	0	05:59	1.78	1.88	1.88	78
ACL_PSS4_KPS1_HS	125	0	0	127	12:56	0	06:00	1.2	0.98	0.98	41
AGE24AL_PSS3_KPS1_S	400	-1	0	414	12:00	0	00:00	3.98	3.75	3.75	156
AGE24L_PSS10_KPS3_S	150	0	0	121	12:02	0	02:37	0.78	1.03	1.03	43
AGE24L_PSS5_KPS1_S	150	0	0	151	12:08	0	06:00	1.48	1.35	1.35	56
AGE25AL_PSS2_KPS1_S	500	0	0	332	17:28	0	00:01	1.34	2.34	2.34	98
AGE25BL_PSS2_KPS1_S	582.98	-1	0	383	17:28	0	04:16	1.57	2.81	2.81	117
AGE25CL_PSS8_KPS3_S	350	-1	0	407	14:27	0	05:20	4.62	3.12	3.12	130
AGE26AL_PSS3_KPS1_S	62.5	0	0	39	12:57	0	06:01	-	0.27	0.27	11
AGE26AL_PSS6_KPS1_S	750	0	0	0	00:00	0	00:00	7.29	0	0	0
AGE26BL_PSS10_KPS1_HS	142	0	0	297	12:30	0	06:02	0.11	2.59	2.59	108
AGE26BL_PSS10_KPS1_S	150	0	0	297	12:30	0	06:02	0.4	2.59	2.59	108
AGE26BL_PSS2_KPS1_S	167	0	0	113	17:28	0	00:00	0.45	0.83	0.83	35
AHEJ5L_PSS5_KPS1_S	570	-1	-1	556	12:46	0	06:00	5.31	4.23	4.23	176
APSEZ_PSS3_KPS1_S	200	0	0	204	11:20	0	00:00	1.78	1.84	1.84	77
ARE3L_PSS8_KPS3_HS	25	0	0	0	-	0	-	0.22	0.13	0.13	5
ARE45L_PSS5_KPS1_S	250	-1	0	240	12:14	0	06:00	2.36	2.16	2.16	90
ARE55L_PSS3_KPS1_HS	25	0	0	23	11:33	0	00:00	0.19	0.22	0.22	9
ARE55L_PSS3_KPS1_S	162.5	12	1	15	19:26	0	00:45	1.61	0.11	0.11	5
ARE56L_PSS10_KPS1_S	500	-1	0	505	12:11	-1	06:01	2.78	4.53	4.53	189
ARE56L_PSS4_KPS1_S	225	0	0	0	-	0	-	2.22	2.11	2.11	88
ARE56L_PSS9_KPS1_S	400	0	0	235	12:43	0	06:00	1.07	2.14	2.14	89
ARE57L_PSS13_KPS1_S	850	-1	-1	598	09:13	-1	00:21	2.28	4.62	4.62	193
AREH4L_PSS1_KPS1_SF	1,000	-4	-3	725	16:29	-3	00:13	4.25	5.74	5.74	239
ARINSUN SOLAR (BARSAITADESH)	250	-1	-1	204	14:11	10	06:30	1.11	1.04	1.04	43
ASEJ6PL_PSS8_KPS3_HS	35	30	30	30	00:00	30	00:00	0.07	0.72	0.72	30
ASEJ6PL_PSS8_KPS3_S	50	30	30	30	00:00	30	00:00	0.48	0.72	0.72	30
ATHENA SOLAR	250	-1	-1	206	14:11	10	06:00	1.34	1.03	1.03	43
AVAADA_AGAR_RUMS_S	200	-1	-1	201	13:24	1	05:59	1.49	1.52	1.52	63
AYANARP4_DVSR_BHJ_HW	150	3	3	3	00:00	3	00:00	0.82	0.07	0.07	3
BEEMPOW_AGAR_RUMS_S	350	-2	-2	328	12:12	6	06:00	2.21	2.27	2.27	95
BLUELEAF_CP_PCHR_HS	128.7	-29	0	68	12:31	-54	06:08	0	0.17	0.17	7
CGERP_MORJAR_BHJ2_HS	30.8	0	0	0	00:00	0	00:00	0.25	0	0	0
ESPL_RSP SOLAR	200	94	0	194	14:07	0	09:57	1.39	1.19	1.19	50
GANDHAR SOLAR	20	0	0	0	00:00	0	00:00	0.12	0.13	0.13	5
GIPCL_PSS1_KPS2_S	600	-3	-4	519	14:02	-16	06:06	4.46	4.39	4.39	183
GIPCL_RSP SOLAR	100	0	0	103	14:07	0	09:30	0.53	0.52	0.52	22
GSEC 2	100	0	0	30	14:13	0	09:37	0.14	0.17	0.17	7
GSECL_RSP SOLAR	100	22	22	22	00:00	22	00:00	0.06	0.53	0.53	22
KAWAS SOLAR	56	0	0	53	12:02	0	00:09	0.34	0.35	0.35	15
KPIG_GSECLS_KPS2_S	200	-1	-1	115	14:03	-1	00:32	1.05	1.03	1.03	43
MAHINDRA SOLAR (BADWAR)	250	-1	-1	192	13:37	8	06:02	0	0.99	0.99	41
MASAYA SOLAR	300	-1	-1	294	11:59	5	05:59	2.02	2.19	2.19	91
NTPCREL_PSS1_KPS3_S	1,095	-2	-2	324	08:10	-2	06:02	-	2.67	2.67	111
NTPCREL_PSS2_KPS2_S	1,555	0	0	0	-	0	-	9.11	9.26	9.26	386
SAELP4_GSECLS_KPS2_S	400	-1	-1	284	09:21	-1	05:45	2.34	2.66	2.66	111
SAELP5_GSECLS_KPS2_S	400	0	0	0	-	0	-	2.35	0	0	0
SGEL_RSP_S	100	0	0	94	14:07	0	00:02	0.54	0.52	0.52	22
SHERISHA RAIPUR	50	0	0	43	12:31	0	00:00	0.29	0.25	0.25	10
SOLAPUR SOLAR PV PROJECT	23	0	0	0	00:00	0	00:00	0.15	0.15	0.15	6
TPREL_RSP SOLAR	100	0	0	100	14:10	0	09:22	0.53	0.55	0.55	23
TPSOURY_BRVD_NMCH_S	160	0	-2	160	12:04	3	06:00	1.38	1.53	1.53	64
TPSOURY_KWAI_NMCH_S	170	-2	-2	150	11:46	3	06:00	1.35	1.43	1.43	60
AHEJ5L_PSS8_KPS3_HW	65	31	17	43	04:35	1	01:50	1.44	0.34	0.34	14
RSRPL_GHTND_KLM_W	138.6	0	0	0	-	0	-	0.64	0.8	0.8	33
ACL_PSS4_KPS1_W	156	86	38	110	04:50	10	12:08	1.3	1.05	1.05	44
ADANI WIND ENERGY KUTCHH FOUR LTD	300	77	-2	189	09:16	59	14:57	2.84	2	2	83
AGE24L_PSS4_KPS1_W	100	67	24	87	04:50	3	11:59	0.63	0.81	0.81	34
AGE25BL_PSS9_KPS1_HW	130	0	0	0	-	0	-	0.38	0.79	0.79	33
AGE25CL_PSS11_KPS3_W	185	0	0	0	00:00	0	00:00	1.22	0	0	0
AGE25CL_PSS14_KPS3_W	65	0	0	0	00:00	0	00:00	0.17	0	0	0
AGE26AL_PSS12_KPS3_W	137.5	0	0	0	00:00	0	00:00	0.65	0	0	0
AGE26BL_PSS10_KPS1_W	156	80	12	83	19:41	1	14:18	1.16	0.79	0.79	33
AHEJ5L_PSS4_KPS1_W	60	41	16	53	04:46	3	11:16	0.38	0.51	0.51	21
AHEJ5L_PSS5_KPS1_HW	202.8	0	0	0	-	0	-	0.94	-	0	0
ALFANAR WIND (NANAVALKA)	300	125	-2	216	08:24	34	14:26	2.05	2.21	2.21	92
APRAAVA ENERGY PRIVATE LIMITED (AEPL)	252	75	0	196	10:06	21	06:20	1.68	1.62	1.62	68

APSEZ_PSS4_KPS1_W	52	25	4	36	04:45	0	12:12	0.43	0.29	0.29	12
ARE3L_PSS8_KPS3_HW	41.6	21	9	27	04:31	1	15:29	0.33	0.22	0.22	9
ARE41L_PSS13_KPS1_W	124.8	48	8	66	04:11	2	14:14	-	0.6	0.6	25
ARE41L_PSS3_KPS1_W	250	140	25	151	19:52	7	12:26	1.73	1.48	1.48	62
ARE41L_PSS4_KPS1_W	50	30	19	39	04:10	1	12:18	0.42	0.42	0.42	18
ARE41L_PSS8_KPS3_W	125	59	34	86	04:39	6	14:07	2.97	0.67	0.67	28
ARE48L_SRPL_PSS9_KPS1_W	119.6	0	0	0	00:00	0	00:00	0	0	0	0
ARE55L_PSS3_KPS1_HW	25	0	0	0	-	0	-	0.17	1.07	1.07	45
ASEJ6PL_PSS8_KPS3_HW	62.4	0	0	0	00:00	0	00:00	1.3	0	0	0
ASIPL WIND (BARANDA)	170.1	0	0	0	00:00	0	00:00	0	0	0	0
AWEK1L WIND (RATADIYA)	425	219	-3	391	08:40	67	14:27	3.21	4.12	4.12	172
AWEKFL WIND (RATADIYA)	130	42	42	42	00:00	42	00:00	1.02	1	1	42
AWEMP1PL_PTNGR_IDR_W	324.4	147	141	222	16:14	-1	10:14	1.79	2.03	2.03	85
AYANARP4_ZURA_BHJ_S	92.4	0	-1	97	13:57	-1	06:04	0.83	0.74	0.74	31
BLUELEAF_CP_PCHR_HW	115.5	48	0	110	06:08	0	01:48	0.97	0.62	0.62	26
CGERP_MORJAR_BHJ2_HW	29.7	0	0	0	00:00	0	00:00	-	0	0	0
CPTTNPL WIND (DAYAPAR)	126	0	0	0	00:00	0	00:00	0.97	0	0	0
GIWEL-II WIND (VADVA)	250	68	-2	171	09:01	33	14:35	1.21	1.56	1.56	65
GIWEL-III WIND (NARANPAR)	300	66	-1	132	18:04	16	13:09	1.4	1.33	1.33	55
IGESL_DAYAPAR_BHUJ_W	250	91	91	91	00:00	91	00:00	0.46	2.18	2.18	91
NETRA_KOTDA_BHUJ_W	206.5	52	-1	138	09:00	-1	15:31	0.9	0.85	0.85	35
NTPC_REL_DYPR_BHUJ_W	146	0	0	0	00:00	0	00:00	0.2	0	0	0
OEPL WIND (OSTRO KUTCH)	50	16	0	35	06:53	5	04:47	0.34	0.38	0.38	16
OKWPL WIND (OSTRO KUTCH)	250	150	150	150	00:00	150	00:00	1.65	3.61	3.61	150
POWERICA WIND	50.6	40	0	71	16:05	9	00:57	0.43	0.81	0.81	34
RENEW AP2 WIND (GHADSISA)	300	81	0	191	09:09	91	05:54	1.83	2.12	2.12	88
RENEW WIND (BHUVAD)	230.1	95	-2	202	05:50	28	13:20	1.39	1.97	1.97	82
RGMHP1_PATODA_KLM_W	135.3	20	0	128	06:23	0	10:33	0.93	0.9	0.9	38
RGMHS1_TLJPR_SLPR_HW	161.7	0	0	0	-	0	-	1.11	1.18	1.18	49
SAUPL_HJRTPR_RJGR_W	100	0	0	0	00:00	0	00:00	0.57	0	0	0
SITAC WIND	300	134	1	251	08:48	67	12:24	2.41	2.64	2.64	110
SRIJAN WIND	148.5	78	-1	149	09:11	43	15:51	1.03	1.73	1.73	72
TEQGREEN_WASI_KLM_W	70.2	0	0	22	12:09	0	05:58	0.49	0.16	0.16	7
TORRENT SOLARGEN LIMITED	115	19	0	36	17:04	0	15:59	0.37	0.16	0.16	7
TOTAL	23,173.28	-	-					135.35	136.97	136.97	5,711

RENEWABLE_BESS

स्टेशन/ Station/Constituents	स्थापित क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
ARE37L_PSS5_KPS1_B	160	73	-1	134	23:59	-198	14:39	0.13	-0.05	-0.05	-2
ARE43L_PSS10_KPS3_B	360	36	-1	275	00:00	-372	15:03	0.19	-0.27	-0.27	-11
SUB-TOTAL	520	109	-2	-	-	-	-	0.32	-0.32	-0.32	-13
TOTAL	520	-	-					0.32	-0.32	-0.32	-13

REGIONAL GENERATION SUMMARY

	THERMAL GEN MU	GAS GEN MU	SOLAR GEN MU	WIND GEN MU	HYDRO GEN MU	NUCLEAR GEN MU	OTHER GEN MU	TOTAL GEN MU	SCHEDULE MU
ISGS	436.95	0.91	-	-	5.7	59.81	-	503.37	506.93
IPP	433.79	0.05	-	-	-	-	-	433.84	433.98
Constituents	660.1	22.4	123.6	78.1	26.6	-	2.3	913.1	895.7
Renewables	-	-	91.21	45.76	-	-	-	136.65	135.67
Region	1,530.84	23.36	214.81	123.86	32.3	59.81	2.3	1,986.96	1,972.28

4(A) अंतर क्षेत्रीय वनिमिय/INTER-REGIONAL EXCHANGES (Import=(+ve) /Export =(-ve))

SL.No.	Element	20:00	03:00	अधिकतम पस्पर वनिमिय/Maximum Interchange (MW)		आयात/Import in MU	नरि्यात/Export in MU	शुद्ध वनिमिय/NET
		(MW)	MW	आयात/Import (MW)	नरि्यात/Export (MW)			
	EAST REGION WEST REGION / /Import/Export between EAST REGION and WEST REGION							
1	220KV-KORBA-BUDIPADAR	-8	-8	34	-141	0.05	-1.14	-1.09
2	220KV-RAIGARH-BUDIPADAR	50	31	87	-159	0.38	-0.85	-0.47
3	400KV-JAGDALPUR-JEYPORE	-	-	-	-	-	-1.02	-1.02
4	400KV-RAIGARH-JHARSUGUDA	182	191	384	-461	1.16	-0.65	0.51
5	400KV-SIPAT-RANCHI	-	-	-	-	0	-7.18	-7.18
6	765KV-DHARJAYGARH-JHARSUGUDA	429	51	483	-1,160	0	-5.04	-5.04
7	765KV-DHARJAYGARH-RANCHI	-870	-1,073	-	-2,624	0	-33.77	-33.77
8	765KV-RAIPUR-PS (DURG)-JHARSUGUDA	533	390	573	-230	7.49	0	7.49
	Sub-Total EAST REGION	316	-418	1,561	-4,775	9.08	-49.65	-40.57
	NORTH REGION WEST REGION / /Import/Export between NORTH REGION and WEST REGION							
1	132KV-RAJGHAT-LALITPUR	0	0	-	0	0	0	0
2	220KV-BHANPURA-MODAK	-48	-39	-	-74	0	-1.06	-1.06
3	220KV-BHANPURA-RANPUR	-30	-30	-	-30	0	-1.88	-1.88
4	220KV-MALANPUR-AURIYA	0	-7	24	-24	0.08	-0.04	0.04
5	220KV-MEHGAON-AURIYA	39	6	44	-10	0.46	-0.01	0.45
6	400KV-KANSARI-KANKROLI	-9	60	153	-85	1.27	-0.25	1.02
7	400KV-KANSARI-KANKROLI 2(BYPASS AT BHINMAL)	-6	41	105	-59	0.87	-0.18	0.69
8	400KV-NEEMUCH-CHITTORGARH	-168	-261	553	-417	3.67	-3.23	0.44

NORTH REGION WEST REGION / /Import/Export between NORTH REGION and WEST REGION								
9	400KV-SUJALPUR-RAPP	89	41	837	-172	7.39	-0.48	6.91
10	400KV-VINDHYACHAL PS-RIHAND(III)	-1	-1	-	-2	0	-0.02	-0.02
11	765KV-BANASKANTHA-CHITTORGARH	101	500	784	-754	4.76	-1.95	2.81
12	765KV-GWALIOR-AGRA	-945	-1,512	-	-1,949	0	-25.77	-25.77
13	765KV-GWALIOR-JAIPUR	-1,146	-1,180	1,337	-1,622	6.98	-17.49	-10.51
14	765KV-GWALIOR-ORAI	575	564	710	0	9.47	0	9.47
15	765KV-JABALPUR-ORAI	-622	-854	98	-1,054	0	-24.79	-24.79
16	765KV-SATNA-ORAI	-864	-918	-	-997	0	-17.23	-17.23
17	765KV-VINDHYACHAL(PS)-VARANASI	-2,309	-2,574	-	-3,108	0	-60.36	-60.36
18	HVDC 500KV VINDHYACHAL B/B	93	93	93	-	2.43	0	2.43
19	HVDC500KV-MUNDRA-MOHINDARGARH	-1,447	-1,448	-	-1,455	0	-36.35	-36.35
20	HVDC800KV-CHAMPA-KURUKSHETRA	-4,029	-2,012	-	-4,056	0	-73.53	-73.53
Sub-Total NORTH REGION		-10,727	-9,531	4,738	-15,868	37.38	-264.62	-227.24
SOUTH REGION WEST REGION / /Import/Export between SOUTH REGION and WEST REGION								
1	220KV-KOLHAPUR-CHIKKODI-II	-	-	-	-	-	-	0
2	220KV-PONDA-AMBEWADI	2	2	2	-	0.04	0	0.04
3	220KV-TALANGADE(MS)-CHIKKODI-II	-	-	-	-	-	-	0
4	220KV-XELDEM-AMBEWADI	100	103	-	112	2.31	0	2.31
5	400KV-KOLHAPUR GIS-NARENDRA KUDGI	1,450	1,282	1,827	-	29.04	0	29.04
6	765KV-SOLAPUR-RAICHUR	839	598	1,599	-1,058	9.29	-3.63	5.66
7	765KV-WARDHA-NIZAMABAD	-560	-861	100	-2,225	0.01	-27.31	-27.3
8	765KV-WARORA-PG-WARANGAL	-723	-998	-	-2,310	0	-29.31	-29.31
9	HVDC205KV-BHADRAWATI-RAMAGUNDAM	-307	-306	-	-308	0	-7.2	-7.2
10	HVDC400KV-BARSUR-L.SILERU	-	-	-	-	-	-	0
11	HVDC800KV-RAIGARH-GIS-HVDC-PUGALUR	-4,839	-2,997	-	-5,007	0	-76.26	-76.26
Sub-Total SOUTH REGION		-4,038	-3,177	3,528	-10,796	40.69	-143.71	-103.02
TOTAL IR EXCHANGE		-14,449	-13,126	9,827	-31,439	87.15	-457.98	-370.83

4(B) Inter Regional Schedule & Actual Exchange (Import=(+ve) /Export =(-ve)) in MU

	ISGS+GNA+URS Schedule	TGNA BILT Schedule	GDAM Schedule	DAM Schedule	HPDAM Schedule	RTM Schedule	Total IR Schedule	Total IR Actual	NET IR UI
WR-ER	28.67	-21.41		-41.19		0	-57.72	-40.57	17.15
WR-NR	-232.86	-66.91		111.25		0	-167.02	-227.24	-60.22
WR-SR	-62.87	-6.65		-75.54		0	-153.26	-103.02	50.24
Total	-267.06	-94.97	0	-5.48	0	0	-378	-370.83	7.17

5.Frequency Profile

RANGE(Hz)	< 48.8	< 49	< 49.2	< 49.5	< 49.7	< 49.9	>= 49.9 - <= 50.05	> 50.05
%	.00	.00	.00	.70	7.40	23.80	56.50	19.70

Percentage of Time Frequency Remained outside IEGC Band	43.5
No. of hours frequency outside IEGC Band	10.44

अधिकतम /Maximum		न्यूनतम/Minimum		औसत/Average	Freq Variation	Standard	Freq. in 15 mnt blk	
Frequency	Time	Frequency	Time	Frequency	Index	Deviation	Max.	Min.
50.23	08:02:20	49.46	22:16:50	49.96	0.205	0.136	50.18	49.54

6.वोल्टेज प्रोफाइल/Voltage Profile: 400kV

	अधिकतम/Maximum		न्यूनतम/Minimum		वभिवांतर/Voltage (in %)			Hours Volatge Outside IEGC Range(VDI)
STATION	VOLTAGE	TIME	VOLTAGE	TIME	>= 4000	IEGC Band (A)	> 420	(100-A)*24/100
AMRELI - 400KV	433.89	04:22	412.72	14:19	0	14.6	85.4	20.5
ASOJ - 400KV	423.2	02:59	403.86	14:21	0	87	13	3.1
BHILAI - 400KV	413.32	08:03	403.98	23:19	0	100	0	0
BHOPAL - 400KV	421.22	08:00	403.79	23:22	0	98.8	1.3	.3
BOISAR - 400KV	425.12	03:51	400.44	14:34	0	83.3	16.7	4
DEHGAM - 400KV	425.67	03:41	406.75	14:19	0	77.4	22.6	5.4
DHULE - 400KV	417.96	03:02	400.83	14:17	0	100	0	0
DAMOH - 400KV	417.42	07:59	396.69	23:36	0	100	0	0
GPEC - 400KV	427.65	04:48	400.79	14:21	0	79.4	20.6	4.9
GWALIOR - 400KV	413.65	08:03	391.28	23:21	0	100	0	0
HAZIRA - 400KV	400.9	00:00	400.9	00:00	0	100	0	0
INDORE - 400KV	415.83	07:59	400.51	23:21	0	100	0	0
ITARSI - 400KV	411.96	08:02	395.17	23:22	0	100	0	0
JETPUR - 400KV	425.6	03:03	403.91	09:17	0	83.6	16.4	3.9
KALA - 400KV	423.41	05:01	396.82	14:34	0	90.8	9.2	2.2
KALWA - 400KV	421.39	03:43	392.51	14:30	0	96.4	3.6	.9
KARAD - 400KV	424.81	17:06	394.96	09:52	0	85.1	14.9	3.6
KASOR - 400KV	425.16	03:41	404.21	14:21	0	80.3	19.7	4.7
KHANDWA - 400KV	415.19	08:02	401.75	23:22	0	100	0	0
MAGARWADA - 400KV	422.71	03:40	395.56	14:20	0	88.9	11.1	2.7
MAPUSA - 400KV	418.07	17:07	383.94	09:48	0	100	0	0
NAGDA - 400KV	418.02	05:01	402.58	23:21	0	100	0	0
NEW KOYNA - 400KV	434.57	17:08	406.86	10:26	0	27.3	72.7	17.4
PARLI - 400KV	421.82	18:05	388.92	10:02	0	99	1	.2
RAIPUR - 400KV	412.78	07:58	404.24	23:18	0	100	0	0
RAIGARH - 400KV	420.14	08:04	412.27	23:28	0	99.7	.3	.1

VAPI - 400KV	423.18	04:47	394.99	14:21	0	92.2	7.8	1.9
WARDHA - 400KV	418.35	13:05	409.41	19:39	0	100	0	0

6.1 Voltage Profile: 765kV

	/Maximum		/Minimum		/Voltage (in %)			Hours Voltage Outside IEGC Range(VDI)
STATION	VOLTAGE	TIME	VOLTAGE	TIME	< 728	IEGC Band (A)	> 800	(100-A)*24/100
BINA - 765KV	794.35	08:02	758.14	23:34	0	100	0	0
DURG - 765KV	779.42	00:00	770.07	14:03	0	100	0	0
GWALIOR - 765KV	799.23	08:04	752.43	23:21	0	100	0	0
INDORE - 765KV	784.95	03:02	761.48	14:17	0	100	0	0
KOTRA - 765KV	791.34	08:02	770.92	23:22	0	100	0	0
SASAN - 765KV	787.52	08:11	764.75	23:34	0	100	0	0
SATNA - 765KV	798.4	08:03	764.61	23:21	0	100	0	0
SEONI - 765KV	792	08:01	765.9	10:02	35.1	64.9	0	8.4
SIPAT - 765KV	777.51	08:51	760.7	23:17	0	100	0	0
TAMNAR - 765KV	781.47	00:00	770.59	23:22	0	100	0	0
VADODARA - 765KV	805.53	02:59	769.71	14:17	0	86.6	13.4	3.2
WARDHA - 765KV	789.5	08:02	762.26	23:37	0	100	0	0

7(A).Power Energy/Schedule Details

State	Off- Peak Hours (03:00)												
	T-GNA Bilateral (MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX HPDAM (MW)	IEX RTM (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXIL HPDAM (MW)	PXI RTM (MW)	HPX GDAM (MW)	HPX DAM (MW)	HPX HPDAM (MW)	HPX RTM (MW)
AMNSIL	0	-	323.58	-	12.56	-	0	-	0	-	-	-	-
BALCO	0	-	0	-	18.55	-	0	-	0	-	-	-	-
CHHATTISG ..	-488.24	-	395.04	-	-41.5	-	0	-	0	-	-	-	-
DNHDDPDCL	9.66	-	48.3	-	0	-	0	-	0	-	-	-	-
GOA	90.21	-	0	-	0	-	0	-	0	-	-	-	-
GUJARAT	325.35	-	728.98	-	687.28	-	0	-	0	-	-	-	-
MADHYA PRADESH	-4.3	-	-759.63	-	-371.9	-	0	-	0	-	-	-	-
MAHARASHT..	172.44	-	1,154.8	-	425.26	-	0	-	0	-	-	-	-
RIL JAMNAGAR	0	-	0	-	0	-	0	-	0	-	-	-	-
TOTAL	105.12	0	1,891.07	-	730.25	0	0	-	0	-	-	-	-

State	Peak Hours (20:00)												
	T-GNA Bilateral (MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX HPDAM (MW)	IEX RTM (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXIL HPDAM (MW)	PXI RTM (MW)	HPX GDAM (MW)	HPX DAM(MW)	HPX HPDAM (MW)	HPX RTM (MW)
AMNSIL	0	-	106.25	-	73.1	-	0	-	0	-	-	-	-
BALCO	0	-	0	-	54.34	-	0	-	0	-	-	-	-
CHHATTISG ..	212.04	-	-32.3	-	-122.9	-	0	-	0	-	-	-	-
DNHDDPDCL	9.66	-	48.3	-	33.51	-	0	-	0	-	-	-	-
GOA	90.21	-	20.23	-	0	-	0	-	0	-	-	-	-
GUJARAT	318.39	-	176.87	-	799.63	-	0	-	0	-	-	-	-
MADHYA PRADESH	-202.56	-	0.66	-	-306.5	-	0	-	0	-	-	-	-
MAHARASHT..	323.62	-	907.4	-	390.34	-	0	-	0	-	-	-	-
RIL JAMNAGAR	0	-	0	-	0	-	0	-	0	-	-	-	-
TOTAL	751.36	0	1,227.41	0	921.52	0	0	-	0	-	-	-	-

State	Day Energy (MU)						
	ISGS + GNA Schedule	T-GNA Bilateral (MW)	GDAM Schedule	DAM Schedule	HPDAM Schedule	RTM Schedule	Total (MU)
AMNSIL	6.18	0	2.08	3.77	-	0.84	12.88
BALCO	16.51	0	0	0	-	0.49	17
CHHATTISGARH	75.95	-3.7	-0.02	-5.09	-	-1.25	65.89
DNHDDPDCL	27.1	0.29	0	1.49	-	1.62	30.49
GOA	14.86	2.32	0.08	0.02	-	0.16	17.44
GUJARAT	136.84	9.35	1.32	13.85	-	4.65	166.01
MADHYA PRADESH	167.85	-1.83	-0.12	-3.48	-	-10.61	151.81
MAHARASHTRA	186.94	3.12	1.65	30.83	-	10.51	233.06
RIL JAMNAGAR	6.62	0	0	0	-	0	6.62
TOTAL	638.85	9.55	4.99	41.39	0	6.41	701.2

7(B).Power Energy/Schedule Details

State	ISGS + GNA Schedule		T-GNA Bilateral (MW)		IEX GDAM (MW)		PXIL GDAM(MW)		HPX GDAM(MW)		IEX DAM (MW)		PXIL DAM(MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
AMNSIL	424.99	66.65	0	0	120.74	0	0	0	0	0	327.94	48.3	0	0
BALCO	720.57	538.47	0	0	0	0	0	0	0	0	0	0	0	0
CHHATTISGARH	3,782.41	2,860.71	244.88	-488.24	0	-3.5	0	0	0	0	395.04	-1,080.3	0	0
DNHDDPDCL	1,186.92	980.53	15.45	8.69	0	0	0	0	0	0	77.27	48.3	0	0
GOA	774.67	505.2	122.57	76.69	27.84	0	0	0	0	0	30.41	-36	0	0
GUJARAT	7,424.12	3,324.84	689.44	9.14	173.57	0	0	0	0	0	1,018.05	173.3	0	0
MADHYA PRADESH	7,768.73	5,637.46	11.28	-304.79	99.08	-74.3	0	0	0	0	1,055.87	-1,024.9	0	0
MAHARASHTRA	9,056.07	6,977.98	323.62	-147.91	454.68	-26.32	0	0	0	0	2,326.14	672.89	0	0
RIL JAMNAGAR	-	-	-	-	-	-	-	-	-	-	-	-	-	-

State	HPX DAM(MW)		IEX HPDAM (MW)		PXIL HPDAM(MW)		HPX HPDAM(MW)		IEX RTM (MW)		PXIL RTM(MW)		HPX RTM(MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
AMNSIL	0	0	0	0	0	0	0	0	118.81	0	0	0	0	0
BALCO	0	0	0	0	0	0	0	0	176.57	0	0	0	0	0
CHHATTISGARH	0	0	0	0	0	0	0	0	529.02	-316.5	54.88	0	0	0
DNHDDPDCL	0	0	0	0	0	0	0	0	217.33	0	0	0	0	0
GOA	0	0	0	0	0	0	0	0	74.38	-35	0	0	0	0
GUJARAT	0	0	0	0	0	0	0	0	980.92	2.24	0	0	0	0
MADHYA PRADESH	0	0	0	0	0	0	0	0	522.38	-1,696.07	0	0	0	0
MAHARASHTRA	0	0	0	0	0	0	0	0	1,136.66	-108.94	109.76	0	4.83	0
RIL JAMNAGAR	-	-	-	-	-	-	-	-	-	-	-	-	-	-

8.Major Reservoir Particulars

RESERVOIR	DESIGNED			PRESENT		LAST YEAR		LAST DAY	MONTH	
	MDDL(Mts)	FRL(Mts)	Energy(MU)	Level(Mts)	Energy(MU)	Level(Mts)	Energy(MU)	Inflow(Mus)	"Prog.Inflow (Mus)"	"Prog.Usage (Mus)"
INDIRASAGAR	243.23	262.13	1,367	250.03	309.4	252.3	412.7	250.07	0	0
OMKARESHWAR	193.3	196.6	21.958	194.67	-	195.8	-	194.51	0	0
UKAI	82.296	105.156	770.67	96.15	288.3	96.83	316.477	96.24	0	0
KADANA	114.3	127.711	126.266	121.1	36.97	117.803	13.93	121.16	0	0
SSP	110.64	138.68	1,342.091	128.26	612.98	122.23	334.13	128.33	0	0
KOYNA	615.54	659.43	3,160	622.95	3,046.828	628.2	3,047.775	0	0	0
TATA BHIRA	590.1	607.1	582.4	594.45	117.28	594.92	132.19	594.55	0	0

9.Significant events (If any):

10.System Constraints (If any)

11. Weather Condition:

12. RE/Load Curtailment details

State	Load Curtailment			RE Curtailment				
	Energy	Maximum	At the time of maximum demand	Wind		Solar		Reason
	MU	MW	MW	Max MW	Energy(MU)	Max MW	Energy(MU)	
AMNSIL	0	0	0	0	0	0	0	
BALCO	0	0	0	0	0	0	0	
CHHATTISGARH	0.18	181	0	0	0	0	0	
DAMAN AND DIU	0	0	0	0	0	0	0	
GOA	0.06	30	0	0	0	0	0	
GUJARAT	0.11	84	0	903.996	2.45	2,104.532	6.98	To control under drawal.
MADHYA PRADESH	0	0	0	0	0	0	0	
MAHARASHTRA	0.136	112	0	0	0	0	0	
RIL JAMNAGAR	0	0	0	0	0	0	0	

Shift In Charge