GRID CONTROLLER OF INDIA (GRID-INDIA)
WESTERN REGIONAL LOAD DESPATCH CENTRE
DAILY OPERATION REPORT OF WESTERN REGION

Power Supply Position in Western Region For 03-Jun-2026

Date of Reporting:04-Jun-2026

1. Regional Availability/Demand:

Evening Peak (20:00) MW				Off-Peak (03:00) MW				/Day Energy(Net MU)	
मांग पूर्ति/ Demand Met	अभाव/Shortage	आवश्यकता/ Requirement	आवृत्ति/Freq (Hz)	मांग पूर्ति/ Demand Met	अभाव/Shortage	आवश्यकता/ Requirement	आवृत्ति/Freq (Hz)	मांग पूर्ति/Demand Met	अभाव/Shortage
70,903	0	70,903	50.09	66,291	0	66,291	50.05	1,690.3	0.97

2(A) /Load Details (/in state periphery) in MU:

राज्य/STATE	State's Control Area Generation (Net MU)							/Net SCH	/Drawal	/UI	Availability	Requirement	/ Shortage	/ Consump -tion
	तापीय/ THERMAL	जलीय/ HYDRO	गैस/ Gas	पवन/ WIND	सौर/ SOLAR	अन्य/ OTHERS	कुल/TOTAL	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)
BALCO	-	0	0	0	0	0	0	17.1	16.9	-0.2	16.9	16.9	0	16.9
CHHATTISGARH	50	0.2	0	0	4.1	1	55.3	69.2	68.2	-1	123.5	123.5	0	123.5
DNHDDPDCL	-	0	0	0	0	0	0	31.8	31.8	0	31.8	31.8	0	31.8
AMNSIL	6.7	0	0	0	0	0	6.7	13.8	13.8	0	20.5	20.5	0	20.5
GOA	0.4	0	0	0	0	0	0.4	16.5	16.3	-0.2	16.7	16.7	0	16.7
GUJARAT	192.5	1.9	20.3	47.1	83	0	344.8	179.7	172.4	-7.3	517.2	517.2	0.04	517.2
MADHYA PRADESH	86.4	10.9	0	13.5	11.6	1.6	124	168.8	168.8	0	292.8	292.8	0	292.8
MAHARASHTRA	334.8	14.7	9.9	23.9	35.2	0	418.5	246.4	246	-0.4	664.5	665.4	0.93	664.5
RIL JAMNAGAR	-	0	0	0	0	0	0	6.6	6.4	-0.2	6.4	6.4	0	6.4
Region	670.8	27.7	30.2	84.5	133.9	2.6	949.7	749.9	740.6	-9.3	1,690.3	1,691.2	0.97	1,690.3

2(B) / /State's Demand Met in MW and day energy forecast and deviation particulars

राज्य/State	Evening Peak (20:00) MW			Off-Peak (03:00) MW				/Day Energy(Net MU)	
	मांग पूर्ति/ Demand Met	अभाव/ Shortage	आवश्यकता/ Requirement at Evening peak	मांग पूर्ति/ Demand Met	अभाव/ Shortage	आवश्यकता/ Requirement at Off-Peak	AVG (MW)	पूर्वानुमान/ForeCast(MU)	विचलन/Deviation[Fore .. -Consumption] (MU)
BALCO	710	0	710	704	0	704	706	14	-2.9
CHHATTISGARH	5,423	0	5,423	5,218	0	5,218	5,151	131	7.5
DNHDDPDCL	1,316	0	1,316	1,291	0	1,291	1,325	31	-0.8
AMNSIL	927	0	927	883	0	883	854	19	-1.5
GOA	767	0	767	666	0	666	698	18	1.3
GUJARAT	21,644	0	21,644	19,766	0	19,766	21,546	487	-30.2
MADHYA PRADESH	11,791	0	11,791	11,626	0	11,626	12,176	285	-7.8
MAHARASHTRA	28,050	0	28,050	25,864	0	25,864	27,726	630	-34.5
RIL JAMNAGAR	275	0	275	273	0	273	267	6	-0.4
Region	70,903	0	70,903	66,291	0	66,291	70,449	1,621	-69.3

2(C) /State's Demand Met in MW (/maximum demand met and /Maximum requirement of the day details)

राज्य/State	Maximum Demand, corresponding shortage and requirement details for the day				ACE			
	अधिकतम मांग पूर्ति/Maximum Demand Met of the day	समय/Time	अभाव/Shortage at maximum demand	आवश्यकता/Requirement at the max demand met of the day	ACE_MAX	बजे/Time	ACE_MIN	बजे/Time
BALCO	710	21:00	0	710	-	-	-	-
CHHATTISGARH	5,810	23:30	0	5,810	444.66	10:06:00	-431.62	23:59:00
DNHDDPDCL	1,386	18:00	0	1,386	51.67	20:33:00	-87.21	00:00:00
AMNSIL	939	19:00	0	939	465.38	11:22:00	-253.62	07:27:00
GOA	785	22:45	0	785	59.75	18:31:00	-54.99	02:03:00
GUJARAT	24,777	16:00	0	24,777	2,170.04	12:23:00	-2,116.91	00:04:00
MADHYA PRADESH	13,241	15:45	0	13,248	720.45	22:51:00	-425.73	13:47:00
MAHARASHTRA	30,398	15:00	0	30,398	1,170.01	09:02:00	-1,406.94	21:02:00
RIL JAMNAGAR	275	21:00	0	275	-	-	-	-
WR	77,534	15:00	0	77,534	-	-	-	-

3(A) State Entities Generation:

CHHATTISGARH

स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
KORBA EAST EXT(DSPM)(2*250)	500	455	440	472	23:50	333	12:08	11.03	10.11	421
KORBA(W) CSETCL(4*210 + 1*500)	1,340	727	717	741	22:29	579.3	12:21	17.7	16.35	681
MARWA TPS(1*500 + 1*500)	1,000	957	865	990	06:36	610	13:15	21.79	20.71	863
OTHER CPP	50	0	0	0	-	0	-	2.84	2.84	118
TOTAL THERMAL	2,890	2,139	2,022	-	-	-	-	53.36	50.01	2,083
HASDEO BANGO(3*40)	120	1	1	81	01:02	0	10:57	0.12	0.12	5
KWB MINI MICRO(2*0.85)	1.7	0	0	0	-	0	-	0.01	0.01	0
SMALL HYDRO	50	0	0	0	-	0	-	0.04	0.04	2
TOTAL HYDEL	171.7	1	1	-	-	-	-	0.17	0.17	7
WIND	0	0	0	0	-	0	-	0	0	0
SOLAR	842	0	0	566	12:03	0	06:00	4.14	4.14	173
BIO MASS	50	0	0	0	-	0	-	0	0	0
TOTAL BIO MASS	50	0	0	-	-	-	-	0	0	0
TOTAL CHHATTISGARH	3,953.7	-	-	-	-	-	-	57.67	54.32	2,263

GUJARAT

स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
AECO(1*120 + 2*121)	362	355	358	365	06:11	229	13:43	7.7	7	292
ALTPS(2*125)	250	106	121	131	08:31	95	17:59	3.11	2.59	108
APL MUNDRA(4*330 + 2*660 + 3*660)	4,620	4,214	4,230	4,241	01:46	2,616	10:33	91.78	84.7	3,529
BLTPS(2*250)	500	322	320	327	05:25	258	12:08	7.89	6.67	278
GANDHINAGAR(GTPS)(3*210)	630	355	410	418	02:29	236	13:42	7.47	6.76	282
KLTPS(2*75)	150	65	64	65	01:41	57	12:24	1.54	1.36	57
OTHER CPP	1,000	0	0	0	-	0	-	6.99	5.74	239
SLPP(4*125)	500	307	384	397	05:51	240	15:00	8.98	7.73	322
STPS(2*250)	500	363	0	477	23:09	0	15:24	2.41	1.7	71
UKAI(2*200 + 1*210 + 1*500)	1,110	351	364	388	03:35	244	10:42	7.74	6.8	283
VADINAR(2*600)	1,200	934	1,133	1,159	22:11	580	08:06	21.46	20.1	838
WANAKBORI(7*210 + 1*800)	2,270	1,913	1,579	1,977	20:45	1,149	12:05	35.23	32.35	1,348
TOTAL THERMAL	13,092	9,285	8,963	-	-	-	-	202.3	183.5	7,647
DGBP(1*107 + 1*112 + 1*376)	594	7	0	67	22:43	0	00:00	3.12	2.99	125
ESSAR POWER GAS(3*110 + 1*185)	515	0	0	0	-	0	-	0	0	0
GIPCL STG(3*32 + 49)	145	0	0	0	00:00	0	00:00	0	0	0
GIPCL STG 2(111 + 54)	165	0	0	0	00:00	0	00:00	0	0	0
GPEC(3*138 +241)	654	0	0	0	-	0	-	0	0	0
GPPC(2*351.43)	702	0	0	0	00:00	0	00:00	0	0	0
GSEC(3*52)	156	322	0	326	21:57	0	00:00	1.81	1.73	72
SUGEN 1(3*382.5)	1,147.5	811	743	1,002	20:16	0	05:41	10.77	10.45	435
UNOSUGEN(1*382.5)	382.5	277	0	362	00:00	0	16:28	2.56	2.47	103
UTRAN STG II(1*229 + 1*146(ST))	375	0	0	194	18:56	0	00:00	2.7	2.63	110
TOTAL GAS	4,836	1,417	743	-	-	-	-	20.96	20.27	845
KADANA(4*60)	240	0	53	53	03:00	0	04:07	0.21	0.21	9
LBC PANAM HYDRO	5	0	0	0	-	0	-	0.08	0.08	3
PVT HYDRO	20.6	0	0	0	-	0	-	0.13	0.13	5
UKAI HYDRO(4*75)	300	65	65	65	00:00	65	00:00	1.68	1.64	68
TOTAL HYDEL	565.6	65	118	-	-	-	-	2.1	2.06	85
WIND	8,836	3,503	964	4,450	18:36	667	09:05	47.13	47.13	1,964
SOLAR	15,238	0	0	10,492	11:55	0	06:04	82.97	82.97	3,457
BIO MASS	51.65	0	0	0	-	0	-	0	0	0
TOTAL GUJARAT	42,619.25	-	-	-	-	-	-	355.46	335.93	13,998

MADHYA PRADESH

स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
AMARKANTAK(1*210)	210	0	0	0	00:00	0	00:00	0.29	0.29	12
BLA IPP(2*45)	90	84	83	84	20:00	46	11:06	1.8	1.61	67
JP BINA(2*250)	500	273	233	443	23:03	144	08:59	6.05	5.48	228
SANJAY GANDHI TPS(4*210 + 1*500)	1,340	964	967	981	00:26	812	10:23	24.38	22.43	935
SATPURA IV(2*250)	500	471	472	478	02:34	259	10:52	11.72	10.76	448
SINGAJI(2*600 + 2*660)	2,520	2,271	2,284	2,344	15:09	1,306	13:19	52.08	49.27	2,053
TOTAL THERMAL	5,160	4,063	4,039	-	-	-	-	96.32	89.84	3,743
BANASAGAR TONS(3*105)	315	104	265	292	06:51	0	14:36	3.71	3.67	153
BARGI(2*45)	90	33	33	33	00:35	33	07:27	0.79	0.78	33
BIRSINGHPUR	20	0	0	0	-	0	-	0.02	0.02	1
BSGR(DEVLONE)(3*20)	60	0	0	0	00:00	0	00:00	0	0	0
BSGR(SILPARA)(2*15)	30	15	0	24	23:37	0	08:18	0.49	0.49	20
INDIRASAGAR(8*125)	1,000	213	319	507	00:05	0	09:57	3.17	3.15	131
JHINNA(2*10)	20	0	16	16	03:00	0	14:31	0.23	0.23	10
MADIKHEADA(3*20)	60	60	60	60	00:00	60	00:00	0	0	0
MP CHAMBAL	386	0	0	0	-	0	-	0	0	0
OMKARESHWAR(8*65)	520	321	189	344	21:21	0	00:00	2.57	2.56	107
PENCH(2*80)	160	0	0	0	-	0	-	0	0	0
RAJGHAT HYDRO(3*15)	45	0	0	0	00:00	0	00:00	0	0	0
TOTAL HYDEL	2,706	746	882	-	-	-	-	10.98	10.9	455
WIND	2,670	490	681	796	04:00	38	11:22	13.49	13.49	562
SOLAR	2,370	0	0	1,619	12:26	0	06:00	11.61	11.61	484
BIO + SMALL HYDRO	100	0	0	0	-	0	-	1.58	1.58	66
TOTAL MADHYA PRADESH	13,006	-	-	-	-	-	-	133.98	127.42	5,310

MAHARASHTRA

स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
APML TIRODA(5*660)	3,300	3,118	3,110	3,143	02:23	1,708	09:57	69.1	65.26	2,719
BHUSAWAL(1*210 + 2*500+1*660)	1,870	1,018	1,689	1,708	01:47	671	13:21	31.57	29.98	1,249
CHANDRAPUR(2*210 + 5*500)	2,920	1,615	1,591	1,826	01:19	993	17:21	38.09	35.58	1,483
DAHANU(2*250)	500	442	501	507	22:22	280	15:26	10.05	9.03	376
IEPL(1*270)	270	269	264	288	16:49	148	14:00	5.69	4.99	208
JAIGAD(4*300)	1,200	905	987	1,022	00:13	730	15:55	23.45	21.57	899
JPL DHULE (SHIRPUR)(2*150)	300	273	274	282	01:45	178	11:55	6.07	5.65	235
KHAPARKHEDA(4*210 + 1*500)	1,340	887	1,013	1,043	00:51	721	11:52	23.74	21.83	910
KORADI(1*210 + 3*660)	4,170	1,065	1,006	1,156	22:08	720	12:00	24.63	23.43	976
NASIK(3*210)	630	268	284	290	20:29	213	10:18	6.71	6.25	260
OTHER CPP	3,305	0	0	0	-	0	-	38.41	38.41	1,600
PARAS(2*250)	500	412	420	442	01:21	240	10:48	9.96	9.19	383
PARLI(3*250)	750	631	650	671	00:22	377	09:49	15.06	13.62	568
RATTAN INDIA (AMARAVATI)(5*270)	1,350	1,225	1,225	1,260	01:29	738	11:58	31.15	28.81	1,200
SWPGL(4*135)	540	432	329	441	18:50	266	15:25	10.21	9.1	379
TROMBAY(250+1*500)	750	639	649	673	01:26	374	08:24	0	0	0
VIPL(2*300)	600	526	541	557	10:32	322	11:34	13.12	12.1	504
TOTAL THERMAL	24,295	13,725	14,533	-	-	-	-	357.01	334.8	13,949
TROMBAY_GAS(1*120+1*60)	180	163	162	173	06:33	103	09:30	3.44	3.35	140
URAN(4*108 + 2*120)	672	269	278	282	08:47	260	15:10	6.76	6.58	274
TOTAL GAS	852	432	440	-	-	-	-	10.2	9.93	414
BHIRA(6*25)	150	86	90	153	00:17	3	15:22	0	0	0
BHIRA PSS	150	161	159	163	06:20	-25	06:32	0	0	0
BHIRA TR(2*40)	80	0	0	0	-	0	-	0.36	0.35	15
BHIVPURI(3*24 + 2*1.5)	75	47	47	48	15:31	5	09:02	0	0	0
GHATGHAR(2*125)	250	0	122	123	21:19	-154	13:04	0.92	0.9	38
HYDRO VTRNA(1*60)	60	0	0	0	00:00	0	00:00	0	0	0
HYDROSMLHY_PTN	350	0	0	0	-	0	-	4.14	4.05	169
KHOPOLI(3*24)	72	24	22	24	20:00	4	16:07	0	0	0
KOYNA I AND II(4*(65+5) + 4*(75+5))	600	40	41	544	00:37	38	11:04	2.78	2.74	114
KOYNA III(4*80)	320	0	78	235	01:39	0	03:02	1.07	1.06	44
KOYNA ST-IV(4*250)	1,000	0	0	198	22:58	0	16:32	0.2	0.2	8
TILLARI(1*66)	66	0	0	0	00:00	0	00:00	0	0	0
OTHER HYDRO	122	0	0	0	-	0	-	5.36	5.36	223
TOTAL HYDEL	3,295	358	559	-	-	-	-	14.83	14.66	611
WIND	5,321	1,043	717	1,240	23:14	239	12:36	23.88	23.88	995
SOLAR	6,028	0	0	4,719	12:42	0	06:00	35.19	35.19	1,466
TOTAL MAHARASHTRA	39,791	-	-	-	-	-	-	441.11	418.46	17,435

3(B) Regional Entities Generation

ISGS

स्टेशन/ Station/Constituents	स्थापित क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
GADARWARA(2*800)	1,600	1,464	1,499	1,537	00:02	762	07:42	28.57	30.35	28.43	1,185
GANDHAR(3*144.3 + 1*224.49)	657	237	0	394	22:11	0	12:22	2.56	2.33	2.21	92
KAPS(2*220)	440	391	391	391	00:00	391	00:00	9.48	10.55	9.53	397
KAPS3&4(2*700)	1,400	576	592	596	02:27	571	15:29	27.74	30.43	27.85	1,160
KAWAS(4*106 + 2*116.1)	656.2	362	201	610	22:06	0	11:58	2.63	4.28	4.14	173
KHARGONE(2*660)	1,320	1,185	1,199	1,274	01:02	654	08:03	23.41	24.91	23.6	983
KSTPS1&2(3*200 + 3*500)	2,100	1,331	1,318	1,377	06:19	739	09:55	32.7	34.57	31.76	1,323
KSTPS3(1*500)	500	481	480	487	00:31	270	10:02	10.15	10.68	9.93	414
LARA(2*800)	1,600	1,444	1,483	1,526	02:18	806	10:05	32.73	34.49	32.45	1,352
MOUDA I(2*500)	1,000	880	915	970	00:16	465	10:04	18.63	19.39	17.57	732
MOUDA II(2*660)	1,320	1,162	1,140	1,232	00:05	588	15:04	24.28	25.46	22.6	942
NSPCL(2*250)	500	428	421	475	00:04	236	09:58	9.51	10.22	9.31	388
RGPPL(2*320 + 4*331.75)	1,967	804	0	1,314	22:31	0	07:13	6.74	7.32	7.08	295
SASAN(6*660)	3,960	3,546	3,753	3,778	00:01	2,961	10:43	85.26	90.96	85.47	3,561
SIPAT I(3*660)	1,980	1,842	1,844	1,946	00:08	966	11:01	40.25	42.49	39.85	1,660
SIPAT II(2*500)	1,000	940	934	971	01:44	522	13:02	20.66	21.8	20.51	855
SOLAPUR STPS(2*660)	1,320	655	1,187	1,278	00:20	636	17:59	21.24	23.05	21.43	893
SSP(RBPH+CHPH)(6*200 + 5*50)	1,450	579	389	1,010	00:05	0	14:09	6.04	6.63	6.57	274
TARAPUR I(2*160)	320	148	153	156	06:49	109	12:46	3.84	3.81	3.4	142
TARAPUR II(2*540)	1,080	789	792	807	11:55	758	11:21	18.72	20.96	18.7	779
VSTPS I(6*210)	1,260	913	936	944	06:49	475	12:44	19.96	22.25	19.61	817
VSTPS II(2*500)	1,000	863	893	930	06:44	472	12:44	19.24	20.36	18.78	783
VSTPS III(2*500)	1,000	903	932	957	15:24	481	12:44	19.63	20.52	19.47	811
VSTPS IV(2*500)	1,000	914	907	963	00:29	492	12:58	19.73	20.9	19.52	813
VSTPS V(1*500)	500	454	461	485	00:32	236	08:46	9.78	10.3	9.71	405
SUB-TOTAL	30,930.2	23,291	22,820	-	-	-	-	513.48	549.01	509.48	21,229
TOTAL	30,930.2	-	-					513.48	549.01	509.48	21,229

IPP/JV

स्टेशन/ Station/Constituents	स्थापित क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
ACBIL(2*135 + 2*50 + 2*30 + 1*63)	493	277	267	298	06:29	247	10:48	6.82	7.85	6.65	277
ADANI RAIPUR(2*685)	1,370	1,226	1,186	1,248	21:35	643	10:43	25.68	28.17	25.36	1,057
APL RAIGARH(1*600)	600	563	0	582	21:20	0	07:54	6.97	7.43	6.87	286
BALCO(4*300)	1,200	955	840	991	22:24	701	10:51	21.08	21.08	20.68	862
DB POWER(2*600)	1,200	1,138	1,126	1,159	10:15	718	11:52	26.36	27.84	26.35	1,098
DCPP(2*135)	270	101	99	201	00:00	65	10:24	2.6	2.97	2.46	103
DGEN(3*400)	1,200	359	0	378	23:52	0	16:46	1.87	1.9	1.82	76
DHARIWAL CTU(2*300)	600	549	558	566	01:29	286	10:26	11.81	12.82	11.9	496
GMR WARORA(2*300)	600	570	570	588	01:04	314	10:27	12.45	13.52	12.49	520
JHABUA POWER(1*600)	600	543	540	559	02:28	307	10:15	12.37	12.91	12.15	506
JP NIGRIE(2*660)	1,320	1,259	1,263	1,286	00:44	694	10:12	26.04	27.94	26.5	1,104
JPL STG-I(4*250)	1,000	843	843	884	22:00	519	10:32	18.11	20.72	18.45	769
JPL STG-II(4*600)	2,400	2,317	2,322	2,350	01:33	1,748	10:18	50.34	54.9	51.96	2,165
JSW MAHANADI(3*600)	1,800	1,697	1,362	1,722	18:30	1,362	00:00	37.8	40.7	37.95	1,581
LANCO(2*300)	600	541	543	568	06:09	310	10:49	12.46	13.83	12.57	524
MAHAN ENERGEN(2*600)	1,200	1,112	1,128	1,136	15:34	633	11:02	25.52	27.39	25.63	1,068
MB POWER(2*600)	1,200	1,177	1,191	1,196	00:58	481	11:28	25.3	26.75	25.23	1,051
MCCPL(1*300)	300	261	259	271	02:39	205	12:12	6.04	6.69	6.06	253
RKM POWER(4*360)	1,440	1,313	1,320	1,325	05:24	872	10:47	28.21	31.4	28.5	1,188
SARDA ENERGY & MINERALS LTD(2*300)	600	524	530	535	23:27	444	10:40	12.38	13.7	12.44	518
TPCL(5*800)	4,000	3,746	3,793	3,817	01:06	2,055	09:29	75	81.06	74.09	3,087
TRN ENERGY(2*300)	600	537	535	550	14:25	354	10:36	12.52	13.82	12.62	526
VEDANTA_LIMITED_CG (1*600)	600	0	0	0	07:29	0	10:07	0	0	0	0
SUB-TOTAL	25,193	21,608	20,275	-	-	-	-	457.73	495.39	458.73	19,115
TOTAL	25,193	-	-					457.73	495.39	458.73	19,115

RENEWABLE

स्टेशन/ Station/Constituents	स्थापित क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
AGE25BL_PSS9_KPS1_HS	100	0	0	83.14	09:00	0	00:00	0.19	0.55	0.55	23
AHEJ5L_PSS8_KPS3_HS	100	0	0	100	12:21	0	06:00	1.43	0.97	0.97	40
AYANARP4_DVSR_BHJ_HS	37.5	0	0	29	12:30	0	00:00	0.22	0.26	0.26	11
ACL_PSS3_KPS1_S	200	0	0	200	12:21	0	06:00	1.76	1.95	1.95	81
ACL_PSS4_KPS1_HS	125	0	0	125	12:50	0	06:00	1.54	0.98	0.98	41
AGE24AL_PSS3_KPS1_S	400	0	0	400	12:25	0	01:01	4.04	3.84	3.84	160
AGE24L_PSS10_KPS3_S	150	0	0	122	12:51	0	06:03	0.72	0.87	0.87	36
AGE24L_PSS5_KPS1_S	150	0	0	150	12:37	0	06:00	1.5	1.42	1.42	59
AGE25AL_PSS2_KPS1_S	500	0	0	306	07:59	0	00:00	1.34	2.15	2.15	90
AGE25BL_PSS2_KPS1_S	582.98	0	0	351	08:41	0	04:29	1.56	2.58	2.58	108
AGE25CL_PSS8_KPS3_S	350	0	0	350	13:26	0	05:57	4.68	3.22	3.22	134
AGE26AL_PSS3_KPS1_S	62.5	0	0	41	13:14	0	00:00	0.634	0.16	0.16	7
AGE26AL_PSS6_KPS1_S	750	0	0	574	12:46	0	00:00	7.34	4.17	4.17	174
AGE26BL_PSS10_KPS1_HS	142	0	0	142	12:59	0	03:37	0.05	2.12	2.12	88
AGE26BL_PSS10_KPS1_S	150	0	0	150	12:59	0	03:37	0.4	2.12	2.12	88
AGE26BL_PSS2_KPS1_S	167	0	0	103	07:59	0	00:00	0.45	0.77	0.77	32
AHEJ5L_PSS5_KPS1_S	570	0	0	561	12:54	0	06:00	5.29	4.32	4.32	180
APSEZ_PSS3_KPS1_S	200	0	0	200	12:25	0	00:00	1.76	1.89	1.89	79
ARE3L_PSS8_KPS3_HS	25	0	0	25	12:43	0	00:00	0.22	0.16	0.16	7
ARE45L_PSS5_KPS1_S	250	0	0	241	12:52	0	06:00	2.35	2.28	2.28	95
ARE55L_PSS3_KPS1_HS	25	0	0	23	11:47	0	00:00	0.22	0.23	0.23	10
ARE55L_PSS3_KPS1_S	162.5	0	0	21	17:21	0	00:00	1.63	0.15	0.15	6
ARE56L_PSS10_KPS1_S	500	0	0	500	12:44	0	06:02	2.7	3.66	3.66	153
ARE56L_PSS4_KPS1_S	225	0	0	234	13:00	0	00:00	2.29	2.2	2.2	92
ARE56L_PSS9_KPS1_S	400	0	0	235	12:58	0	06:00	1.07	2.23	2.23	93
ARE57L_PSS13_KPS1_S	850	0	0	704	09:00	0	00:00	2.28	4.28	4.28	178
AREH4L_PSS1_KPS1_SF	1,000	0	0	663	08:20	0	06:00	4.24	4.92	4.92	205
ARINSUN SOLAR (BARSAITADESH)	250	0	0	242	13:09	0	00:00	1.42	1.31	1.31	55
ASEJ6PL_PSS8_KPS3_HS	35	0	0	35	13:00	0	00:00	0.07	0.05	0.05	2
ASEJ6PL_PSS8_KPS3_S	50	0	0	50	12:44	0	00:00	0.45	0.32	0.32	13
ATHENA SOLAR	250	0	0	238	12:51	0	00:00	1.51	1.34	1.34	56
AVAADA_AGAR_RUMS_S	200	0	0	196	12:32	0	06:00	1.47	1.29	1.29	54
AYANARP4_DVSR_BHJ_HW	150	3	3	3	00:00	0	00:00	1.02	0.07	0.07	3
BEEMPOW_AGAR_RUMS_S	350	0	0	350	11:54	0	06:00	2.29	2.43	2.43	101
BLUELEAF_CP_PCHR_HS	128.7	0	0	67	12:50	0	06:10	0	0.04	0.04	2
CGERP_MORJAR_BHJ2_HS	30.8	0	0	0	00:00	0	00:00	0	0	0	0
ESPL_RSP SOLAR	200	0	0	198	13:37	0	06:00	1.49	1.48	1.48	62
GANDHAR SOLAR	20	0	0	20	12:44	0	00:00	0.12	0.1	0.1	4
GIPCL_PSS1_KPS2_S	600	0	0	546	12:31	0	06:09	5.12	4.92	4.92	205
GIPCL_RSP SOLAR	100	0	0	100	13:39	0	03:53	0.8	0.78	0.78	33
GSEC 2	100	0	0	54	12:57	0	09:13	0.43	0.17	0.17	7
GSECL_RSP SOLAR	100	0	0	0	03:00	0	08:09	0	0	0	0
KAWAS SOLAR	56	0	0	50	11:57	0	05:29	0.35	0.35	0.35	15
KPIG_GSECLS_KPS2_S	200	0	0	120	11:58	0	06:02	1.11	1.13	1.13	47
MAHINDRA SOLAR (BADWAR)	250	0	0	232	12:42	0	00:00	1.38	1.26	1.26	53
MASAYA SOLAR	300	0	0	294	12:56	0	06:00	2.06	2.12	2.12	88
NTPCREL_PSS1_KPS3_S	1,095	0	0	389	08:39	0	06:02	2.6	2.8	2.8	117
NTPCREL_PSS2_KPS2_S	1,555	0	0	1,015	12:50	0	00:00	9.97	9.84	9.84	410
SAELP4_GSECLS_KPS2_S	400	0	0	291	09:05	0	05:43	2.54	2.88	2.88	120
SAELP5_GSECLS_KPS2_S	400	0	0	400	12:50	0	00:00	2.55	2.3	2.3	96
SGEL_RSP_S	100	0	0	96	12:32	0	00:00	0.77	0.74	0.74	31
SHERISHA RAIPUR	50	0	0	46	11:57	0	00:00	0.29	0.23	0.23	10
SOLAPUR SOLAR PV PROJECT	23	0	0	20	12:00	0	00:00	0.14	0.13	0.13	5
TPREL_RSP SOLAR	100	0	0	100	12:25	0	06:00	0.78	0.76	0.76	32
TPSOURY_BRVD_NMCH_S	160	0	0	160	13:23	0	06:00	1.49	1.43	1.43	60
TPSOURY_KWAI_NMCH_S	170	0	0	170	13:09	0	06:00	1.54	1.53	1.53	64
AHEJ5L_PSS8_KPS3_HW	65	33	5	60	17:11	0	01:32	1.49	0.47	0.47	20
RSRPL_GHTND_KLM_W	138.6	78	24	87.6	19:50	2	12:19	0.78	0.74	0.74	31
ACL_PSS4_KPS1_W	156	84	3	142	17:14	3	08:43	1.15	1.23	1.23	51
ADANI WIND ENERGY KUTCHH FOUR LTD	300	104	3	170	15:23	0	02:30	3.1	2.06	2.06	86
AGE24L_PSS4_KPS1_W	100	70	0	99	16:18	2	08:49	0.72	0.86	0.86	36
AGE25BL_PSS9_KPS1_HW	130	84	3	110.16	17:15	1.37	02:00	0.44	1.03	1.03	43
AGE25CL_PSS11_KPS3_W	185	0	0	0	00:00	0	00:00	0	0	0	0
AGE25CL_PSS14_KPS3_W	65	0	0	0	00:00	0	00:00	0	0	0	0
AGE26AL_PSS12_KPS3_W	137.5	0	0	0	00:00	0	00:00	0	0	0	0
AGE26BL_PSS10_KPS1_W	156	107	3	134	16:51	1	02:54	1.03	1.11	1.11	46
AHEJ5L_PSS4_KPS1_W	60	42	1	60	15:28	1	08:40	0.44	0.53	0.53	22
AHEJ5L_PSS5_KPS1_HW	202.8	31	4	57	17:25	0	01:33	0.94	0.45	0.45	19
ALFANAR WIND (NANAVALKA)	300	127	67	195	23:58	29	06:03	2.65	2.34	2.34	98
APRAAVA ENERGY PRIVATE LIMITED (AEPL)	252	53	0	168	06:54	0	02:50	1.71	1.52	1.52	63

APSEZ_PSS4_KPS1_W	52	36	0	50	16:18	0	08:44	0.37	0.38	0.38	16
ARE3L_PSS8_KPS3_HW	41.6	22	2	37	16:31	0	07:23	0.29	0.29	0.29	12
ARE41L_PSS13_KPS1_W	124.8	65	0	106	16:43	2	07:30	0.96	0.83	0.83	35
ARE41L_PSS3_KPS1_W	250	159	1	232	16:39	7	01:51	1.7	1.92	1.92	80
ARE41L_PSS4_KPS1_W	50	39	0	50	17:02	0	01:12	0.43	0.47	0.47	20
ARE41L_PSS8_KPS3_W	125	69	3	112	16:29	1	07:24	2.97	0.89	0.89	37
ARE48L_SRPL_PSS9_KPS1_W	119.6	0	0	0	00:00	0	00:00	0	0	0	0
ARE55L_PSS3_KPS1_HW	25	3	5	7.5	14:59	0	13:06	0.13	0.07	0.07	3
ASEJ6PL_PSS8_KPS3_HW	62.4	0	0	0	00:00	0	00:00	0	0	0	0
ASIPL WIND (BARANDA)	170.1	0	0	0	00:00	0	00:00	0	0	0	0
AWEK1L WIND (RATADIYA)	425	242	100	315	15:49	49	06:00	4.21	4.08	4.08	170
AWEKFL WIND (RATADIYA)	130	16	8	42	15:50	0	00:00	1.2	0.8	0.8	33
AWEMP1PL_PTNGR_IDR_W	324.4	188	146	278	20:32	0	12:31	2.61	2.64	2.64	110
AYANARP4_ZURA_BHJ_S	92.4	0	0	92.4	14:33	0	00:11	0.83	0.82	0.82	34
BLUELEAF_CP_PCHR_HW	115.5	34	101	110	03:44	0	11:00	1.36	0.94	0.94	39
CGERP_MORJAR_BHJ2_HW	29.7	0	0	0	00:00	0	00:00	0	0	0	0
CPTTNPL WIND (DAYAPAR)	126	45	0	69	15:43	0	00:00	1.13	0.52	0.52	22
GIWEL-II WIND (VADVA)	250	94	1	143	08:39	0	06:52	1.58	1.61	1.61	67
GIWEL-III WIND (NARANPAR)	300	103	4	111	08:33	0	06:52	1.63	1.47	1.47	61
IGESL_DAYAPAR_BHUJ_W	250	16	28	145	07:25	0	01:50	1.53	2.18	2.18	91
NETRA_KOTDA_BHUJ_W	206.5	72	36	114	15:48	26	06:14	1.67	1.51	1.51	63
NTPC_REL_DYPR_BHUJ_W	146	52	0	72	15:44	0	01:00	0.99	0.61	0.61	25
OEPL WIND (OSTRO KUTCH)	50	23	0	30	20:06	0	02:49	0.44	0.33	0.33	14
OKWPL WIND (OSTRO KUTCH)	250	150	150	150	00:00	150	00:00	2.05	3.61	3.61	150
POWERICA WIND	50.6	41	0	50.6	18:08	0	02:41	0.44	0.73	0.73	30
RENEW AP2 WIND (GHADSISA)	300	137	0	173	17:12	0	07:12	2.27	2.03	2.03	85
RENEW WIND (BHUVAD)	230.1	131	1	149	17:16	0	06:12	1.93	1.7	1.7	71
RGMHP1_PATODA_KLM_W	135.3	106	28	130	22:11	0	10:50	0.85	0.86	0.86	36
RGMHS1_TLJPR_SLPR_HW	161.7	56	75	130.4	18:15	0	12:35	1.26	1.03	1.03	43
SAUPL_HJRTPR_RJGR_W	100	100	65	100	20:28	0	12:00	0.61	0.48	0.48	20
SITAC WIND	300	160	96	225	23:55	43	09:59	2.92	2.76	2.76	115
SRIJAN WIND	148.5	78	23	148.5	15:51	16	06:01	1.12	1.71	1.71	71
TEQGREEN_WASI_KLM_W	70.2	0	0	25	11:14	0	00:00	0.53	0.15	0.15	6
TORRENT SOLARGEN LIMITED	115	37	18	105	14:32	18	00:00	0.74	0.94	0.94	39
TOTAL	23,173.28	-	-					150.864	146.95	146.95	6,128

RENEWABLE_BESS

स्टेशन/ Station/Constituents	स्थापित क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
ARE37L_PSS5_KPS1_B	160	36	0	134	00:00	-207	10:41	0.13	0.14	0.14	6
ARE43L_PSS10_KPS3_B	360	26	0	303	22:57	-362	13:17	0.12	-0.21	-0.21	-9
SUB-TOTAL	520	62	0	-	-	-	-	0.25	-0.07	-0.07	-3
TOTAL	520	-	-					0.25	-0.07	-0.07	-3

REGIONAL GENERATION SUMMARY

	THERMAL GEN MU	GAS GEN MU	SOLAR GEN MU	WIND GEN MU	HYDRO GEN MU	NUCLEAR GEN MU	OTHER GEN MU	TOTAL GEN MU	SCHEDULE MU
ISGS	430	13.43	-	-	6.57	59.48	-	509.48	513.48
IPP	456.91	1.82	-	-	-	-	-	458.73	457.73
Constituents	670.8	30.2	133.9	84.5	27.7	-	2.6	949.7	940.4
Renewables	-	-	96.25	50.7	-	-	-	146.88	151.11
Region	1,557.71	45.45	230.15	135.2	34.27	59.48	2.6	2,064.79	2,062.72

4(A) अंतर क्षेत्रीय विनिमय/INTER-REGIONAL EXCHANGES (Import=(+ve) /Export =(-ve))

SL.No.	Element	20:00	03:00	अधिकतम पस्पर विनिमय/Maximum Interchange (MW)		आयात/Import in MU	नरि्यात/Export in MU	शुद्ध विनिमय/NET
		(MW)	MW	आयात/Import (MW)	नरि्यात/Export (MW)			
	EAST REGION WEST REGION / /Import/Export between EAST REGION and WEST REGION							
1	220KV-KORBA-BUDIPADAR	4	-16	31	-112	0.04	-0.9	-0.86
2	220KV-RAIGARH-BUDIPADAR	24	0	80	-135	0.31	-0.76	-0.45
3	400KV-JAGDALPUR-JEYPORE	-85	-44	91	188	-	-1.8	-1.8
4	400KV-RAIGARH-JHARSUGUDA	212	225	472	-377	1.95	-0.23	1.72
5	400KV-SIPAT-RANCHI	-	-	-	-	0	-7.9	-7.9
6	765KV-DHARJAYGARH-JHARSUGUDA	-117	-12	294	-940	0	-5.33	-5.33
7	765KV-DHARJAYGARH-RANCHI	-1,562	-1,368	-	-3,092	0	-39.22	-39.22
8	765KV-RAIPUR-PS (DURG)-JHARSUGUDA	333	380	592	-269	5.41	0	5.41
	Sub-Total EAST REGION	-1,191	-835	1,560	-4,737	7.71	-56.14	-48.43
	NORTH REGION WEST REGION / /Import/Export between NORTH REGION and WEST REGION							
1	132KV-RAJGHAT-LALITPUR	0	0	-	0	0	0	0
2	220KV-BHANPURA-MODAK	-34	-51	-	-69	0	-1.14	-1.14
3	220KV-BHANPURA-RANPUR	-30	-30	-	-30	0	-2.04	-2.04
4	220KV-MALANPUR-AURIYA	49	8	63	-28	0.37	-0.07	0.3
5	220KV-MEHGAON-AURIYA	0	25	76	0	0.42	0	0.42
6	400KV-KANSARI-KANKROLI	-67	36	183	-194	0.75	-0.76	-0.01
7	400KV-KANSARI-KANKROLI 2(BYPASS AT BHINMAL)	-47	24	126	-135	0.51	-0.53	-0.02
8	400KV-NEEMUCH-CHITTORGARH	-171	-318	401	-466	2.93	-3.6	-0.67

NORTH REGION WEST REGION / /Import/Export between NORTH REGION and WEST REGION								
9	400KV-SUJALPUR-RAPP	60	-36	663	-205	6.18	-0.99	5.19
10	400KV-VINDHYACHAL PS-RIHAND(III)	-1	-1	-	-1	0	-0.02	-0.02
11	765KV-BANASKANTHA-CHITTORGARH	-320	484	1,191	-1,020	4.47	-7.73	-3.26
12	765KV-GWALIOR-AGRA	-1,226	-1,191	-	-1,930	0	-27.45	-27.45
13	765KV-GWALIOR-JAIPUR	-1,016	-1,380	1,062	-1,678	4.22	-18.44	-14.22
14	765KV-GWALIOR-ORAI	571	638	720	-	11.29	0	11.29
15	765KV-JABALPUR-ORAI	-712	-777	-	-1,047	0	-27.34	-27.34
16	765KV-SATNA-ORAI	-793	-886	-	-983	0	-17.01	-17.01
17	765KV-VINDHYACHAL(PS)-VARANASI	-2,508	-2,457	-	-3,669	0	-62.34	-62.34
18	HVDC 500KV VINDHYACHAL B/B	-205	93	93	-207	1.28	-2.26	-0.98
19	HVDC500KV-MUNDRA-MOHINDARGARH	-1,449	-1,450	-	-1,455	0	-36.35	-36.35
20	HVDC800KV-CHAMPA-KURUKSHETRA	-4,543	-4,029	-	-4,588	0	-101.64	-101.64
Sub-Total NORTH REGION		-12,442	-11,298	4,578	-17,705	32.42	-309.71	-277.29
SOUTH REGION WEST REGION / /Import/Export between SOUTH REGION and WEST REGION								
1	220KV-KOLHAPUR-CHIKKODI-II	-	-	-	-	-	-	0
2	220KV-PONDA-AMBEWADI	2	2	2	-	0.04	0	0.04
3	220KV-TALANGADE(MS)-CHIKKODI-II	-	-	-	-	-	-	0
4	220KV-XELDEM-AMBEWADI	101	82	-	108	2.02	0	2.02
5	400KV-KOLHAPUR GIS-NARENDRA KUDGI	911	1,067	1,790	-	28.29	0	28.29
6	765KV-SOLAPUR-RAICHUR	-171	513	1,378	-954	10.14	-2.23	7.91
7	765KV-WARDHA-NIZAMABAD	-1,357	-697	34	-2,073	0	-24.87	-24.87
8	765KV-WARORA-PG-WARANGAL	-1,546	-937	-	-2,202	0	-28.3	-28.3
9	HVDC205KV-BHADRAWATI-RAMAGUNDAM	302	-307	303	-308	0	-1.2	-1.2
10	HVDC400KV-BARSUR-L.SILERU	-	-	-	-	-	-	0
11	HVDC800KV-RAIGARH-GIS-HVDC-PUGALUR	-600	-603	-	-1,499	0	-12.28	-12.28
Sub-Total SOUTH REGION		-2,358	-880	3,507	-6,928	40.49	-68.88	-28.39
TOTAL IR EXCHANGE		-15,991	-13,013	9,645	-29,370	80.62	-434.73	-354.11

4(B) Inter Regional Schedule & Actual Exchange (Import=(+ve) /Export =(-ve)) in MU

	ISGS+GNA+URS Schedule	TGNA BILT Schedule	GDAM Schedule	DAM Schedule	HPDAM Schedule	RTM Schedule	Total IR Schedule	Total IR Actual	NET IR UI
WR-ER	27.18	-25.74		-40.98		0	-62.39	-48.43	13.96
WR-NR	-232.13	-66.67		78		0	-209.08	-277.29	-68.21
WR-SR	-60.87	-12.81		-27.81		0	-98.69	-28.39	70.3
Total	-265.82	-105.22	0	9.21	0	0	-370.16	-354.11	16.05

5.Frequency Profile

RANGE(Hz)	< 48.8	< 49	< 49.2	< 49.5	< 49.7	< 49.9	>= 49.9 - <= 50.05	> 50.05
%	.00	.00	.00	.40	4.60	10.30	70.30	19.40

Percentage of Time Frequency Remained outside IEGC Band	29.7
No. of hours frequency outside IEGC Band	7.128

अधिकतम /Maximum		न्यूनतम/Minimum		औसत/Average	Freq Variation	Standard	Freq. in 15 mnt blk	
Frequency	Time	Frequency	Time	Frequency	Index	Deviation	Max.	Min.
50.28	18:02:30	49.45	00:36:00	49.99	0.12	0.108	50.16	49.51

6.वोल्टेज प्रोफाइल/Voltage Profile: 400kV

	अधिकतम/Maximum		न्यूनतम/Minimum		वभिवांतर/Voltage (in %)			Hours Volatge Outside IEGC Range(VDI)
STATION	VOLTAGE	TIME	VOLTAGE	TIME	>= 4000	IEGC Band (A)	> 420	(100-A)*24/100
AMRELI - 400KV	430.73	13:01	417.61	09:05	0	3.4	96.6	23.2
ASOJ - 400KV	414.41	13:03	400.34	15:23	0	100	0	0
BHILAI - 400KV	412.63	10:00	404.8	00:08	0	100	0	0
BHOPAL - 400KV	417.62	18:03	404.59	00:06	0	100	0	0
BOISAR - 400KV	419.96	02:30	399.06	15:23	0	100	0	0
DEHGAM - 400KV	417.43	03:22	402.02	15:25	0	100	0	0
DHULE - 400KV	414.05	22:01	398.38	15:24	0	100	0	0
DAMOH - 400KV	413.42	18:04	397.07	00:05	0	100	0	0
GPEC - 400KV	416.51	03:22	397.89	15:35	0	100	0	0
GWALIOR - 400KV	410.67	07:54	391.7	00:04	0	100	0	0
HAZIRA - 400KV	400.9	00:00	400.9	00:00	0	100	0	0
INDORE - 400KV	411.98	18:04	400.58	15:25	0	100	0	0
ITARSI - 400KV	407.76	18:04	395.8	00:04	0	100	0	0
JETPUR - 400KV	425.66	13:04	404.02	09:08	0	79.3	20.7	5
KALA - 400KV	414.22	02:58	392.53	15:23	0	100	0	0
KALWA - 400KV	418.94	02:26	392.02	15:18	0	100	0	0
KARAD - 400KV	423.83	02:22	399.85	11:47	0	79.7	20.3	4.9
KASOR - 400KV	418.12	19:06	404.42	15:24	0	100	0	0
KHANDWA - 400KV	412.64	18:04	401.55	06:21	0	100	0	0
MAGARWADA - 400KV	414.37	02:28	392.37	15:18	0	100	0	0
MAPUSA - 400KV	423.34	17:19	385.78	09:23	0	95.9	4.1	1
NAGDA - 400KV	414.89	18:04	403.31	15:25	0	100	0	0
NEW KOYNA - 400KV	432.23	02:24	414.34	06:32	0	25.2	74.8	18
PARLI - 400KV	421.82	01:48	389.74	00:14	0	94.9	5.1	1.2
RAIPUR - 400KV	411.82	09:42	404.23	15:25	0	100	0	0
RAIGARH - 400KV	419.03	08:43	412.26	15:25	0	100	0	0

VAPI - 400KV	413.57	02:30	391.16	15:23	0	100	0	0
WARDHA - 400KV	419.11	10:00	405.52	06:34	0	100	0	0

6.1 Voltage Profile: 765kV

	/Maximum		/Minimum		/Voltage (in %)			Hours Voltage Outside IEGC Range(VDI)
STATION	VOLTAGE	TIME	VOLTAGE	TIME	< 728	IEGC Band (A)	> 800	(100-A)*24/100
BINA - 765KV	786.22	08:02	0	19:23	.2	99.8	0	0
DURG - 765KV	779.3	10:00	770.07	00:00	0	100	0	0
GWALIOR - 765KV	792.78	07:54	754.15	00:05	0	100	0	0
INDORE - 765KV	776.86	18:04	755.24	15:25	0	100	0	0
KOTRA - 765KV	786.45	09:27	770.41	15:24	0	100	0	0
SASAN - 765KV	783.24	08:28	764.76	00:32	0	100	0	0
SATNA - 765KV	790.44	13:03	764.61	00:03	0	100	0	0
SEONI - 765KV	791	09:57	763	06:18	0	100	0	0
SIPAT - 765KV	775.77	11:07	758.92	06:35	0	100	0	0
TAMNAR - 765KV	786.31	09:30	771.14	00:03	0	100	0	0
VADODARA - 765KV	790.55	19:07	759.34	15:25	0	100	0	0
WARDHA - 765KV	797.16	10:49	757.28	06:37	0	100	0	0

7(A).Power Energy/Schedule Details

State	Off- Peak Hours (03:00)												
	T-GNA Bilateral (MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX HPDAM (MW)	IEX RTM (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXIL HPDAM (MW)	PXI RTM (MW)	HPX GDAM (MW)	HPX DAM (MW)	HPX HPDAM (MW)	HPX RTM (MW)
AMNSIL	0	-	185.45	-	104.58	-	0	-	0	-	-	-	-
BALCO	0	-	0	-	15.14	-	0	-	0	-	-	-	-
CHHATTISG ..	34.66	-	311.36	-	-115	-	0	-	0	-	-	-	-
DNHDDPDCL	9.66	-	73.41	-	31.27	-	0	-	0	-	-	-	-
GOA	90.21	-	-39	-	6.25	-	0	-	0	-	-	-	-
GUJARAT	318.75	-	-66.61	-	437.1	-	0	-	0	-	-	-	-
MADHYA PRADESH	-307.38	-	-522.02	-	-101.62	-	0	-	0	-	-	-	-
MAHARASHT..	329.41	-	150.52	-	632.47	-	0	-	0	-	-	-	-
RIL JAMNAGAR	0	-	0	-	0	-	0	-	0	-	-	-	-
TOTAL	475.31	0	93.11	-	1,010.19	0	0	-	0	-	-	-	-

State	Peak Hours (20:00)												
	T-GNA Bilateral (MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX HPDAM (MW)	IEX RTM (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXIL HPDAM (MW)	PXI RTM (MW)	HPX GDAM (MW)	HPX DAM(MW)	HPX HPDAM (MW)	HPX RTM (MW)
AMNSIL	0	-	0	-	16.91	-	0	-	0	-	-	-	-
BALCO	0	-	0	-	0	-	0	-	0	-	-	-	-
CHHATTISG ..	-4.18	-	144.93	-	-23.3	-	0	-	0	-	-	-	-
DNHDDPDCL	14.49	-	91.76	-	39.86	-	0	-	0	-	-	-	-
GOA	90.21	-	7.43	-	-6.54	-	0	-	0	-	-	-	-
GUJARAT	109.28	-	-684.41	-	53.95	-	0	-	0	-	-	-	-
MADHYA PRADESH	-105.65	-	-81.65	-	60.32	-	0	-	0	-	-	-	-
MAHARASHT..	212.92	-	410.12	-	2,261.25	-	0	-	0	-	-	-	-
RIL JAMNAGAR	0	-	0	-	0	-	0	-	0	-	-	-	-
TOTAL	317.07	0	-111.82	0	2,402.45	0	0	-	0	-	-	-	-

State	Day Energy (MU)						
	ISGS + GNA Schedule	T-GNA Bilateral (MW)	GDAM Schedule	DAM Schedule	HPDAM Schedule	RTM Schedule	Total (MU)
AMNSIL	7.63	0	2.41	1.89	-	1.83	13.76
BALCO	16.81	0	0	0	-	0.26	17.07
CHHATTISGARH	78.02	-3.17	0.15	-5.11	-	-0.65	69.24
DNHDDPDCL	27.03	0.32	0	3.12	-	1.29	31.76
GOA	14.83	2.37	0	-0.51	-	-0.21	16.48
GUJARAT	154.88	9.33	0.84	2.57	-	11.56	179.19
MADHYA PRADESH	177.64	-3.32	-0.32	-6.49	-	1.33	168.84
MAHARASHTRA	196.4	3.93	0.46	18.55	-	27.04	246.38
RIL JAMNAGAR	6.63	0	0	0	-	0	6.63
TOTAL	679.87	9.46	3.54	14.02	0	42.45	749.35

7(B).Power Energy/Schedule Details

State	ISGS + GNA Schedule		T-GNA Bilateral (MW)		IEX GDAM (MW)		PXIL GDAM(MW)		HPX GDAM(MW)		IEX DAM (MW)		PXIL DAM(MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
AMNSIL	565.05	128.08	0	0	176.67	0	0	0	0	0	279.15	0	0	0
BALCO	714.49	628.81	0	0	0	0	0	0	0	0	0	0	0	0
CHHATTISGARH	3,899.27	2,834.33	221.04	-521.44	96.59	-5.6	0	0	0	0	311.36	-1,216.5	0	0
DNHDDPDCL	1,187.91	982.67	23.34	8.69	0	0	0	0	0	0	222.16	39.6	0	0
GOA	766.71	518.45	123.73	76.69	1.82	0	0	0	0	0	15.81	-75	0	0
GUJARAT	7,832.48	3,867.28	719.95	59.52	144.6	0	0	0	0	0	569.43	-1,264.8	0	0
MADHYA PRADESH	8,266.56	6,352.81	8.21	-407.87	94.06	-107.8	0	0	0	0	109.74	-1,025.47	0	0
MAHARASHTRA	9,790.93	7,382.14	329.41	-161.86	249.4	-31.33	0	0	0	0	1,601.9	9.46	0	0
RIL JAMNAGAR	-	-	-	-	-	-	-	-	-	-	-	-	-	-

State	HPX DAM(MW)		IEX HPDAM (MW)		PXIL HPDAM(MW)		HPX HPDAM(MW)		IEX RTM (MW)		PXIL RTM(MW)		HPX RTM(MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
AMNSIL	0	0	0	0	0	0	0	0	176.76	0	0	0	0	0
BALCO	0	0	0	0	0	0	0	0	106.25	0	0	0	0	0
CHHATTISGARH	0	0	0	0	0	0	0	0	295.41	-322.3	43.51	0	0	0
DNHDDPDCL	0	0	0	0	0	0	0	0	120.74	0	0	0	0	0
GOA	0	0	0	0	0	0	0	0	42.27	-90	0	0	0	0
GUJARAT	0	0	0	-15	0	0	0	0	1,525.05	-328.68	12.01	0	0	0
MADHYA PRADESH	0	0	0	0	0	0	0	0	1,350.81	-848.48	0	0	0	0
MAHARASHTRA	0	0	0	0	0	0	0	0	3,182.3	-104.64	36.03	0	0	0
RIL JAMNAGAR	-	-	-	-	-	-	-	-	-	-	-	-	-	-

8.Major Reservoir Particulars

RESERVOIR	DESIGNED			PRESENT		LAST YEAR		LAST DAY	MONTH	
	MDDL(Mts)	FRL(Mts)	Energy(MU)	Level(Mts)	Energy(MU)	Level(Mts)	Energy(MU)	Inflow(Mus)	"Prog.Inflow (Mus)"	"Prog.Usage (Mus)"
INDIRASAGAR	243.23	262.13	1,367	250	308.37	252.27	409.98	250.03	0	0
OMKARESHWAR	193.3	196.6	21.958	194.77	-	195.68	-	194.67	0	0
UKAI	82.296	105.156	770.67	96.07	284.88	96.769	313.939	96.15	0	0
KADANA	114.3	127.711	126.266	121.05	36.57	117.803	13.93	121.1	0	0
SSP	110.64	138.68	1,342.091	128.15	607.04	122.04	326.21	128.33	0	0
KOYNA	615.54	659.43	3,160	622.9	506.659	628.15	819.79	0	0	0
TATA BHIRA	590.1	607.1	582.4	594.38	115.17	594.83	128.83	594.45	0	0

9.Significant events (If any):

10.System Constraints (If any)

11. Weather Condition:

12. RE/Load Curtailment details

State	Load Curtailment			RE Curtailment				Reason
	Energy	Maximum	At the time of maximum demand	Wind		Solar		
	MU	MW	MW	Max MW	Energy(MU)	Max MW	Energy(MU)	
AMNSIL	0	0	0	0	0	0	0	
BALCO	0	0	0	0	0	0	0	
CHHATTISGARH	0	0	0	0	0	0	0	
DAMAN AND DIU	0	0	0	0	0	0	0	
GOA	0	0	0	0	0	0	0	
GUJARAT	0.041	40	0	261.576	0.46	1,746.259	3.74	To control under drawal.
MADHYA PRADESH	0	0	0	0	0	0	0	
MAHARASHTRA	0.925	375	0	0	0	0	0	
RIL JAMNAGAR	0	0	0	0	0	0	0	

Shift In Charge