GRID CONTROLLER OF INDIA (GRID-INDIA)
WESTERN REGIONAL LOAD DESPATCH CENTRE
DAILY OPERATION REPORT OF WESTERN REGION

Power Supply Position in Western Region For 04-Jun-2026

Date of Reporting:05-Jun-2026

1. Regional Availability/Demand:

Evening Peak (20:00) MW				Off-Peak (03:00) MW				/Day Energy(Net MU)	
मांग पूरता/ Demand Met	अभाव/Shortage	आवश्यकता/ Requirement	आवृतता/Freq (Hz)	मांग पूरता/ Demand Met	अभाव/Shortage	आवश्यकता/ Requirement	आवृतता/Freq (Hz)	मांग पूरता/Demand Met	अभाव/Shortage
71,250	0	71,250	50.04	66,035	0	66,035	49.99	1,698.3	0

2(A) /Load Details (/in state periphery) in MU:

राज्य/STATE	State's Control Area Generation (Net MU)							/Net SCH	/Drawal	/UI	Availability	Requirement	/ Shortage	/ Consump -tion
	तापीय/ THERMAL	जलीय/ HYDRO	गैस/ Gas	पवन/ WIND	सौर/ SOLAR	अन्य/ OTHERS	कुल/TOTAL	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)
BALCO	-	0	0	0	0	0	0	17.1	16.9	-0.2	16.9	16.9	0	16.9
CHHATTISGARH	41.4	0.2	0	0	4.5	1.1	47.2	79	78.3	-0.7	125.5	125.5	0	125.5
DNHDDPDCL	-	0	0	0	0	0	0	31.9	32.1	0.2	32.1	32.1	0	32.1
AMNSIL	6.8	0	0	0	0	0	6.7	13	13	0	19.7	19.7	0	19.7
GOA	0.2	0	0	0	0	0	0.2	16.6	15.9	-0.7	16.1	16.1	0	16.1
GUJARAT	182.9	2.4	17.5	87.6	80.4	0	370.8	174.7	160.9	-13.8	531.7	531.7	0	531.7
MADHYA PRADESH	81.8	5.9	0	14.7	11.2	1.5	115.1	165	165	0	280.1	280.1	0	280.1
MAHARASHTRA	332.9	12.4	9.8	26.9	33.1	0	415.1	258.7	254.5	-4.2	669.6	669.6	0	669.6
RIL JAMNAGAR	-	0	0	0	0	0	0	6.6	6.6	0	6.6	6.6	0	6.6
Region	646	20.9	27.3	129.2	129.2	2.6	955.1	762.6	743.2	-19.4	1,698.3	1,698.3	0	1,698.3

2(B) / /State's Demand Met in MW and day energy forecast and deviation particulars

राज्य/State	Evening Peak (20:00) MW			Off-Peak (03:00) MW				/Day Energy(Net MU)	
	मांग पूरता/ Demand Met	अभाव/ Shortage	आवश्यकता/ Requirement at Evening peak	मांग पूरता/ Demand Met	अभाव/ Shortage	आवश्यकता/ Requirement at Off-Peak	AVG (MW)	पूर्वानुमान/ForeCast(MU)	विचलन/Deviation[Fore .. -Consumption] (MU)
BALCO	706	0	706	708	0	708	706	14	-2.9
CHHATTISGARH	5,393	0	5,393	5,406	0	5,406	5,278	125.36	-0.14
DNHDDPDCL	1,327	0	1,327	1,317	0	1,317	1,335	31.51	-0.59
AMNSIL	874	0	874	815	0	815	822	19	-0.7
GOA	756	0	756	650	0	650	682	16.92	0.82
GUJARAT	22,244	0	22,244	19,870	0	19,870	22,153	523.6	-8.1
MADHYA PRADESH	11,319	0	11,319	11,126	0	11,126	11,658	289.53	9.43
MAHARASHTRA	28,357	0	28,357	25,868	0	25,868	27,903	652.11	-17.49
RIL JAMNAGAR	274	0	274	275	0	275	275	6	-0.6
Region	71,250	0	71,250	66,035	0	66,035	70,812	1,678.03	-20.27

2(C) /State's Demand Met in MW (/maximum demand met and /Maximum requirement of the day details)

राज्य/State	Maximum Demand, corresponding shortage and requirement details for the day				ACE			
	अधिकतम मांग पूरता/Maximum Demand Met of the day	समय/Time	अभाव/Shortage at maximum demand	आवश्यकता/Requirement at the max demand met of the day	ACE_MAX	बजे/Time	ACE_MIN	बजे/Time
BALCO	710	02:00	0	710	-	-	-	-
CHHATTISGARH	5,788	22:45	0	5,788	654.82	10:59:00	-522.52	05:47:00
DNHDDPDCL	1,398	17:00	0	1,398	153.47	02:22:00	-123.64	16:47:00
AMNSIL	970	20:00	0	970	417.52	18:12:00	-261.35	14:40:00
GOA	762	20:00	0	762	139.74	18:06:00	-81.46	11:15:00
GUJARAT	25,576	15:00	0	25,576	2,668.5	08:16:00	-779.7	17:35:00
MADHYA PRADESH	12,855	15:00	0	12,855	1,078.33	18:48:00	-2,796.89	10:58:00
MAHARASHTRA	30,275	16:00	0	30,275	971.21	20:15:00	-4,089.82	10:58:00
RIL JAMNAGAR	275	10:00	0	275	-	-	-	-
WR	76,971	16:00	0	76,971	-	-	-	-

3(A) State Entities Generation:

CHHATTISGARH

स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
KORBA EAST EXT(DSPM)(2*250)	500	436	453	470	00:40	420	06:10	11.37	10.43	435
KORBA(W) CSETCL(4*210 + 1*500)	1,340	284	700	733	00:16	256	06:25	9.49	8.32	347
MARWA TPS(1*500 + 1*500)	1,000	821	956	967	01:09	634	12:38	21.02	19.89	829
OTHER CPP	50	0	0	0	-	0	-	2.77	2.77	115
TOTAL THERMAL	2,890	1,541	2,109	-	-	-	-	44.65	41.41	1,726
HASDEO BANGO(3*40)	120	1	1	40	21:09	0	11:00	0.12	0.12	5
KWB MINI MICRO(2*0.85)	1.7	0	0	0	-	0	-	0.01	0.01	0
SMALL HYDRO	50	0	0	0	-	0	-	0.05	0.05	2
TOTAL HYDEL	171.7	1	1	-	-	-	-	0.18	0.18	7
WIND	0	0	0	0	-	0	-	0	0	0
SOLAR	842	3	0	598	12:08	16	06:00	4.51	4.51	188
BIO MASS	50	0	0	0	-	0	-	1.05	1.05	44
TOTAL BIO MASS	50	0	0	-	-	-	-	1.05	1.05	44
TOTAL CHHATTISGARH	3,953.7	-	-	-	-	-	-	50.39	47.15	1,965

GUJARAT

स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
AECO(1*120 + 2*121)	362	237	240	359	00:14	149	12:09	5.23	4.76	198
ALTPS(2*125)	250	108	103	110	22:43	77	06:08	3.05	2.54	106
APL MUNDRA(4*330 + 2*660 + 3*660)	4,620	3,019	3,817	4,230	00:28	2,760	09:20	83	76.31	3,180
BLTPS(2*250)	500	322	324	327	01:03	262	12:06	7.81	6.59	275
GANDHINAGAR(GTPS)(3*210)	630	470	431	582	23:32	353	10:40	10	8.99	375
KLTPS(2*75)	150	65	64	67	08:40	57	14:07	1.51	1.32	55
OTHER CPP	1,000	0	0	0	-	0	-	4.69	5.74	239
SLPP(4*125)	500	303	298	314	06:46	184	13:30	7.33	6.28	262
STPS(2*250)	500	287	293	475	00:48	146	13:54	7.35	6.56	273
UKAI(2*200 + 1*210 + 1*500)	1,110	318	382	391	03:42	240	16:01	7.35	6.38	266
VADINAR(2*600)	1,200	620	1,150	1,153	02:59	576	15:28	20.65	19.3	804
WANAKBORI(7*210 + 1*800)	2,270	1,643	1,765	1,964	01:18	1,036	15:11	34.64	31.81	1,325
TOTAL THERMAL	13,092	7,392	8,867	-	-	-	-	192.61	176.58	7,358
DGBP(1*107 + 1*112 + 1*376)	594	0	0	0	00:00	0	00:00	0.15	0.11	5
ESSAR POWER GAS(3*110 + 1*185)	515	0	0	0	-	0	-	0	0	0
GIPCL STG(3*32 + 49)	145	0	0	0	00:00	0	00:00	0	0	0
GIPCL STG 2(111 + 54)	165	0	0	0	00:00	0	00:00	0	0	0
GPEC(3*138 +241)	654	0	0	0	-	0	-	0	0	0
GPPC(2*351.43)	702	0	0	0	00:00	0	00:00	0	0	0
GSEC(3*52)	156	20	6	326	00:14	0	14:14	1.36	1.27	53
SUGEN 1(3*382.5)	1,147.5	963	778	1,000	18:45	-355	06:11	13.17	12.81	534
UNOSUGEN(1*382.5)	382.5	273	210	362	21:15	-10	16:59	3.12	3.02	126
UTRAN STG II(1*229 + 1*146(ST))	375	0	0	0	00:00	0	00:00	0.25	0.24	10
TOTAL GAS	4,836	1,256	994	-	-	-	-	18.05	17.45	728
KADANA(4*60)	240	0	50	53	21:28	0	04:49	0.4	0.4	17
LBC PANAM HYDRO	5	0	0	0	-	0	-	0.08	0.08	3
PVT HYDRO	20.6	0	0	0	-	0	-	0.14	0.14	6
UKAI HYDRO(4*75)	300	130	65	132	22:28	65	00:00	2.04	1.99	83
TOTAL HYDEL	565.6	130	115	-	-	-	-	2.66	2.61	109
WIND	8,836	5,483	2,211	5,633	20:24	1,222	06:14	87.63	87.63	3,651
SOLAR	15,238	1	0	9,457	11:43	76	06:07	80.37	80.37	3,349
BIO MASS	51.65	0	0	0	-	0	-	1.05	1.05	44
TOTAL GUJARAT	42,619.25	-	-	-	-	-	-	382.37	365.69	15,239

MADHYA PRADESH

स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
AMARKANTAK(1*210)	210	0	0	0	00:00	0	00:00	0.01	0.01	0
BLA IPP(2*45)	90	55	84	84	22:43	46	09:28	1.67	1.46	61
JP BINA(2*250)	500	312	235	474	22:03	143	14:16	9.73	8.87	370
SANJAY GANDHI TPS(4*210 + 1*500)	1,340	926	957	966	03:12	786	13:41	23.43	21.49	895
SATPURA IV(2*250)	500	470	471	478	23:36	257	10:23	10.89	9.95	415
SINGAJI(2*600 + 2*660)	2,520	1,877	2,128	2,348	18:51	1,302	10:28	46.72	44.06	1,836
TOTAL THERMAL	5,160	3,640	3,875	-	-	-	-	92.45	85.84	3,577
BANASAGAR TONS(3*105)	315	0	101	106	21:30	0	05:22	0.72	0.71	30
BARGI(2*45)	90	30	33	43	12:42	27	12:36	0.75	0.74	31
BIRSINGHPUR	20	0	0	0	-	0	-	0	0	0
BSGR(DEVLONE)(3*20)	60	0	0	0	00:00	0	00:00	0	0	0
BSGR(SILPARA)(2*15)	30	0	0	6	22:41	0	00:06	0	0	0
INDIRASAGAR(8*125)	1,000	295	111	800	21:06	0	13:07	3.44	3.42	143
JHINNA(2*10)	20	0	0	0	00:39	0	13:10	0	0	0
MADIKHEADA(3*20)	60	60	60	60	00:00	60	00:00	0	0	0
MP CHAMBAL	386	0	0	0	-	0	-	0	0	0
OMKARESHWAR(8*65)	520	0	0	328	21:43	0	02:35	1.03	1.03	43
PENCH(2*80)	160	0	0	0	-	0	-	0	0	0
RAJGHAT HYDRO(3*15)	45	0	0	0	00:00	0	00:00	0	0	0
TOTAL HYDEL	2,706	385	305	-	-	-	-	5.94	5.9	247
WIND	2,670	532	436	803	18:45	222	10:20	14.65	14.65	610
SOLAR	2,370	0	0	1,679	12:09	8	06:00	11.24	11.24	468
BIO + SMALL HYDRO	100	0	0	0	-	0	-	1.51	1.51	63
TOTAL MADHYA PRADESH	13,006	-	-	-	-	-	-	125.79	119.14	4,965

MAHARASHTRA

स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
APML TIRODA(5*660)	3,300	3,088	3,117	3,136	04:30	1,717	10:23	68.63	64.77	2,699
BHUSAWAL(1*210 + 2*500+1*660)	1,870	1,093	1,050	1,102	21:27	661	09:44	24.1	22.75	948
CHANDRAPUR(2*210 + 5*500)	2,920	1,830	1,793	1,887	20:09	1,250	09:03	41.92	39.28	1,637
DAHANU(2*250)	500	452	422	503	06:32	280	08:16	9.18	8.2	342
IEPL(1*270)	270	252	272	275	21:48	147	09:26	5.82	5.23	218
JAIGAD(4*300)	1,200	786	891	994	04:25	641	15:20	20.65	18.89	787
JPL DHULE (SHIRPUR)(2*150)	300	256	262	278	02:10	158	10:24	5.72	5.64	235
KHAPARKHEDA(4*210 + 1*500)	1,340	850	936	1,051	15:45	700	11:00	23.6	21.71	905
KORADI(1*210 + 3*660)	4,170	1,185	1,143	1,235	16:38	842	10:28	28.47	27.34	1,139
NASIK(3*210)	630	385	273	399	18:18	246	06:01	8.45	7.77	324
OTHER CPP	3,305	0	0	0	-	0	-	37.27	37.27	1,553
PARAS(2*250)	500	414	389	436	19:31	251	11:34	10.07	9.15	381
PARLI(3*250)	750	663	654	677	07:12	377	10:31	15.67	14.04	585
RATTAN INDIA (AMARAVATI)(5*270)	1,350	1,204	1,215	1,249	03:30	1,124	10:27	31.51	29.14	1,214
SWPGL(4*135)	540	424	425	442	13:27	289	10:19	11.09	9.99	416
TROMBAY(250+1*500)	750	543	412	666	01:50	367	14:43	0	0	0
VIPL(2*300)	600	498	513	544	08:26	326	10:20	12.72	11.77	490
TOTAL THERMAL	24,295	13,923	13,767	-	-	-	-	354.87	332.94	13,873
TROMBAY_GAS(1*120+1*60)	180	162	169	174	03:09	106	08:51	3.32	3.3	138
URAN(4*108 + 2*120)	672	270	276	279	06:04	259	13:31	6.73	6.54	273
TOTAL GAS	852	432	445	-	-	-	-	10.05	9.84	411
BHIRA(6*25)	150	139	4	152	23:48	3	11:17	1.2	1.2	50
BHIRA PSS	150	-1	137	163	01:30	-1	07:02	1.5	1.5	63
BHIRA TR(2*40)	80	0	0	0	-	0	-	0.28	0.27	11
BHIVPURI(3*24 + 2*1.5)	75	47	47	48	02:48	24	14:32	1.08	1.08	45
GHATGHAR(2*125)	250	0	0	122	01:28	-157	07:59	0.19	0.18	8
HYDRO VTRNA(1*60)	60	0	0	0	00:00	0	00:00	0	0	0
HYDROSMLHY_PTN	350	0	0	0	-	0	-	5.69	5.58	233
KHOPOLI(3*24)	72	24	22	24	20:00	4	16:07	0.4	0.4	17
KOYNA I AND II(4*(65+5) + 4*(75+5))	600	40	40	397	00:07	37	09:55	1.28	1.24	52
KOYNA III(4*80)	320	0	0	157	00:51	0	01:12	0.17	0.16	7
KOYNA ST-IV(4*250)	1,000	-3	-4	18	12:29	-20	14:47	0	0	0
TILLARI(1*66)	66	0	0	0	00:00	0	00:00	0	0	0
OTHER HYDRO	122	0	0	0	-	0	-	4.94	4.94	206
TOTAL HYDEL	3,295	246	246	-	-	-	-	16.73	16.55	692
WIND	5,321	1,039	893	1,255	00:16	100	12:04	26.9	26.9	1,121
SOLAR	6,028	192	-14	4,489	11:23	22	06:00	33.07	33.07	1,378
TOTAL MAHARASHTRA	39,791	-	-	-	-	-	-	441.62	419.3	17,475

3(B) Regional Entities Generation

ISGS

स्टेशन/ Station/Constituents	स्थापित क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
GADARWARA(2*800)	1,600	1,398	1,494	1,542	05:40	751	15:41	26.41	28.59	26.75	1,115
GANDHAR(3*144.3 + 1*224.49)	657	227	-8	387	00:05	-56	14:01	1.53	1.55	1.42	59
KAPS(2*220)	440	391	391	391	00:00	391	00:00	9.55	10.55	9.53	397
KAPS3&4(2*700)	1,400	585	595	602	08:38	581	16:20	27.94	30.99	28.4	1,183
KAWAS(4*106 + 2*116.1)	656.2	420	-3	458	20:20	-110	14:02	1.67	2.38	2.27	95
KHARGONE(2*660)	1,320	1,130	1,235	1,270	03:16	659	07:42	21.78	23.36	21.78	908
KSTPS1&2(3*200 + 3*500)	2,100	1,217	1,337	1,352	01:49	763	11:00	31.61	32.97	30.29	1,262
KSTPS3(1*500)	500	443	483	492	17:52	270	10:21	10.02	10.61	9.88	412
LARA(2*800)	1,600	1,392	1,509	1,522	17:57	806	10:41	31.78	33.62	31.58	1,316
MOUDA I(2*500)	1,000	838	948	998	23:47	428	16:31	17.48	18.48	16.61	692
MOUDA II(2*660)	1,320	1,082	1,203	1,226	06:09	587	15:31	22.66	24.34	21.49	895
NSPCL(2*250)	500	389	454	464	05:48	234	10:23	8.75	9.5	8.64	360
RGPPL(2*320 + 4*331.75)	1,967	773	496	1,274	00:19	351	14:51	13.4	13.97	13.51	563
SASAN(6*660)	3,960	3,076	3,100	3,170	18:12	1,694	10:48	69.06	74.11	69.06	2,878
SIPAT I(3*660)	1,980	1,737	1,905	1,929	03:19	1,008	08:48	39.29	41.45	38.99	1,625
SIPAT II(2*500)	1,000	865	963	967	23:52	514	10:46	20.07	21.19	19.9	829
SOLAPUR STPS(2*660)	1,320	660	772	1,264	05:50	638	17:07	17.9	19.91	18.41	767
SSP(RBPH+CHPH)(6*200 + 5*50)	1,450	47	-2	977	23:47	-2	05:21	6.29	6.37	6.3	263
TARAPUR I(2*160)	320	149	152	156	18:29	146	15:42	3.84	3.81	3.4	142
TARAPUR II(2*540)	1,080	794	795	804	12:10	763	11:23	18.72	20.92	18.65	777
VSTPS I(6*210)	1,260	918	919	935	06:24	505	08:01	18.28	20.49	17.98	749
VSTPS II(2*500)	1,000	850	883	926	05:59	509	09:58	18.04	19.16	17.63	735
VSTPS III(2*500)	1,000	846	938	969	23:47	501	08:12	18.09	19.04	18.02	751
VSTPS IV(2*500)	1,000	848	925	956	05:47	475	14:29	18.62	19.82	18.48	770
VSTPS V(1*500)	500	429	467	476	02:48	242	08:10	8.95	9.51	8.93	372
SUB-TOTAL	30,930.2	21,504	21,951	-	-	-	-	481.73	516.69	477.9	19,915
TOTAL	30,930.2	-	-					481.73	516.69	477.9	19,915

IPP/JV

स्टेशन/ Station/Constituents	स्थापित क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
ACBIL(2*135 + 2*50 + 2*30 + 1*63)	493	293	278	295	19:39	243	10:04	6.79	7.8	6.59	275
ADANI RAIPUR(2*685)	1,370	1,058	1,111	1,140	03:57	524	11:22	22.94	25.85	23.18	966
APL RAIGARH(1*600)	600	541	565	586	05:54	309	10:37	12.14	12.98	12.25	510
BALCO(4*300)	1,200	977	942	1,006	22:32	701	11:23	21.69	21.79	21.69	904
DB POWER(2*600)	1,200	1,121	1,132	1,155	19:14	670	10:07	25.51	27.01	25.55	1,065
DCPP(2*135)	270	111	108	114	12:22	67	11:54	2.49	2.91	2.51	105
DGEN(3*400)	1,200	450	132	752	22:34	-8	15:46	4.28	4.38	4.2	175
DHARIWAL CTU(2*300)	600	505	548	561	04:28	281	10:33	11.46	12.48	11.57	482
GMR WARORA(2*300)	600	552	564	589	07:20	322	09:43	12.34	13.43	12.4	517
JHABUA POWER(1*600)	600	529	537	547	04:07	302	10:33	11.79	12.27	11.54	481
JP NIGRIE(2*660)	1,320	1,245	1,264	1,274	17:43	691	10:43	26.21	28.1	26.67	1,111
JPL STG-I(4*250)	1,000	850	859	904	20:45	513	10:18	17.68	20.4	18.06	753
JPL STG-II(4*600)	2,400	2,326	2,326	2,344	00:41	1,698	12:52	49.77	54.51	51.58	2,149
JSW MAHANADI(3*600)	1,800	1,704	1,707	1,729	19:09	891	10:06	36.9	39.76	37.03	1,543
LANCO(2*300)	600	524	555	570	03:18	291	10:15	11.83	13.2	11.96	498
MAHAN ENERGEN(2*600)	1,200	1,118	1,123	1,137	14:53	598	11:03	24.41	26.12	24.4	1,017
MB POWER(2*600)	1,200	1,150	1,181	1,193	03:15	493	10:31	24.5	26.02	24.53	1,022
MCCPL(1*300)	300	220	257	265	05:17	154	10:50	5.47	6.07	5.46	228
RKM POWER(4*360)	1,440	1,270	1,314	1,324	01:01	722	08:40	27.09	30.1	27.27	1,136
SARDA ENERGY & MINERALS LTD(2*300)	600	512	526	532	02:39	328	10:36	-	13.25	12	500
TPCL(5*800)	4,000	3,339	3,688	3,777	02:09	2,042	08:32	66.86	72.13	65.91	2,746
TRN ENERGY(2*300)	600	532	537	541	01:38	315	10:25	11.62	12.88	11.78	491
VEDANTA_LIMITED_CG (1*600)	600	0	-1	0	12:40	-2	12:48	0	0.05	0.05	2
SUB-TOTAL	25,193	20,927	21,253	-	-	-	-	433.77	483.49	448.18	18,676
TOTAL	25,193	-	-					433.77	483.49	448.18	18,676

RENEWABLE

स्टेशन/ Station/Constituents	स्थापित क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
AGE25BL_PSS9_KPS1_HS	100	0	0	98	12:51	0	00:00	0.16	0.14	0.14	6
AHEJ5L_PSS8_KPS3_HS	100	0	0	106	12:51	0	00:01	1.56	0.95	0.95	40
AYANARP4_DVSR_BHJ_HS	37.5	0	0	27	12:45	0	00:00	0.18	0.16	0.16	7
ACL_PSS3_KPS1_S	200	0	0	190	11:54	0	05:57	1.91	1.79	1.79	75
ACL_PSS4_KPS1_HS	125	0	0	107	10:54	0	06:00	1.36	0.85	0.85	35
AGE24AL_PSS3_KPS1_S	400	0	0	376	11:21	0	00:00	4.11	3.48	3.48	145
AGE24L_PSS10_KPS3_S	150	0	0	94	11:54	0	00:00	0.71	0.56	0.56	23
AGE24L_PSS5_KPS1_S	150	0	0	152	13:38	0	06:00	1.54	1.4	1.4	58
AGE25AL_PSS2_KPS1_S	500	0	0	392	08:47	0	04:59	1.43	1.98	1.98	83
AGE25BL_PSS2_KPS1_S	582.98	0	0	434	08:51	0	04:38	1.65	2.41	2.41	100
AGE25CL_PSS8_KPS3_S	350	0	0	424	12:40	0	00:47	5.09	3.3	3.3	138
AGE26AL_PSS3_KPS1_S	62.5	0	0	35	11:26	0	13:37	0.02	0.01	0.01	0
AGE26AL_PSS6_KPS1_S	750	0	0	651	00:00	0	00:00	7.35	7.23	7.23	301
AGE26BL_PSS10_KPS1_HS	142	0	0	234	11:54	0	00:12	0.11	1.59	1.59	66
AGE26BL_PSS10_KPS1_S	150	0	0	234	11:54	0	00:12	0.43	1.59	1.59	66
AGE26BL_PSS2_KPS1_S	167	0	0	132	08:49	0	00:00	0.47	0.71	0.71	30
AHEJ5L_PSS5_KPS1_S	570	0	0	570	13:25	0	06:00	4.35	4.47	4.47	186
APSEZ_PSS3_KPS1_S	200	0	0	189	11:21	0	00:00	1.91	1.74	1.74	73
ARE3L_PSS8_KPS3_HS	25	0	0	22	12:23	0	00:00	0.23	0.21	0.21	9
ARE45L_PSS5_KPS1_S	250	0	0	245	13:27	0	06:00	2.56	2.26	2.26	94
ARE55L_PSS3_KPS1_HS	25	0	0	22	09:35	0	00:00	0.2	0.21	0.21	9
ARE55L_PSS3_KPS1_S	162.5	0	0	21	13:55	0	00:00	1.67	0.26	0.26	11
ARE56L_PSS10_KPS1_S	500	0	0	375	11:54	0	06:00	2.71	2.13	2.13	89
ARE56L_PSS4_KPS1_S	225	0	0	212	12:13	0	00:00	2.33	2.23	2.23	93
ARE56L_PSS9_KPS1_S	400	0	0	228	10:13	0	06:00	1.12	1.69	1.69	70
ARE57L_PSS13_KPS1_S	850	0	0	649	08:52	0	00:17	2.38	2.87	2.87	120
AREH4L_PSS1_KPS1_SF	1,000	0	0	768	08:49	0	06:00	4.33	4.44	4.44	185
ARINSUN SOLAR (BARSAITADESH)	250	0	0	233	13:01	0	15:33	1.45	1.03	1.03	43
ASEJ6PL_PSS8_KPS3_HS	35	0	0	30	13:10	0	00:00	0.07	0.06	0.06	3
ASEJ6PL_PSS8_KPS3_S	50	0	0	40	13:12	0	00:00	0.48	0.46	0.46	19
ATHENA SOLAR	250	0	0	249	12:21	0	15:37	1.39	1.14	1.14	48
AVAADA_AGAR_RUMS_S	200	0	0	200	11:53	0	00:00	1.29	1.26	1.26	53
AYANARP4_DVSR_BHJ_HW	150	0	0	134	11:43	0	00:00	1.76	1.67	1.67	70
BEEMPOW_AGAR_RUMS_S	350	0	0	344	11:52	0	06:00	2.06	2.12	2.12	88
BLUELEAF_CP_PCHR_HS	128.7	0	0	47	10:46	0	17:35	0	-0.06	-0.06	-3
CGERP_MORJAR_BHJ2_HS	30.8	0	0	24	11:54	0	00:00	0.26	0.24	0.24	10
ESPL_RSP SOLAR	200	0	0	205	12:41	0	06:00	1.49	1.59	1.59	66
GANDHAR SOLAR	20	0	0	20	12:59	0	00:00	0.13	0.14	0.14	6
GIPCL_PSS1_KPS2_S	600	0	0	543	14:12	0	06:09	4.73	4.74	4.74	198
GIPCL_RSP SOLAR	100	0	0	102	14:04	0	06:00	0.72	0.73	0.73	30
GSEC 2	100	0	0	61	12:55	0	00:00	0.42	0.26	0.26	11
GSECL_RSP SOLAR	100	0	0	3	09:41	0	00:00	0	0.02	0.02	1
KAWAS SOLAR	56	0	0	51	12:36	0	05:25	0.34	0.34	0.34	14
KPIG_GSECLS_KPS2_S	200	0	0	121	11:15	0	05:59	1.12	1.12	1.12	47
MAHINDRA SOLAR (BADWAR)	250	0	0	202	12:05	0	00:00	1.04	1.03	1.03	43
MASAYA SOLAR	300	0	0	293	12:22	0	00:00	1.87	1.82	1.82	76
NTPCREL_PSS1_KPS3_S	1,095	0	0	388	12:35	0	00:00	2.79	2.78	2.78	116
NTPCREL_PSS2_KPS2_S	1,555	0	0	1,443	12:34	0	00:00	9.91	9.87	9.87	411
SAELP4_GSECLS_KPS2_S	400	0	0	308	09:26	0	05:59	2.49	2.7	2.7	113
SAELP5_GSECLS_KPS2_S	400	0	0	309	12:56	0	00:00	2.5	2.4	2.4	100
SGEL_RSP_S	100	0	0	99	12:53	0	00:03	0.69	0.77	0.77	32
SHERISHA RAIPUR	50	0	0	47	11:33	0	00:00	0.28	0.27	0.27	11
SOLAPUR SOLAR PV PROJECT	23	0	0	21	11:56	0	00:00	0.15	0.13	0.13	5
TPREL_RSP SOLAR	100	0	0	98	14:03	0	00:00	0.71	0.63	0.63	26
TPSOURY_BRVD_NMCH_S	160	0	0	162	12:01	0	00:00	1.22	1.12	1.12	47
TPSOURY_KWAI_NMCH_S	170	0	0	211	12:30	0	00:00	1.27	1.45	1.45	60
AHEJ5L_PSS8_KPS3_HW	65	51	25	67	13:39	9	06:05	1.49	0.99	0.99	41
RSRPL_GHTND_KLM_W	138.6	110	34	113	17:19	10	06:10	0.8	0.6	0.6	25
ACL_PSS4_KPS1_W	156	144	78	155	13:28	21	06:14	2.28	2.49	2.49	104
ADANI WIND ENERGY KUTCHH FOUR LTD	300	241	156	289	15:13	51	06:01	5.79	5.07	5.07	211
AGE24L_PSS4_KPS1_W	100	94	50	104	13:07	18	06:11	0.77	1.76	1.76	73
AGE25BL_PSS9_KPS1_HW	130	115	60	121	13:06	23	06:11	0.98	0.96	0.96	40
AGE25CL_PSS11_KPS3_W	185	150	65	167	16:07	45	07:10	1.73	1.65	1.65	69
AGE25CL_PSS14_KPS3_W	65	55	16	56	17:06	12	07:10	0.62	0.6	0.6	25
AGE26AL_PSS12_KPS3_W	137.5	101	78	110	17:06	67	06:10	1.09	1.01	1.01	42
AGE26BL_PSS10_KPS1_W	156	111	54	147	14:13	27	07:06	1.34	2.09	2.09	87
AHEJ5L_PSS4_KPS1_W	60	60	33	62	13:13	10	06:15	0.46	1.01	1.01	42
AHEJ5L_PSS5_KPS1_HW	202.8	184	112	190	13:40	65	06:11	1.92	1.87	1.87	78
ALFANAR WIND (NANAVALKA)	300	208	188	259	10:48	24	06:08	4.95	4.7	4.7	196
APRAAVA ENERGY PRIVATE LIMITED (AEPL)	252	152	97	234	17:31	31	07:10	3.31	3.23	3.23	135

APSEZ_PSS4_KPS1_W	52	38	25	52	12:36	5	06:10	0.68	0.78	0.78	33
ARE3L_PSS8_KPS3_HW	41.6	31	15	41	13:32	5	06:14	0.51	0.6	0.6	25
ARE41L_PSS13_KPS1_W	124.8	90	44	112	14:14	18	06:06	1.71	1.61	1.61	67
ARE41L_PSS3_KPS1_W	250	189	93	249	14:23	43	06:14	1.83	3.76	3.76	157
ARE41L_PSS4_KPS1_W	50	49	25	52	14:20	11	06:15	0.71	0.9	0.9	38
ARE41L_PSS8_KPS3_W	125	80	52	124	13:47	16	06:03	2.96	1.76	1.76	73
ARE48L_SRPL_PSS9_KPS1_W	119.6	0	0	0	00:00	0	00:00	0	0	0	0
ARE55L_PSS3_KPS1_HW	25	19	9	21	13:08	8	00:03	0.23	0.21	0.21	9
ASEJ6PL_PSS8_KPS3_HW	62.4	54	32	57	17:08	31	06:10	1.3	1.2	1.2	50
ASIPL WIND (BARANDA)	170.1	0	0	0	00:00	0	00:00	0	0	0	0
AWEK1L WIND (RATADIYA)	425	359	318	428	17:03	44	06:05	7.3	7.93	7.93	330
AWEKFL WIND (RATADIYA)	130	104	78	121	17:05	42	06:10	1.89	1.78	1.78	74
AWEMP1PL_PTNGR_IDR_W	324.4	109	151	247	18:23	18	11:00	3	2.25	2.25	94
AYANARP4_ZURA_BHJ_S	92.4	67	34	89	15:29	20	06:01	0.78	0.84	0.84	35
BLUELEAF_CP_PCHR_HW	115.5	28	14	105	17:32	2	08:55	1.54	0.84	0.84	35
CGERP_MORJAR_BHJ2_HW	29.7	0	0	0	00:00	0	00:00	-	0	0	0
CPTTNPL WIND (DAYAPAR)	126	89	59	103	12:56	4	06:04	1.8	1.74	1.74	73
GIWEL-II WIND (VADVA)	250	171	117	232	16:12	31	06:04	3.87	3.79	3.79	158
GIWEL-III WIND (NARANPAR)	300	176	110	194	12:59	28	06:01	3.55	3.26	3.26	136
IGESL_DAYAPAR_BHUJ_W	250	234	91	235	13:45	56	00:00	2.98	2.18	2.18	91
NETRA_KOTDA_BHUJ_W	206.5	156	97	182	11:26	30	06:01	3.25	3.13	3.13	130
NTPC_REL_DYPR_BHUJ_W	146	71	67	72	02:34	12	06:12	1.92	1.54	1.54	64
OEPL WIND (OSTRO KUTCH)	50	40	27	41	18:59	8	06:00	0.87	0.76	0.76	32
OKWPL WIND (OSTRO KUTCH)	250	189	150	215	17:06	123	06:10	4.26	3.61	3.61	150
POWERICA WIND	50.6	72	35	90	17:18	5	06:26	0.71	1.27	1.27	53
RENEW AP2 WIND (GHADSISA)	300	222	111	260	15:47	45	06:00	4.84	4.53	4.53	189
RENEW WIND (BHUVAD)	230.1	194	122	211	19:21	41	06:11	3.64	3.78	3.78	158
RGMHP1_PATODA_KLM_W	135.3	83	31	129	21:51	0	10:46	0.88	1	1	42
RGMHS1_TLJPR_SLPR_HW	161.7	112	67	123	17:18	32	06:10	1.02	0.98	0.98	41
SAUPL_HJRTPR_RJGR_W	100	0	0	0	00:00	0	00:00	0.68	0	0	0
SITAC WIND	300	222	213	281	15:18	65	06:16	5.53	5.36	5.36	223
SRIJAN WIND	148.5	0	0	0	-	0	-	2.54	0	0	0
TEQGREEN_WASI_KLM_W	70.2	0	0	56	11:40	0	06:00	0.52	0.37	0.37	15
TORRENT SOLARGEN LIMITED	115	77	48	137	15:13	13	06:59	1.56	1.7	1.7	71
TOTAL	23,173.28	-	-					190.89	183.98	183.98	7,670

RENEWABLE_BESS

स्टेशन/ Station/Constituents	स्थापित क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
ARE37L_PSS5_KPS1_B	160	-92	-1	256	23:52	-146	11:12	0.09	-0.27	-0.27	-11
ARE43L_PSS10_KPS3_B	360	21	-1	305	23:55	-402	13:25	0.12	-0.58	-0.58	-24
SUB-TOTAL	520	-71	-2	-	-	-	-	0.21	-0.85	-0.85	-35
TOTAL	520	-	-					0.21	-0.85	-0.85	-35

REGIONAL GENERATION SUMMARY

	THERMAL GEN MU	GAS GEN MU	SOLAR GEN MU	WIND GEN MU	HYDRO GEN MU	NUCLEAR GEN MU	OTHER GEN MU	TOTAL GEN MU	SCHEDULE MU
ISGS	394.42	17.2	-	-	6.3	59.98	-	477.9	481.73
IPP	443.98	4.2	-	-	-	-	-	448.18	433.77
Constituents	646	27.3	129.2	129.2	20.9	-	2.6	955.1	935.7
Renewables	-	-	92.49	91.49	-	-	-	183.13	191.1
Region	1,484.4	48.7	221.69	220.69	27.2	59.98	2.6	2,064.31	2,042.3

4(A) अंतर क्षेत्रीय विनिमय/INTER-REGIONAL EXCHANGES (Import=(+ve) /Export =(-ve))

SL.No.	Element	20:00	03:00	अधिकतम पस्पर विनिमय/Maximum Interchange (MW)		आयात/Import in MU	नरि्यात/Export in MU	शुद्ध विनिमय/NET
		(MW)	MW	आयात/Import (MW)	नरि्यात/Export (MW)			
	EAST REGION WEST REGION / /Import/Export between EAST REGION and WEST REGION							
1	220KV-KORBA-BUDIPADAR	40	-8	68	-116	0.32	-0.75	-0.43
2	220KV-RAIGARH-BUDIPADAR	67	0	110	-157	0.37	-0.79	-0.42
3	400KV-JAGDALPUR-JEYPORE	-	-	-	-	-	-2.55	-2.55
4	400KV-RAIGARH-JHARSUGUDA	162	174	474	-501	1.39	-0.73	0.66
5	400KV-SIPAT-RANCHI	-	-	-	-	0	-9.7	-9.7
6	765KV-DHARJAYGARH-JHARSUGUDA	-1,043	95	230	-1,479	0	-14.08	-14.08
7	765KV-DHARJAYGARH-RANCHI	-1,924	-1,511	-	-3,070	0	-46.9	-46.9
8	765KV-RAIPUR-PS (DURG)-JHARSUGUDA	274	586	943	-594	5.3	0	5.3
	Sub-Total EAST REGION	-2,424	-664	1,825	-5,917	7.38	-75.5	-68.12
	NORTH REGION WEST REGION / /Import/Export between NORTH REGION and WEST REGION							
1	132KV-RAJGHAT-LALITPUR	0	0	-	0	0	0	0
2	220KV-BHANPURA-MODAK	-58	-50	-	-72	0	-1.18	-1.18
3	220KV-BHANPURA-RANPUR	-30	-30	-	-30	0	-1.8	-1.8
4	220KV-MALANPUR-AURIYA	64	-19	72	-40	0.34	-0.1	0.24
5	220KV-MEHGAON-AURIYA	0	-1	73	-37	0.3	-0.01	0.29
6	400KV-KANSARI-KANKROLI	-48	-92	143	-198	0.23	-1.68	-1.45
7	400KV-KANSARI-KANKROLI 2(BYPASS AT BHINMAL)	-34	-65	99	-137	0.16	-1.17	-1.01
8	400KV-NEEMUCH-CHITTORGARH	-26	-278	567	-381	4.02	-2.66	1.36

NORTH REGION WEST REGION / /Import/Export between NORTH REGION and WEST REGION								
9	400KV-SUJALPUR-RAPP	153	-113	734	-222	6.6	-0.82	5.78
10	400KV-VINDHYACHAL PS-RIHAND(III)	-1	-1	-	-1	0	-0.02	-0.02
11	765KV-BANASKANTHA-CHITTORGARH	-318	-426	962	-1,808	1.63	-15.6	-13.97
12	765KV-GWALIOR-AGRA	-951	-1,714	-	-2,040	0	-26.91	-26.91
13	765KV-GWALIOR-JAIPUR	-597	-1,354	1,367	-1,501	7.7	-15.03	-7.33
14	765KV-GWALIOR-ORAI	500	617	654	-	9.6	0	9.6
15	765KV-JABALPUR-ORAI	-578	-946	36	-1,060	0	-26.29	-26.29
16	765KV-SATNA-ORAI	-644	-897	-	-912	0	-14.23	-14.23
17	765KV-VINDHYACHAL(PS)-VARANASI	-2,493	-2,503	-	-3,396	0	-58.74	-58.74
18	HVDC 500KV VINDHYACHAL B/B	-205	-205	-	-207	0	-4.83	-4.83
19	HVDC500KV-MUNDRA-MOHINDARGARH	-976	-1,448	-	-1,454	0	-32.76	-32.76
20	HVDC800KV-CHAMPA-KURUKSHETRA	-2,511	-4,545	-	-4,577	0	-85.09	-85.09
Sub-Total NORTH REGION		-8,753	-14,070	4,707	-18,073	30.58	-288.92	-258.34
SOUTH REGION WEST REGION / /Import/Export between SOUTH REGION and WEST REGION								
1	220KV-KOLHAPUR-CHIKKODI-II	-	-	-	-	-	-	0
2	220KV-PONDA-AMBEWADI	2	2	2	-	0.04	0	0.04
3	220KV-TALANGADE(MS)-CHIKKODI-II	-	-	-	-	-	-	0
4	220KV-XELDEM-AMBEWADI	96	87	-	105	2.03	0	2.03
5	400KV-KOLHAPUR GIS-NARENDRA KUDGI	1,212	1,389	2,081	-	34.38	0	34.38
6	765KV-SOLAPUR-RAICHUR	-591	870	1,631	-1,424	13.19	-4.69	8.5
7	765KV-WARDHA-NIZAMABAD	-1,699	-395	-	-2,418	0	-26.1	-26.1
8	765KV-WARORA-PG-WARANGAL	-1,940	-624	-	-2,579	0	-28.96	-28.96
9	HVDC205KV-BHADRAWATI-RAMAGUNDAM	503	302	902	-	11.88	0	11.88
10	HVDC400KV-BARSUR-L.SILERU	-	-	-	-	-	-	0
11	HVDC800KV-RAIGARH-GIS-HVDC-PUGALUR	-603	-1,497	-	-1,500	0	-23.78	-23.78
Sub-Total SOUTH REGION		-3,020	134	4,616	-7,816	61.52	-83.53	-22.01
TOTAL IR EXCHANGE		-14,197	-14,600	11,148	-31,806	99.48	-447.95	-348.47

4(B) Inter Regional Schedule & Actual Exchange (Import=(+ve) /Export =(-ve)) in MU

	ISGS+GNA+URS Schedule	TGNA BILT Schedule	GDAM Schedule	DAM Schedule	HPDAM Schedule	RTM Schedule	Total IR Schedule	Total IR Actual	NET IR UI
WR-ER	25.62	-28.15		-27.4		0	-65.36	-68.12	-2.76
WR-NR	-215.54	-69.94		81.19		0	-210.06	-258.34	-48.28
WR-SR	-64.11	-8.96		-38.33		0	-96.7	-22.01	74.69
Total	-254.03	-107.05	0	15.46	0	0	-372.12	-348.47	23.65

5.Frequency Profile

RANGE(Hz)	< 48.8	< 49	< 49.2	< 49.5	< 49.7	< 49.9	>= 49.9 - <= 50.05	> 50.05
%	.00	.00	.00	.00	.00	4.20	71.50	24.30

Percentage of Time Frequency Remained outside IEGC Band	28.5
No. of hours frequency outside IEGC Band	6.84

अधिकतम /Maximum		न्यूनतम/Minimum		औसत/Average	Freq Variation	Standard	Freq. in 15 mnt blk	
Frequency	Time	Frequency	Time	Frequency	Index	Deviation	Max.	Min.
50.25	07:59:40	49.84	11:32:30	50.01	0.045	0.067	50.18	49.9

6.वोल्टेज प्रोफाइल/Voltage Profile: 400kV

	अधिकतम/Maximum		न्यूनतम/Minimum		वभिवांतर/Voltage (in %)			Hours Volatge Outside IEGC Range(VDI)
STATION	VOLTAGE	TIME	VOLTAGE	TIME	>= 4000	IEGC Band (A)	> 420	(100-A)*24/100
AMRELI - 400KV	430.98	04:15	0	13:27	0	30.3	69.6	16.7
ASOJ - 400KV	415.58	04:00	0	10:57	0	99.9	0	0
BHILAI - 400KV	413.73	08:59	405.49	15:58	0	100	0	0
BHOPAL - 400KV	420.53	18:31	410.56	05:52	0	99.8	.2	0
BOISAR - 400KV	421.28	04:00	398.8	15:47	0	95.8	4.2	1
DEHGAM - 400KV	418.96	04:52	399.58	14:43	0	100	0	0
DHULE - 400KV	414.05	18:04	399.36	15:45	0	100	0	0
DAMOH - 400KV	416.34	08:01	402.01	19:50	0	100	0	0
GPEC - 400KV	417.43	04:54	394.39	14:44	0	100	0	0
GWALIOR - 400KV	411.98	08:05	396.29	00:21	0	100	0	0
HAZIRA - 400KV	400.9	00:00	400.9	00:00	0	100	0	0
INDORE - 400KV	414.12	20:15	403.28	15:41	0	100	0	0
ITARSI - 400KV	410.64	18:04	400.73	05:51	0	100	0	0
JETPUR - 400KV	422.52	04:24	0	13:27	0	64.5	35.4	8.5
KALA - 400KV	414.82	04:00	392.21	15:16	0	100	0	0
KALWA - 400KV	419.92	04:01	392.02	15:16	0	100	0	0
KARAD - 400KV	424.81	18:04	402.79	10:44	0	84.7	15.3	3.7
KASOR - 400KV	417.27	04:48	0	14:02	0	99.9	0	0
KHANDWA - 400KV	414.35	18:03	404.76	05:52	0	100	0	0
MAGARWADA - 400KV	414.35	03:15	391.98	14:38	0	100	0	0
MAPUSA - 400KV	421.27	03:43	389.66	09:06	0	97.1	2.9	.7
NAGDA - 400KV	416.23	18:04	405.61	15:41	0	100	0	0
NEW KOYNA - 400KV	429.84	03:27	417.5	09:49	0	18.1	81.9	19.7
PARLI - 400KV	423.05	18:06	389.74	11:17	0	97.4	2.6	.6
RAIPUR - 400KV	412.76	08:59	404.57	15:58	0	100	0	0
RAIGARH - 400KV	419.75	08:58	413.05	15:58	0	100	0	0

VAPI - 400KV	413.97	04:22	390.13	15:15	0	100	0	0
WARDHA - 400KV	420.36	10:08	408.59	06:37	0	94.9	5.1	1.2

6.1 Voltage Profile: 765kV

	/Maximum		/Minimum		/Voltage (in %)			Hours Voltage Outside IEGC Range(VDI)
STATION	VOLTAGE	TIME	VOLTAGE	TIME	< 728	IEGC Band (A)	> 800	(100-A)*24/100
BINA - 765KV	792.17	08:01	770.97	00:20	0	100	0	0
DURG - 765KV	788.47	10:00	779.28	00:00	0	100	0	0
GWALIOR - 765KV	796.8	15:14	770.34	00:55	0	100	0	0
INDORE - 765KV	779.09	08:01	761.14	15:41	0	100	0	0
KOTRA - 765KV	791.58	09:45	777.2	05:51	0	100	0	0
SASAN - 765KV	788.87	08:59	773.33	01:36	0	100	0	0
SATNA - 765KV	797.2	15:08	777.4	00:00	0	100	0	0
SEONI - 765KV	793	10:02	771	05:46	0	100	0	0
SIPAT - 765KV	779.22	09:42	762.58	06:11	0	100	0	0
TAMNAR - 765KV	791.41	09:02	775.17	15:11	0	100	0	0
VADODARA - 765KV	796.54	20:17	761.3	09:49	0	100	0	0
WARDHA - 765KV	792.33	10:35	768.65	06:47	0	100	0	0

7(A).Power Energy/Schedule Details

State	Off- Peak Hours (03:00)												
	T-GNA Bilateral (MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX HPDAM (MW)	IEX RTM (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXIL HPDAM (MW)	PXI RTM (MW)	HPX GDAM (MW)	HPX DAM (MW)	HPX HPDAM (MW)	HPX RTM (MW)
AMNSIL	0	-	154.54	-	118.81	-	0	-	0	-	-	-	-
BALCO	0	-	0	-	0	-	0	-	0	-	-	-	-
CHHATTISG ..	-10.72	-	-45.3	-	-33.7	-	0	-	0	-	-	-	-
DNHDDPDCL	21.73	-	0	-	101.42	-	0	-	0	-	-	-	-
GOA	90.21	-	-13	-	-20	-	0	-	0	-	-	-	-
GUJARAT	305.45	-	23.24	-	113.4	-	0	-	0	-	-	-	-
MADHYA PRADESH	-18.52	-	-258.83	-	34.93	-	0	-	0	-	-	-	-
MAHARASHT..	440.25	-	371.75	-	537.02	-	0	-	0	-	-	-	-
RIL JAMNAGAR	0	-	0	-	0	-	0	-	0	-	-	-	-
TOTAL	828.4	0	232.4	-	851.88	0	0	-	0	-	-	-	-

State	Peak Hours (20:00)												
	T-GNA Bilateral (MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX HPDAM (MW)	IEX RTM (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXIL HPDAM (MW)	PXI RTM (MW)	HPX GDAM (MW)	HPX DAM(MW)	HPX HPDAM (MW)	HPX RTM (MW)
AMNSIL	0	-	0	-	122.67	-	0	-	0	-	-	-	-
BALCO	0	-	0	-	0	-	0	-	0	-	-	-	-
CHHATTISG ..	728.87	-	-32.3	-	-154.9	-	0	-	0	-	-	-	-
DNHDDPDCL	147.3	-	0	-	0	-	0	-	0	-	-	-	-
GOA	90.21	-	2.69	-	-70	-	0	-	0	-	-	-	-
GUJARAT	203.76	-	-0.51	-	226.5	-	0	-	0	-	-	-	-
MADHYA PRADESH	-66.79	-	16.89	-	59.61	-	0	-	0	-	-	-	-
MAHARASHT..	243.43	-	807.77	-	1,644.56	-	0	-	0	-	-	-	-
RIL JAMNAGAR	0	-	0	-	0	-	0	-	0	-	-	-	-
TOTAL	1,346.78	0	794.54	0	1,828.44	0	0	-	0	-	-	-	-

State	Day Energy (MU)						
	ISGS + GNA Schedule	T-GNA Bilateral (MW)	GDAM Schedule	DAM Schedule	HPDAM Schedule	RTM Schedule	Total (MU)
AMNSIL	8.5	0	0.71	1.8	-	1.95	12.96
BALCO	17.15	0	0	0	-	0	17.15
CHHATTISGARH	81.95	2.12	0	-5.31	-	0.19	78.96
DNHDDPDCL	27.28	1.56	0	0	-	3.02	31.86
GOA	15.86	2.31	0	-0.45	-	-1.16	16.56
GUJARAT	149.82	10.11	1.47	6.99	-	7.18	175.57
MADHYA PRADESH	162.27	-1.85	-0.08	6.86	-	-2.23	164.97
MAHARASHTRA	196.47	4.79	1.06	25.71	-	30.69	258.72
RIL JAMNAGAR	6.63	0	0	0	-	0	6.63
TOTAL	665.93	19.04	3.16	35.6	0	39.64	763.38

7(B).Power Energy/Schedule Details

State	ISGS + GNA Schedule		T-GNA Bilateral (MW)		IEX GDAM (MW)		PXIL GDAM(MW)		HPX GDAM(MW)		IEX DAM (MW)		PXIL DAM(MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
AMNSIL	549.6	127.4	0	0	61.48	0.19	0	0	0	0	278.18	0	0	0
BALCO	728.76	713.51	0	0	0	0	0	0	0	0	0	0	0	0
CHHATTISGARH	4,378.06	2,991.49	828.46	-280.12	0	-1.7	0	0	0	0	78.79	-1,091.8	0	0
DNHDDPDCL	1,188.05	1,041.43	162.76	20.76	0	0	0	0	0	0	0	0	0	0
GOA	810.05	547.96	119.19	76.69	1.39	0	0	0	0	0	6.3	-73	0	0
GUJARAT	7,724.09	3,713.46	682.25	157.15	302.47	0.01	0	0	0	0	821.22	-26.88	0	0
MADHYA PRADESH	7,598.64	5,574.39	8.21	-248.98	98.35	-111.4	0	0	0	0	1,543.94	-921.5	0	0
MAHARASHTRA	9,533.06	7,475.31	440.25	-40.14	402.56	-27.3	0	0	0	0	1,972.4	354.87	0	0
RIL JAMNAGAR	-	-	-	-	-	-	-	-	-	-	-	-	-	-

State	HPX DAM(MW)		IEX HPDAM (MW)		PXIL HPDAM(MW)		HPX HPDAM(MW)		IEX RTM (MW)		PXIL RTM(MW)		HPX RTM(MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
AMNSIL	0	0	0	0	0	0	0	0	209.6	0	0	0	0	0
BALCO	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CHHATTISGARH	0	0	0	0	0	0	0	0	404.85	-265.3	0	0	0	0
DNHDDPDCL	0	0	0	0	0	0	0	0	304.26	0	0	0	0	0
GOA	0	0	0	0	0	0	0	0	2.36	-150	0	0	0	0
GUJARAT	0	0	0	-386.9	0	0	0	0	918.38	49.65	0	0	0	0
MADHYA PRADESH	0	0	0	0	0	0	0	0	1,156.08	-1,098.6	0	0	0	0
MAHARASHTRA	0	0	0	0	0	0	0	0	2,481.72	-211.31	0	0	0	0
RIL JAMNAGAR	-	-	-	-	-	-	-	-	-	-	-	-	-	-

8.Major Reservoir Particulars

RESERVOIR	DESIGNED			PRESENT		LAST YEAR		LAST DAY	MONTH	
	MDDL(Mts)	FRL(Mts)	Energy(MU)	Level(Mts)	Energy(MU)	Level(Mts)	Energy(MU)	Inflow(Mus)	"Prog.Inflow (Mus)"	"Prog.Usage (Mus)"
INDIRASAGAR	243.23	262.13	1,367	249.92	303.58	252.22	405.44	250	0	0
OMKARESHWAR	193.3	196.6	21.958	194.66	-	195.74	-	194.77	0	0
UKAI	82.296	105.156	770.67	96	281.87	96.702	311.147	96.07	0	0
KADANA	114.3	127.711	126.266	121	36.16	117.751	13.67	121.05	0	0
SSP	110.64	138.68	1,342.091	128.05	601.64	121.87	319.24	128.33	0	0
KOYNA	615.54	659.43	3,160	622.85	505.032	628.15	819.79	0	0	0
TATA BHIRA	590.1	607.1	582.4	594.28	115.05	594.73	1,291.79	594.38	0	0

9.Significant events (If any):

10.System Constraints (If any)

11. Weather Condition:

12. RE/Load Curtailment details

State	Load Curtailment			RE Curtailment				Reason
	Energy	Maximum	At the time of maximum demand	Wind		Solar		
	MU	MW	MW	Max MW	Energy(MU)	Max MW	Energy(MU)	
AMNSIL	0	0	0	0	0	0	0	
BALCO	0	0	0	0	0	0	0	
CHHATTISGARH	0	0	0	0	0	0	0	
DAMAN AND DIU	0	0	0	0	0	0	0	
GOA	0	0	0	0	0	0	0	
GUJARAT	0	0	0	927.513	2.96	2,406.523	6.56	In view of system requirement and to control High UD at high frequency
MADHYA PRADESH	0	0	0	0	0	0	0	
MAHARASHTRA	0	0	0	0	0	0	0	
RIL JAMNAGAR	0	0	0	0	0	0	0	

Shift In Charge