GRID CONTROLLER OF INDIA (GRID-INDIA)
WESTERN REGIONAL LOAD DESPATCH CENTRE
DAILY OPERATION REPORT OF WESTERN REGION

Power Supply Position in Western Region For 05-Jun-2026

Date of Reporting:06-Jun-2026

1. Regional Availability/Demand:

Evening Peak (20:00) MW				Off-Peak (03:00) MW				/Day Energy(Net MU)	
मांग पूर्ति/ Demand Met	अभाव/Shortage	आवश्यकता/ Requirement	आवृत्ति/Freq (Hz)	मांग पूर्ति/ Demand Met	अभाव/Shortage	आवश्यकता/ Requirement	आवृत्ति/Freq (Hz)	मांग पूर्ति/Demand Met	अभाव/Shortage
65,692	0	65,692	50.1	66,367	0	66,367	50	1,706.1	0

2(A) /Load Details (/in state periphery) in MU:

राज्य/STATE	State's Control Area Generation (Net MU)							/Net SCH	/Drawal	/UI	Availability	Requirement	/ Shortage	/ Consump -tion
	तापीय/ THERMAL	जलीय/ HYDRO	गैस/ Gas	पवन/ WIND	सौर/ SOLAR	अन्य/ OTHERS	कुल/TOTAL	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)
BALCO	-	0	0	0	0	0	0	17.1	16.9	-0.2	16.9	16.9	0	16.9
CHHATTISGARH	38	0.2	0	0	5.4	1	44.6	83.1	82.9	-0.2	127.5	127.5	0	127.5
DNHDDPDCL	-	0	0	0	0	0	0	31.2	31	-0.2	31	31	0	31
AMNSIL	6.7	0	0	0	0	0	6.7	14.2	14.2	0	20.9	20.9	0	20.9
GOA	0.4	0	0	0	0	0	0.4	16.2	16.1	-0.1	16.5	16.5	0	16.5
GUJARAT	188.7	2.1	13.5	88.5	79.7	0	372.5	179.7	174	-5.7	546.5	546.5	0	546.5
MADHYA PRADESH	81.1	7.3	0	16.9	10.8	1.5	117.6	153.7	153.7	0	271.3	271.3	0	271.3
MAHARASHTRA	332.5	12.9	9.9	25.5	35.4	0	416.2	256.9	252.9	-4	669.1	669.1	0	669.1
RIL JAMNAGAR	-	0	0	0	0	0	0	6.4	6.4	0	6.4	6.4	0	6.4
Region	647.4	22.5	23.4	130.9	131.3	2.5	958	758.5	748.1	-10.4	1,706.1	1,706.1	0	1,706.1

2(B) / /State's Demand Met in MW and day energy forecast and deviation particulars

राज्य/State	Evening Peak (20:00) MW			Off-Peak (03:00) MW				/Day Energy(Net MU)	
	मांग पूर्ति/ Demand Met	अभाव/ Shortage	आवश्यकता/ Requirement at Evening peak	मांग पूर्ति/ Demand Met	अभाव/ Shortage	आवश्यकता/ Requirement at Off-Peak	AVG (MW)	पूर्वानुमान/ForeCast(MU)	विचलन/Deviation[Fore .. -Consumption] (MU)
BALCO	708	0	708	707	0	707	706	-	-16.9
CHHATTISGARH	5,388	0	5,388	5,435	0	5,435	5,316	-	-127.5
DNHDDPDCL	1,242	0	1,242	1,313	0	1,313	1,287	-	-31
AMNSIL	857	0	857	945	0	945	871	-	-20.9
GOA	779	0	779	630	0	630	688	-	-16.5
GUJARAT	22,709	0	22,709	20,479	0	20,479	22,768	-	-546.5
MADHYA PRADESH	5,192	0	5,192	10,684	0	10,684	9,904	-	-271.3
MAHARASHTRA	28,559	0	28,559	25,916	0	25,916	27,881	-	-669.1
RIL JAMNAGAR	258	0	258	258	0	258	265	-	-6.4
Region	65,692	0	65,692	66,367	0	66,367	69,686	0	-1,706.1

2(C) /State's Demand Met in MW (/maximum demand met and /Maximum requirement of the day details)

राज्य/State	Maximum Demand, corresponding shortage and requirement details for the day				ACE			
	अधिकतम मांग पूर्ति/Maximum Demand Met of the day	समय/Time	अभाव/Shortage at maximum demand	आवश्यकता/Requirement at the max demand met of the day	ACE_MAX	बजे/Time	ACE_MIN	बजे/Time
BALCO	709	22:00	0	709	-	-	-	-
CHHATTISGARH	5,863	23:30	0	5,863	451.35	12:06:00	-378.39	14:40:00
DNHDDPDCL	1,339	00:00	0	1,339	106.35	20:01:00	-294.51	12:01:00
AMNSIL	945	04:00	0	945	356.64	00:47:00	-313.25	12:15:00
GOA	786	22:30	0	786	55.54	00:30:00	-154.53	06:39:00
GUJARAT	25,804	15:00	0	25,804	2,369.46	13:05:00	-1,036.01	15:00:00
MADHYA PRADESH	12,406	16:30	0	12,406	1,485.45	06:26:00	-826.69	07:22:00
MAHARASHTRA	30,319	16:00	0	30,319	1,195.1	10:01:00	-1,462.84	12:01:00
RIL JAMNAGAR	275	16:00	0	275	-	-	-	-
WR	77,470	16:00	0	77,470	-	-	-	-

3(A) State Entities Generation:

CHHATTISGARH

स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
KORBA EAST EXT(DSPM)(2*250)	500	451	450	467	09:56	348	13:20	11.48	10.53	439
KORBA(W) CSETCL(4*210 + 1*500)	1,340	289	289	293	05:24	262	16:29	7.24	6.19	258
MARWA TPS(1*500 + 1*500)	1,000	797	795	959	14:57	562	13:22	19.36	18.33	764
OTHER CPP	50	0	0	0	-	0	-	2.94	2.94	123
TOTAL THERMAL	2,890	1,537	1,534	-	-	-	-	41.02	37.99	1,584
HASDEO BANGO(3*40)	120	1	1	40	21:04	1	00:01	0.12	0.12	5
KWB MINI MICRO(2*0.85)	1.7	0	0	0	-	0	-	0	0	0
SMALL HYDRO	50	0	0	0	-	0	-	0.04	0.04	2
TOTAL HYDEL	171.7	1	1	-	-	-	-	0.16	0.16	7
WIND	0	0	0	0	-	0	-	0	0	0
SOLAR	842	0	0	649	11:50	19	06:00	5.42	5.42	226
BIO MASS	50	0	0	0	-	0	-	1.03	1.03	43
TOTAL BIO MASS	50	0	0	-	-	-	-	1.03	1.03	43
TOTAL CHHATTISGARH	3,953.7	-	-	-	-	-	-	47.63	44.6	1,860

GUJARAT

स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
AECO(1*120 + 2*121)	362	233	236	242	07:09	152	09:41	5.04	4.59	191
ALTPS(2*125)	250	69	69	70	00:28	69	00:00	1.91	1.49	62
APL MUNDRA(4*330 + 2*660 + 3*660)	4,620	3,641	3,279	4,253	23:12	2,547	10:52	82.3	75.61	3,150
BLTPS(2*250)	500	323	321	328	20:12	270	13:00	7.91	6.68	278
GANDHINAGAR(GTPS)(3*210)	630	616	566	627	21:27	361	08:29	11.99	10.86	453
KLTPS(2*75)	150	64	65	67	19:25	57	14:01	1.53	1.34	56
OTHER CPP	1,000	0	0	0	-	0	-	5.64	6.7	279
SLPP(4*125)	500	304	303	313	17:12	191	11:03	7.56	6.5	271
STPS(2*250)	500	296	291	496	22:17	283	12:12	7.66	6.86	286
UKAI(2*200 + 1*210 + 1*500)	1,110	381	368	385	20:03	238	17:37	7.62	6.67	278
VADINAR(2*600)	1,200	1,132	1,125	1,159	21:59	603	13:23	23.39	21.87	911
WANAKBORI(7*210 + 1*800)	2,270	1,927	1,697	1,962	21:52	1,108	14:54	36.01	33.05	1,377
TOTAL THERMAL	13,092	8,986	8,320	-	-	-	-	198.56	182.22	7,592
DGBP(1*107 + 1*112 + 1*376)	594	0	0	0	00:00	0	00:00	0	0	0
ESSAR POWER GAS(3*110 + 1*185)	515	0	0	0	-	0	-	0	0	0
GIPCL STG(3*32 + 49)	145	0	0	0	00:00	0	00:00	0	0	0
GIPCL STG 2(111 + 54)	165	0	0	0	00:00	0	00:00	0	0	0
GPEC(3*138 +241)	654	0	0	0	-	0	-	0	0	0
GPPC(2*351.43)	702	0	0	0	00:00	0	00:00	0	0	0
GSEC(3*52)	156	0	0	0	00:00	0	00:00	0	0	0
SUGEN 1(3*382.5)	1,147.5	776	654	1,000	21:15	0	07:10	11	10.67	445
UNOSUGEN(1*382.5)	382.5	278	71	361	22:28	0	17:03	2.93	2.83	118
UTRAN STG II(1*229 + 1*146(ST))	375	0	0	0	00:00	0	00:00	0	0	0
TOTAL GAS	4,836	1,054	725	-	-	-	-	13.93	13.5	563
KADANA(4*60)	240	50	0	60	18:15	0	00:09	0.38	0.38	16
LBC PANAM HYDRO	5	0	0	0	-	0	-	0.08	0.08	3
PVT HYDRO	20.6	0	0	0	-	0	-	0.14	0.14	6
UKAI HYDRO(4*75)	300	69	70	135	21:29	0	17:26	1.7	1.67	70
TOTAL HYDEL	565.6	119	70	-	-	-	-	2.3	2.27	95
WIND	8,836	4,430	3,566	4,565	17:32	1,969	07:16	88.52	88.52	3,688
SOLAR	15,238	0	9	9,636	13:14	13	06:05	79.66	79.66	3,319
BIO MASS	51.65	0	0	0	-	0	-	1.03	1.03	43
TOTAL GUJARAT	42,619.25	-	-	-	-	-	-	384	367.2	15,300

MADHYA PRADESH

स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
AMARKANTAK(1*210)	210	0	0	0	00:00	0	00:00	0.74	0.51	21
BLA IPP(2*45)	90	84	57	84	20:00	43	11:19	1.62	1.46	61
JP BINA(2*250)	500	470	467	476	05:45	273	09:05	9.89	9.08	378
SANJAY GANDHI TPS(4*210 + 1*500)	1,340	906	888	942	17:37	724	08:32	22.03	20.15	840
SATPURA IV(2*250)	500	472	476	480	17:41	257	09:09	10.27	9.38	391
SINGAJI(2*600 + 2*660)	2,520	2,292	2,313	2,344	05:37	1,311	13:21	47.72	45.04	1,877
TOTAL THERMAL	5,160	4,224	4,201	-	-	-	-	92.27	85.62	3,568
BANASAGAR TONS(3*105)	315	0	0	103	15:50	0	00:00	0.08	0.08	3
BARGI(2*45)	90	30	31	33	17:55	30	11:36	0.73	0.72	30
BIRSINGHPUR	20	0	0	0	-	0	-	0	0	0
BSGR(DEVLONE)(3*20)	60	0	0	0	00:00	0	00:00	0	0	0
BSGR(SILPARA)(2*15)	30	0	0	0	00:00	0	00:00	0	0	0
INDIRASAGAR(8*125)	1,000	212	329	653	19:12	0	11:00	4.17	4.15	173
JHINNA(2*10)	20	0	0	0	00:00	0	17:02	0	0	0
MADIKHEADA(3*20)	60	60	60	60	00:00	60	00:00	0	0	0
MP CHAMBAL	386	0	0	0	-	0	-	0	0	0
OMKARESHWAR(8*65)	520	320	0	477	22:23	0	00:00	2.38	2.37	99
PENCH(2*80)	160	0	0	0	-	0	-	0	0	0
RAJGHAT HYDRO(3*15)	45	0	0	0	00:00	0	00:00	0	0	0
TOTAL HYDEL	2,706	622	420	-	-	-	-	7.36	7.32	305
WIND	2,670	399	444	1,030	14:24	306	09:16	16.94	16.94	706
SOLAR	2,370	0	0	1,706	13:07	11	06:00	10.83	10.83	451
BIO + SMALL HYDRO	100	0	0	0	-	0	-	1.47	1.47	61
TOTAL MADHYA PRADESH	13,006	-	-	-	-	-	-	128.87	122.18	5,091

MAHARASHTRA

स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
APML TIRODA(5*660)	3,300	3,077	3,111	3,144	20:43	1,710	15:15	65.45	61.77	2,574
BHUSAWAL(1*210 + 2*500+1*660)	1,870	1,052	1,021	1,095	00:47	660	09:56	23.06	21.8	908
CHANDRAPUR(2*210 + 5*500)	2,920	1,800	1,816	2,000	11:16	1,221	09:22	40.37	37.76	1,573
DAHANU(2*250)	500	473	286	502	23:25	280	09:13	8.41	7.48	312
IEPL(1*270)	270	273	266	274	19:02	150	13:15	5.62	4.92	205
JAIGAD(4*300)	1,200	897	906	1,002	01:11	740	06:15	22.78	20.92	872
JPL DHULE (SHIRPUR)(2*150)	300	242	258	281	22:58	145	11:30	5.8	5.4	225
KHAPARKHEDA(4*210 + 1*500)	1,340	980	935	999	06:20	721	11:24	24.13	22.35	931
KORADI(1*210 + 3*660)	4,170	1,661	1,173	1,750	23:59	1,130	11:51	35.64	33.29	1,387
NASIK(3*210)	630	343	349	400	01:12	298	17:22	9.11	8.37	349
OTHER CPP	3,305	0	0	0	-	0	-	38.19	38.19	1,591
PARAS(2*250)	500	400	349	430	00:00	263	13:45	9.37	8.39	350
PARLI(3*250)	750	589	597	647	00:00	377	13:30	14.23	12.8	533
RATTAN INDIA (AMARAVATI)(5*270)	1,350	1,224	1,214	1,250	22:45	736	11:52	30.55	28.24	1,177
SWPGL(4*135)	540	434	431	444	21:32	257	11:23	10.81	9.74	406
TROMBAY(250+1*500)	750	484	383	662	22:19	373	12:20	9.96	10.49	437
VIPL(2*300)	600	503	493	536	00:18	318	13:12	12.01	11.12	463
TOTAL THERMAL	24,295	14,432	13,588	-	-	-	-	365.49	343.03	14,293
TROMBAY_GAS(1*120+1*60)	180	165	168	174	22:33	105	11:22	3.38	3.35	140
URAN(4*108 + 2*120)	672	270	273	279	08:31	259	14:35	6.7	6.56	273
TOTAL GAS	852	435	441	-	-	-	-	10.08	9.91	413
BHIRA(6*25)	150	130	4	151	22:21	3	15:18	1.31	1.31	55
BHIRA PSS	150	161	114	164	18:20	0	00:00	1.65	1.65	69
BHIRA TR(2*40)	80	0	0	0	-	0	-	0.26	0.26	11
BHIVPURI(3*24 + 2*1.5)	75	48	14	48	20:00	31	14:21	1.03	1.03	43
GHATGHAR(2*125)	250	0	0	122	23:12	-152	09:05	0.2	0.2	8
HYDRO VTRNA(1*60)	60	0	0	0	00:00	0	00:00	0	0	0
HYDROSMLHY_PTN	350	0	0	0	-	0	-	5.83	5.71	238
KHOPOLI(3*24)	72	24	24	24	03:45	5	15:44	0.44	0.44	18
KOYNA I AND II(4*(65+5) + 4*(75+5))	600	139	41	239	23:20	25	14:46	1.23	1.19	50
KOYNA III(4*80)	320	0	0	79	23:36	0	00:00	0.21	0.2	8
KOYNA ST-IV(4*250)	1,000	0	0	0	20:00	0	14:47	0	0	0
TILLARI(1*66)	66	0	0	0	00:00	0	00:00	0	0	0
OTHER HYDRO	122	0	0	0	-	0	-	5.32	5.32	222
TOTAL HYDEL	3,295	502	197	-	-	-	-	17.48	17.31	722
WIND	5,321	657	603	1,366	22:08	99	08:22	25.48	25.48	1,062
SOLAR	6,028	93	170	4,713	12:00	193	06:00	35.44	35.44	1,477
TOTAL MAHARASHTRA	39,791	-	-	-	-	-	-	453.97	431.17	17,967

3(B) Regional Entities Generation

ISGS

स्टेशन/ Station/Constituents	स्थापित क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
GADARWARA(2*800)	1,600	1,452	1,160	1,517	22:41	770	17:41	25.12	26.94	25.1	1,046
GANDHAR(3*144.3 + 1*224.49)	657	215	12	371	23:29	0	16:07	1.55	1.61	1.49	62
KAPS(2*220)	440	391	391	391	00:00	391	00:00	9.53	10.52	9.5	396
KAPS3&4(2*700)	1,400	592	600	604	07:19	585	15:36	27.96	31.17	28.57	1,190
KAWAS(4*106 + 2*116.1)	656.2	428	0	499	22:54	0	16:07	1.86	2.59	2.49	104
KHARGONE(2*660)	1,320	1,210	744	1,262	22:12	659	03:45	19.63	21.63	20.11	838
KSTPS1&2(3*200 + 3*500)	2,100	1,299	1,293	1,358	22:33	735	10:01	30.98	33.02	30.35	1,265
KSTPS3(1*500)	500	484	479	492	23:25	275	10:00	9.81	10.43	9.71	405
LARA(2*800)	1,600	1,477	1,501	1,520	06:30	808	12:27	31.02	33.2	31.13	1,297
MOUDA I(2*500)	1,000	926	929	969	23:20	442	17:38	17.38	18.59	16.68	695
MOUDA II(2*660)	1,320	1,175	1,213	1,216	02:31	592	17:38	22.59	24.46	21.54	898
NSPCL(2*250)	500	441	447	470	23:12	238	13:06	8.92	9.89	9.02	376
RGPPL(2*320 + 4*331.75)	1,967	807	405	1,298	23:18	361	10:00	13.18	13.77	13.26	553
SASAN(6*660)	3,960	3,733	3,072	3,769	22:49	2,014	09:16	73	78.9	73.66	3,069
SIPAT I(3*660)	1,980	1,859	1,892	1,937	07:07	1,009	10:57	38.61	41.04	38.57	1,607
SIPAT II(2*500)	1,000	941	936	970	15:21	500	08:31	19.76	20.99	19.75	823
SOLAPUR STPS(2*660)	1,320	659	713	1,260	22:51	662	17:32	17.47	19.87	18.32	763
SSP(RBPH+CHPH)(6*200 + 5*50)	1,450	47	47	974	00:00	0	09:59	5.21	5.31	5.22	218
TARAPUR I(2*160)	320	154	152	156	21:15	146	12:34	3.41	3.82	3.4	142
TARAPUR II(2*540)	1,080	796	793	816	08:31	778	16:27	18.72	20.96	18.67	778
VSTPS I(6*210)	1,260	888	930	945	04:32	420	09:07	18.76	20.97	18.42	768
VSTPS II(2*500)	1,000	852	872	900	02:23	423	09:04	18.08	19.21	17.68	737
VSTPS III(2*500)	1,000	920	938	971	20:44	504	09:26	18.64	19.81	18.73	780
VSTPS IV(2*500)	1,000	914	940	963	07:02	482	09:55	18.64	20.21	18.81	784
VSTPS V(1*500)	500	460	471	480	17:55	239	08:10	9.3	9.97	9.39	391
SUB-TOTAL	30,930.2	23,120	20,930	-	-	-	-	479.13	518.88	479.57	19,985
TOTAL	30,930.2	-	-					479.13	518.88	479.57	19,985

IPP/JV

स्टेशन/ Station/Constituents	स्थापित क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
ACBIL(2*135 + 2*50 + 2*30 + 1*63)	493	295	288	299	18:05	252	12:33	6.68	7.94	6.72	280
ADANI RAIPUR(2*685)	1,370	1,114	1,100	1,143	20:16	672	11:33	23.54	26.4	23.68	987
APL RAIGARH(1*600)	600	569	559	579	06:59	287	09:03	11.89	12.72	11.99	500
BALCO(4*300)	1,200	902	981	999	01:51	666	09:29	20.79	20.84	20.79	866
DB POWER(2*600)	1,200	1,142	1,128	1,165	01:59	636	09:55	23.82	25.43	24.06	1,003
DCPP(2*135)	270	111	111	111	00:00	111	00:00	2.37	2.76	2.38	99
DGEN(3*400)	1,200	0	133	762	00:56	0	12:07	1.77	1.82	1.66	69
DHARIWAL CTU(2*300)	600	265	267	512	00:00	144	13:21	6.35	6.66	6.06	253
GMR WARORA(2*300)	600	560	544	573	22:22	304	08:51	11.77	12.83	11.83	493
JHABUA POWER(1*600)	600	530	492	556	22:05	294	15:50	10.64	11.33	10.65	444
JP NIGRIE(2*660)	1,320	1,258	1,257	1,275	22:44	692	10:00	25.84	27.76	26.34	1,098
JPL STG-I(4*250)	1,000	969	878	993	20:08	447	11:12	17.19	19.94	17.62	734
JPL STG-II(4*600)	2,400	2,310	2,319	2,340	03:27	1,702	09:19	47.7	53.59	50.69	2,112
JSW MAHANADI(3*600)	1,800	1,702	1,709	1,740	23:19	901	08:53	34.09	36.83	34.2	1,425
LANCO(2*300)	600	540	544	563	21:19	292	09:58	11.25	12.6	11.4	475
MAHAN ENERGEN(2*600)	1,200	905	905	1,059	00:00	607	12:14	19.74	21.37	19.83	826
MB POWER(2*600)	1,200	1,184	1,177	1,192	20:47	491	12:35	22.21	23.58	22.14	923
MCCPL(1*300)	300	156	224	235	23:14	153	17:20	4.33	4.95	4.4	183
RKM POWER(4*360)	1,440	1,166	1,315	1,323	05:15	727	09:17	25.86	28.79	26	1,083
SARDA ENERGY & MINERALS LTD(2*300)	600	518	526	529	02:38	511	06:36	11.24	12.66	11.46	478
TPCL(5*800)	4,000	3,396	2,773	3,809	23:01	2,042	08:10	65.42	71	64.86	2,703
TRN ENERGY(2*300)	600	503	529	533	00:46	313	13:14	11.18	12.14	11.02	459
VEDANTA_LIMITED_CG (1*600)	600	0	0	0	00:00	0	10:24	0.2	0.05	0.05	2
SUB-TOTAL	25,193	20,095	19,759	-	-	-	-	415.87	453.99	419.83	17,495
TOTAL	25,193	-	-					415.87	453.99	419.83	17,495

RENEWABLE

स्टेशन/ Station/Constituents	स्थापित क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
AGE25BL_PSS9_KPS1_HS	100	0	0	82	12:45	0	00:00	0.17	0.15	0.15	6
AHEJ5L_PSS8_KPS3_HS	100	0	0	91	12:04	0	05:59	1.59	0.88	0.88	37
AYANARP4_DVSR_BHJ_HS	37.5	0	0	21	13:01	0	00:00	0.17	0.15	0.15	6
ACL_PSS3_KPS1_S	200	0	0	205	11:46	0	00:00	1.75	1.69	1.69	70
ACL_PSS4_KPS1_HS	125	0	0	115	12:53	0	00:00	1.58	0.87	0.87	36
AGE24AL_PSS3_KPS1_S	400	0	0	402	12:29	0	00:00	3.86	3.28	3.28	137
AGE24L_PSS10_KPS3_S	150	0	0	122	11:35	0	00:00	0.67	0.71	0.71	30
AGE24L_PSS5_KPS1_S	150	0	0	156	11:38	0	06:00	1.56	1.23	1.23	51
AGE25AL_PSS2_KPS1_S	500	0	0	353	12:23	0	04:32	1.32	2.42	2.42	101
AGE25BL_PSS2_KPS1_S	582.98	0	0	396	12:54	0	00:03	1.54	2.89	2.89	120
AGE25CL_PSS8_KPS3_S	350	0	0	456	13:14	0	00:22	5.18	2.96	2.96	123
AGE26AL_PSS3_KPS1_S	62.5	0	0	45	12:22	0	00:00	0.65	0.61	0.61	25
AGE26AL_PSS6_KPS1_S	750	0	0	701	13:24	0	00:00	7.55	7.23	7.23	301
AGE26BL_PSS10_KPS1_HS	142	0	0	61	13:23	0	00:00	0.1	0.09	0.09	4
AGE26BL_PSS10_KPS1_S	150	0	0	98	13:35	0	00:00	0.42	0.38	0.38	16
AGE26BL_PSS2_KPS1_S	167	0	0	132	09:01	0	00:00	0.44	0.85	0.85	35
AHEJ5L_PSS5_KPS1_S	570	0	0	580	13:25	0	00:00	4.21	3.95	3.95	165
APSEZ_PSS3_KPS1_S	200	0	0	207	14:08	0	00:00	1.74	1.63	1.63	68
ARE3L_PSS8_KPS3_HS	25	0	0	19	13:45	0	00:00	0.23	0.21	0.21	9
ARE45L_PSS5_KPS1_S	250	0	0	248	14:00	0	00:00	2.36	2	2	83
ARE55L_PSS3_KPS1_HS	25	0	0	23	11:17	0	00:00	0.22	0.2	0.2	8
ARE55L_PSS3_KPS1_S	162.5	0	0	21	00:27	0	00:00	1.57	0.24	0.24	10
ARE56L_PSS10_KPS1_S	500	0	0	465	11:15	0	00:00	2.42	2.96	2.96	123
ARE56L_PSS4_KPS1_S	225	0	0	212	13:12	0	00:00	2.13	2.01	2.01	84
ARE56L_PSS9_KPS1_S	400	0	0	238	12:03	0	00:00	1.05	1.81	1.81	75
ARE57L_PSS13_KPS1_S	850	0	0	617	08:39	0	00:22	2.24	4.18	4.18	174
AREH4L_PSS1_KPS1_SF	1,000	0	0	729	17:25	0	02:47	3.9	5.38	5.38	224
ARINSUN SOLAR (BARSAITADESH)	250	0	0	202	14:18	0	18:00	1.28	1.36	1.36	57
ASEJ6PL_PSS8_KPS3_HS	35	0	0	25	13:14	0	00:00	0.07	0.06	0.06	3
ASEJ6PL_PSS8_KPS3_S	50	0	0	39	12:13	0	00:00	0.48	0.52	0.52	22
ATHENA SOLAR	250	0	0	197	14:16	0	00:00	1.37	1.31	1.31	55
AVAADA_AGAR_RUMS_S	200	0	0	190	14:44	0	00:00	0.87	0.91	0.91	38
AYANARP4_DVSR_BHJ_HW	150	0	0	132	13:45	0	00:00	1.58	1.46	1.46	61
BEEMPOW_AGAR_RUMS_S	350	0	0	310	14:17	0	00:00	1.68	1.7	1.7	71
BLUELEAF_CP_PCHR_HS	128.7	0	0	78	13:45	0	00:00	0.9	0.76	0.76	32
CGERP_MORJAR_BHJ2_HS	30.8	0	0	24	13:14	0	00:00	0.13	0.11	0.11	5
ESPL_RSP SOLAR	200	0	0	198	13:54	0	00:00	1.33	2.3	2.3	96
GANDHAR SOLAR	20	0	0	19	11:22	0	00:00	0.13	0.27	0.27	11
GIPCL_PSS1_KPS2_S	600	0	0	541	14:17	0	00:00	4.37	4.06	4.06	169
GIPCL_RSP SOLAR	100	0	0	104	14:04	0	06:00	0.65	1.17	1.17	49
GSEC 2	100	0	0	68	12:06	0	00:00	0.4	0.48	0.48	20
GSECL_RSP SOLAR	100	0	0	0	00:00	0	00:00	0	0	0	0
KAWAS SOLAR	56	0	0	49	11:17	0	00:00	0.33	0.28	0.28	12
KPIG_GSECLS_KPS2_S	200	0	0	135	14:10	0	00:00	1.08	1.11	1.11	46
MAHINDRA SOLAR (BADWAR)	250	0	0	232	11:18	0	00:00	1.02	1.36	1.36	57
MASAYA SOLAR	300	0	0	261	14:19	0	00:00	1.5	1.57	1.57	65
NTPCREL_PSS1_KPS3_S	1,095	0	0	333	08:51	0	00:00	2.7	2.64	2.64	110
NTPCREL_PSS2_KPS2_S	1,555	0	0	1,403	12:45	0	00:00	9.02	8.81	8.81	367
SAELP4_GSECLS_KPS2_S	400	0	0	279	09:51	0	00:00	2.55	2.9	2.9	121
SAELP5_GSECLS_KPS2_S	400	0	0	341	13:41	0	00:00	2.55	2.45	2.45	102
SGEL_RSP_S	100	0	0	97	14:06	0	00:00	0.63	0.67	0.67	28
SHERISHA RAIPUR	50	0	0	42	11:28	0	00:00	0.29	0.3	0.3	13
SOLAPUR SOLAR PV PROJECT	23	0	0	16	12:45	0	00:00	0.13	0.11	0.11	5
TPREL_RSP SOLAR	100	0	0	101	14:09	0	00:00	0.65	1.16	1.16	48
TPSOURY_BRVD_NMCH_S	160	0	0	165	12:24	0	02:34	1.15	1.22	1.22	51
TPSOURY_KWAI_NMCH_S	170	0	0	182	12:34	0	00:00	1.22	1.28	1.28	53
AHEJ5L_PSS8_KPS3_HW	65	25	33	50	04:28	12	09:25	1.49	0.75	0.75	31
RSRPL_GHTND_KLM_W	138.6	112	101	119	21:04	19	12:32	0.66	0.62	0.62	26
ACL_PSS4_KPS1_W	156	93	88	127	21:07	40	10:03	1.83	2.08	2.08	87
ADANI WIND ENERGY KUTCHH FOUR LTD	300	114	246	264	04:30	127	17:38	4.42	4.34	4.34	181
AGE24L_PSS4_KPS1_W	100	73	64	95	21:10	27	09:58	0.91	1.51	1.51	63
AGE25BL_PSS9_KPS1_HW	130	86	45	91	21:30	17	10:05	0.95	0.93	0.93	39
AGE25CL_PSS11_KPS3_W	185	121	101	165	00:32	65	11:51	1.93	1.89	1.89	79
AGE25CL_PSS14_KPS3_W	65	48	23	54	00:31	19	11:56	0.57	0.55	0.55	23
AGE26AL_PSS12_KPS3_W	137.5	86	96	117	01:34	35	12:11	1.03	1.01	1.01	42
AGE26BL_PSS10_KPS1_W	156	52	88	139	00:53	36	09:50	1.34	1.86	1.86	78
AHEJ5L_PSS4_KPS1_W	60	44	40	55	07:24	14	10:00	0.56	0.95	0.95	40
AHEJ5L_PSS5_KPS1_HW	202.8	132	76	156	21:00	56	10:01	1.88	1.82	1.82	76
ALFANAR WIND (NANAVALKA)	300	123	188	215	05:38	90	07:21	4.05	3.71	3.71	155
APRAAVA ENERGY PRIVATE LIMITED (AEPL)	252	138	163	201	00:16	104	12:26	3.12	3.52	3.52	147

APSEZ_PSS4_KPS1_W	52	34	29	49	00:29	11	07:46	0.61	0.61	0.61	25
ARE3L_PSS8_KPS3_HW	41.6	18	19	33	00:58	9	10:01	0.37	0.49	0.49	20
ARE41L_PSS13_KPS1_W	124.8	43	49	103	04:26	26	09:50	1.07	1.25	1.25	52
ARE41L_PSS3_KPS1_W	250	122	150	229	01:23	60	09:41	2.14	3.3	3.3	138
ARE41L_PSS4_KPS1_W	50	38	41	48	01:16	15	09:54	0.6	0.87	0.87	36
ARE41L_PSS8_KPS3_W	125	53	64	91	00:29	33	09:27	2.85	1.41	1.41	59
ARE48L_SRPL_PSS9_KPS1_W	119.6	0	0	0	00:00	0	00:00	0	0	0	0
ARE55L_PSS3_KPS1_HW	25	14	7	15	21:35	4	11:31	0.16	0.15	0.15	6
ASEJ6PL_PSS8_KPS3_HW	62.4	45	43	51	05:34	31	12:34	1.3	1.26	1.26	53
ASIPL WIND (BARANDA)	170.1	0	0	0	00:00	0	00:00	0	0	0	0
AWEK1L WIND (RATADIYA)	425	224	339	380	09:14	166	07:20	6.2	6.75	6.75	281
AWEKFL WIND (RATADIYA)	130	81	91	115	01:32	42	12:45	1.69	1.65	1.65	69
AWEMP1PL_PTNGR_IDR_W	324.4	113	131	218	02:29	81	08:53	2.95	2.62	2.62	109
AYANARP4_ZURA_BHJ_S	92.4	42	21	111	14:25	2	00:07	0.86	0.78	0.78	33
BLUELEAF_CP_PCHR_HW	115.5	51	0	111	13:55	17	09:04	1.47	1.29	1.29	54
CGERP_MORJAR_BHJ2_HW	29.7	0	0	0	00:00	0	00:00	-	0	0	0
CPTTNPL WIND (DAYAPAR)	126	89	89	89	00:00	89	00:00	1.23	2.13	2.13	89
GIWEL-II WIND (VADVA)	250	90	168	200	00:12	71	12:47	3.13	3.13	3.13	130
GIWEL-III WIND (NARANPAR)	300	92	146	169	04:46	78	12:10	3.39	2.83	2.83	118
IGESL_DAYAPAR_BHUJ_W	250	101	98	198	00:00	76	13:14	2.4	2.18	2.18	91
NETRA_KOTDA_BHUJ_W	206.5	73	140	166	09:47	82	16:05	2.93	2.77	2.77	115
NTPC_REL_DYPR_BHUJ_W	146	87	71	101	00:00	42	00:00	1.3	1.23	1.23	51
OEPL WIND (OSTRO KUTCH)	50	30	35	40	04:03	14	11:26	0.85	0.69	0.69	29
OKWPL WIND (OSTRO KUTCH)	250	181	178	198	21:12	78	00:00	3.78	3.61	3.61	150
POWERICA WIND	50.6	65	48	78	13:12	43	07:16	0.72	1.31	1.31	55
RENEW AP2 WIND (GHADSISA)	300	114	226	239	04:37	136	17:42	4.37	4.19	4.19	175
RENEW WIND (BHUVAD)	230.1	123	177	207	04:12	76	07:39	3.3	3.4	3.4	142
RGMHP1_PATODA_KLM_W	135.3	65	64	124	22:49	21	09:09	0.8	0.92	0.92	38
RGMHS1_TLJPR_SLPR_HW	161.7	131	121	143	21:01	34	12:32	1.11	1.09	1.09	45
SAUPL_HJRTPR_RJGR_W	100	48	54	67	21:10	18	00:00	0.63	0.61	0.61	25
SITAC WIND	300	163	241	257	09:10	129	07:20	4.87	4.77	4.77	199
SRIJAN WIND	148.5	66	129	153	09:21	54	07:31	2.11	2.68	2.68	112
TEQGREEN_WASI_KLM_W	70.2	32	41	54	13:23	8	06:00	0.56	0.28	0.28	12
TORRENT SOLARGEN LIMITED	115	49	77	93	08:10	29	12:08	1.45	1.51	1.51	63
TOTAL	23,173.28	-	-					176.62	180.59	180.59	7,529

RENEWABLE_BESS

स्टेशन/ Station/Constituents	स्थापित क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
ARE37L_PSS5_KPS1_B	160	76	0	256	00:05	-186	10:57	0.11	0.02	0.02	1
ARE43L_PSS10_KPS3_B	360	51	1	307	23:47	-361	10:28	0.18	-0.12	-0.12	-5
SUB-TOTAL	520	127	1	-	-	-	-	0.29	-0.1	-0.1	-4
TOTAL	520	-	-					0.29	-0.1	-0.1	-4

REGIONAL GENERATION SUMMARY

	THERMAL GEN MU	GAS GEN MU	SOLAR GEN MU	WIND GEN MU	HYDRO GEN MU	NUCLEAR GEN MU	OTHER GEN MU	TOTAL GEN MU	SCHEDULE MU
ISGS	396.97	17.24	-	-	5.22	60.14	-	479.57	479.13
IPP	418.17	1.66	-	-	-	-	-	419.83	415.87
Constituents	647.4	23.4	131.3	130.9	22.5	-	2.5	958	947.6
Renewables	-	-	93.29	87.3	-	-	-	180.49	176.91
Region	1,462.54	42.3	224.59	218.2	27.72	60.14	2.5	2,037.89	2,019.51

4(A) अंतर क्षेत्रीय विनिमय/INTER-REGIONAL EXCHANGES (Import=(+ve) /Export =(-ve))

SL.No.	Element	20:00	03:00	अधिकतम पस्पर विनिमय/Maximum Interchange (MW)		आयात/Import in MU	नरि्यात/Export in MU	शुद्ध विनिमय/NET
		(MW)	MW	आयात/Import (MW)	नरि्यात/Export (MW)			
	EAST REGION WEST REGION / /Import/Export between EAST REGION and WEST REGION							
1	220KV-KORBA-BUDIPADAR	42	37	69	-122	0.47	-0.69	-0.22
2	220KV-RAIGARH-BUDIPADAR	48	34	116	-126	0.67	-0.54	0.13
3	400KV-JAGDALPUR-JEYPORE	-	-	-	-	-	-2.22	-2.22
4	400KV-RAIGARH-JHARSUGUDA	149	265	481	-427	1.31	-0.73	0.58
5	400KV-SIPAT-RANCHI	-	-	-	-	0	-7.37	-7.37
6	765KV-DHARJAYGARH-JHARSUGUDA	-301	-680	-	-1,369	0	-18.89	-18.89
7	765KV-DHARJAYGARH-RANCHI	-1,413	-1,592	-	-2,631	0	-39.49	-39.49
8	765KV-RAIPUR-PS (DURG)-JHARSUGUDA	432	461	757	-642	3.2	0	3.2
	Sub-Total EAST REGION	-1,043	-1,475	1,423	-5,317	5.65	-69.93	-64.28
	NORTH REGION WEST REGION / /Import/Export between NORTH REGION and WEST REGION							
1	132KV-RAJGHAT-LALITPUR	0	0	-	0	0	0	0
2	220KV-BHANPURA-MODAK	-52	-55	-	-72	0	-1.21	-1.21
3	220KV-BHANPURA-RANPUR	-30	-30	-	-30	0	-1.42	-1.42
4	220KV-MALANPUR-AURIYA	0	-5	56	-31	0.23	-0.08	0.15
5	220KV-MEHGAON-AURIYA	84	10	84	-29	0.86	-0.04	0.82
6	400KV-KANSARI-KANKROLI	-77	-58	207	-180	1.09	-1.05	0.04
7	400KV-KANSARI-KANKROLI 2(BYPASS AT BHINMAL)	-53	-41	143	-125	0.75	-0.73	0.02
8	400KV-NEEMUCH-CHITTORGARH	-221	-246	625	-339	3.42	-2.44	0.98

NORTH REGION WEST REGION / /Import/Export between NORTH REGION and WEST REGION								
9	400KV-SUJALPUR-RAPP	-19	-51	904	-132	7.58	-0.46	7.12
10	400KV-VINDHYACHAL PS-RIHAND(III)	-1	-1	-	-1	0	-0.02	-0.02
11	765KV-BANASKANTHA-CHITTORGARH	-224	-259	769	-820	2.5	-8.37	-5.87
12	765KV-GWALIOR-AGRA	-1,307	-1,510	130	-1,853	0.04	-23.71	-23.67
13	765KV-GWALIOR-JAIPUR	-1,155	-1,212	1,645	-1,325	9.62	-13.91	-4.29
14	765KV-GWALIOR-ORAI	482	568	591	-137	7.65	-0.26	7.39
15	765KV-JABALPUR-ORAI	-872	-839	122	-1,031	0	-24.88	-24.88
16	765KV-SATNA-ORAI	-922	-847	-	-1,030	0	-15.34	-15.34
17	765KV-VINDHYACHAL(PS)-VARANASI	-2,589	-2,365	-	-3,214	0	-57.59	-57.59
18	HVDC 500KV VINDHYACHAL B/B	93	-205	93	-207	0.68	-3.42	-2.74
19	HVDC500KV-MUNDRA-MOHINDARGARH	-975	-972	-	-982	0	-24.28	-24.28
20	HVDC800KV-CHAMPA-KURUKSHETRA	-3,534	-2,513	-	-3,567	0	-68.26	-68.26
Sub-Total NORTH REGION		-11,372	-10,631	5,369	-15,105	34.42	-247.47	-213.05
SOUTH REGION WEST REGION / /Import/Export between SOUTH REGION and WEST REGION								
1	220KV-KOLHAPUR-CHIKKODI-II	-	-	-	-	-	-	0
2	220KV-PONDA-AMBEWADI	2	2	2	-	0.04	0	0.04
3	220KV-TALANGADE(MS)-CHIKKODI-II	-	-	-	-	-	-	0
4	220KV-XELDEM-AMBEWADI	94	82	-	98	2.09	0	2.09
5	400KV-KOLHAPUR GIS-NARENDRA KUDGI	1,660	1,083	1,906	-	30.95	0	30.95
6	765KV-SOLAPUR-RAICHUR	490	183	960	-865	5.72	-2.94	2.78
7	765KV-WARDHA-NIZAMABAD	-916	-1,140	-	-2,151	0	-30.41	-30.41
8	765KV-WARORA-PG-WARANGAL	-1,158	-1,314	-	-2,348	0	-34.2	-34.2
9	HVDC205KV-BHADRAWATI-RAMAGUNDAM	503	503	504	-	12	0	12
10	HVDC400KV-BARSUR-L.SILERU	-	-	-	-	-	-	0
11	HVDC800KV-RAIGARH-GIS-HVDC-PUGALUR	-603	-603	-	-603	0	-14.62	-14.62
Sub-Total SOUTH REGION		72	-1,204	3,372	-5,869	50.8	-82.17	-31.37
TOTAL IR EXCHANGE		-12,343	-13,310	10,164	-26,291	90.87	-399.57	-308.7

4(B) Inter Regional Schedule & Actual Exchange (Import=(+ve) /Export =(-ve)) in MU

	ISGS+GNA+URS Schedule	TGNA BILT Schedule	GDAM Schedule	DAM Schedule	HPDAM Schedule	RTM Schedule	Total IR Schedule	Total IR Actual	NET IR UI
WR-ER	29.25	-25.41		-22.75		0	-55.03	-64.28	-9.25
WR-NR	-201.38	-68.77		92.21		0	-181.17	-213.05	-31.88
WR-SR	-61.03	-9.37		-42.85		0	-97.88	-31.37	66.51
Total	-233.16	-103.55	0	26.61	0	0	-334.08	-308.7	25.38

5.Frequency Profile

RANGE(Hz)	< 48.8	< 49	< 49.2	< 49.5	< 49.7	< 49.9	>= 49.9 - <= 50.05	> 50.05
%	.00	.00	.00	.00	.00	5.00	86.70	8.30

Percentage of Time Frequency Remained outside IEGC Band	13.3
No. of hours frequency outside IEGC Band	3.192

अधिकतम /Maximum		न्यूनतम/Minimum		औसत/Average	Freq Variation	Standard	Freq. in 15 mnt blk	
Frequency	Time	Frequency	Time	Frequency	Index	Deviation	Max.	Min.
50.18	09:03:30	49.83	07:04:20	49.99	0.027	0.05	50.09	49.89

6.वोल्टेज प्रोफाइल/Voltage Profile: 400kV

	अधिकतम/Maximum		न्यूनतम/Minimum		वभिवांतर/Voltage (in %)			Hours Volatge Outside IEGC Range(VDI)
STATION	VOLTAGE	TIME	VOLTAGE	TIME	>= 4000	IEGC Band (A)	> 420	(100-A)*24/100
AMRELI - 400KV	429.93	18:53	410.6	14:45	0	27.9	72.1	17.3
ASOJ - 400KV	416.75	04:01	395.07	14:34	0	100	0	0
BHILAI - 400KV	414.55	09:04	405.08	23:17	0	100	0	0
BHOPAL - 400KV	420.31	07:57	409.57	22:45	0	99.5	.5	.1
BOISAR - 400KV	420.63	04:01	400.23	12:34	0	99.5	.5	.1
DEHGAM - 400KV	418.81	04:01	398.66	14:40	0	100	0	0
DHULE - 400KV	414.54	03:59	403.28	14:33	0	100	0	0
DAMOH - 400KV	416	09:04	402.26	09:19	0	100	0	0
GPEC - 400KV	416.66	04:00	394.84	14:24	0	100	0	0
GWALIOR - 400KV	413.39	07:57	395.52	21:19	0	100	0	0
HAZIRA - 400KV	400.9	00:00	400.9	00:00	0	100	0	0
INDORE - 400KV	414.71	07:57	405.46	14:39	0	100	0	0
ITARSI - 400KV	411.52	08:00	400.43	22:42	0	100	0	0
JETPUR - 400KV	422.28	18:53	400.97	10:13	0	88.1	11.9	2.9
KALA - 400KV	414.45	03:59	392.26	14:34	0	100	0	0
KALWA - 400KV	419.43	03:58	395.45	14:35	0	100	0	0
KARAD - 400KV	423.83	04:01	398.87	14:32	0	80.3	19.7	4.7
KASOR - 400KV	417.36	04:02	0	16:07	0	99.8	0	0
KHANDWA - 400KV	413.27	07:46	406.3	22:39	0	100	0	0
MAGARWADA - 400KV	413.11	03:34	392.67	14:34	0	100	0	0
MAPUSA - 400KV	404.23	00:00	404.23	00:00	0	100	0	0
NAGDA - 400KV	416.89	03:59	405.97	14:28	0	100	0	0
NEW KOYNA - 400KV	431.35	03:57	413.86	14:44	0	26.5	73.5	17.7
PARLI - 400KV	419.91	17:24	389.74	00:46	0	100	0	0
RAIPUR - 400KV	413.34	08:24	404.31	16:50	0	100	0	0
RAIGARH - 400KV	421.26	09:15	413.18	16:51	0	95.3	4.7	1.1

VAPI - 400KV	413.24	04:01	390.06	14:34	0	100	0	0
WARDHA - 400KV	418.44	00:00	418.44	00:00	0	100	0	0

6.1 Voltage Profile: 765kV

	/Maximum		/Minimum		/Voltage (in %)			Hours Voltage Outside IEGC Range(VDI)
STATION	VOLTAGE	TIME	VOLTAGE	TIME	< 728	IEGC Band (A)	> 800	(100-A)*24/100
BINA - 765KV	794.18	07:56	769.01	21:18	0	100	0	0
DURG - 765KV	788.46	10:00	770.09	06:23	0	100	0	0
GWALIOR - 765KV	795.73	07:40	767.93	20:52	0	100	0	0
INDORE - 765KV	779.4	07:56	762.93	22:45	0	100	0	0
KOTRA - 765KV	786.52	04:01	781.2	06:22	0	100	0	0
SASAN - 765KV	790.3	07:56	771.2	21:18	0	100	0	0
SATNA - 765KV	798.92	07:54	773.58	21:04	0	100	0	0
SEONI - 765KV	794	12:02	775	22:22	0	100	0	0
SIPAT - 765KV	781.68	09:14	764.71	22:25	0	100	0	0
TAMNAR - 765KV	795.64	09:16	778.44	22:33	0	100	0	0
VADODARA - 765KV	796.31	04:02	757.3	14:09	0	100	0	0
WARDHA - 765KV	792.57	09:01	765.13	06:24	0	100	0	0

7(A).Power Energy/Schedule Details

State	Off- Peak Hours (03:00)												
	T-GNA Bilateral (MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX HPDAM (MW)	IEX RTM (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXIL HPDAM (MW)	PXI RTM (MW)	HPX GDAM (MW)	HPX DAM (MW)	HPX HPDAM (MW)	HPX RTM (MW)
AMNSIL	0	-	149.71	-	171.93	-	0	-	0	-	-	-	-
BALCO	0	-	0	-	0	-	0	-	0	-	-	-	-
CHHATTISG ..	263.37	-	30.03	-	-11.9	-	0	-	0	-	-	-	-
DNHDDPDCL	21.73	-	0	-	106.25	-	0	-	0	-	-	-	-
GOA	90.21	-	-8.39	-	-70	-	0	-	0	-	-	-	-
GUJARAT	259.84	-	141.46	-	328.98	-	0	-	0	-	-	-	-
MADHYA PRADESH	-365.69	-	-147.17	-	28.75	-	0	-	0	-	-	-	-
MAHARASHT..	361.88	-	302.31	-	1,126.42	-	0	-	0	-	-	-	-
RIL JAMNAGAR	0	-	0	-	0	-	0	-	0	-	-	-	-
TOTAL	631.34	0	467.95	-	1,680.43	0	0	-	0	-	-	-	-

State	Peak Hours (20:00)												
	T-GNA Bilateral (MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX HPDAM (MW)	IEX RTM (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXIL HPDAM (MW)	PXI RTM (MW)	HPX GDAM (MW)	HPX DAM(MW)	HPX HPDAM (MW)	HPX RTM (MW)
AMNSIL	0	-	0	-	121.7	-	0	-	0	-	-	-	-
BALCO	0	-	0	-	0	-	0	-	0	-	-	-	-
CHHATTISG ..	911.72	-	5.85	-	-17.5	-	0	-	0	-	-	-	-
DNHDDPDCL	118.32	-	28.98	-	0	-	0	-	0	-	-	-	-
GOA	90.21	-	4.39	-	-20	-	0	-	0	-	-	-	-
GUJARAT	420.81	-	64.27	-	136.57	-	0	-	0	-	-	-	-
MADHYA PRADESH	-315.17	-	9.32	-	74.07	-	0	-	0	-	-	-	-
MAHARASHT..	146.3	-	594.09	-	1,160.22	-	0	-	0	-	-	-	-
RIL JAMNAGAR	0	-	0	-	0	-	0	-	0	-	-	-	-
TOTAL	1,372.19	0	706.9	0	1,455.06	0	0	-	0	-	-	-	-

State	Day Energy (MU)						
	ISGS + GNA Schedule	T-GNA Bilateral (MW)	GDAM Schedule	DAM Schedule	HPDAM Schedule	RTM Schedule	Total (MU)
AMNSIL	9.19	0	0.04	1.73	-	3.26	14.23
BALCO	17.11	0	0	0	-	0	17.11
CHHATTISGARH	80.08	5.15	0.09	-2.04	-	-0.16	83.12
DNHDDPDCL	26.89	1.26	0	0.24	-	2.86	31.25
GOA	14.78	2.32	0.08	-0.21	-	-0.73	16.25
GUJARAT	152.2	10.23	0.98	7.14	-	10.32	180.87
MADHYA PRADESH	157.68	-6.82	-0.06	5.85	-	-2.91	153.74
MAHARASHTRA	193.71	3.24	0.33	22.88	-	36.48	256.64
RIL JAMNAGAR	6.23	0	0.13	0.02	-	0.05	6.42
TOTAL	657.87	15.38	1.59	35.61	0	49.17	759.63

7(B).Power Energy/Schedule Details

State	ISGS + GNA Schedule		T-GNA Bilateral (MW)		IEX GDAM (MW)		PXIL GDAM(MW)		HPX GDAM(MW)		IEX DAM (MW)		PXIL DAM(MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
AMNSIL	576.65	189.61	0	0	41.1	0	0	0	0	0	194.14	0	0	0
BALCO	723.57	656.22	0	0	0	0	0	0	0	0	0	0	0	0
CHHATTISGARH	4,353.94	2,976.01	911.72	-289.41	154.54	-3.1	0	0	0	0	111.34	-685	0	0
DNHDDPDCL	1,188	988.55	122.51	20.76	0	0	0	0	0	0	28.98	0	0	0
GOA	732.9	477.09	119.67	76.69	19.4	0	0	0	0	0	10.85	-46	0	0
GUJARAT	7,905.52	3,993.28	652.85	105.81	146.43	0	0	0	0	0	847.06	-27.79	0	0
MADHYA PRADESH	7,959.2	4,770.95	7.18	-914.66	109.49	-94.4	0	0	0	0	1,537.57	-503.9	0	0
MAHARASHTRA	9,456.5	7,121.93	364.77	-135.94	386.83	-45.14	0	0	0	0	1,726.65	160.58	0	0
RIL JAMNAGAR	-	-	-	-	-	-	-	-	-	-	-	-	-	-

State	HPX DAM(MW)		IEX HPDAM (MW)		PXIL HPDAM(MW)		HPX HPDAM(MW)		IEX RTM (MW)		PXIL RTM(MW)		HPX RTM(MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
AMNSIL	0	0	0	0	0	0	0	0	235.68	2.97	0	0	0	0
BALCO	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CHHATTISGARH	0	0	0	0	0	0	0	0	277.87	-228.5	0	0	0	0
DNHDDPDCL	0	0	0	0	0	0	0	0	294.6	0	0	0	0	0
GOA	0	0	0	0	0	0	0	0	3.16	-90	0	0	0	0
GUJARAT	0	0	0	-498.8	0	0	0	0	1,699.17	-239.17	0	0	0	0
MADHYA PRADESH	0	0	0	0	0	0	0	0	478.22	-1,240.82	0	0	0	0
MAHARASHTRA	0	0	127.2	0	0	0	0	0	3,026.95	270.72	10.61	0	14.21	0
RIL JAMNAGAR	-	-	-	-	-	-	-	-	-	-	-	-	-	-

8.Major Reservoir Particulars

RESERVOIR	DESIGNED			PRESENT		LAST YEAR		LAST DAY	MONTH	
	MDDL(Mts)	FRL(Mts)	Energy(MU)	Level(Mts)	Energy(MU)	Level(Mts)	Energy(MU)	Inflow(Mus)	"Prog.Inflow (Mus)"	"Prog.Usage (Mus)"
INDIRASAGAR	243.23	262.13	1,367	249.86	299.98	252.15	399.09	249.92	0	0
OMKARESHWAR	193.3	196.6	21.958	194.87	-	195.69	-	194.66	0	0
UKAI	82.296	105.156	770.67	95.9	278.06	96.644	308.736	96	0	0
KADANA	114.3	127.711	126.266	120.98	35.95	117.727	13.55	121	0	0
SSP	110.64	138.68	1,342.091	128.04	601.103	121.7	312.303	128.04	0	0
KOYNA	615.54	659.43	3,160	622.75	498.57	628.2	824.173	0	0	0
TATA BHIRA	590.1	607.1	582.4	594.2	109.77	594.73	129.54	594.28	0	0

9.Significant events (If any):

10.System Constraints (If any)

11. Weather Condition:

12. RE/Load Curtailment details

State	Load Curtailment			RE Curtailment				
	Energy	Maximum	At the time of maximum demand	Wind		Solar		Reason
	MU	MW	MW	Max MW	Energy(MU)	Max MW	Energy(MU)	
AMNSIL	0	0	0	0	0	0	0	
BALCO	0	0	0	0	0	0	0	
CHHATTISGARH	0	0	0	0	0	0	0	
DAMAN AND DIU	0	0	0	0	0	0	0	
GOA	0	0	0	0	0	0	0	
GUJARAT	0	0	0	0	0	0	0	
MADHYA PRADESH	0	0	0	0	0	0	0	
MAHARASHTRA	0	0	0	0	0	0	0	
RIL JAMNAGAR	0	0	0	0	0	0	0	

Shift In Charge