GRID CONTROLLER OF INDIA (GRID-INDIA)
WESTERN REGIONAL LOAD DESPATCH CENTRE
DAILY OPERATION REPORT OF WESTERN REGION

Power Supply Position in Western Region For 07-Jun-2026

Date of Reporting:08-Jun-2026

1. Regional Availability/Demand:

Evening Peak (20:00) MW				Off-Peak (03:00) MW				/Day Energy(Net MU)	
मांग पूरता/ Demand Met	अभाव/Shortage	आवश्यकता/ Requirement	आवृतता/Freq (Hz)	मांग पूरता/ Demand Met	अभाव/Shortage	आवश्यकता/ Requirement	आवृतता/Freq (Hz)	मांग पूरता/Demand Met	अभाव/Shortage
68,121	0	68,121	50.14	66,735	0	66,735	50.02	1,668.7	0

2(A) /Load Details (/in state periphery) in MU:

राज्य/STATE	State's Control Area Generation (Net MU)							/Net SCH	/Drawal	/UI	Availability	Requirement	/ Shortage	/ Consump -tion
	तापीय/ THERMAL	जलीय/ HYDRO	गैस/ Gas	पवन/ WIND	सौर/ SOLAR	अन्य/ OTHERS	कुल/TOTAL	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)
BALCO	-	0	0	0	0	0	0	17.1	17	-0.1	17	17	0	17
CHHATTISGARH	48.5	0.2	0	0	5.4	1	55.1	75	73.7	-1.3	128.8	128.8	0	128.8
DNHDDPDCL	-	0	0	0	0	0	0	30.4	30.6	0.2	30.6	30.6	0	30.6
AMNSIL	6.6	0	0	0	0	0	6.7	13	13.1	0.1	19.8	19.8	0	19.8
GOA	0.4	0	0	0	0	0	0.4	15.9	13.9	-2	14.3	14.3	0	14.3
GUJARAT	182.7	2.3	9.5	76.9	83.3	0	354.7	192.7	178.2	-14.5	532.9	532.9	0	532.9
MADHYA PRADESH	87.2	7.1	0	15.9	11.2	1.3	122.7	159.5	159.5	0	282.2	282.2	0	282.2
MAHARASHTRA	333	11.1	9.7	33.4	33.5	0	420.7	220.6	216	-4.6	636.7	636.7	0	636.7
RIL JAMNAGAR	-	0	0	0	0	0	0	6.4	6.4	0	6.4	6.4	0	6.4
Region	658.4	20.7	19.2	126.2	133.4	2.3	960.3	730.6	708.4	-22.2	1,668.7	1,668.7	0	1,668.7

2(B) / /State's Demand Met in MW and day energy forecast and deviation particulars

राज्य/State	Evening Peak (20:00) MW			Off-Peak (03:00) MW				/Day Energy(Net MU)	
	मांग पूरता/ Demand Met	अभाव/ Shortage	आवश्यकता/ Requirement at Evening peak	मांग पूरता/ Demand Met	अभाव/ Shortage	आवश्यकता/ Requirement at Off-Peak	AVG (MW)	पूर्वानुमान/ForeCast(MU)	विचलन/Deviation[Fore .. -Consumption] (MU)
BALCO	707	0	707	709	0	709	707	14	-3
CHHATTISGARH	5,543	0	5,543	5,586	0	5,586	5,380	128.25	-0.55
DNHDDPDCL	1,235	0	1,235	1,323	0	1,323	1,269	29.8	-0.8
AMNSIL	818	0	818	836	0	836	824	17	-2.8
GOA	716	0	716	628	0	628	616	13.48	-0.82
GUJARAT	21,329	0	21,329	21,202	0	21,202	22,205	525.96	-6.94
MADHYA PRADESH	12,041	0	12,041	11,264	0	11,264	11,759	277.93	-4.27
MAHARASHTRA	25,470	0	25,470	24,930	0	24,930	26,525	629.76	-6.94
RIL JAMNAGAR	262	0	262	257	0	257	266	6	-0.4
Region	68,121	0	68,121	66,735	0	66,735	69,551	1,642.18	-26.52

2(C) /State's Demand Met in MW (/maximum demand met and /Maximum requirement of the day details)

राज्य/State	Maximum Demand, corresponding shortage and requirement details for the day				ACE			
	अधिकतम मांग पूरता/Maximum Demand Met of the day	समय/Time	अभाव/Shortage at maximum demand	आवश्यकता/Requirement at the max demand met of the day	ACE_MAX	बजे/Time	ACE_MIN	बजे/Time
BALCO	711	03:00	0	711	-	-	-	-
CHHATTISGARH	5,947	23:30	0	5,947	369.21	07:30:00	-666.8	17:24:00
DNHDDPDCL	1,350	01:00	0	1,350	34.86	17:34:00	-87.08	10:29:00
AMNSIL	897	06:00	0	897	324.79	08:38:00	-297.9	05:21:00
GOA	719	21:15	0	719	96.01	20:30:00	-141.09	05:32:00
GUJARAT	25,390	15:15	0	25,390	2,132.95	11:00:00	-1,872.34	08:42:00
MADHYA PRADESH	12,700	23:45	0	12,700	1,130.71	07:05:00	-974.16	17:34:00
MAHARASHTRA	27,700	15:00	0	27,700	1,396.86	09:57:00	-943.99	20:32:00
RIL JAMNAGAR	275	18:00	0	275	-	-	-	-
WR	74,520	15:00	0	75,017	-	-	-	-

3(A) State Entities Generation:

CHHATTISGARH

स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
KORBA EAST EXT(DSPM)(2*250)	500	462	455	474	15:11	310	11:55	11.14	10.24	427
KORBA(W) CSETCL(4*210 + 1*500)	1,340	702	702	717	23:55	-161	08:36	17.03	15.75	656
MARWA TPS(1*500 + 1*500)	1,000	860	956	969	03:02	556	15:05	20.52	19.45	810
OTHER CPP	50	0	0	0	-	0	-	3.06	3.06	128
TOTAL THERMAL	2,890	2,024	2,113	-	-	-	-	51.75	48.5	2,021
HASDEO BANGO(3*40)	120	1	1	80	23:41	1	00:02	0.12	0.12	5
KWB MINI MICRO(2*0.85)	1.7	0	0	0	-	0	-	0.02	0.02	1
SMALL HYDRO	50	0	0	0	-	0	-	0.03	0.03	1
TOTAL HYDEL	171.7	1	1	-	-	-	-	0.17	0.17	7
WIND	0	0	0	0	-	0	-	0	0	0
SOLAR	842	0	0	536	14:56	0	00:00	5.42	5.42	226
BIO MASS	50	0	0	0	-	0	-	0	0	0
TOTAL BIO MASS	50	0	0	-	-	-	-	0	0	0
TOTAL CHHATTISGARH	3,953.7	-	-	-	-	-	-	57.34	54.09	2,254

GUJARAT

स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
AECO(1*120 + 2*121)	362	236	239	244	03:54	151	09:49	5.1	4.65	194
ALTPS(2*125)	250	35	0	69	00:00	0	02:53	0.9	0.6	25
APL MUNDRA(4*330 + 2*660 + 3*660)	4,620	3,024	3,036	4,240	00:27	2,362	10:00	78.34	71.81	2,992
BLTPS(2*250)	500	325	324	328	22:15	268	09:34	7.68	6.45	269
GANDHINAGAR(GTPS)(3*210)	630	253	409	461	23:36	231	13:48	7.53	6.86	286
KLTPS(2*75)	150	59	65	66	02:57	57	14:45	1.5	1.32	55
OTHER CPP	1,000	0	0	0	-	0	-	12.13	13.08	545
SLPP(4*125)	500	305	201	306	20:11	131	13:24	5.78	4.83	201
STPS(2*250)	500	288	289	488	00:40	280	17:06	7.25	6.48	270
UKAI(2*200 + 1*210 + 1*500)	1,110	259	382	390	23:30	242	15:13	7.28	6.36	265
VADINAR(2*600)	1,200	638	1,130	1,160	06:00	593	16:24	20.7	19.35	806
WANAKBORI(7*210 + 1*800)	2,270	1,505	1,994	2,190	23:04	1,269	12:04	39.38	36.06	1,503
TOTAL THERMAL	13,092	6,927	8,069	-	-	-	-	193.57	177.85	7,411
DGBP(1*107 + 1*112 + 1*376)	594	0	0	0	00:00	0	00:00	0.09	0.09	4
ESSAR POWER GAS(3*110 + 1*185)	515	0	0	0	-	0	-	0	0	0
GIPCL STG(3*32 + 49)	145	0	0	0	00:00	0	00:00	0	0	0
GIPCL STG 2(111 + 54)	165	0	0	0	00:00	0	00:00	0	0	0
GPEC(3*138 +241)	654	0	0	0	-	0	-	0	0	0
GPPC(2*351.43)	702	0	0	0	00:00	0	00:00	0	0	0
GSEC(3*52)	156	7	7	323	00:04	7	01:25	0.29	0.27	11
SUGEN 1(3*382.5)	1,147.5	442	590	991	00:00	-7	05:56	6.95	6.68	278
UNOSUGEN(1*382.5)	382.5	278	-5	365	23:01	-10	17:13	2.46	2.37	99
UTRAN STG II(1*229 + 1*146(ST))	375	0	0	0	00:00	0	00:00	0.15	0.14	6
TOTAL GAS	4,836	727	592	-	-	-	-	9.94	9.55	398
KADANA(4*60)	240	0	49	50	23:57	0	07:05	0.36	0.36	15
LBC PANAM HYDRO	5	0	0	0	-	0	-	0.08	0.08	3
PVT HYDRO	20.6	0	0	0	-	0	-	0.13	0.13	5
UKAI HYDRO(4*75)	300	123	64	129	17:48	64	00:07	1.95	1.89	79
TOTAL HYDEL	565.6	123	113	-	-	-	-	2.52	2.46	102
WIND	8,836	5,094	2,230	5,379	18:55	834	07:04	76.92	76.92	3,205
SOLAR	15,238	0	0	9,883	14:11	0	00:00	83.28	83.28	3,470
BIO MASS	51.65	0	0	0	-	0	-	0	0	0
TOTAL GUJARAT	42,619.25	-	-	-	-	-	-	366.23	350.06	14,586

MADHYA PRADESH

स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
AMARKANTAK(1*210)	210	0	0	0	00:00	0	00:00	3.25	2.88	120
BLA IPP(2*45)	90	60	83	84	00:03	45	10:59	1.75	1.55	65
JP BINA(2*250)	500	438	471	477	06:45	269	09:55	9.89	9.08	378
SANJAY GANDHI TPS(4*210 + 1*500)	1,340	979	933	981	17:06	808	10:39	23.77	21.86	911
SATPURA IV(2*250)	500	470	471	482	19:48	253	09:18	10.57	9.69	404
SINGAJI(2*600 + 2*660)	2,520	2,109	2,064	2,231	23:48	1,296	09:54	46.6	43.81	1,825
TOTAL THERMAL	5,160	4,056	4,022	-	-	-	-	95.83	88.87	3,703
BANASAGAR TONS(3*105)	315	0	0	0	00:00	0	00:00	0	0	0
BARGI(2*45)	90	30	32	33	10:17	30	11:53	0.74	0.73	30
BIRSINGHPUR	20	0	0	0	-	0	-	0	0	0
BSGR(DEVLONE)(3*20)	60	0	0	0	00:00	0	00:00	0	0	0
BSGR(SILPARA)(2*15)	30	0	0	0	00:00	0	00:00	0	0	0
INDIRASAGAR(8*125)	1,000	2	227	679	06:37	0	07:45	4.26	4.23	176
JHINNA(2*10)	20	0	0	0	00:00	0	07:13	0	0	0
MADIKHEADA(3*20)	60	60	60	60	00:00	60	00:00	0	0	0
MP CHAMBAL	386	0	0	0	-	0	-	0	0	0
OMKARESHWAR(8*65)	520	265	127	284	20:26	0	10:30	2.17	2.16	90
PENCH(2*80)	160	0	0	0	-	0	-	0	0	0
RAJGHAT HYDRO(3*15)	45	0	0	0	00:00	0	00:00	0	0	0
TOTAL HYDEL	2,706	357	446	-	-	-	-	7.17	7.12	296
WIND	2,670	429	365	803	23:59	204	15:01	15.86	15.86	661
SOLAR	2,370	0	0	1,616	11:38	0	00:00	11.21	11.21	467
BIO + SMALL HYDRO	100	0	0	0	-	0	-	1.27	1.27	53
TOTAL MADHYA PRADESH	13,006	-	-	-	-	-	-	131.34	124.33	5,180

MAHARASHTRA

स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
APML TIRODA(5*660)	3,300	1,989	2,195	2,299	04:29	1,709	09:50	61.84	58.32	2,430
BHUSAWAL(1*210 + 2*500+1*660)	1,870	1,542	1,432	1,641	23:46	1,021	14:26	33.75	31.86	1,328
CHANDRAPUR(2*210 + 5*500)	2,920	1,482	1,494	1,944	05:37	1,239	09:43	39.22	36.45	1,519
DAHANU(2*250)	500	402	502	503	02:22	280	09:50	9.18	8.22	343
IEPL(1*270)	270	267	266	271	23:11	146	11:39	5.51	4.84	202
JAIGAD(4*300)	1,200	883	996	1,024	02:17	764	14:12	22.97	22.97	957
JPL DHULE (SHIRPUR)(2*150)	300	248	265	281	23:45	137	10:31	5.33	5.25	219
KHAPARKHEDA(4*210 + 1*500)	1,340	928	913	948	19:24	428	13:28	22.74	20.76	865
KORADI(1*210 + 3*660)	4,170	1,649	1,751	1,775	00:00	1,194	11:45	39.79	37.46	1,561
NASIK(3*210)	630	330	349	392	05:19	288	13:36	8.91	8.16	340
OTHER CPP	3,305	0	0	0	-	0	-	58.87	58.87	2,453
PARAS(2*250)	500	417	419	430	08:03	257	10:29	9.71	8.69	362
PARLI(3*250)	750	536	635	670	21:14	374	09:55	13.59	12.17	507
RATTAN INDIA (AMARAVATI)(5*270)	1,350	989	995	1,005	07:08	547	12:00	23.63	21.67	903
SWPGL(4*135)	540	434	439	444	00:46	254	10:46	10.57	9.51	396
TROMBAY(250+1*500)	750	396	380	574	21:26	375	14:01	0	0	0
VIPL(2*300)	600	513	497	520	18:17	321	14:05	11.61	10.73	447
TOTAL THERMAL	24,295	13,005	13,528	-	-	-	-	377.22	355.93	14,832
TROMBAY_GAS(1*120+1*60)	180	171	165	174	02:20	104	09:30	3.25	3.22	134
URAN(4*108 + 2*120)	672	269	273	276	06:04	258	14:10	6.66	6.46	269
TOTAL GAS	852	440	438	-	-	-	-	9.91	9.68	403
BHIRA(6*25)	150	3	72	150	04:25	1	10:54	0	0	0
BHIRA PSS	150	131	0	163	01:16	0	02:46	0	0	0
BHIRA TR(2*40)	80	0	0	0	-	0	-	0.28	0.27	11
BHIVPURI(3*24 + 2*1.5)	75	34	48	48	03:00	5	06:24	0	0	0
GHATGHAR(2*125)	250	0	0	123	01:58	-152	10:00	0	0	0
HYDRO VTRNA(1*60)	60	0	0	0	00:00	0	00:00	0	0	0
HYDROSMLHY_PTN	350	0	0	0	-	0	-	5.56	5.45	227
KHOPOLI(3*24)	72	18	22	24	01:32	0	08:30	0	0	0
KOYNA I AND II(4*(65+5) + 4*(75+5))	600	41	41	41	03:43	40	11:27	1.07	1.03	43
KOYNA III(4*80)	320	0	0	156	23:03	0	02:53	0.69	0.69	29
KOYNA ST-IV(4*250)	1,000	-3	-4	-1	18:04	-14	15:29	0	0	0
TILLARI(1*66)	66	0	0	0	00:00	0	00:00	0	0	0
OTHER HYDRO	122	0	0	0	-	0	-	3.66	3.66	153
TOTAL HYDEL	3,295	224	179	-	-	-	-	11.26	11.1	463
WIND	5,321	1,267	1,076	1,333	21:16	267	13:11	33.4	33.4	1,392
SOLAR	6,028	0	0	4,417	12:13	0	00:00	33.5	33.5	1,396
TOTAL MAHARASHTRA	39,791	-	-	-	-	-	-	465.29	443.61	18,486

3(B) Regional Entities Generation

ISGS

स्टेशन/ Station/Constituents	स्थापित क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
GADARWARA(2*800)	1,600	985	1,495	2,136	00:47	537	17:54	26.59	28.38	26.75	1,115
GANDHAR(3*144.3 + 1*224.49)	657	-17	-24	7	11:43	-31	06:08	0.07	0.06	0.06	3
KAPS(2*220)	440	391	391	391	00:00	391	00:00	4.68	5.26	4.73	197
KAPS3&4(2*700)	1,400	585	597	602	05:16	578	16:31	28.56	31.46	28.89	1,204
KAWAS(4*106 + 2*116.1)	656.2	-13	-15	71	00:14	-20	06:07	0.03	0.03	0.03	1
KHARGONE(2*660)	1,320	747	1,184	1,262	23:41	659	09:30	21.33	23.08	21.43	893
KSTPS1&2(3*200 + 3*500)	2,100	1,360	1,314	1,366	20:30	742	09:39	29.74	32.04	29.47	1,228
KSTPS3(1*500)	500	481	485	491	06:36	273	09:10	9.57	10.16	9.46	394
LARA(2*800)	1,600	1,509	1,503	1,522	07:22	804	09:24	30.87	32.89	30.84	1,285
MOUDA I(2*500)	1,000	923	889	1,149	05:33	444	06:01	17.39	18.4	16.53	689
MOUDA II(2*660)	1,320	1,194	1,185	1,234	02:12	595	06:01	22.71	24.72	21.82	909
NSPCL(2*250)	500	453	447	468	02:08	236	09:42	8.57	9.43	8.57	357
RGPPL(2*320 + 4*331.75)	1,967	-21	-18	990	00:08	-31	02:01	0.45	1.02	0.8	33
SASAN(6*660)	3,960	3,737	3,740	3,775	06:45	2,112	13:37	81.33	87.28	81.8	3,408
SIPAT I(3*660)	1,980	1,908	1,847	1,940	18:28	998	09:04	38.58	41.01	38.32	1,597
SIPAT II(2*500)	1,000	972	966	987	02:15	520	08:48	19.72	20.83	19.91	830
SOLAPUR STPS(2*660)	1,320	769	665	1,207	22:15	661	17:18	17.11	19.31	17.8	742
SSP(RBPH+CHPH)(6*200 + 5*50)	1,450	47	47	877	00:00	-2	05:31	6.84	6.93	6.84	285
TARAPUR I(2*160)	320	240	236	241	19:43	216	17:06	5.52	5.92	5.41	225
TARAPUR II(2*540)	1,080	794	796	809	20:35	759	11:56	18.72	20.93	18.75	781
VSTPS I(6*210)	1,260	919	915	937	06:27	510	16:11	17.92	20.13	17.61	734
VSTPS II(2*500)	1,000	919	899	947	18:00	516	09:41	17.87	18.98	17.45	727
VSTPS III(2*500)	1,000	946	929	980	06:31	509	08:59	17.76	18.78	17.74	739
VSTPS IV(2*500)	1,000	928	909	955	02:16	480	15:33	18.11	19.48	18.17	757
VSTPS V(1*500)	500	473	459	480	06:55	244	09:21	8.83	9.49	8.9	371
SUB-TOTAL	30,930.2	21,229	21,841	-	-	-	-	468.87	506	468.08	19,504
TOTAL	30,930.2	-	-					468.87	506	468.08	19,504

IPP/JV

स्टेशन/ Station/Constituents	स्थापित क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
ACBIL(2*135 + 2*50 + 2*30 + 1*63)	493	239	229	243	22:54	190	08:53	5.46	6.5	5.39	225
ADANI RAIPUR(2*685)	1,370	1,118	1,112	1,160	21:31	684	11:27	23.81	26.84	24.13	1,005
APL RAIGARH(1*600)	600	560	567	583	20:36	-29	09:50	11	11.68	10.97	457
BALCO(4*300)	1,200	864	878	971	00:00	554	12:44	19.12	19.12	19.01	792
DB POWER(2*600)	1,200	1,149	1,142	1,167	18:24	631	10:38	24.66	26.22	24.8	1,033
DCPP(2*135)	270	111	111	111	00:00	111	00:00	4.88	5.64	4.93	205
DGEN(3*400)	1,200	-3	374	378	00:37	-6	15:39	1.36	1.39	1.3	54
DHARIWAL CTU(2*300)	600	331	270	334	19:59	141	08:33	5.57	6.21	5.69	237
GMR WARORA(2*300)	600	548	565	572	07:04	305	09:55	11.88	13	11.99	500
JHABUA POWER(1*600)	600	524	540	545	04:49	298	14:53	11.03	11.72	10.96	457
JP NIGRIE(2*660)	1,320	1,264	1,257	1,269	20:41	688	09:44	24.04	25.84	24.49	1,020
JPL STG-I(4*250)	1,000	980	991	1,001	22:44	508	09:48	16.94	19.65	17.45	727
JPL STG-II(4*600)	2,400	2,334	2,309	2,341	01:33	1,648	10:20	47.81	53.52	50.56	2,107
JSW MAHANADI(3*600)	1,800	1,701	1,701	1,734	14:59	922	11:24	38.16	41.02	38.27	1,595
LANCO(2*300)	600	270	268	282	02:20	135	13:16	5.27	6.1	5.34	223
MAHAN ENERGEN(2*600)	1,200	912	908	917	02:24	619	10:33	20.07	21.77	20.23	843
MB POWER(2*600)	1,200	1,176	1,185	1,198	18:40	487	12:31	23.87	25.24	23.77	990
MCCPL(1*300)	300	219	214	255	07:50	155	12:16	4.86	5.47	4.91	205
RKM POWER(4*360)	1,440	1,317	1,317	1,323	05:09	726	09:43	26.85	29.81	27	1,125
SARDA ENERGY & MINERALS LTD(2*300)	600	521	525	531	20:45	328	13:45	-	12.76	11.54	481
TPCL(5*800)	4,000	2,900	2,865	3,820	23:36	2,024	09:17	64.86	70.29	64.32	2,680
TRN ENERGY(2*300)	600	527	537	542	17:40	312	12:29	11.58	12.9	11.77	490
VEDANTA_LIMITED_CG (1*600)	600	-1	-1	0	20:49	-2	13:48	0	0.04	0.04	2
SUB-TOTAL	25,193	19,561	19,864	-	-	-	-	403.08	452.73	418.86	17,453
TOTAL	25,193	-	-					403.08	452.73	418.86	17,453

RENEWABLE

स्टेशन/ Station/Constituents	स्थापित क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
AGE25BL_PSS9_KPS1_HS	100	0	0	93.7	12:30	0	00:00	0.23	0.529	0.529	22
AHEJ5L_PSS8_KPS3_HS	100	0	0	100	11:52	0	00:00	1.38	0.87	0.87	36
AYANARP4_DVSR_BHJ_HS	37.5	0	0	29.7	11:30	0	00:00	0.23	0.21	0.21	9
ACL_PSS3_KPS1_S	200	0	0	200	12:00	0	00:00	1.66	1.61	1.61	67
ACL_PSS4_KPS1_HS	125	0	0	125	12:01	0	00:00	1.29	0.87	0.87	36
AGE24AL_PSS3_KPS1_S	400	0	0	399	11:45	0	00:00	3.71	3.06	3.06	128
AGE24L_PSS10_KPS3_S	150	0	0	125	11:15	0	00:00	0.66	0.63	0.63	26
AGE24L_PSS5_KPS1_S	150	0	0	150	12:24	0	00:00	1.53	1.23	1.23	51
AGE25AL_PSS2_KPS1_S	500	0	0	285	13:37	0	00:00	0.6	1.51	1.51	63
AGE25BL_PSS2_KPS1_S	582.98	0	0	389	09:21	0	00:19	0.84	1.89	1.89	79
AGE25CL_PSS8_KPS3_S	350	0	0	449	13:43	0	00:08	4.92	2.92	2.92	122
AGE26AL_PSS3_KPS1_S	62.5	0	0	61	13:50	0	00:00	0.28	0.25	0.25	10
AGE26AL_PSS6_KPS1_S	750	-	-	-	-	-	-	-	-	-	0
AGE26BL_PSS10_KPS1_HS	142	0	0	142	11:52	0	00:00	0.9	1.14	1.14	48
AGE26BL_PSS10_KPS1_S	150	0	0	150	11:52	0	00:00	1.1	1.04	1.04	43
AGE26BL_PSS2_KPS1_S	167	0	0	129	09:24	0	00:00	0.4	0.57	0.57	24
AHEJ5L_PSS5_KPS1_S	570	0	0	570	12:01	0	00:00	4.02	3.87	3.87	161
APSEZ_PSS3_KPS1_S	200	0	0	200	10:39	0	00:00	1.6	1.53	1.53	64
ARE3L_PSS8_KPS3_HS	25	-	-	-	-	-	-	-	-	-	0
ARE45L_PSS5_KPS1_S	250	0	0	249	12:31	0	00:00	2.22	1.96	1.96	82
ARE55L_PSS3_KPS1_HS	25	0	0	23	10:53	0	00:00	0.23	0.18	0.18	8
ARE55L_PSS3_KPS1_S	162.5	0	0	131	10:40	0	00:00	1.39	1.1	1.1	46
ARE56L_PSS10_KPS1_S	500	0	0	494	12:06	0	00:00	2.64	2.61	2.61	109
ARE56L_PSS4_KPS1_S	225	0	0	223	12:30	0	00:00	2.3038	1.7124	1.71	71
ARE56L_PSS9_KPS1_S	400	0	0	235	11:03	0	00:00	0.98	1.7	1.7	71
ARE57L_PSS13_KPS1_S	850	0	0	531	13:25	0	00:00	2.07	3.12	3.12	130
AREH4L_PSS1_KPS1_SF	1,000	0	0	580	13:41	0	00:00	2.81	3.06	3.06	128
ARINSUN SOLAR (BARSAITADESH)	250	0	0	184	13:32	0	00:00	1.24	0.56	0.56	23
ASEJ6PL_PSS8_KPS3_HS	35	0	0	30	10:00	0	00:00	0.07	0.09	0.09	4
ASEJ6PL_PSS8_KPS3_S	50	0	0	30	11:00	0	00:00	0.47	0.72	0.72	30
ATHENA SOLAR	250	0	0	209	13:29	0	06:00	1.31	1.12	1.12	47
AVAADA_AGAR_RUMS_S	200	0	0	183	13:54	0	00:00	1.09	1.09	1.09	45
AYANARP4_DVSR_BHJ_HW	150	0	0	101.61	12:30	0	00:00	0.6457	0.82	0.82	34
BEEMPOW_AGAR_RUMS_S	350	0	0	309	14:05	0	00:00	1.92	1.96	1.96	82
BLUELEAF_CP_PCHR_HS	128.7	-	-	-	-	-	-	-	-	-	0
CGERP_MORJAR_BHJ2_HS	30.8	-	-	-	-	-	-	-	-	-	0
ESPL_RSP SOLAR	200	0	0	144	13:10	0	00:00	1.36	1.26	1.26	53
GANDHAR SOLAR	20	0	0	19	12:30	0	00:00	0.13	0.46	0.46	19
GIPCL_PSS1_KPS2_S	600	0	0	544	14:00	0	00:00	4.84	3.89	3.89	162
GIPCL_RSP SOLAR	100	0	0	77	14:10	0	00:00	0.6	0.64	0.64	27
GSEC 2	100	0	0	58	11:44	0	00:00	0.36	0.52	0.52	22
GSECL_RSP SOLAR	100	-	-	-	-	-	-	-	-	-	0
KAWAS SOLAR	56	0	0	50.5	13:00	0	00:00	0.35	0.34	0.34	14
KPIG_GSECLS_KPS2_S	200	0	0	174	10:51	0	00:00	1.15	1.31	1.31	55
MAHINDRA SOLAR (BADWAR)	250	0	0	181	09:18	0	00:00	1.43	1.5	1.5	63
MASAYA SOLAR	300	0	0	236	13:47	0	00:00	1.47	1.33	1.33	55
NTPCREL_PSS1_KPS3_S	1,095	0	0	307	13:34	0	00:00	2.41	2.36	2.36	98
NTPCREL_PSS2_KPS2_S	1,555	0	0	996	12:30	0	-	7.53	7.335	7.335	306
SAELP4_GSECLS_KPS2_S	400	0	0	306	09:31	0	00:00	2.47	2.53	2.53	105
SAELP5_GSECLS_KPS2_S	400	-	-	-	-	-	-	-	-	-	0
SGEL_RSP_S	100	0	0	98	14:06	0	00:00	0.58	0.64	0.64	27
SHERISHA RAIPUR	50	0	0	46	11:53	0	00:00	0.29	0.29	0.29	12
SOLAPUR SOLAR PV PROJECT	23	0	0	21	11:30	0	00:00	0.15	0.13	0.13	5
TPREL_RSP SOLAR	100	0	0	74	13:00	0	00:00	0.6	0.63	0.63	26
TPSOURY_BRVD_NMCH_S	160	0	0	160	11:19	0	00:00	1.38	1.32	1.32	55
TPSOURY_KWAI_NMCH_S	170	0	0	175	12:34	0	00:00	1.47	1.45	1.45	60
AHEJ5L_PSS8_KPS3_HW	65	49	40	63	17:42	1	06:11	1.46	0.89	0.89	37
RSRPL_GHTND_KLM_W	138.6	0	0	0	-	0	-	0.89	-	0	0
ACL_PSS4_KPS1_W	156	145	120	149	20:42	15	08:38	1.71	2.46	2.46	103
ADANI WIND ENERGY KUTCHH FOUR LTD	300	232	159	252	18:55	54	10:14	4.42	4.14	4.14	173
AGE24L_PSS4_KPS1_W	100	99	92	103	20:43	13	08:43	1	1.82	1.82	76
AGE25BL_PSS9_KPS1_HW	130	0	0	0	-	0	-	1.09	-	0	0
AGE25CL_PSS11_KPS3_W	185	0	0	0	00:00	0	00:00	1.8	0	0	0
AGE25CL_PSS14_KPS3_W	65	0	0	0	00:00	0	00:00	0.48	0	0	0
AGE26AL_PSS12_KPS3_W	137.5	0	0	0	00:00	0	00:00	0.99	0	0	0
AGE26BL_PSS10_KPS1_W	156	115	110	139	21:48	16	06:01	1.41	2.11	2.11	88
AHEJ5L_PSS4_KPS1_W	60	59	51	62	19:31	8	08:37	0.6	1.05	1.05	44
AHEJ5L_PSS5_KPS1_HW	202.8	0	0	0	-	0	-	1.41	-	0	0
ALFANAR WIND (NANAVALKA)	300	200	132	220	18:53	35	07:15	3.42	3.56	3.56	148
APRAAVA ENERGY PRIVATE LIMITED (AEPL)	252	138	138	138	00:00	138	00:00	2.44	3.32	3.32	138

APSEZ_PSS4_KPS1_W	52	37	42	51	19:41	3	08:32	0.6	0.72	0.72	30
ARE3L_PSS8_KPS3_HW	41.6	34	29	40	17:25	3	06:10	0.46	0.56	0.56	23
ARE41L_PSS13_KPS1_W	124.8	96	75	116	19:33	5	06:05	-	1.61	1.61	67
ARE41L_PSS3_KPS1_W	250	224	179	229	20:10	20	06:07	2.66	3.6	3.6	150
ARE41L_PSS4_KPS1_W	50	51	46	52	18:44	7	08:46	0.71	0.93	0.93	39
ARE41L_PSS8_KPS3_W	125	100	86	116	17:50	7	06:17	2.96	1.75	1.75	73
ARE48L_SRPL_PSS9_KPS1_W	119.6	0	0	0	00:00	0	00:00	0	0	0	0
ARE55L_PSS3_KPS1_HW	25	0	0	0	-	0	-	0.17	-	0	0
ASEJ6PL_PSS8_KPS3_HW	62.4	0	0	0	00:00	0	00:00	1.3	0	0	0
ASIPL WIND (BARANDA)	170.1	0	0	0	00:00	0	00:00	0	0	0	0
AWEK1L WIND (RATADIYA)	425	358	294	388	18:41	109	12:15	5.56	7.29	7.29	304
AWEKFL WIND (RATADIYA)	130	42	42	42	00:00	42	00:00	1.17	1	1	42
AWEMP1PL_PTNGR_IDR_W	324.4	207	44	260	22:39	39	15:31	3.13	3.08	3.08	128
AYANARP4_ZURA_BHJ_S	92.4	0	86	101	14:32	41	18:00	0.83	1.54	1.54	64
BLUELEAF_CP_PCHR_HW	115.5	30	31	111	01:13	8	07:03	0.02	0.99	0.99	41
CGERP_MORJAR_BHJ2_HW	29.7	0	0	0	00:00	0	00:00	-	0	0	0
CPTTNPL WIND (DAYAPAR)	126	89	89	89	00:00	89	00:00	1.74	2.13	2.13	89
GIWEL-II WIND (VADVA)	250	170	136	183	18:17	63	12:12	2.8	3.38	3.38	141
GIWEL-III WIND (NARANPAR)	300	153	87	167	20:17	40	10:11	2.81	2.55	2.55	106
IGESL_DAYAPAR_BHUJ_W	250	91	91	91	00:00	91	00:00	2.21	2.18	2.18	91
NETRA_KOTDA_BHUJ_W	206.5	149	116	162	19:45	100	12:35	2.62	3.02	3.02	126
NTPC_REL_DYPR_BHUJ_W	146	71	71	71	00:00	71	00:00	1.51	1.69	1.69	70
OEPL WIND (OSTRO KUTCH)	50	30	30	30	00:00	30	00:00	0.74	0.71	0.71	30
OKWPL WIND (OSTRO KUTCH)	250	150	150	150	00:00	150	00:00	3.19	3.61	3.61	150
POWERICA WIND	50.6	62	34	80	15:31	13	07:22	0.67	1.21	1.21	50
RENEW AP2 WIND (GHADSISA)	300	202	141	219	17:01	71	12:17	3.97	3.94	3.94	164
RENEW WIND (BHUVAD)	230.1	192	104	203	18:12	14	07:10	3.02	3.09	3.09	129
RGMHP1_PATODA_KLM_W	135.3	65	115	132	22:00	0	06:21	0.77	1.06	1.06	44
RGMHS1_TLJPR_SLPR_HW	161.7	0	0	0	-	0	-	0.67	-	0	0
SAUPL_HJRTPR_RJGR_W	100	0	0	0	00:00	0	00:00	0.55	0	0	0
SITAC WIND	300	254	171	266	19:14	39	07:26	5.17	4.54	4.54	189
SRIJAN WIND	148.5	138	73	148	17:24	27	07:01	2.07	2.36	2.36	98
TEQGREEN_WASI_KLM_W	70.2	0	0	54	11:49	0	06:00	0.8	0.32	0.32	13
TORRENT SOLARGEN LIMITED	115	69	46	93	17:43	9	10:23	1.13	1.16	1.16	48
TOTAL	23,173.28	-	-					154.4395	152.8364	152.834	6,369

RENEWABLE_BESS

स्टेशन/ Station/Constituents	स्थापित क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
ARE37L_PSS5_KPS1_B	160	30	-1	100	13:58	-116	11:43	0.07	-0.1	-0.1	-4
ARE43L_PSS10_KPS3_B	360	52	-1	305	23:24	-382	13:26	0.18	-0.17	-0.17	-7
SUB-TOTAL	520	82	-2	-	-	-	-	0.25	-0.27	-0.27	-11
TOTAL	520	-	-					0.25	-0.27	-0.27	-11

REGIONAL GENERATION SUMMARY

	THERMAL GEN MU	GAS GEN MU	SOLAR GEN MU	WIND GEN MU	HYDRO GEN MU	NUCLEAR GEN MU	OTHER GEN MU	TOTAL GEN MU	SCHEDULE MU
ISGS	402.57	0.89	-	-	6.84	57.78	-	468.08	468.87
IPP	417.56	1.3	-	-	-	-	-	418.86	403.08
Constituents	658.4	19.2	133.4	126.2	20.7	-	2.3	960.3	938.1
Renewables	-	-	73.464	79.37	-	-	-	152.56	154.69
Region	1,478.53	21.39	206.864	205.57	27.54	57.78	2.3	1,999.8	1,964.74

4(A) अंतर क्षेत्रीय विनिमय/INTER-REGIONAL EXCHANGES (Import=(+ve) /Export =(-ve))

SL.No.	Element	20:00	03:00	अधिकतम पस्पर विनिमय/Maximum Interchange (MW)		आयात/Import in MU	नरि्यात/Export in MU	शुद्ध विनिमय/NET
		(MW)	MW	आयात/Import (MW)	नरि्यात/Export (MW)			
	EAST REGION WEST REGION / /Import/Export between EAST REGION and WEST REGION							
1	220KV-KORBA-BUDIPADAR	4	34	51	-118	0.34	-0.69	-0.35
2	220KV-RAIGARH-BUDIPADAR	19	42	77	-184	0.42	-0.86	-0.44
3	400KV-JAGDALPUR-JEYPORE	-	-	-	-	-	-0.53	-0.53
4	400KV-RAIGARH-JHARSUGUDA	365	246	480	-405	2.33	0	2.33
5	400KV-SIPAT-RANCHI	-	-	-	-	0	-5.5	-5.5
6	765KV-DHARJAYGARH-JHARSUGUDA	-227	-195	-	-1,186	0	-12.41	-12.41
7	765KV-DHARJAYGARH-RANCHI	-1,066	-579	61	-2,507	0.02	-31.1	-31.08
8	765KV-RAIPUR-PS (DURG)-JHARSUGUDA	378	510	691	-746	2.13	0	2.13
	Sub-Total EAST REGION	-527	58	1,360	-5,146	5.24	-51.09	-45.85
	NORTH REGION WEST REGION / /Import/Export between NORTH REGION and WEST REGION							
1	132KV-RAJGHAT-LALITPUR	0	0	-	0	0	0	0
2	220KV-BHANPURA-MODAK	-52	-53	-	-73	0	-1.22	-1.22
3	220KV-BHANPURA-RANPUR	-30	-30	-	-30	0	-1.86	-1.86
4	220KV-MALANPUR-AURIYA	19	-2	45	-24	0.3	-0.09	0.21
5	220KV-MEHGAON-AURIYA	0	16	73	-8	0.41	0	0.41
6	400KV-KANSARI-KANKROLI	-84	32	367	-220	1.41	-1.47	-0.06
7	400KV-KANSARI-KANKROLI 2(BYPASS AT BHINMAL)	-59	22	254	-153	0.97	-1.03	-0.06
8	400KV-NEEMUCH-CHITTORGARH	-250	-261	465	-513	2.77	-3.81	-1.04

NORTH REGION WEST REGION / /Import/Export between NORTH REGION and WEST REGION								
9	400KV-SUJALPUR-RAPP	-99	-88	792	-347	5.88	-1.56	4.32
10	400KV-VINDHYACHAL PS-RIHAND(III)	-1	-1	-	-1	0	-0.02	-0.02
11	765KV-BANASKANTHA-CHITTORGARH	-649	163	2,008	-1,588	7.03	-14.18	-7.15
12	765KV-GWALIOR-AGRA	-1,264	-1,410	203	-2,018	0.12	-25.96	-25.84
13	765KV-GWALIOR-JAIPUR	-1,315	-1,512	1,384	-1,690	6.36	-18.54	-12.18
14	765KV-GWALIOR-ORAI	496	489	576	-26	7.86	-0.01	7.85
15	765KV-JABALPUR-ORAI	-944	-1,018	155	-1,283	0	-32.89	-32.89
16	765KV-SATNA-ORAI	-959	-1,073	-	-1,129	0	-18.07	-18.07
17	765KV-VINDHYACHAL(PS)-VARANASI	-2,723	-2,126	-	-3,260	0	-57.17	-57.17
18	HVDC 500KV VINDHYACHAL B/B	93	93	93	-	2.44	0	2.44
19	HVDC500KV-MUNDRA-MOHINDARGARH	-1,449	-1,450	-	-1,454	0	-36.36	-36.36
20	HVDC800KV-CHAMPA-KURUKSHETRA	-3,534	-3,535	-	-3,564	0	-96.85	-96.85
Sub-Total NORTH REGION		-12,804	-11,744	6,415	-17,381	35.55	-311.09	-275.54
SOUTH REGION WEST REGION / /Import/Export between SOUTH REGION and WEST REGION								
1	220KV-KOLHAPUR-CHIKKODI-II	-	-	-	-	-	-	0
2	220KV-PONDA-AMBEWADI	2	2	2	-	0.04	0	0.04
3	220KV-TALANGADE(MS)-CHIKKODI-II	-	-	-	-	-	-	0
4	220KV-XELDEM-AMBEWADI	91	79	-	101	1.72	0	1.72
5	400KV-KOLHAPUR GIS-NARENDRA KUDGI	1,433	1,123	1,860	-	33.01	0	33.01
6	765KV-SOLAPUR-RAICHUR	491	491	1,265	-345	12.02	-0.28	11.74
7	765KV-WARDHA-NIZAMABAD	-871	-674	-	-1,674	0	-19.98	-19.98
8	765KV-WARORA-PG-WARANGAL	-1,031	-1,002	-	-1,708	0	-24.32	-24.32
9	HVDC205KV-BHADRAWATI-RAMAGUNDAM	503	503	690	-	12.12	0	12.12
10	HVDC400KV-BARSUR-L.SILERU	-	-	-	-	-	-	0
11	HVDC800KV-RAIGARH-GIS-HVDC-PUGALUR	-1,214	-603	-	-1,237	0	-14.61	-14.61
Sub-Total SOUTH REGION		-596	-81	3,817	-4,863	58.91	-59.19	-0.28
TOTAL IR EXCHANGE		-13,927	-11,767	11,592	-27,390	99.7	-421.37	-321.67

4(B) Inter Regional Schedule & Actual Exchange (Import=(+ve) /Export =(-ve)) in MU

	ISGS+GNA+URS Schedule	TGNA BILT Schedule	GDAM Schedule	DAM Schedule	HPDAM Schedule	RTM Schedule	Total IR Schedule	Total IR Actual	NET IR UI
WR-ER	36.66	-25.91		-9.93		0	-32.06	-45.85	-13.79
WR-NR	-215.19	-81.64		37.37		0	-257.55	-275.54	-17.99
WR-SR	-56.61	-1.84		-22.29		0	-46.99	-0.28	46.71
Total	-235.14	-109.39	0	5.15	0	0	-336.6	-321.67	14.93

5.Frequency Profile

RANGE(Hz)	< 48.8	< 49	< 49.2	< 49.5	< 49.7	< 49.9	>= 49.9 - <= 50.05	> 50.05
%	.00	.00	.00	.00	.00	7.30	75.00	17.70

Percentage of Time Frequency Remained outside IEGC Band	25
No. of hours frequency outside IEGC Band	6

अधिकतम /Maximum		न्यूनतम/Minimum		औसत/Average	Freq Variation	Standard	Freq. in 15 mnt blk	
Frequency	Time	Frequency	Time	Frequency	Index	Deviation	Max.	Min.
50.27	08:57:40	49.69	07:48:00	50	0.052	0.072	50.23	49.85

6.वोल्टेज प्रोफाइल/Voltage Profile: 400kV

	अधिकतम/Maximum		न्यूनतम/Minimum		वभिवांतर/Voltage (in %)			Hours Volatge Outside IEGC Range(VDI)
STATION	VOLTAGE	TIME	VOLTAGE	TIME	>= 4000	IEGC Band (A)	> 420	(100-A)*24/100
AMRELI - 400KV	429.57	04:57	416.24	14:42	0	19.9	80	19.2
ASOJ - 400KV	416.75	18:04	399.17	14:09	0	100	0	0
BHILAI - 400KV	414.83	09:40	404.39	23:38	0	100	0	0
BHOPAL - 400KV	420.46	18:04	407.68	23:32	0	98.5	1.5	.4
BOISAR - 400KV	419.11	18:04	400.23	11:25	0	100	0	0
DEHGAM - 400KV	418.04	18:47	401.41	14:35	0	100	0	0
DHULE - 400KV	416.98	18:04	400.83	06:20	0	100	0	0
DAMOH - 400KV	417.3	09:41	400.78	23:34	0	100	0	0
GPEC - 400KV	415.75	18:47	397.44	14:36	0	100	0	0
GWALIOR - 400KV	414.31	09:08	393.14	21:04	0	100	0	0
HAZIRA - 400KV	400.9	00:00	400.9	00:00	0	100	0	0
INDORE - 400KV	416.63	18:04	403.02	05:48	0	100	0	0
ITARSI - 400KV	411.06	11:02	398.08	05:46	0	100	0	0
JETPUR - 400KV	422.63	16:47	407.25	07:12	0	85.6	14.4	3.5
KALA - 400KV	412.47	09:01	394.07	14:42	0	100	0	0
KALWA - 400KV	416.49	08:45	396.92	15:17	0	100	0	0
KARAD - 400KV	421.39	17:16	406.22	14:44	0	98.1	1.9	.5
KASOR - 400KV	420.47	18:05	399.41	14:43	0	99.9	.1	0
KHANDWA - 400KV	414.5	09:45	402.67	05:49	0	100	0	0
MAGARWADA - 400KV	411.31	18:03	395.86	14:21	0	100	0	0
MAPUSA - 400KV	404.23	00:00	404.23	00:00	0	100	0	0
NAGDA - 400KV	418.05	18:03	405.31	05:49	0	100	0	0
NEW KOYNA - 400KV	429.91	17:18	417.43	14:35	0	5.4	94.6	22.7
PARLI - 400KV	417.23	00:00	389.74	11:35	0	100	0	0
RAIPUR - 400KV	413.99	09:00	404.16	23:37	0	100	0	0
RAIGARH - 400KV	421.59	09:11	413.79	23:37	0	98.4	1.6	.4

VAPI - 400KV	411.27	18:46	393.74	14:43	0	100	0	0
WARDHA - 400KV	418.44	00:00	418.44	00:00	0	100	0	0

6.1 Voltage Profile: 765kV

	/Maximum		/Minimum		/Voltage (in %)			Hours Voltage Outside IEGC Range(VDI)
STATION	VOLTAGE	TIME	VOLTAGE	TIME	< 728	IEGC Band (A)	> 800	(100-A)*24/100
BINA - 765KV	795.94	09:39	763.5	20:42	0	100	0	0
DURG - 765KV	787.23	10:00	768.82	05:36	0	100	0	0
GWALIOR - 765KV	800.46	10:00	764.81	00:00	0	96.8	3.2	.8
INDORE - 765KV	784.54	09:45	757.29	05:46	0	100	0	0
KOTRA - 765KV	793.04	09:39	775.42	05:46	0	100	0	0
SASAN - 765KV	790.79	09:37	767.2	20:39	0	100	0	0
SATNA - 765KV	799.18	10:00	769.95	20:37	0	100	0	0
SEONI - 765KV	799	09:38	767	05:48	0	100	0	0
SIPAT - 765KV	781.03	10:00	762.39	05:52	0	100	0	0
TAMNAR - 765KV	793.2	09:43	775.46	23:37	0	100	0	0
VADODARA - 765KV	796.52	09:46	762	14:43	0	100	0	0
WARDHA - 765KV	800.11	09:45	763.8	06:20	0	99.9	.1	0

7(A).Power Energy/Schedule Details

State	Off- Peak Hours (03:00)												
	T-GNA Bilateral (MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX HPDAM (MW)	IEX RTM (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXIL HPDAM (MW)	PXI RTM (MW)	HPX GDAM (MW)	HPX DAM (MW)	HPX HPDAM (MW)	HPX RTM (MW)
AMNSIL	0	-	199.07	-	70.51	-	0	-	0	-	-	-	-
BALCO	0	-	0	-	62.01	-	0	-	0	-	-	-	-
CHHATTISG ..	-524.74	-	-28.3	-	29.6	-	0	-	0	-	-	-	-
DNHDDPDCL	9.66	-	120.74	-	28.98	-	0	-	0	-	-	-	-
GOA	90.21	-	-49	-	0	-	0	-	0	-	-	-	-
GUJARAT	353.37	-	681.36	-	778.43	-	0	-	0	-	-	-	-
MADHYA PRADESH	-17.03	-	-1,233.9	-	-1.7	-	0	-	0	-	-	-	-
MAHARASHT..	189.02	-	908.17	-	0.77	-	0	-	0	-	-	-	-
RIL JAMNAGAR	0	-	0	-	0	-	0	-	0	-	-	-	-
TOTAL	100.49	0	598.14	-	968.6	0	0	-	0	-	-	-	-

State	Peak Hours (20:00)												
	T-GNA Bilateral (MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX HPDAM (MW)	IEX RTM (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXIL HPDAM (MW)	PXI RTM (MW)	HPX GDAM (MW)	HPX DAM(MW)	HPX HPDAM (MW)	HPX RTM (MW)
AMNSIL	0	-	0	-	97.56	-	0	-	0	-	-	-	-
BALCO	0	-	0	-	0	-	0	-	0	-	-	-	-
CHHATTISG ..	-250.82	-	-28.3	-	-20.5	-	0	-	0	-	-	-	-
DNHDDPDCL	9.66	-	57.95	-	0.97	-	0	-	0	-	-	-	-
GOA	90.21	-	-72	-	-30	-	0	-	0	-	-	-	-
GUJARAT	362.25	-	278.42	-	69.46	-	0	-	0	-	-	-	-
MADHYA PRADESH	-115.69	-	66.76	-	190.38	-	0	-	0	-	-	-	-
MAHARASHT..	178.11	-	496.23	-	374.89	-	0	-	0	-	-	-	-
RIL JAMNAGAR	0	-	0	-	16.81	-	0	-	0	-	-	-	-
TOTAL	273.72	0	799.06	0	699.57	0	0	-	0	-	-	-	-

State	Day Energy (MU)						
	ISGS + GNA Schedule	T-GNA Bilateral (MW)	GDAM Schedule	DAM Schedule	HPDAM Schedule	RTM Schedule	Total (MU)
AMNSIL	7.9	0	0.69	2.1	-	2.35	13.04
BALCO	16.56	0.02	0	0	-	0.53	17.1
CHHATTISGARH	83.07	-7.75	0.09	-0.86	-	0.41	74.96
DNHDDPDCL	26.35	0.27	0	2.81	-	0.99	30.42
GOA	15.01	2.29	0	-1.04	-	-0.4	15.86
GUJARAT	157.84	11.67	1.11	6.97	-	14.61	192.19
MADHYA PRADESH	158.05	-1.38	-0.74	-2.65	-	6.18	159.48
MAHARASHTRA	187.83	2.29	-0.14	13.35	-	17.23	220.56
RIL JAMNAGAR	6.23	0	0.15	0.03	-	0.03	6.43
TOTAL	658.84	7.41	1.16	20.71	0	41.93	730.04

7(B).Power Energy/Schedule Details

State	ISGS + GNA Schedule		T-GNA Bilateral (MW)		IEX GDAM (MW)		PXIL GDAM(MW)		HPX GDAM(MW)		IEX DAM (MW)		PXIL DAM(MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
AMNSIL	492.62	97.56	0	0	120.95	0	0	0	0	0	253.94	0	0	0
BALCO	743.88	623.98	19.32	0	0	0	0	0	0	0	0	0	0	0
CHHATTISGARH	4,165.23	2,249.37	-202.53	-551.74	83.63	-3.4	0	0	0	0	143.32	-478.8	0	0
DNHDDPDCL	1,179.66	973.27	14.63	8.69	0	0	0	0	0	0	144.88	24.15	0	0
GOA	810.01	473.22	121.99	76.69	0	0	0	0	0	0	0	-101	0	0
GUJARAT	7,801.35	3,992.95	755.69	169.5	135.8	0	0	0	0	0	681.36	82.32	0	0
MADHYA PRADESH	7,634.23	3,566.15	9.23	-344.66	76.08	-116	0	0	0	0	871.23	-1,311.78	0	0
MAHARASHTRA	9,246.13	6,892.97	424.63	-162.16	117.09	-53.7	0	0	0	0	1,629.25	-15	0	0
RIL JAMNAGAR	-	-	-	-	-	-	-	-	-	-	-	-	-	-

State	HPX DAM(MW)		IEX HPDAM (MW)		PXIL HPDAM(MW)		HPX HPDAM(MW)		IEX RTM (MW)		PXIL RTM(MW)		HPX RTM(MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
AMNSIL	0	0	0	0	0	0	0	0	170.96	6.76	0	0	0	0
BALCO	0	0	0	0	0	0	0	0	101.61	0	0	0	0	0
CHHATTISGARH	0	0	0	0	0	0	0	0	423.66	-234.9	0	0	0	0
DNHDDPDCL	0	0	0	0	0	0	0	0	125.57	0	0	0	0	0
GOA	0	0	0	0	0	0	0	0	72.69	-140	0	0	0	0
GUJARAT	0	0	0	-93.8	0	0	0	0	2,406.55	10.35	0	0	0	0
MADHYA PRADESH	0	0	0	0	0	0	0	0	1,628.53	-245.37	0	0	0	0
MAHARASHTRA	0	0	96.59	0	0	0	0	0	2,033.83	-89.5	0	0	0	0
RIL JAMNAGAR	-	-	-	-	-	-	-	-	-	-	-	-	-	-

8.Major Reservoir Particulars

RESERVOIR	DESIGNED			PRESENT		LAST YEAR		LAST DAY	MONTH	
	MDDL(Mts)	FRL(Mts)	Energy(MU)	Level(Mts)	Energy(MU)	Level(Mts)	Energy(MU)	Inflow(Mus)	"Prog.Inflow (Mus)"	"Prog.Usage (Mus)"
INDIRASAGAR	243.23	262.13	1,367	249.75	293.38	251.94	382.9	249.8	0	0
OMKARESHWAR	193.3	196.6	21.958	194.58	-	195.94	-	194.5	0	0
UKAI	82.296	105.156	770.67	95.72	271.03	96.538	304.294	95.81	0	0
KADANA	114.3	127.711	126.266	120.9	35.34	117.651	13.16	120.93	0	0
SSP	110.64	138.68	1,342.091	127.95	596.8	121.3	295.98	127.93	0	0
KOYNA	615.54	659.43	3,160	622.65	493.735	628.15	819.79	0	0	0
TATA BHIRA	590.1	607.1	582.4	594.02	104.4	594.54	120	594.1	0	0

9.Significant events (If any):

10.System Constraints (If any)

11. Weather Condition:

12. RE/Load Curtailment details

State	Load Curtailment			RE Curtailment				
	Energy	Maximum	At the time of maximum demand	Wind		Solar		Reason
	MU	MW	MW	Max MW	Energy(MU)	Max MW	Energy(MU)	
AMNSIL	0	0	0	0	0	0	0	
BALCO	0	0	0	0	0	0	0	
CHHATTISGARH	0	0	0	0	0	0	0	
DAMAN AND DIU	0	0	0	0	0	0	0	
GOA	0	0	0	0	0	0	0	
GUJARAT	0	0	0	356	1.12	1,668	4.74	To control Underdrawl
MADHYA PRADESH	0	0	0	0	0	0	0	
MAHARASHTRA	0	0	0	0	0	0	0	
RIL JAMNAGAR	0	0	0	0	0	0	0	

Shift In Charge