GRID CONTROLLER OF INDIA (GRID-INDIA)
WESTERN REGIONAL LOAD DESPATCH CENTRE
DAILY OPERATION REPORT OF WESTERN REGION

Power Supply Position in Western Region For 08-Jun-2026

Date of Reporting:09-Jun-2026

1. Regional Availability/Demand:

Evening Peak (20:00) MW				Off-Peak (03:00) MW				/Day Energy(Net MU)	
मांग पूरता/ Demand Met	अभाव/Shortage	आवश्यकता/ Requirement	आवृतता/Freq (Hz)	मांग पूरता/ Demand Met	अभाव/Shortage	आवश्यकता/ Requirement	आवृतता/Freq (Hz)	मांग पूरता/Demand Met	अभाव/Shortage
73,511	0	73,511	50.11	66,434	0	66,434	50.02	1,732.7	0

2(A) /Load Details (/in state periphery) in MU:

राज्य/STATE	State's Control Area Generation (Net MU)							/Net SCH	/Drawal	/UI	Availability	Requirement	/ Shortage	/ Consump -tion
	तापीय/ THERMAL	जलीय/ HYDRO	गैस/ Gas	पवन/ WIND	सौर/ SOLAR	अन्य/ OTHERS	कुल/TOTAL	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)
BALCO	-	0	0	0	0	0	0	17.1	17	-0.1	17	17	0	17
CHHATTISGARH	50.3	0.2	0	0	4.6	1.1	56.2	76.7	76.4	-0.3	132.6	132.6	0	132.6
DNHDDPDCL	-	0	0	0	0	0	0	31.4	30.6	-0.8	30.6	30.6	0	30.6
AMNSIL	6.4	0	0	0	0	0	6.4	10.6	10.8	0.2	17.2	17.2	0	17.2
GOA	0.4	0	0	0	0	0	0.4	15.7	15.2	-0.5	15.6	15.6	0	15.6
GUJARAT	186.5	2.3	11.8	96.2	83.3	0	380.1	185.6	178.2	-7.4	558.3	558.3	0	558.3
MADHYA PRADESH	86.9	5.7	0	27.4	12.1	1.2	133.3	163.5	163.5	0	296.8	296.8	0	296.8
MAHARASHTRA	343.8	13.1	9.8	35.8	32	0	434.5	223.5	223.7	0.2	658.2	658.2	0	658.2
RIL JAMNAGAR	-	0	0	0	0	0	0	6.4	6.4	0	6.4	6.4	0	6.4
Region	674.3	21.3	21.6	159.4	132	2.3	1,010.9	730.5	721.8	-8.7	1,732.7	1,732.7	0	1,732.7

2(B) / /State's Demand Met in MW and day energy forecast and deviation particulars

राज्य/State	Evening Peak (20:00) MW			Off-Peak (03:00) MW				/Day Energy(Net MU)	
	मांग पूरता/ Demand Met	अभाव/ Shortage	आवश्यकता/ Requirement at Evening peak	मांग पूरता/ Demand Met	अभाव/ Shortage	आवश्यकता/ Requirement at Off-Peak	AVG (MW)	पूर्वानुमान/ForeCast(MU)	विचलन/Deviation[Fore .. -Consumption] (MU)
BALCO	711	0	711	709	0	709	707	14	-3
CHHATTISGARH	5,760	0	5,760	5,645	0	5,645	5,519	132	-0.6
DNHDDPDCL	1,250	0	1,250	1,322	0	1,322	676	32	1.4
AMNSIL	688	0	688	705	0	705	716	19	1.8
GOA	755	0	755	580	0	580	659	14	-1.6
GUJARAT	23,092	0	23,092	20,359	0	20,359	23,260	558	-0.3
MADHYA PRADESH	12,534	0	12,534	11,640	0	11,640	12,387	297	0.2
MAHARASHTRA	28,464	0	28,464	25,200	0	25,200	27,425	633	-25.2
RIL JAMNAGAR	257	0	257	274	0	274	266	6	-0.4
Region	73,511	0	73,511	66,434	0	66,434	71,615	1,705	-27.7

2(C) /State's Demand Met in MW (/maximum demand met and /Maximum requirement of the day details)

राज्य/State	Maximum Demand, corresponding shortage and requirement details for the day				ACE			
	अधिकतम मांग पूरता/Maximum Demand Met of the day	समय/Time	अभाव/Shortage at maximum demand	आवश्यकता/Requirement at the max demand met of the day	ACE_MAX	बजे/Time	ACE_MIN	बजे/Time
BALCO	711	00:00	0	711	-	-	-	-
CHHATTISGARH	5,950	19:15	0	5,950	829.49	21:47:00	-426.78	07:01:00
DNHDDPDCL	1,407	17:33	0	1,407	224.03	11:47:00	-62.49	12:49:00
AMNSIL	795	20:00	0	795	257.94	20:42:00	-268.92	18:10:00
GOA	759	19:45	0	759	86.84	17:59:00	-135.42	04:47:00
GUJARAT	27,549	15:01	0	27,549	2,438.93	12:03:00	-863.47	10:17:00
MADHYA PRADESH	13,236	23:00	0	13,236	1,031.6	07:25:00	-728.98	19:13:00
MAHARASHTRA	29,790	16:00	0	29,790	1,228.98	11:48:00	-959.76	16:46:00
RIL JAMNAGAR	276	15:00	0	276	-	-	-	-
WR	78,324	15:00	0	78,324	-	-	-	-

3(A) State Entities Generation:

CHHATTISGARH

स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
KORBA EAST EXT(DSPM)(2*250)	500	462	454	469	21:48	308	13:45	11.09	10.17	424
KORBA(W) CSETCL(4*210 + 1*500)	1,340	724	710	737	22:40	-163	13:06	17.64	16.35	681
MARWA TPS(1*500 + 1*500)	1,000	941	947	970	02:31	551	11:09	21.4	20.32	847
OTHER CPP	50	0	0	0	-	0	-	3.5	3.5	146
TOTAL THERMAL	2,890	2,127	2,111	-	-	-	-	53.63	50.34	2,098
HASDEO BANGO(3*40)	120	1	1	78	23:13	1	00:04	0.12	0.12	5
KWB MINI MICRO(2*0.85)	1.7	0	0	0	-	0	-	0.01	0.01	0
SMALL HYDRO	50	0	0	0	-	0	-	0.05	0.05	2
TOTAL HYDEL	171.7	1	1	-	-	-	-	0.18	0.18	7
WIND	0	0	0	0	-	0	-	0	0	0
SOLAR	842	90	0	700	13:22	11	01:02	4.58	4.58	191
BIO MASS	50	0	0	0	-	0	-	1.05	1.05	44
TOTAL BIO MASS	50	0	0	-	-	-	-	1.05	1.05	44
TOTAL CHHATTISGARH	3,953.7	-	-	-	-	-	-	59.44	56.15	2,340

GUJARAT

स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
AECO(1*120 + 2*121)	362	234	238	243	02:28	149	08:32	5.1	4.64	193
ALTPS(2*125)	250	35	35	35	00:00	35	00:00	1.44	1.13	47
APL MUNDRA(4*330 + 2*660 + 3*660)	4,620	3,027	3,031	4,251	23:55	2,567	10:51	79.18	72.61	3,025
BLTPS(2*250)	500	331	320	338	18:55	237	11:55	7.72	6.5	271
GANDHINAGAR(GTPS)(3*210)	630	560	550	626	05:33	350	16:01	11.2	10.11	421
KLTPS(2*75)	150	65	65	65	19:31	57	10:06	1.52	1.33	55
OTHER CPP	1,000	0	0	0	-	0	-	5.71	6.69	279
SLPP(4*125)	500	302	304	306	03:15	195	15:20	7.11	6.13	255
STPS(2*250)	500	289	294	511	21:45	279	14:01	7.54	6.73	280
UKAI(2*200 + 1*210 + 1*500)	1,110	371	376	477	23:59	245	09:37	7.67	6.57	274
VADINAR(2*600)	1,200	777	1,083	1,151	00:03	567	07:43	20.64	19.29	804
WANAKBORI(7*210 + 1*800)	2,270	2,164	2,149	2,198	23:33	1,263	08:42	42.11	38.64	1,610
TOTAL THERMAL	13,092	8,155	8,445	-	-	-	-	196.94	180.37	7,514
DGBP(1*107 + 1*112 + 1*376)	594	0	0	0	00:00	0	00:00	0	0	0
ESSAR POWER GAS(3*110 + 1*185)	515	0	0	0	-	0	-	0	0	0
GIPCL STG(3*32 + 49)	145	0	0	0	00:00	0	00:00	0	0	0
GIPCL STG 2(111 + 54)	165	0	0	0	00:00	0	00:00	0	0	0
GPEC(3*138 +241)	654	0	0	0	-	0	-	0	0	0
GPPC(2*351.43)	702	0	0	0	00:00	0	00:00	0	0	0
GSEC(3*52)	156	0	7	7	00:00	0	10:50	0	0	0
SUGEN 1(3*382.5)	1,147.5	777	354	997	21:11	-6	06:40	9.46	9.15	381
UNOSUGEN(1*382.5)	382.5	276	-5	362	23:06	-10	16:27	2.75	2.65	110
UTRAN STG II(1*229 + 1*146(ST))	375	0	0	0	00:00	0	00:00	0	0	0
TOTAL GAS	4,836	1,053	356	-	-	-	-	12.21	11.8	491
KADANA(4*60)	240	0	49	50	00:05	0	07:04	0.37	0.37	15
LBC PANAM HYDRO	5	0	0	0	-	0	-	0.08	0.08	3
PVT HYDRO	20.6	0	0	0	-	0	-	0.14	0.14	6
UKAI HYDRO(4*75)	300	65	63	131	18:10	61	06:20	1.91	1.87	78
TOTAL HYDEL	565.6	65	112	-	-	-	-	2.5	2.46	102
WIND	8,836	5,621	2,806	5,904	18:45	1,442	06:30	96.19	96.19	4,008
SOLAR	15,238	158	0	10,202	11:52	0	00:00	83.33	83.33	3,472
BIO MASS	51.65	0	0	0	-	0	-	1.05	1.05	44
TOTAL GUJARAT	42,619.25	-	-	-	-	-	-	392.22	375.2	15,631

MADHYA PRADESH

स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
AMARKANTAK(1*210)	210	182	0	182	20:00	0	00:00	3.35	2.97	124
BLA IPP(2*45)	90	83	83	84	00:06	45	09:30	1.72	1.51	63
JP BINA(2*250)	500	237	467	470	01:30	145	15:43	7.17	6.52	272
SANJAY GANDHI TPS(4*210 + 1*500)	1,340	972	973	984	15:19	811	12:08	24.16	22.21	925
SATPURA IV(2*250)	500	470	476	481	16:45	260	11:56	10.94	10.04	418
SINGAJI(2*600 + 2*660)	2,520	2,060	2,187	2,255	02:16	1,302	13:46	47.71	44.88	1,870
TOTAL THERMAL	5,160	4,004	4,186	-	-	-	-	95.05	88.13	3,672
BANASAGAR TONS(3*105)	315	0	0	0	00:00	0	00:00	0	0	0
BARGI(2*45)	90	30	30	32	09:03	30	14:53	0.73	0.72	30
BIRSINGHPUR	20	0	0	0	-	0	-	0	0	0
BSGR(DEVLONE)(3*20)	60	0	0	0	00:00	0	00:00	0	0	0
BSGR(SILPARA)(2*15)	30	0	0	0	00:00	0	00:00	0	0	0
INDIRASAGAR(8*125)	1,000	211	0	576	23:05	0	12:08	3.04	3.02	126
JHINNA(2*10)	20	0	0	0	07:36	0	01:36	0	0	0
MADIKHEADA(3*20)	60	60	60	60	00:00	60	00:00	0	0	0
MP CHAMBAL	386	0	0	0	-	0	-	0	0	0
OMKARESHWAR(8*65)	520	187	0	407	21:25	0	00:44	1.98	1.97	82
PENCH(2*80)	160	0	0	0	-	0	-	0	0	0
RAJGHAT HYDRO(3*15)	45	0	0	0	00:00	0	00:00	0	0	0
TOTAL HYDEL	2,706	488	90	-	-	-	-	5.75	5.71	238
WIND	2,670	879	921	1,085	23:59	603	13:20	27.37	27.37	1,140
SOLAR	2,370	0	0	1,703	12:01	22	06:00	12.13	12.13	505
BIO + SMALL HYDRO	100	0	0	0	-	0	-	1.22	1.22	51
TOTAL MADHYA PRADESH	13,006	-	-	-	-	-	-	141.52	134.56	5,606

MAHARASHTRA

स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
APML TIRODA(5*660)	3,300	3,105	2,133	3,123	21:39	1,706	14:14	64.59	60.97	2,540
BHUSAWAL(1*210 + 2*500+1*660)	1,870	1,656	1,525	1,671	19:54	1,004	09:57	36.09	33.79	1,408
CHANDRAPUR(2*210 + 5*500)	2,920	2,085	1,481	2,117	05:46	1,475	15:04	45.81	42.1	1,754
DAHANU(2*250)	500	472	365	504	16:27	281	14:45	9.6	8.61	359
IEPL(1*270)	270	268	265	274	23:04	150	10:25	5.72	5.22	218
JAIGAD(4*300)	1,200	753	735	819	00:05	486	10:40	17.03	15.62	651
JPL DHULE (SHIRPUR)(2*150)	300	253	256	282	02:37	138	12:01	5.89	5.63	235
KHAPARKHEDA(4*210 + 1*500)	1,340	910	892	949	18:58	733	10:15	23.01	21.07	878
KORADI(1*210 + 3*660)	4,170	1,561	1,603	1,781	18:10	1,193	10:31	38.9	36.58	1,524
NASIK(3*210)	630	379	335	401	22:15	308	07:33	9.1	8.35	348
OTHER CPP	3,305	0	0	0	-	0	-	30.364	30.364	1,265
PARAS(2*250)	500	408	405	431	23:59	259	14:59	9.88	8.87	370
PARLI(3*250)	750	604	618	671	00:43	378	12:09	14.11	12.42	518
RATTAN INDIA (AMARAVATI)(5*270)	1,350	978	977	1,004	07:00	572	12:38	25.03	22.82	951
SWPGL(4*135)	540	432	433	444	17:09	239	12:01	11	9.9	413
TROMBAY(250+1*500)	750	385	388	665	21:34	376	08:49	10.264	9.606	400
VIPL(2*300)	600	569	482	581	17:55	320	12:11	12.82	11.91	496
TOTAL THERMAL	24,295	14,818	12,893	-	-	-	-	369.208	343.83	14,328
TROMBAY_GAS(1*120+1*60)	180	163	167	174	02:17	103	08:20	3.41	3.32	138
URAN(4*108 + 2*120)	672	270	272	275	08:01	258	13:51	6.67	6.48	270
TOTAL GAS	852	433	439	-	-	-	-	10.08	9.8	408
BHIRA(6*25)	150	128	3	150	18:22	2	11:36	0	0	0
BHIRA PSS	150	158	144	163	00:02	0	06:46	0	0	0
BHIRA TR(2*40)	80	0	0	0	-	0	-	0.22	0.22	9
BHIVPURI(3*24 + 2*1.5)	75	48	47	48	20:00	20	12:47	0	0	0
GHATGHAR(2*125)	250	0	0	124	22:41	-149	12:04	0.54	0.53	22
HYDRO VTRNA(1*60)	60	0	0	0	00:00	0	00:00	0	0	0
HYDROSMLHY_PTN	350	0	0	0	-	0	-	5.37	5.26	219
KHOPOLI(3*24)	72	24	22	24	20:00	6	16:24	0	0	0
KOYNA I AND II(4*(65+5) + 4*(75+5))	600	41	42	45	17:54	35	13:00	1.04	1	42
KOYNA III(4*80)	320	0	0	157	23:42	0	00:06	0.2	0.19	8
KOYNA ST-IV(4*250)	1,000	-1	-6	254	23:04	-24	11:35	0.29	0.29	12
TILLARI(1*66)	66	0	0	0	00:00	0	00:00	0	0	0
OTHER HYDRO	122	0	0	0	-	0	-	5.59	5.59	233
TOTAL HYDEL	3,295	398	252	-	-	-	-	13.25	13.08	545
WIND	5,321	1,421	868	1,489	20:13	418	07:15	35.84	35.84	1,493
SOLAR	6,028	152	18	4,331	12:09	49	06:00	31.98	31.98	1,333
TOTAL MAHARASHTRA	39,791	-	-	-	-	-	-	460.358	434.53	18,107

3(B) Regional Entities Generation

ISGS

स्टेशन/ Station/Constituents	स्थापित क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
GADARWARA(2*800)	1,600	1,479	1,487	1,527	02:44	751	15:02	28.19	30.07	28.15	1,173
GANDHAR(3*144.3 + 1*224.49)	657	368	-27	524	22:26	-59	11:30	1.13	2.41	2.29	95
KAPS(2*220)	440	391	391	391	00:00	391	00:00	4.68	5.21	4.63	193
KAPS3&4(2*700)	1,400	583	593	600	06:11	577	15:52	28.53	31.44	28.82	1,201
KAWAS(4*106 + 2*116.1)	656.2	412	-15	535	22:27	-18	06:05	1.14	2.97	2.87	120
KHARGONE(2*660)	1,320	1,134	1,208	1,264	00:09	651	08:03	22.23	23.82	22.17	924
KSTPS1&2(3*200 + 3*500)	2,100	1,258	1,326	1,358	02:10	743	13:21	32.16	33.72	31.05	1,294
KSTPS3(1*500)	500	466	476	485	04:35	276	09:07	10.1	10.64	9.89	412
LARA(2*800)	1,600	1,461	1,481	1,519	02:18	812	10:04	32.34	34.05	31.97	1,332
MOUDA I(2*500)	1,000	793	915	968	05:35	420	07:48	18.34	19.03	17.22	718
MOUDA II(2*660)	1,320	1,063	1,179	1,221	01:58	562	07:48	23.85	25.25	22.44	935
NSPCL(2*250)	500	400	438	466	05:23	238	08:26	9.42	10.03	9.14	381
RGPPL(2*320 + 4*331.75)	1,967	838	-14	1,216	22:16	-35	08:34	4.31	4.57	4.33	180
SASAN(6*660)	3,960	3,163	3,722	3,773	14:25	2,135	11:06	81.55	86.64	81.18	3,383
SIPAT I(3*660)	1,980	1,782	1,869	1,932	23:09	1,003	09:36	39.95	42.18	39.45	1,644
SIPAT II(2*500)	1,000	919	962	990	21:30	523	09:29	20.37	21.36	20.41	850
SOLAPUR STPS(2*660)	1,320	657	671	1,137	22:28	648	06:08	17.29	19.04	17.52	730
SSP(RBPH+CHPH)(6*200 + 5*50)	1,450	47	47	840	00:55	47	04:35	6.59	6.67	6.58	274
TARAPUR I(2*160)	320	233	236	252	20:25	217	13:34	5.52	5.87	5.35	223
TARAPUR II(2*540)	1,080	761	790	812	12:39	772	12:03	18.72	20.98	18.72	780
VSTPS I(6*210)	1,260	883	921	989	16:07	439	13:26	19.86	21.82	19.13	797
VSTPS II(2*500)	1,000	864	918	982	16:34	451	13:26	19.54	20.51	18.87	786
VSTPS III(2*500)	1,000	909	925	1,021	15:39	497	08:30	19.63	20.48	19.36	807
VSTPS IV(2*500)	1,000	862	930	952	02:13	479	08:33	19.8	20.89	19.54	814
VSTPS V(1*500)	500	438	465	488	01:43	240	08:57	9.87	10.37	9.75	406
SUB-TOTAL	30,930.2	22,164	21,894	-	-	-	-	495.11	530.02	490.83	20,452
TOTAL	30,930.2	-	-					495.11	530.02	490.83	20,452

IPP/JV

स्टेशन/ Station/Constituents	स्थापित क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
ACBIL(2*135 + 2*50 + 2*30 + 1*63)	493	244	242	252	21:55	209	11:06	5.78	6.82	5.71	238
ADANI RAIPUR(2*685)	1,370	1,077	1,113	1,150	23:27	679	13:13	24.51	27.32	24.55	1,023
APL RAIGARH(1*600)	600	558	568	587	02:11	293	09:32	12.12	12.93	12.2	508
BALCO(4*300)	1,200	961	859	983	19:01	573	10:57	20.55	20.55	20.2	842
DB POWER(2*600)	1,200	1,108	1,145	1,159	22:27	614	10:37	24.88	26.31	24.9	1,038
DCPP(2*135)	270	224	111	224	18:58	111	00:00	5.04	5.77	5.04	210
DGEN(3*400)	1,200	-3	-3	-2	12:57	-4	10:56	0	0.05	0.05	2
DHARIWAL CTU(2*300)	600	221	373	389	06:39	73	12:04	5.94	6.55	5.96	248
GMR WARORA(2*300)	600	546	548	582	21:23	310	12:05	12.31	13.43	12.4	517
JHABUA POWER(1*600)	600	519	538	544	06:56	302	09:30	11.89	12.22	11.44	477
JP NIGRIE(2*660)	1,320	1,247	1,257	1,267	02:09	692	11:02	26.46	28.2	26.79	1,116
JPL STG-I(4*250)	1,000	864	1,000	1,007	02:14	521	09:19	17.73	20.37	18.11	755
JPL STG-II(4*600)	2,400	1,708	2,308	2,347	02:35	1,347	11:58	43.17	45.74	42.93	1,789
JSW MAHANADI(3*600)	1,800	1,704	1,705	1,838	15:02	894	11:27	39.1	41.88	39.07	1,628
LANCO(2*300)	600	264	271	281	21:21	143	09:28	5.88	6.64	5.86	244
MAHAN ENERGEN(2*600)	1,200	910	906	928	17:31	615	11:25	20.47	22.11	20.54	856
MB POWER(2*600)	1,200	1,178	1,179	1,198	22:09	488	12:35	24.84	26.19	24.68	1,028
MCCPL(1*300)	300	-6	232	238	05:46	-16	09:34	2.44	2.35	2.11	88
RKM POWER(4*360)	1,440	1,312	1,315	1,323	19:02	728	12:14	27.63	30.63	27.76	1,157
SARDA ENERGY & MINERALS LTD(2*300)	600	524	524	529	01:36	331	10:58	-	13.06	11.81	492
TPCL(5*800)	4,000	3,778	2,630	3,822	23:09	2,058	17:06	65.5	70.45	64.77	2,699
TRN ENERGY(2*300)	600	540	536	541	19:34	311	12:07	11.99	13.32	12.15	506
VEDANTA_LIMITED_CG (1*600)	600	-1	-1	-1	05:50	-2	18:00	0.06	0.05	0.05	2
SUB-TOTAL	25,193	19,477	19,356	-	-	-	-	408.29	452.94	419.08	17,463
TOTAL	25,193	-	-					408.29	452.94	419.08	17,463

RENEWABLE

स्टेशन/ Station/Constituents	स्थापित क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
AGE25BL_PSS9_KPS1_HS	100	0	0	0	-	0	-	0.15	0.47	0.47	20
AHEJ5L_PSS8_KPS3_HS	100	0	0	107	12:18	0	05:52	1.47	0.92	0.92	38
AYANARP4_DVSR_BHJ_HS	37.5	0	0	0	00:00	0	00:00	0.21	0.2	0.2	8
ACL_PSS3_KPS1_S	200	0	0	210	11:42	0	00:01	1.92	1.7	1.7	71
ACL_PSS4_KPS1_HS	125	0	0	126	11:38	0	06:00	1.43	0.81	0.81	34
AGE24AL_PSS3_KPS1_S	400	0	0	395	12:19	0	00:55	4.11	3.22	3.22	134
AGE24L_PSS10_KPS3_S	150	0	0	114	11:42	0	00:03	0.72	0.61	0.61	25
AGE24L_PSS5_KPS1_S	150	0	0	154	12:26	0	05:58	1.58	1.24	1.24	52
AGE25AL_PSS2_KPS1_S	500	0	0	333	17:32	0	04:59	1.38	1.88	1.88	78
AGE25BL_PSS2_KPS1_S	582.98	0	0	422	08:52	0	00:11	1.61	2.33	2.33	97
AGE25CL_PSS8_KPS3_S	350	0	0	420	12:21	0	00:00	5.04	3.06	3.06	128
AGE26AL_PSS3_KPS1_S	62.5	0	0	0	19:51	-44	12:10	0.2	0.15	0.15	6
AGE26AL_PSS6_KPS1_S	750	0	0	0	00:00	0	00:00	7.42	4.34	4.34	181
AGE26BL_PSS10_KPS1_HS	142	0	0	272	11:42	0	01:48	0.11	1.38	1.38	58
AGE26BL_PSS10_KPS1_S	150	0	0	272	11:42	0	01:48	0.41	1.38	1.38	58
AGE26BL_PSS2_KPS1_S	167	0	0	122	08:52	0	00:00	0.46	0.7	0.7	29
AHEJ5L_PSS5_KPS1_S	570	0	0	580	00:40	0	06:00	5.57	3.91	3.91	163
APSEZ_PSS3_KPS1_S	200	0	0	210	12:21	0	04:24	1.92	1.61	1.61	67
ARE3L_PSS8_KPS3_HS	25	0	0	0	-	0	-	0.23	0.2	0.2	8
ARE45L_PSS5_KPS1_S	250	0	0	247	12:37	0	06:00	2.61	1.99	1.99	83
ARE55L_PSS3_KPS1_HS	25	0	0	23	11:55	0	00:00	0.22	0.2	0.2	8
ARE55L_PSS3_KPS1_S	162.5	0	0	20	00:01	3	06:46	1.66	0.2	0.2	8
ARE56L_PSS10_KPS1_S	500	0	0	457	11:51	0	05:40	2.78	2.48	2.48	103
ARE56L_PSS4_KPS1_S	225	0	0	0	-	0	-	2.37	1.57	1.57	65
ARE56L_PSS9_KPS1_S	400	0	0	236	11:31	0	06:00	1.1	1.59	1.59	66
ARE57L_PSS13_KPS1_S	850	0	0	525	17:37	-1	01:57	2.35	3.04	3.04	127
AREH4L_PSS1_KPS1_SF	1,000	0	0	654	17:31	0	00:00	4.23	4.09	4.09	170
ARINSUN SOLAR (BARSAITADESH)	250	0	0	249	12:17	-1	00:00	1.54	1.38	1.38	58
ASEJ6PL_PSS8_KPS3_HS	35	0	0	30	00:00	30	00:00	0.07	0.72	0.72	30
ASEJ6PL_PSS8_KPS3_S	50	0	0	30	00:00	30	00:00	0.49	0.72	0.72	30
ATHENA SOLAR	250	0	0	244	12:16	8	06:00	1.64	1.47	1.47	61
AVAADA_AGAR_RUMS_S	200	0	0	202	12:24	0	00:00	1.49	1.48	1.48	62
AYANARP4_DVSR_BHJ_HW	150	0	0	3	00:00	3	00:00	1.52	0.07	0.07	3
BEEMPOW_AGAR_RUMS_S	350	0	0	348	12:19	-2	00:10	2.55	2.56	2.56	107
BLUELEAF_CP_PCHR_HS	128.7	0	0	43	13:12	-43	06:18	0.4	0.35	0.35	15
CGERP_MORJAR_BHJ2_HS	30.8	0	0	0	00:00	0	00:00	0.13	0.1	0.1	4
ESPL_RSP SOLAR	200	0	0	144	00:00	144	00:00	1.55	3.45	3.45	144
GANDHAR SOLAR	20	0	0	19	00:00	19	00:00	0.13	0.46	0.46	19
GIPCL_PSS1_KPS2_S	600	0	0	549	11:49	-16	06:06	4.74	4.51	4.51	188
GIPCL_RSP SOLAR	100	0	0	77	00:00	77	00:00	0.76	1.85	1.85	77
GSEC 2	100	0	0	48	00:24	12	00:00	0.44	0.51	0.51	21
GSECL_RSP SOLAR	100	0	0	0	00:00	0	00:00	0	0	0	0
KAWAS SOLAR	56	0	0	11	00:00	11	00:00	0.35	0.26	0.26	11
KPIG_GSECLS_KPS2_S	200	0	0	171	14:27	-1	06:19	1.23	1.31	1.31	55
MAHINDRA SOLAR (BADWAR)	250	0	0	227	12:52	7	05:59	1.4	1.4	1.4	58
MASAYA SOLAR	300	0	0	294	12:10	5	06:00	1.99	2.09	2.09	87
NTPCREL_PSS1_KPS3_S	1,095	0	0	326	09:17	-2	06:01	2.5	2.59	2.59	108
NTPCREL_PSS2_KPS2_S	1,555	0	0	0	-	0	-	9.03	9.014	9.014	376
SAELP4_GSECLS_KPS2_S	400	0	0	371	13:58	-1	06:03	2.38	2.69	2.69	112
SAELP5_GSECLS_KPS2_S	400	0	0	0	-	0	-	2.39	2.2	2.2	92
SGEL_RSP_S	100	0	0	103	12:37	0	00:00	0.74	0.77	0.77	32
SHERISHA RAIPUR	50	0	0	39	11:53	0	00:00	0.27	0.22	0.22	9
SOLAPUR SOLAR PV PROJECT	23	0	0	0	00:00	0	00:00	0.13	0.12	0.12	5
TPREL_RSP SOLAR	100	0	0	74	00:00	74	00:00	0.75	1.77	1.77	74
TPSOURY_BRVD_NMCH_S	160	0	0	162	13:14	1	06:00	1.51	1.48	1.48	62
TPSOURY_KWAI_NMCH_S	170	0	0	177	11:29	0	06:00	1.6	1.65	1.65	69
AHEJ5L_PSS8_KPS3_HW	65	43	25	67	16:19	10	06:43	1.49	0.97	0.97	40
RSRPL_GHTND_KLM_W	138.6	0	0	0	-	0	-	1.01	-	0	0
ACL_PSS4_KPS1_W	156	129	69	155	16:31	34	06:55	1.97	2.57	2.57	107
ADANI WIND ENERGY KUTCHH FOUR LTD	300	235	186	285	14:30	139	06:06	5.4	5.38	5.38	224
AGE24L_PSS4_KPS1_W	100	98	40	103	19:33	28	06:32	0.88	1.85	1.85	77
AGE25BL_PSS9_KPS1_HW	130	0	0	0	-	0	-	1.05	1.82	1.82	76
AGE25CL_PSS11_KPS3_W	185	0	0	0	00:00	0	00:00	1.67	1.5	1.5	63
AGE25CL_PSS14_KPS3_W	65	0	0	0	00:00	0	00:00	0.51	0.5	0.5	21
AGE26AL_PSS12_KPS3_W	137.5	0	0	0	00:00	0	00:00	1.24	1.2	1.2	50
AGE26BL_PSS10_KPS1_W	156	106	78	133	18:28	30	06:35	1.59	2.11	2.11	88
AHEJ5L_PSS4_KPS1_W	60	54	30	62	17:08	15	08:25	0.54	1.05	1.05	44
AHEJ5L_PSS5_KPS1_HW	202.8	0	0	0	-	0	-	1.06	1.01	1.01	42
ALFANAR WIND (NANAVALKA)	300	213	120	242	18:02	87	06:56	4.57	4.26	4.26	178
APRAAVA ENERGY PRIVATE LIMITED (AEPL)	252	138	138	138	00:00	138	00:00	3.8	3.32	3.32	138

APSEZ_PSS4_KPS1_W	52	40	23	52	19:27	4	06:43	0.62	0.77	0.77	32
ARE3L_PSS8_KPS3_HW	41.6	30	12	41	15:17	7	06:37	0.51	0.6	0.6	25
ARE41L_PSS13_KPS1_W	124.8	82	45	119	16:55	21	06:52	1.76	1.77	1.77	74
ARE41L_PSS3_KPS1_W	250	195	167	232	19:16	57	06:52	2.53	3.73	3.73	155
ARE41L_PSS4_KPS1_W	50	45	29	52	17:12	18	06:47	0.68	0.96	0.96	40
ARE41L_PSS8_KPS3_W	125	89	35	122	15:12	21	06:43	2.96	1.81	1.81	75
ARE48L_SRPL_PSS9_KPS1_W	119.6	0	0	0	00:00	0	00:00	0	0	0	0
ARE55L_PSS3_KPS1_HW	25	0	0	0	-	0	-	0.15	0.14	0.14	6
ASEJ6PL_PSS8_KPS3_HW	62.4	0	0	0	00:00	0	00:00	1.3	1.21	1.21	50
ASIPL WIND (BARANDA)	170.1	0	0	0	00:00	0	00:00	0	0	0	0
AWEK1L WIND (RATADIYA)	425	335	294	404	15:51	294	00:02	6.5	7.74	7.74	323
AWEKFL WIND (RATADIYA)	130	42	42	42	00:00	42	00:00	1.82	1	1	42
AWEMP1PL_PTNGR_IDR_W	324.4	222	247	278	23:59	80	10:25	4.48	5.04	5.04	210
AYANARP4_ZURA_BHJ_S	92.4	-1	86	101	13:58	32	15:22	0.83	1.57	1.57	65
BLUELEAF_CP_PCHR_HW	115.5	90	103	110	12:28	34	06:43	1.96	1.92	1.92	80
CGERP_MORJAR_BHJ2_HW	29.7	0	0	0	00:00	0	00:00	-	0	0	0
CPTTNPL WIND (DAYAPAR)	126	89	89	89	00:00	89	00:00	1.62	2.13	2.13	89
GIWEL-II WIND (VADVA)	250	168	136	220	14:22	136	00:02	3.78	3.73	3.73	155
GIWEL-III WIND (NARANPAR)	300	144	93	173	14:13	62	06:10	3.47	3.11	3.11	130
IGESL_DAYAPAR_BHUJ_W	250	91	91	91	00:00	91	00:00	2.92	2.18	2.18	91
NETRA_KOTDA_BHUJ_W	206.5	146	116	166	15:13	116	00:02	3.43	3.09	3.09	129
NTPC_REL_DYPR_BHUJ_W	146	71	71	71	00:00	71	00:00	1.71	1.69	1.69	70
OEPL WIND (OSTRO KUTCH)	50	30	30	30	00:00	30	00:00	0.88	0.71	0.71	30
OKWPL WIND (OSTRO KUTCH)	250	150	150	150	00:00	150	00:00	4.07	3.61	3.61	150
POWERICA WIND	50.6	84	50	90	19:10	18	06:04	0.83	1.49	1.49	62
RENEW AP2 WIND (GHADSISA)	300	212	141	256	14:21	141	00:02	5.04	4.4	4.4	183
RENEW WIND (BHUVAD)	230.1	179	91	201	18:25	66	06:00	3.6	3.42	3.42	143
RGMHP1_PATODA_KLM_W	135.3	124	65	132	22:11	12	14:20	1.42	1.89	1.89	79
RGMHS1_TLJPR_SLPR_HW	161.7	0	0	0	-	0	-	0.51	0.5	0.5	21
SAUPL_HJRTPR_RJGR_W	100	0	0	0	00:00	0	00:00	0.78	0	0	0
SITAC WIND	300	253	193	280	15:08	144	07:42	5.77	5.49	5.49	229
SRIJAN WIND	148.5	134	60	153	10:02	48	06:46	2.09	2.79	2.79	116
TEQGREEN_WASI_KLM_W	70.2	0	0	54	11:54	0	00:00	0.47	0.3	0.3	13
TORRENT SOLARGEN LIMITED	115	92	48	107	15:30	15	06:13	1.73	1.63	1.63	68
TOTAL	23,173.28	-	-					193.98	190.424	190.424	7,937

RENEWABLE_BESS

स्टेशन/ Station/Constituents	स्थापित क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
ARE37L_PSS5_KPS1_B	160	55	-1	73	23:04	-165	13:41	0.06	-0.01	-0.01	0
ARE43L_PSS10_KPS3_B	360	27	-1	322	23:04	-424	12:46	0.18	-0.18	-0.18	-8
SUB-TOTAL	520	82	-2	-	-	-	-	0.24	-0.19	-0.19	-8
TOTAL	520	-	-					0.24	-0.19	-0.19	-8

REGIONAL GENERATION SUMMARY

	THERMAL GEN MU	GAS GEN MU	SOLAR GEN MU	WIND GEN MU	HYDRO GEN MU	NUCLEAR GEN MU	OTHER GEN MU	TOTAL GEN MU	SCHEDULE MU
ISGS	417.24	9.49	-	-	6.58	57.52	-	490.83	495.11
IPP	419.03	0.05	-	-	-	-	-	419.08	408.29
Constituents	674.3	21.6	132	159.4	21.3	-	2.3	1,010.9	1,002.2
Renewables	-	-	92.464	97.96	-	-	-	190.23	194.22
Region	1,510.57	31.14	224.464	257.36	27.88	57.52	2.3	2,111.04	2,099.82

4(A) अंतर क्षेत्रीय विनिमय/INTER-REGIONAL EXCHANGES (Import=(+ve) /Export =(-ve))

SL.No.	Element	20:00	03:00	अधिकतम पस्पर विनिमय/Maximum Interchange (MW)		आयात/Import in MU	नरि्यात/Export in MU	शुद्ध विनिमय/NET
		(MW)	MW	आयात/Import (MW)	नरि्यात/Export (MW)			
	EAST REGION WEST REGION / /Import/Export between EAST REGION and WEST REGION							
1	220KV-KORBA-BUDIPADAR	14	37	82	-99	0.43	-0.59	-0.16
2	220KV-RAIGARH-BUDIPADAR	20	40	121	-152	0.51	-0.73	-0.22
3	400KV-JAGDALPUR-JEYPORE	-	-	-	-	0.25	-	0.25
4	400KV-RAIGARH-JHARSUGUDA	194	279	415	-442	1.69	-0.45	1.24
5	400KV-SIPAT-RANCHI	-	-	-	-	0	-6.31	-6.31
6	765KV-DHARJAYGARH-JHARSUGUDA	48	-207	294	-950	0	-8.73	-8.73
7	765KV-DHARJAYGARH-RANCHI	-1,306	-708	-	-2,773	0	-33.98	-33.98
8	765KV-RAIPUR-PS (DURG)-JHARSUGUDA	197	400	650	-702	1.82	0	1.82
	Sub-Total EAST REGION	-833	-159	1,562	-5,118	4.7	-50.79	-46.09
	NORTH REGION WEST REGION / /Import/Export between NORTH REGION and WEST REGION							
1	132KV-RAJGHAT-LALITPUR	0	0	-	0	0	0	0
2	220KV-BHANPURA-MODAK	-50	-53	-	-72	0	-1.24	-1.24
3	220KV-BHANPURA-RANPUR	-30	-30	-	-30	0	-1.86	-1.86
4	220KV-MALANPUR-AURIYA	69	-8	72	-24	0.33	-0.06	0.27
5	220KV-MEHGAON-AURIYA	0	11	66	-9	0.36	0	0.36
6	400KV-KANSARI-KANKROLI	-163	-11	202	-341	0.66	-2.48	-1.82
7	400KV-KANSARI-KANKROLI 2(BYPASS AT BHINMAL)	-113	-9	138	-236	0.45	-1.73	-1.28
8	400KV-NEEMUCH-CHITTORGARH	-289	-404	406	-562	2.18	-5.25	-3.07

NORTH REGION WEST REGION / /Import/Export between NORTH REGION and WEST REGION								
9	400KV-SUJALPUR-RAPP	-172	-188	737	-447	5.05	-2.91	2.14
10	400KV-VINDHYACHAL PS-RIHAND(III)	-1	-1	-	-1	0	0	0
11	765KV-BANASKANTHA-CHITTORGARH	-1,069	11	849	-1,829	2.8	-20.79	-17.99
12	765KV-GWALIOR-AGRA	-1,541	-1,584	-	-2,221	0	-32.63	-32.63
13	765KV-GWALIOR-JAIPUR	-1,258	-1,556	1,248	-1,764	6	-19.54	-13.54
14	765KV-GWALIOR-ORAI	426	488	574	-111	7.7	-0.24	7.46
15	765KV-JABALPUR-ORAI	-1,024	-1,105	-	-1,388	0	-37.95	-37.95
16	765KV-SATNA-ORAI	-932	-1,083	-	-1,156	0	-19.77	-19.77
17	765KV-VINDHYACHAL(PS)-VARANASI	-2,534	-2,530	-	-3,513	0	-63.75	-63.75
18	HVDC 500KV VINDHYACHAL B/B	-498	93	93	-499	0	-4.3	-4.3
19	HVDC500KV-MUNDRA-MOHINDARGARH	-1,069	-1,448	-	-1,455	0	-32.43	-32.43
20	HVDC800KV-CHAMPA-KURUKSHETRA	-4,563	-3,533	-	-4,567	0	-98.85	-98.85
Sub-Total NORTH REGION		-14,811	-12,940	4,385	-20,225	25.53	-345.78	-320.25
SOUTH REGION WEST REGION / /Import/Export between SOUTH REGION and WEST REGION								
1	220KV-KOLHAPUR-CHIKKODI-II	-	-	-	-	-	-	0
2	220KV-PONDA-AMBEWADI	2	2	2	-	0.04	0	0.04
3	220KV-TALANGADE(MS)-CHIKKODI-II	-	-	-	-	-	-	0
4	220KV-XELDEM-AMBEWADI	89	74	-	95	1.79	0	1.79
5	400KV-KOLHAPUR GIS-NARENDRA KUDGI	1,419	1,245	2,000	-	32.96	0	32.96
6	765KV-SOLAPUR-RAICHUR	565	349	1,877	-769	13.22	-1.52	11.7
7	765KV-WARDHA-NIZAMABAD	-686	-741	325	-1,921	0.11	-21.02	-20.91
8	765KV-WARORA-PG-WARANGAL	-865	-1,077	130	-2,074	0.02	-24.95	-24.93
9	HVDC205KV-BHADRAWATI-RAMAGUNDAM	901	503	963	-	24	0	24
10	HVDC400KV-BARSUR-L.SILERU	-	-	-	-	-	-	0
11	HVDC800KV-RAIGARH-GIS-HVDC-PUGALUR	-611	-603	-	-621	0	-14.61	-14.61
Sub-Total SOUTH REGION		814	-248	5,297	-5,290	72.14	-62.1	10.04
TOTAL IR EXCHANGE		-14,830	-13,347	11,244	-30,633	102.37	-458.67	-356.3

4(B) Inter Regional Schedule & Actual Exchange (Import=(+ve) /Export =(-ve)) in MU

	ISGS+GNA+URS Schedule	TGNA BILT Schedule	GDAM Schedule	DAM Schedule	HPDAM Schedule	RTM Schedule	Total IR Schedule	Total IR Actual	NET IR UI
WR-ER	29.28	-28.29	0	-2.35	0	0	-33.45	-46.09	-12.64
WR-NR	-220.75	-80.35	0	13.91	0	0	-295.73	-320.25	-24.52
WR-SR	-54.54	-0.29	0	-15.36	0	0	-53.09	10.04	63.13
Total	-246.01	-108.93	0	-3.8	0	0	-382.27	-356.3	25.97

5.Frequency Profile

RANGE(Hz)	< 48.8	< 49	< 49.2	< 49.5	< 49.7	< 49.9	>= 49.9 - <= 50.05	> 50.05
%	.00	.00	.00	.00	.20	4.60	72.60	22.90

Percentage of Time Frequency Remained outside IEGC Band	27.4
No. of hours frequency outside IEGC Band	6.576

अधिकतम /Maximum		न्यूनतम/Minimum		औसत/Average	Freq Variation	Standard	Freq. in 15 mnt blk	
Frequency	Time	Frequency	Time	Frequency	Index	Deviation	Max.	Min.
50.18	08:00:00	49.67	12:40:30	50.01	0.04	0.062	50.14	49.76

6.वोल्टेज प्रोफाइल/Voltage Profile: 400kV

	अधिकतम/Maximum		न्यूनतम/Minimum		वभिवांतर/Voltage (in %)			Hours Volatge Outside IEGC Range(VDI)
STATION	VOLTAGE	TIME	VOLTAGE	TIME	>= 4000	IEGC Band (A)	> 420	(100-A)*24/100
AMRELI - 400KV	430.51	18:19	0	10:21	0	33.5	66.3	16
ASOJ - 400KV	413.24	03:59	392.14	14:57	0	100	0	0
BHILAI - 400KV	410.98	08:28	403.43	15:39	0	100	0	0
BHOPAL - 400KV	416.67	08:01	407.32	23:22	0	100	0	0
BOISAR - 400KV	418.76	03:37	398.79	15:11	0	100	0	0
DEHGAM - 400KV	417.43	04:08	395.76	14:37	0	100	0	0
DHULE - 400KV	411.11	22:01	397.41	15:55	0	100	0	0
DAMOH - 400KV	413.19	08:01	400.65	23:23	0	100	0	0
GPEC - 400KV	415.9	04:45	391.49	14:40	0	100	0	0
GWALIOR - 400KV	409.64	08:01	389.82	23:19	0	100	0	0
HAZIRA - 400KV	400.9	00:00	400.9	00:00	0	100	0	0
INDORE - 400KV	411.61	18:04	402.69	11:51	0	100	0	0
ITARSI - 400KV	407.06	13:03	399.11	23:24	0	100	0	0
JETPUR - 400KV	423.73	03:58	398.64	11:52	0	78.3	21.7	5.2
KALA - 400KV	412.2	20:06	0	11:46	0	99.9	0	0
KALWA - 400KV	416.49	03:56	391.04	15:04	0	100	0	0
KARAD - 400KV	423.35	02:39	407.19	10:24	0	86.3	13.8	3.3
KASOR - 400KV	415.78	04:45	396.03	14:36	0	100	0	0
KHANDWA - 400KV	410.45	19:16	402.92	15:57	0	100	0	0
MAGARWADA - 400KV	413.19	03:59	390.83	11:39	0	100	0	0
MAPUSA - 400KV	414.27	18:58	404.23	00:00	0	100	0	0
NAGDA - 400KV	413.65	18:03	403.31	11:52	0	100	0	0
NEW KOYNA - 400KV	431.56	02:40	416.68	15:04	0	15.9	84.1	20.2
PARLI - 400KV	418.46	19:07	389.74	00:50	0	100	0	0
RAIPUR - 400KV	410.49	08:28	403.47	15:36	0	100	0	0
RAIGARH - 400KV	418.12	09:11	412.89	12:42	0	100	0	0

VAPI - 400KV	411.68	03:58	389.5	15:11	0	100	0	0
WARDHA - 400KV	419.75	13:12	0	11:40	0	88.8	0	2.7

6.1 Voltage Profile: 765kV

	/Maximum		/Minimum		/Voltage (in %)			Hours Voltage Outside IEGC Range(VDI)
STATION	VOLTAGE	TIME	VOLTAGE	TIME	< 728	IEGC Band (A)	> 800	(100-A)*24/100
BINA - 765KV	787.33	08:01	761.42	23:24	0	100	0	0
DURG - 765KV	779.29	18:58	778.04	00:00	0	100	0	0
GWALIOR - 765KV	793.27	08:02	758.35	21:33	0	100	0	0
INDORE - 765KV	775.1	08:01	755.49	11:17	0	100	0	0
KOTRA - 765KV	786.41	09:57	771.66	21:55	0	100	0	0
SASAN - 765KV	785.92	08:00	770.31	00:02	0	100	0	0
SATNA - 765KV	794.23	13:05	769.24	00:02	0	100	0	0
SEONI - 765KV	792	13:02	768	06:14	0	100	0	0
SIPAT - 765KV	776.92	10:51	763.52	05:57	0	100	0	0
TAMNAR - 765KV	786.78	09:28	775.72	00:04	0	100	0	0
VADODARA - 765KV	791.69	19:04	749.2	11:51	0	100	0	0
WARDHA - 765KV	790.8	13:04	765.56	06:21	0	100	0	0

7(A).Power Energy/Schedule Details

State	Off- Peak Hours (03:00)												
	T-GNA Bilateral (MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX HPDAM (MW)	IEX RTM (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXIL HPDAM (MW)	PXI RTM (MW)	HPX GDAM (MW)	HPX DAM (MW)	HPX HPDAM (MW)	HPX RTM (MW)
AMNSIL	0	0	139.88	0	169.79	0	0	0	0	0	0	0	0
BALCO	0	0	0	0	11.96	0	0	0	0	0	0	0	0
CHHATTISG ..	-158.61	0	-32.3	0	-102.03	0	0	0	0	0	0	0	0
DNHDDPDCL	13.22	0	28.94	0	33.76	0	0	0	0	0	0	0	0
GOA	90.12	0	-20	0	-20	0	0	0	0	0	0	0	0
GUJARAT	303.94	8.68	490.05	0	273.21	0	0	0	0	0	0	0	0
MADHYA PRADESH	-617.02	-1.3	-310.22	0	0.18	0	0	0	0	0	0	0	0
MAHARASHT..	369.44	-39.06	-42.63	0	746.16	0	0	0	0	0	0	0	0
RIL JAMNAGAR	0	0	0	0	16.79	0	0	0	0	0	0	0	0
TOTAL	1.09	-31.68	253.72	0	1,129.82	0	0	0	0	0	0	0	0

State	Peak Hours (20:00)												
	T-GNA Bilateral (MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX HPDAM (MW)	IEX RTM (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXIL HPDAM (MW)	PXI RTM (MW)	HPX GDAM (MW)	HPX DAM(MW)	HPX HPDAM (MW)	HPX RTM (MW)
AMNSIL	0	14.47	0	0	105.15	0	0	0	0	0	0	0	0
BALCO	0	0	0	0	0	0	0	0	0	0	0	0	0
CHHATTISG ..	-518.05	0	-17.3	0	281.71	0	0	0	0	0	0	0	0
DNHDDPDCL	115.2	0	28.94	0	9.65	0	0	0	0	0	0	0	0
GOA	90.12	0	0	0	-110	0	0	0	0	0	0	0	0
GUJARAT	305.47	108.5	79.72	0	90.51	0	0	0	0	0	0	0	0
MADHYA PRADESH	-1.59	17.45	9.39	0	49.08	0	0	0	0	0	0	0	0
MAHARASHT..	188.68	90.08	61.21	0	482.82	0	0	0	0	0	0	0	0
RIL JAMNAGAR	0	0	0	0	0	0	0	0	0	0	0	0	0
TOTAL	179.83	230.5	161.96	0	908.92	0	0	0	0	0	0	0	0

State	Day Energy (MU)						
	ISGS + GNA Schedule	T-GNA Bilateral (MW)	GDAM Schedule	DAM Schedule	HPDAM Schedule	RTM Schedule	Total (MU)
AMNSIL	6.95	0	0.31	1.3	0	2.03	10.59
BALCO	16.93	0.03	0	0	0	0.17	17.14
CHHATTISGARH	87.57	-6.93	0.01	-3.61	0	-0.33	76.72
DNHDDPDCL	26.9	0.93	0	0.69	0	2.84	31.37
GOA	15.26	2.27	0	-0.77	0	-1.07	15.69
GUJARAT	155.3	9.05	2.09	11.3	0	7.26	185
MADHYA PRADESH	163.9	-4.05	-0.42	3.58	0	0.47	163.49
MAHARASHTRA	189.85	4.13	0.92	9.14	0	19.47	223.51
RIL JAMNAGAR	6.22	0	0.12	0.03	0	0.07	6.44
TOTAL	668.88	5.43	3.03	21.66	0	30.91	729.95

7(B).Power Energy/Schedule Details

State	ISGS + GNA Schedule		T-GNA Bilateral (MW)		IEX GDAM (MW)		PXIL GDAM(MW)		HPX GDAM(MW)		IEX DAM (MW)		PXIL DAM(MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
AMNSIL	439.04	105.05	0	0	29.91	0	0	0	0	0	159.19	0	0	0
BALCO	764.37	660.6	24.35	0	0	0	0	0	0	0	0	0	0	0
CHHATTISGARH	4,578.48	2,950.29	-89.17	-518.05	36.16	-3.2	0	0	0	0	-10.8	-1,000.3	0	0
DNHDDPDCL	1,178.19	972.04	122.71	12.25	0	0	0	0	0	0	28.94	28.94	0	0
GOA	762.75	529.88	121.66	76.61	0	0	0	0	0	0	0	-119	0	0
GUJARAT	7,707.73	4,001.8	718.81	-305.53	271.76	0	0	0	0	0	930.06	-21.99	0	0
MADHYA PRADESH	7,412.67	5,702.51	7.9	-617.02	77.87	-112.7	0	0	0	0	1,421.93	-779.29	0	0
MAHARASHTRA	9,095.12	7,045.38	408.64	-20.29	189.49	-39.36	0	0	0	0	994.23	-77.71	0	0
RIL JAMNAGAR	-	-	-	-	-	-	-	-	-	-	-	-	-	-

State	HPX DAM(MW)		IEX HPDAM (MW)		PXIL HPDAM(MW)		HPX HPDAM(MW)		IEX RTM (MW)		PXIL RTM(MW)		HPX RTM(MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
AMNSIL	0	0	0	0	0	0	0	0	220.92	0	0	0	0	0
BALCO	0	0	0	0	0	0	0	0	54.41	0	0	0	0	0
CHHATTISGARH	0	0	0	0	0	0	0	0	613.78	-339.4	0	0	0	0
DNHDDPDCL	0	0	0	0	0	0	0	0	308.7	6.06	0	0	0	0
GOA	0	0	0	0	0	0	0	0	11.22	-140	0	0	0	0
GUJARAT	0	0	0	0	0	0	0	0	1,788	-963.68	0	0	0	0
MADHYA PRADESH	0	0	0	0	0	0	0	0	302.14	-550.51	0	0	0	0
MAHARASHTRA	0	0	0	0	0	0	0	0	1,931.02	-32.87	175.26	-23.98	0	0
RIL JAMNAGAR	-	-	-	-	-	-	-	-	-	-	-	-	-	-

8.Major Reservoir Particulars

RESERVOIR	DESIGNED			PRESENT		LAST YEAR		LAST DAY	MONTH	
	MDDL(Mts)	FRL(Mts)	Energy(MU)	Level(Mts)	Energy(MU)	Level(Mts)	Energy(MU)	Inflow(Mus)	"Prog.Inflow (Mus)"	"Prog.Usage (Mus)"
INDIRASAGAR	243.23	262.13	1,367	249.69	289.78	251.84	378.61	249.75	0	0
OMKARESHWAR	193.3	196.6	21.958	194.44	-	195.91	-	194.58	0	0
UKAI	82.296	105.156	770.67	95.63	267.58	96.464	301.249	95.63	0	0
KADANA	114.3	127.711	126.266	120.85	34.93	117.599	12.91	120.9	0	0
SSP	110.64	138.68	1,342.091	127.83	591.89	121.09	287.41	127.95	0	0
KOYNA	615.54	659.43	3,160	622.45	484.065	628.1	815.542	0	0	0
TATA BHIRA	590.1	607.1	582.4	593.96	102.61	594.49	118.48	594.02	0	0

9.Significant events (If any):

10.System Constraints (If any)

11. Weather Condition:

12. RE/Load Curtailment details

State	Load Curtailment			RE Curtailment				
	Energy	Maximum	At the time of maximum demand	Wind		Solar		Reason
	MU	MW	MW	Max MW	Energy(MU)	Max MW	Energy(MU)	
AMNSIL	0	0	0	0	0	0	0	
BALCO	0	0	0	0	0	0	0	
CHHATTISGARH	0	0	0	0	0	0	0	
DAMAN AND DIU	0	0	0	0	0	0	0	
GOA	0	0	0	0	0	0	0	
GUJARAT	0	0	0	0	0	0	0	
MADHYA PRADESH	0	0	0	0	0	0	0	
MAHARASHTRA	0	0	0	0	0	0	0	
RIL JAMNAGAR	0	0	0	0	0	0	0	

Shift In Charge