ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
GRID CONTROLLER OF INDIA LIMITED
क्षेत्रीय लोड प्रेषण केन्द्र
SOUTHERN REGIONAL LOAD DESPATCH CENTER

**Date of Reporting: 07-Jun-2026**

# Power Supply Position Report For

**06-Jun-2026**

## 1. Regional Availability/Demand:

| Evening Peak (20:00) MW | | | | Off-Peak (03:00) MW | | | | Day Energy (Net MU) | |
|---|---|---|---|---|---|---|---|---|---|
| Demand Met | Shortage | Requirement | Freq (Hz) | Demand Met | Shortage | Requirement | Freq (Hz) | Demand Met | Shortage # |
| 53798 | 0 | 53798 | 50.04 | 48046 | 0 | 48046 | 50 | 1275.18 | 0 |

## 2(A) State's Load Deails (At State Periphery) in MUs:

| State | State's Control Area Generation (Net MU) | | | | | | Net SCH | Drawal | UI | Availability | Demand Met | Shortage # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | THERMAL | HYDRO | GAS/DIESEL /NAPTHA | WIND | SOLAR | OTHERS | (Net Mu) | (Net Mu) | (Net Mu) | (Net Mu) | (Net Mu) | (Net Mu) |
| Andhra Pradesh | 133.72 | 4.24 | 0 | 26.68 | 20 | 2.12 | 82.17 | 81.21 | -0.96 | 268.93 | 267.97 | 0 |
| Karnataka | 84 | 17.13 | 0 | 23.88 | 29.76 | 7.07 | 105.09 | 103.22 | -1.87 | 266.93 | 265.06 | 0 |
| Kerala | 0 | 11.4 | 0 | 0.58 | 0.84 | 0.28 | 73.2 | 72.44 | -0.76 | 86.3 | 85.54 | 0 |
| Puducherry | 0 | 0 | 0.36 | 0 | 0.06 | 0 | 11.43 | 11.19 | -0.24 | 11.85 | 11.61 | 0 |
| Tamil Nadu | 73.22 | 7.62 | 3.25 | 67.38 | 54.6 | 4.13 | 205.67 | 204.73 | -0.94 | 415.87 | 414.93 | 0 |
| Telangana | 102.67 | 1.91 | 0 | 0.73 | 23.57 | 2.97 | 99.25 | 98.22 | -1.03 | 231.1 | 230.07 | 0 |
| Total | 393.61 | 42.3 | 3.61 | 119.25 | 128.83 | 16.57 | 576.81 | 571.01 | -5.8 | 1280.98 | 1275.18 | 0 |

## 2(B) State's Demand Met in MWs and day energy forecast and deviation particulars

| State | Evening Peak (20:00) MW | | | Off-Peak (03:00) MW | | | Average Demand | Day Energy (Net MU) | |
|---|---|---|---|---|---|---|---|---|---|
| | Demand Met | Shortage | Requirement | Demand Met | Shortage | Requirement | (MW) | Forecast (LGBR) | Deviation [Forecast - Consumption] |
| Andhra Pradesh | 10533 | 0 | 10533 | 10408 | 0 | 10408 | 11166 | 259 | 8.97 |
| Karnataka | 10389 | 0 | 10389 | 8906 | 0 | 8906 | 10989 | 279.47 | -14.41 |
| Kerala | 4269 | 0 | 4269 | 3010 | 0 | 3010 | 3635 | 86.19 | -0.65 |
| Puducherry | 501 | 0 | 501 | 462 | 0 | 462 | 473 | 11 | 0.61 |
| Tamil Nadu | 19140 | 0 | 19140 | 16788 | 0 | 16788 | 17973 | 418 | -3.07 |
| Telangana | 8966 | 0 | 8966 | 8472 | 0 | 8472 | 9796 | 228 | 2.07 |
| Total | 53798 | 0 | 53798 | 48046 | 0 | 48046 | 54032 | 1281.66 | -6.48 |

## 2(C) State's Demand Met in MWs ( maximum demand met and Maximum requirement of the day details)

| State | Maximum Demand, corresponding shortage and requirement details for the day | | | | Maximum requirement, corresponding shortage and demand details for the day | | | | ACE | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Maximum Demand Met | Time | Shortage at maximum demand | Requirement at the max demand met | Demand Met at maximum requiremnet | Time | Shortage at maximum Requirement | Maximum Requirement | Maximum ACE(MW) | Time | Minimum ACE(MW) | Time |
| Andhra Pradesh | 13935 | 14:48 | 0 | 13935 | 13935 | 14:48 | 0 | 13935 | 946.65 | 15:07 | -418.81 | 11:30 |
| Karnataka | 13478 | 10:00 | 0 | 13478 | 13478 | 10:00 | 0 | 13478 | 1098.65 | 04:02 | -818.5 | 12:29 |
| Kerala | 4428 | 19:19 | 0 | 4428 | 4428 | 19:19 | 0 | 4428 | 714.29 | 02:02 | -467.05 | 21:17 |
| Puducherry | 552 | 22:45 | 0 | 552 | 552 | 22:45 | 0 | 552 | 52.11 | 08:35 | -41.22 | 16:31 |
| Tamil Nadu | 21233 | 23:00 | 0 | 21233 | 21233 | 23:00 | 0 | 21233 | 1271.35 | 14:31 | -1604.35 | 00:12 |
| Telangana | 11710 | 15:05 | 0 | 11710 | 11710 | 15:05 | 0 | 11710 | 826.5 | 17:22 | -676.74 | 18:40 |
| Region | 60305 | 14:57 | 0 | 60305 | 60305 | 14:57 | 0 | 60305 | 3998.87 | 15:21 | -2428.93 | 20:23 |

## 3(A) State Entities Generation:

**ANDHRA PRADESH**

| Station/Constituents | Inst. Capacity | 19:00 | 03:00 | Day Peak | | Min Generation (06:00 to 18:00) | | Day Energy | | Avg |
|---|---|---|---|---|---|---|---|---|---|---|
| | (MW) | Peak MW | Off Peak MW | (MW) | Hrs | (MW) | Hrs | Gross (MU) | Net (MU) | (MW) |
| HINDUJA POWER CORPORATION LTD ( 2*520 ) | 1040 | 1012 | 1026 | 1032 | 00:32 | 555 | 09:27 | 22.41 | 21.21 | 884 |
| KRISHNAPATTANAM ( 3*800 ) | 2400 | 1543 | 1541 | 1991 | 22:14 | 1330 | 16:32 | 39.58 | 37.47 | 1561 |
| RAYALASEEMA TPP ( 5*210 + 600 ) | 1650 | 626 | 640 | 944 | 21:03 | 598 | 12:59 | 17.36 | 15.19 | 633 |
| SEIL P2 Unit-2 ( 1*660 ) | 660 | 626 | 625 | 635 | 12:46 | 335 | 10:37 | 15.15 | 14.37 | 599 |
| VIJAYAWADA TPS ( 6*210 + 500 + 800 ) | 2560 | 2166 | 2195 | 2236 | 06:25 | 1414 | 11:34 | 49.31 | 45.49 | 1895 |
| Total Thermal | 8310 | 5973 | 6027 | - | - | - | - | 143.81 | 133.73 | 5572 |

| | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| DONKARAYI ( 1*25 ) | 25 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| HAMPI & T.B.DAM (8 * 9) | 57 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| LOWER SILERU ( 4*115 ) | 460 | 13 | 211 | 314 | 11:28 | 13 | 07:19 | 3.07 | 3.06 | 128 |
| MACHKUND (3 * 17 + 3 * 23) | 84 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| NAGARJUNASAGAR TAILPOND ( 2*25 ) | 50 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| NSR RT.CANAL.P.H ( 3*30 ) | 90 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| SRISAILAM RBPH ( 7*110 ) | 770 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| UPPER SILERU ( 4*60 ) | 240 | 0 | 0 | 160 | 05:50 | 0 | 09:13 | 1.19 | 1.18 | 49 |
| OTHER HYDEL | 124 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| Total Hydro | 1900 | 13 | 211 | - | - | - | - | 4.26 | 4.24 | 177 |
| GAUTAMI CCPP ( 2*145 + 174 ) | 464 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| GMR (BARG) (1 * 237) | 237 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| JEGURUPADU (GAS) ( 2*45.8 + 49.9 + 75.5 ) | 217 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| Jegrupadu Ext. (1 * 220) | 220 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| KONASEEMA CCPP ( 145 + 140 + 165 ) | 450 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| LANCO (GAS) ( 2*115 + 121 ) | 351 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| RELIANCE ENERGY LTD. (GAS) ( 140 + 80 ) | 220 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| SPECTRUM (GAS) ( 46.8 + 2*46.1 + 68.8 ) | 208 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| VEMAGIRI POWER GENERATION LTD.(GAS) ( 233 + 137 ) | 370 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| VIJJESWARAM GTS ( 2*33 + 34 + 112.5 + 59.5 ) | 272 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| OTHER GAS/NAPTHA/DIESEL | 27 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| Total Gas | 3036 | 0 | 0 | - | - | - | - | 0 | 0 | 0 |
| WIND | 4102 | 1711 | 1778 | 2205 | 22:13 | 276 | 17:20 | 26.68 | 26.68 | 1112 |
| SOLAR | 3965 | 2 | 1 | 2537 | 12:19 | 17 | 06:00 | 20 | 20 | 833 |
| OTHERS | 619 | 124 | 117 | 155 | 11:31 | 112 | 15:16 | 2.12 | 2.12 | 88 |
| Total ANDHRA PRADESH | 21932 | 7823 | 8134 | - | - | - | - | 196.87 | 186.77 | 7782 |

TELANGANA

| Station/Constituents | Inst. Capacity | 19:00 | 03:00 | Day Peak | | Min Generation (06:00 to 18:00) | | Day Energy | | Avg |
|---|---|---|---|---|---|---|---|---|---|---|
| | (MW) | Peak MW | Off Peak MW | (MW) | Hrs | (MW) | Hrs | Gross (MU) | Net (MU) | (MW) |
| BHADRADRI TPS ( 4*270 ) | 1080 | 844 | 810 | 868 | 21:34 | 514 | 13:21 | 19.16 | 17.28 | 720 |
| KAKATIYA ST1&ST2 ( 500 + 600 ) | 1100 | 1026 | 1034 | 1055 | 07:32 | 538 | 11:17 | 22.64 | 21.36 | 890 |
| KOTHAGUDEM TPS ( 2*250 + 500 + 800 ) | 1800 | 1333 | 1419 | 1652 | 06:05 | 908 | 09:01 | 30.76 | 28.57 | 1190 |
| RAMAGUNDAM-B ( 1*62.5 ) | 63 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| SINGARENI TPS ( 2*600 ) | 1200 | 1029 | 1067 | 1116 | 04:26 | 574 | 13:21 | 23.43 | 22.02 | 918 |
| YADADRI ( 4*800 ) | 3200 | 643 | 533 | 675 | 23:02 | 528 | 16:43 | 15.71 | 13.44 | 560 |
| Total Thermal | 8443 | 4875 | 4863 | - | - | - | - | 111.7 | 102.67 | 4278 |
| L JURALA ( 6*40 ) | 240 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| NAGARJUNA SAGAR ( 110 + 7*100.8 ) | 816 | 0 | 0 | 614 | 00:45 | 0 | 06:00 | 1.93 | 1.91 | 80 |
| NAGARJUNA SAGAR (Pump) ( 110 + 7*100.8 ) | 816 | 0 | 0 | 434 | 06:49 | 107 | 17:34 | 3.35 | 3.35 | 140 |
| NIZAMSAGAR ( 2*5 ) | 10 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| NSR LT.CANAL.P.H ( 2*30 ) | 60 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| POCHAMPAD ( 4*9 ) | 36 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| PULICHINTALA ( 4*30 ) | 120 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| SINGUR ( 2*7.5 ) | 15 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| SRISAILAM LBPH ( 6*150 ) | 900 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| SRISAILAM LBPH(Pump) ( 6*150 ) | 900 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| U JURALA ( 6*39 ) | 234 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| OTHER HYDEL | 51 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| Total Hydro | 2482 | 0 | 0 | - | - | - | - | 1.93 | 1.91 | 80 |
| WIND | 128 | 2 | 88 | 103 | 23:58 | 1 | 16:15 | 0.73 | 0.73 | 30 |
| SOLAR | 3848 | 0 | 0 | 2665 | 12:15 | 27 | 06:00 | 23.57 | 23.57 | 982 |
| OTHERS | 252 | 124 | 124 | 124 | 00:00 | 124 | 06:00 | 2.97 | 2.97 | 124 |
| Total TELANGANA | 15153 | 5001 | 5075 | - | - | - | - | 140.9 | 131.85 | 5494 |

KARNATAKA

| Station/Constituents | Inst. Capacity | 19:00 | 03:00 | Day Peak | Min Generation (06:00 to 18:00) | Day Energy | Avg |
|---|---|---|---|---|---|---|---|

| | (MW) | Peak MW | Off Peak MW | (MW) | Hrs | (MW) | Hrs | Gross (MU) | Net (MU) | (MW) |
|---|---|---|---|---|---|---|---|---|---|---|
| Bellary TPS ( 2*500 + 700 ) | 1700 | 1444 | 1423 | 1486 | 18:40 | 1166 | 16:47 | 34.48 | 32.44 | 1352 |
| JINDAL ( 2*130 + 4*300 ) | 1460 | 817 | 867 | 1208 | 23:45 | 751 | 09:50 | 24.25 | 22.31 | 930 |
| Jindal (Excl. Captive Consumption) (2 * 130 + 4 * 300) | 1460 | 80 | 120 | 299 | 19:29 | 0 | 07:11 | 1.96 | 1.96 | 82 |
| Raichur TPS ( 7*210 + 250 ) | 1720 | 972 | 1042 | 1060 | 07:31 | 858 | 12:32 | 26.11 | 23.4 | 975 |
| UPCL ( 2*600 ) | 1200 | 1111 | 1109 | 1128 | 01:50 | 573 | 16:15 | 23.07 | 21.69 | 904 |
| YERAMARAS TPS ( 2*800 ) | 1600 | 581 | 0 | 668 | 22:57 | 0 | 06:00 | 5.36 | 4.5 | 188 |
| Total Thermal | 7680 | 4188 | 3694 | - | - | - | - | 90.98 | 83.99 | 3501 |
| Almatty ( 15 + 5*55 ) | 290 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| Bhadra ( 2*12.1 + 7 + 2 + 6 ) | 39 | 0 | 0 | 0 | 19:06 | 0 | 08:34 | 0 | 0 | 0 |
| Ghataprabha ( 2*16 ) | 32 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| JOG (MGHES) ( 4*21.6 + 4*13.2 ) | 139 | 60 | 48 | 60 | 21:38 | 37 | 09:20 | 1.2 | 1.19 | 50 |
| LINGANAMAKKI.P.H. ( 2*27.5 ) | 55 | 8 | 8 | 9 | 15:08 | 8 | 11:38 | 0.2 | 0.18 | 8 |
| Kadra ( 3*50 ) | 150 | 99 | 0 | 146 | 19:04 | 0 | 06:00 | 0.65 | 0.64 | 27 |
| Kodasalli ( 3*40 ) | 120 | 73 | 25 | 110 | 18:44 | 0 | 06:00 | 0.48 | 0.47 | 20 |
| MANI DAM.P.H. ( 2*4.5 ) | 9 | 1 | 1 | 1 | 06:57 | 1 | 11:51 | 0.04 | 0.04 | 2 |
| Munirabad ( 3*9 + 10 ) | 37 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| NAGJHERI ( 135 + 5*150 ) | 885 | 298 | 0 | 422 | 00:01 | 91 | 15:05 | 3.89 | 3.83 | 160 |
| SHARAVATHI ( 10*103.5 ) | 1035 | 258 | 295 | 762 | 06:29 | 254 | 16:17 | 8.26 | 8.16 | 340 |
| Sharavati Tail Race ( 4*60 ) | 240 | 53 | 0 | 157 | 19:11 | 0 | 07:33 | 0.31 | 0.3 | 13 |
| SIVANSAMUDRAM ( 6*3 + 4*6 ) | 42 | 1 | 1 | 1 | 00:00 | 1 | 06:00 | 0.13 | 0.13 | 5 |
| Supa ( 2*50 ) | 100 | 30 | 30 | 30 | 00:00 | 29 | 06:57 | 0.73 | 0.72 | 30 |
| U JURALA ( 6*39 ) | 234 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| Varahi UGPH ( 4*115 ) | 460 | 57 | 57 | 258 | 06:33 | 45 | 14:49 | 1.53 | 1.5 | 63 |
| OTHER HYDEL | 143 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| Total Hydro | 4010 | 938 | 465 | - | - | - | - | 17.42 | 17.16 | 718 |
| OTHER GAS/NAPTHA/DIESEL | 126 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| Total Gas | 126 | 0 | 0 | - | - | - | - | 0 | 0 | 0 |
| WIND | 5676 | 1635 | 1151 | 1719 | 20:08 | 466 | 08:16 | 23.88 | 23.88 | 995 |
| SOLAR | 7171 | 10 | 0 | 3936 | 11:23 | 97 | 06:00 | 29.76 | 29.76 | 1240 |
| OTHERS | 1832 | 92 | 97 | 116 | 00:16 | 84 | 13:39 | 7.07 | 7.07 | 295 |
| Total KARNATAKA | 26495 | 6863 | 5407 | - | - | - | - | 169.11 | 161.86 | 6749 |

KERALA

| Station/Constituents | Inst. Capacity | 19:00 | 03:00 | Day Peak | | Min Generation (06:00 to 18:00) | | Day Energy | | Avg |
|---|---|---|---|---|---|---|---|---|---|---|
| | (MW) | Peak MW | Off Peak MW | (MW) | Hrs | (MW) | Hrs | Gross (MU) | Net (MU) | (MW) |
| Idamalayar ( 2*37.5 ) | 75 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| Iddukki ( 6*130 ) | 780 | 99 | 169 | 629 | 21:37 | 28 | 08:50 | 4.09 | 4.06 | 169 |
| Kakkad ( 2*25 ) | 50 | 18 | 35 | 35 | 00:35 | 0 | 07:09 | 0.38 | 0.37 | 15 |
| KALLADA ( 2*7.5 ) | 15 | 8 | 7 | 8 | 18:58 | 5 | 17:11 | 0.11 | 0.1 | 4 |
| Kuttiyadi ( 3*25 ) | 75 | 83 | 0 | 149 | 21:39 | 0 | 06:00 | 0.5 | 0.49 | 20 |
| Lower Periyar ( 3*60 ) | 180 | 0 | 45 | 138 | 00:03 | 0 | 06:00 | 0.57 | 0.57 | 24 |
| Neriamangalam ( 3*17.5 + 25 ) | 78 | 54 | 0 | 71 | 20:45 | 0 | 06:00 | 0.52 | 0.52 | 22 |
| PALLIVASAL ( 3*5 + 3*7.5 ) | 38 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| PALLIVASAL EXTENSION SCHEME ( 2*30 ) | 60 | 44 | 18 | 60 | 05:45 | 16 | 14:47 | 1.11 | 1.11 | 46 |
| Panniar ( 2*16.2 ) | 32 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0.28 | 0.28 | 12 |
| PORINGALKUTHU ( 4*9 ) | 36 | 0 | 0 | 16 | 21:25 | 0 | 06:00 | 0.05 | 0.05 | 2 |
| Sengulam ( 4*12.8 ) | 51 | 31 | 13 | 50 | 21:44 | 6 | 14:37 | 0.49 | 0.49 | 20 |
| Sholayar ( 3*18 ) | 54 | 0 | 0 | 53 | 22:57 | 0 | 06:00 | 0.15 | 0.15 | 6 |
| Sabarigiri ( 4*55 + 2*60 ) | 340 | 110 | 86 | 184 | 00:21 | 0 | 09:00 | 1.33 | 1.33 | 55 |
| THOTTIYAR HEP ( 2*20 ) | 40 | 38 | 4 | 39 | 18:44 | 0 | 06:00 | 0.5 | 0.5 | 21 |
| OTHER HYDEL | 230 | 0 | 84 | 100 | 00:02 | 0 | 06:00 | 1.38 | 1.38 | 58 |
| Total Hydro | 2134 | 485 | 461 | - | - | - | - | 11.46 | 11.4 | 474 |
| BRAHMAPURAM DGPP (DIESEL) ( 3*21.32 ) | 64 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| BSES (NAPTHA) ( 3*40.5 + 35.5 ) | 157 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| KOZHIKODE DPP (DIESEL) ( 6*16 ) | 96 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| MPS STEEL CASTINGS (1 * 10) | 10 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |

| | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| RGCCPP KAYAMKULAM (KSEB) - NTPC ( 2*116.6 + 126.38 ) | 360 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| OTHER GAS/NAPTHA/DIESEL | 22 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| Total Gas | 709 | 0 | 0 | - | - | - | - | 0 | 0 | 0 |
| WIND | 70 | 7 | 1 | 22 | 18:07 | 4 | 12:55 | 0.58 | 0.58 | 24 |
| SOLAR | 1988 | 0 | 1 | 157 | 11:30 | 1 | 06:00 | 0.84 | 0.84 | 35 |
| OTHERS | 20 | 8 | 2 | 165 | 11:30 | 10 | 06:01 | 0.28 | 0.28 | 12 |
| Total KERALA | 4921 | 500 | 465 | - | - | - | - | 13.16 | 13.1 | 545 |

TAMIL NADU

| Station/Constituents | Inst. Capacity | 19:00 | 03:00 | Day Peak | | Min Generation (06:00 to 18:00) | | Day Energy | | Avg |
|---|---|---|---|---|---|---|---|---|---|---|
| | (MW) | Peak MW | Off Peak MW | (MW) | Hrs | (MW) | Hrs | Gross (MU) | Net (MU) | (MW) |
| Mettur TPS ( 4*210 + 600 ) | 1440 | 619 | 1077 | 1084 | 03:19 | 604 | 16:31 | 24.72 | 22.7 | 946 |
| NORTH CHENNAI TPS STG-III ( 1*800 ) | 800 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| NORTH CHENNAI TPS STG-II ( 2*600 ) | 1200 | 611 | 610 | 720 | 22:00 | 599 | 17:35 | 17.29 | 15.87 | 661 |
| North Chennai TPS ( 3*210 ) | 630 | 408 | 487 | 500 | 04:55 | 386 | 16:41 | 11.82 | 10.64 | 443 |
| UDANGUDI(Infirm - 660MW) | 0 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| OPG PGPL ( 2*77 + 80 + 180 ) | 414 | 273 | 294 | 301 | 22:03 | 263 | 07:32 | 7.45 | 6.8 | 283 |
| SEPC ( 1*525 ) | 525 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| ST - CMS ( 1*250 ) | 250 | 215 | 213 | 223 | 05:30 | 148 | 15:33 | 5.5 | 5.05 | 210 |
| Tuticorin ( 5*210 ) | 1050 | 569 | 578 | 584 | 06:47 | 433 | 10:55 | 13.42 | 12.16 | 507 |
| Total Thermal | 6309 | 2695 | 3259 | - | - | - | - | 80.2 | 73.22 | 3050 |
| Kadamparai ( 4*100 ) | 400 | 0 | 0 | 102 | 20:34 | 0 | 06:21 | 0.74 | 0.74 | 31 |
| Kadamparai (Pump) ( 4*100 ) | 400 | 1 | 1 | 110 | 17:05 | 0 | 06:00 | 0.7 | 0.7 | 29 |
| Kodayar I ( 1*60 ) | 60 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| Kodayar II ( 1*40 ) | 40 | 0 | 0 | 40 | 05:22 | 0 | 08:56 | 0.33 | 0.33 | 14 |
| Kundah I ( 3*20 ) | 60 | 22 | 51 | 53 | 10:43 | 1 | 15:05 | 0.57 | 0.57 | 24 |
| Kundah II ( 5*35 ) | 175 | 53 | 105 | 176 | 18:26 | 47 | 07:59 | 1.42 | 1.41 | 59 |
| Kundah III ( 3*60 ) | 180 | 34 | 65 | 141 | 00:55 | 6 | 11:15 | 0.86 | 0.86 | 36 |
| Kundah IV ( 2*50 ) | 100 | 0 | 0 | 90 | 00:01 | 0 | 06:00 | 0.1 | 0.1 | 4 |
| Kundah V ( 2*20 ) | 40 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0.47 | 0.46 | 19 |
| Kundah VI ( 1*30 ) | 30 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| Mettur Dam ( 4*12.5 ) | 50 | 0 | 0 | 0 | 14:13 | 0 | 06:16 | 0.21 | 0.21 | 9 |
| Mettur Tunnel ( 4*50 ) | 200 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| Moyar ( 3*12 ) | 36 | 28 | 28 | 28 | 03:31 | 0 | 09:27 | 0.43 | 0.43 | 18 |
| PAPANASAM ( 4*8 ) | 32 | 6 | 6 | 6 | 00:00 | 0 | 08:56 | 0.14 | 0.14 | 6 |
| Periyar ( 4*35 ) | 140 | 28 | 24 | 28 | 16:07 | 24 | 08:01 | 0.62 | 0.62 | 26 |
| Pykara ( 3*6.65 + 11 + 2*14 ) | 59 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| PYKARA ULTIMATE ( 3*50 ) | 150 | 71 | 60 | 151 | 03:54 | 0 | 10:10 | 1.16 | 1.15 | 48 |
| Sarkarpathy ( 1*30 ) | 30 | 12 | 12 | 13 | 10:41 | 12 | 06:06 | 0.3 | 0.3 | 13 |
| Servalar ( 1*20 ) | 20 | 0 | 0 | 14 | 06:02 | 0 | 06:00 | 0.03 | 0.03 | 1 |
| Sholayar I ( 2*42 ) | 84 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| Sholayar II ( 1*25 ) | 25 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| Suruliyar ( 1*35 ) | 35 | 0 | 0 | 21 | 00:06 | 0 | 06:00 | 0.06 | 0.06 | 3 |
| OTHER HYDEL | 1826 | 53 | 18 | 267 | 00:08 | 4 | 10:00 | 0.24 | 0.23 | 10 |
| Total Hydro | 3772 | 307 | 369 | - | - | - | - | 7.68 | 7.64 | 321 |
| BASIN BRIDGE (NAPTHA) ( 4*30 ) | 120 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| KOVIL KALAPPAL (GAS) ( 70 + 37.88 ) | 108 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| KUTTALAM (GAS) ( 64 + 37 ) | 101 | 75 | 84 | 85 | 08:29 | 70 | 16:01 | 1.82 | 1.69 | 70 |
| MADURAI POWER CL (DIESEL) (1 * 106) | 106 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| P P NALLUR (NAPTHA) (1 * 330.5) | 331 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| SAMALPATTY (DIESEL) (7 * 15.1) | 106 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| VALATTUR(STG1&STG2) ( 2*60 + 35 + 32 ) | 187 | 27 | 18 | 56 | 10:24 | 19 | 06:37 | 1.68 | 1.57 | 65 |
| OTHER GAS/NAPTHA/DIESEL | 362 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| Total Gas | 1421 | 102 | 102 | - | - | - | - | 3.5 | 3.26 | 135 |
| WIND | 9495 | 3019 | 1738 | 4241 | 12:22 | 1153 | 06:00 | 67.38 | 67.38 | 2808 |
| SOLAR | 12065 | 0 | 0 | 7244 | 11:19 | 56 | 06:00 | 54.6 | 54.6 | 2275 |
| OTHERS | 2029 | 587 | 586 | 784 | 08:56 | 550 | 09:33 | 4.13 | 4.13 | 172 |

| | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| Total TAMIL NADU | 35091 | 6710 | 6054 | - | - | - | - | 217.49 | 210.23 | 8761 |

PUDUCHERRY

| Station/Constituents | Inst. Capacity | 19:00 | 03:00 | Day Peak | | Min Generation (06:00 to 18:00) | | Day Energy | | Avg |
|---|---|---|---|---|---|---|---|---|---|---|
| | (MW) | Peak MW | Off Peak MW | (MW) | Hrs | (MW) | Hrs | Gross (MU) | Net (MU) | (MW) |
| KARAIKAL POWER PLANT (GAS) (1 * 22.9 + 1 * 9.6) | 33 | 15 | 15 | 15 | 00:00 | 15 | 06:00 | 0.38 | 0.36 | 15 |
| Total Gas | 33 | 15 | 15 | - | - | - | - | 0.38 | 0.36 | 15 |
| SOLAR | 20 | 0 | 0 | 10 | 11:44 | 0 | 06:00 | 0.06 | 0.06 | 3 |
| Total PUDUCHERRY | 53 | 15 | 15 | - | - | - | - | 0.44 | 0.42 | 18 |

### 3(B) Regional Entities Generation:

ISGS

| Station/Constituents | Inst. Capacity | 19:00 | 03:00 | Day Peak | | Min Generation (06:00 to 18:00) | | Day Energy | | Avg |
|---|---|---|---|---|---|---|---|---|---|---|
| | (MW) | Peak MW | Off Peak MW | (MW) | Hrs | (MW) | Hrs | Gross (MU) | Net (MU) | (MW) |
| KUDGI ( 3*800 ) | 2400 | 1293 | 2026 | 2308 | 05:31 | 1203 | 15:10 | 37.77 | 35.12 | 1463 |
| Neyveli TS I Expn ( 2*210 ) | 420 | 760 | 266 | 816 | 20:53 | 95 | 13:39 | 7.2 | 6.43 | 268 |
| Neyveli TS II ( 7*210 ) | 1470 | 576 | 577 | 615 | 23:55 | 447 | 12:45 | 14.93 | 11.98 | 499 |
| Neyveli TS II Expn ( 2*250 ) | 500 | 74 | 0 | 95 | 23:31 | 0 | 06:00 | 1.37 | 0.89 | 37 |
| NNTPS ( 2*500 ) | 1000 | 664 | 638 | 729 | 02:12 | 301 | 10:02 | 13.46 | 11.43 | 476 |
| NTPC-TELANGANA STPP ( 2*800 ) | 1600 | 1472 | 1492 | 1524 | 21:17 | 805 | 09:17 | 29.31 | 29.31 | 1221 |
| Ramagundam ( 3*200 + 4*500 ) | 2600 | 1489 | 1808 | 2404 | 23:50 | 1096 | 09:57 | 40.07 | 37.2 | 1550 |
| Simhadri Stage I ( 2*500 ) | 1000 | 919 | 909 | 934 | 04:33 | 489 | 16:26 | 19.05 | 17.68 | 737 |
| Simhadri Stage II ( 2*500 ) | 1000 | 947 | 933 | 974 | 19:51 | 502 | 13:21 | 19.7 | 18.35 | 765 |
| TALCHER ST2 ( 4*500 ) | 2000 | 1866 | 1848 | 1882 | 20:53 | 1003 | 10:02 | 42.04 | 39.54 | 1648 |
| Total Thermal | 13990 | 10060 | 10497 | - | - | - | - | 224.9 | 207.93 | 8664 |
| KAIGA STG1 ( 2*220 ) | 440 | 200 | 203 | 210 | 12:10 | 185 | 12:44 | 5 | 4.5 | 188 |
| KAIGA STG2 ( 2*220 ) | 440 | 447 | 448 | 450 | 06:01 | 435 | 09:56 | 11.33 | 10.36 | 432 |
| KUDANKULAM ( 2*1000 ) | 2000 | 1994 | 2003 | 2018 | 23:43 | 1974 | 16:01 | 49.11 | 45.85 | 1910 |
| MAPS ( 2*220 ) | 440 | 213 | 213 | 214 | 20:16 | 186 | 10:14 | 5.05 | 4.15 | 173 |
| Total Nuclear | 3320 | 2854 | 2867 | - | - | - | - | 70.49 | 64.86 | 2703 |
| Total ISGS | 17310 | 12914 | 13364 | - | - | - | - | 295.39 | 272.79 | 11367 |

JOINT VENTURE

| Station/Constituents | Inst. Capacity | 19:00 | 03:00 | Day Peak | | Min Generation (06:00 to 18:00) | | Day Energy | | Avg |
|---|---|---|---|---|---|---|---|---|---|---|
| | (MW) | Peak MW | Off Peak MW | (MW) | Hrs | (MW) | Hrs | Gross (MU) | Net (MU) | (MW) |
| NTPL ( 2*500 ) | 1000 | 561 | 455 | 929 | 23:27 | 254 | 07:53 | 11.43 | 10.77 | 449 |
| Vallur TPS ( 3*500 ) | 1500 | 1361 | 1352 | 1384 | 04:37 | 743 | 09:51 | 29.32 | 27.3 | 1138 |
| Total Thermal | 2500 | 1922 | 1807 | - | - | - | - | 40.75 | 38.07 | 1587 |
| Total JOINT VENTURE | 2500 | 1922 | 1807 | - | - | - | - | 40.75 | 38.07 | 1587 |

IPP UNDER OPEN ACCESS

| Station/Constituents | Inst. Capacity | 19:00 | 03:00 | Day Peak | | Min Generation (06:00 to 18:00) | | Day Energy | | Avg |
|---|---|---|---|---|---|---|---|---|---|---|
| | (MW) | Peak MW | Off Peak MW | (MW) | Hrs | (MW) | Hrs | Gross (MU) | Net (MU) | (MW) |
| COASTAL ENERGEN ( 2*600 ) | 1200 | 701 | 1130 | 1157 | 05:45 | 625 | 08:28 | 22.31 | 20.73 | 864 |
| IL&FS ( 2*600 ) | 1200 | 594 | 992 | 1001 | 05:40 | 591 | 09:27 | 20.47 | 19.18 | 799 |
| JINDAL POWER LIMITED (Simhapuri Unit) ( 4*150 ) | 600 | 303 | 540 | 545 | 00:48 | 256 | 08:46 | 9.56 | 8.77 | 365 |
| MEENAKSHI ENERGY LTD STAGE1 ( 2*150 ) | 300 | 90 | 92 | 95 | 10:25 | 88 | 10:38 | 2.37 | 2.13 | 89 |
| MEENAKSHI ENERGY LTD STAGE2 ( 2*350 ) | 700 | 8 | 10 | 242 | 00:01 | 7 | 10:32 | 0.17 | 0.15 | 6 |
| SEIL ( 2*660 ) | 1320 | 1252 | 1269 | 1275 | 18:10 | 964 | 08:19 | 27.88 | 26.35 | 1098 |
| SEIL-PROJECT2 ( 1*660 ) | 660 | 624 | 627 | 631 | 20:31 | 319 | 09:20 | 13.69 | 12.96 | 540 |
| Total Thermal | 5980 | 3572 | 4660 | - | - | - | - | 96.45 | 90.27 | 3761 |
| Greenko (6 * 240 + 2 * 120) | 1680 | 1177 | 415 | 1229 | 20:49 | 0 | 07:31 | 10.56 | 10.51 | 438 |
| GREENKO(Pump) (6 * 240 + 2 * 120) | 1680 | 0 | 0 | 1565 | 09:30 | 0 | 06:00 | 12.63 | 12.66 | 528 |
| Total Hydro | 1680 | 1177 | 415 | - | - | - | - | 10.56 | 10.51 | 438 |
| LKPPL ST2 ( 233 + 133 ) | 366 | 13 | 2 | 238 | 00:15 | 1 | 14:55 | 0.84 | 0.81 | 34 |
| LKPPL ST3 ( 2*233 + 2*133 ) | 732 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |

| | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| Total Gas | 1098 | 13 | 2 | - | - | - | - | 0.84 | 0.81 | 34 |
| Total IPP UNDER OPEN ACCESS | 8758 | 4762 | 5077 | - | - | - | - | 107.85 | 101.59 | 4233 |

RENEWABLE WIND

| Station/Constituents | Inst. Capacity | 19:00 | 03:00 | Day Peak | | Min Generation (06:00 to 18:00) | | Day Energy | | Avg |
|---|---|---|---|---|---|---|---|---|---|---|
| | (MW) | Peak MW | Off Peak MW | (MW) | Hrs | (MW) | Hrs | Gross (MU) | Net (MU) | (MW) |
| GADAG_GreenInfra_W | 55 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| GADAG_RSPPL_W | 202 | 234 | 85 | 276 | 17:38 | 6 | 08:56 | 2.2 | 2.2 | 92 |
| GADAG_Serentica3_W | 52 | 54 | 107 | 164 | 18:43 | 3 | 13:48 | 1.58 | 1.58 | 66 |
| GADAG_VENA_W | 133 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| GREEN INFRA | 250 | 227 | 69 | 236 | 19:51 | 5 | 08:08 | 3.11 | 3.11 | 130 |
| Hiriyur_Ostro | 300 | 175 | 78 | 234 | 19:33 | 5 | 07:46 | 1.72 | 1.72 | 72 |
| HIRIYUR_ZREPL_W | 66 | 80 | 55 | 93 | 19:20 | 2 | 16:38 | 0.75 | 0.75 | 31 |
| JSW RENEW ENERGY TWO LTD | 300 | 281 | 220 | 284 | 18:44 | 77 | 09:29 | 5.35 | 5.35 | 223 |
| KARUR_JSWRENEW_W | 162 | 91 | 66 | 152 | 15:08 | 23 | 06:10 | 1.82 | 1.82 | 76 |
| Karur_JSWRETwo_W | 150 | 122 | 103 | 134 | 14:03 | 0 | 11:45 | 2.42 | 2.42 | 101 |
| KARUR_TPVARDHAMAN_W | 50 | 180 | 154 | 190 | 23:08 | 115 | 10:47 | 3.86 | 3.86 | 161 |
| KOPPAL_AyanaSix_W | 300 | 203 | 94 | 285 | 17:52 | 2 | 13:37 | 2.18 | 2.18 | 91 |
| KOPPAL_Kleio_W | 101 | 31 | 50 | 68 | 01:13 | 5 | 14:17 | 0.65 | 0.65 | 27 |
| Koppal_RenewOjas_W | 322 | 105 | 169 | 250 | 17:55 | 0 | 12:37 | 2.31 | 2.31 | 96 |
| Koppal_RenewRoshni_W | 286 | 126 | 25 | 241 | 17:57 | 0 | 13:44 | 1.56 | 1.56 | 65 |
| KOPPAL_SRI1PL_W | 79 | 133 | 163 | 169 | 04:36 | 0 | 16:10 | 1.61 | 1.61 | 67 |
| Kurnool_AMGreeen_W | 304 | 164 | 201 | 274 | 02:05 | 9 | 07:45 | 2.27 | 2.27 | 95 |
| MYTRA | 250 | 183 | 158 | 216 | 18:43 | 52 | 06:58 | 3.62 | 3.62 | 151 |
| ORANGE | 200 | 172 | 49 | 187 | 15:02 | 7 | 08:11 | 2.35 | 2.35 | 98 |
| PGLR_SAUPL_W | 53 | 22 | 9 | 47 | 11:19 | 2 | 07:38 | 0.57 | 0.57 | 24 |
| PGLR_SREPL | 300 | 182 | 153 | 307 | 14:12 | 34 | 06:09 | 4.36 | 4.36 | 182 |
| TuticorinJSWRenewW | 540 | 482 | 457 | 487 | 20:02 | 338 | 10:38 | 10.45 | 10.45 | 435 |
| VIVID SOLAIRE (BEETAM) | 220 | 214 | 101 | 221 | 18:53 | 18 | 07:43 | 3.38 | 3.38 | 141 |
| Total SR_Wind | 4675 | 3461 | 2566 | - | - | - | - | 58.12 | 58.12 | 2424 |
| Total RENEWABLE WIND | 4675 | 3461 | 2566 | - | - | - | - | 58.12 | 58.12 | 2424 |

RENEWABLE SOLAR

| Station/Constituents | Inst. Capacity | 19:00 | 03:00 | Day Peak | | Min Generation (06:00 to 18:00) | | Day Energy | | Avg |
|---|---|---|---|---|---|---|---|---|---|---|
| | (MW) | Peak MW | Off Peak MW | (MW) | Hrs | (MW) | Hrs | Gross (MU) | Net (MU) | (MW) |
| ANP_AdaniAPSeven | 250 | 0 | 0 | 247 | 14:14 | 1 | 06:00 | 1.76 | 1.76 | 73 |
| ANP_ATHENA BIWADI | 50 | 0 | 0 | 42 | 13:15 | 1 | 06:00 | 0.32 | 0.32 | 13 |
| ANP_ATHENA HISAR | 50 | 0 | 0 | 50 | 12:53 | 0 | 06:00 | 0.33 | 0.33 | 14 |
| ANP_ATHENA KARNAL | 50 | 0 | 0 | 47 | 13:31 | 1 | 06:00 | 0.32 | 0.32 | 13 |
| ANP_AYANA | 250 | 0 | 0 | 264 | 13:27 | 3 | 06:00 | 1.86 | 1.86 | 78 |
| ANP_AZURE | 50 | 0 | 0 | 44 | 12:20 | 0 | 06:00 | 0.31 | 0.31 | 13 |
| ANP_IGS1 | 50 | 0 | 0 | 48 | 13:28 | 1 | 06:00 | 0.32 | 0.32 | 13 |
| ANP_IGS2 | 50 | 0 | 0 | 52 | 12:04 | 1 | 06:00 | 0.4 | 0.4 | 17 |
| ANP_NTPC | 250 | 0 | 0 | 164 | 13:38 | 0 | 06:04 | 1.19 | 1.19 | 50 |
| ANP_TATA | 100 | 0 | 0 | 93 | 13:31 | 1 | 06:00 | 0.59 | 0.59 | 25 |
| SPRING ANG ITRA | 250 | 0 | 0 | 262 | 13:19 | 3 | 06:00 | 1.9 | 1.9 | 79 |
| Total NP_KUNTA | 1400 | 0 | 0 | - | - | - | - | 9.3 | 9.3 | 388 |
| PVG_ADYAH | 300 | 0 | 0 | 262 | 13:41 | 0 | 06:00 | 1.68 | 1.68 | 70 |
| PVG_AMPLUS PAVAGADA | 50 | 0 | 0 | 51 | 12:43 | 0 | 06:00 | 0.36 | 0.36 | 15 |
| PVG_AMPLUS TUMKUR | 50 | 0 | 0 | 51 | 11:34 | 0 | 06:00 | 0.36 | 0.36 | 15 |
| PVG_AVAADA SOLAR | 150 | 0 | 0 | 144 | 13:34 | 1 | 06:00 | 0.93 | 0.93 | 39 |
| PVG_AVAADA SOLARISE | 150 | 0 | 0 | 143 | 13:24 | 0 | 06:00 | 0.93 | 0.93 | 39 |
| PVG_AZURE POWER EARTH | 100 | 0 | 0 | 98 | 13:42 | 0 | 06:00 | 0.68 | 0.68 | 28 |
| PVG_FORTUM FIN SURYA | 100 | 0 | 0 | 87 | 13:33 | 0 | 06:00 | 0.54 | 0.54 | 23 |
| PVG_IRCON_S | 225 | 0 | 0 | 372 | 14:09 | 1 | 06:00 | 2.7 | 2.7 | 113 |
| PVG_KREDL | 50 | 0 | 0 | 45 | 12:09 | 1 | 06:00 | 0.32 | 0.32 | 13 |
| PVG_PARAMPUJYA | 150 | 0 | 0 | 124 | 14:20 | 1 | 06:00 | 0.87 | 0.87 | 36 |

| | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| PVG_RENEW TN2 | 50 | 0 | 0 | 48 | 11:23 | 0 | 06:00 | 0.37 | 0.37 | 15 |
| PVG_SBG ENERGY | 200 | 0 | 0 | 182 | 11:08 | 0 | 06:00 | 1.24 | 1.24 | 52 |
| PVG_SPRING SOLAR INDIA | 250 | 0 | 0 | 245 | 13:44 | 0 | 06:00 | 1.63 | 1.63 | 68 |
| PVG_TATA RENEWABLES | 400 | 0 | 0 | 355 | 13:23 | 1 | 06:00 | 2.45 | 2.45 | 102 |
| PVG_YARROW | 50 | 0 | 0 | 45 | 12:31 | 0 | 06:00 | 0.29 | 0.29 | 12 |
| Total PAVAGADA | 2275 | 0 | 0 | - | - | - | - | 15.35 | 15.35 | 640 |
| GADAG_Serentica3_S | 69 | 0 | 0 | 154 | 10:51 | 0 | 06:00 | 0.93 | 0.93 | 39 |
| GADAG_VENA_S | 31 | 0 | 0 | 0 | 00:00 | 0 | 06:00 | 0 | 0 | 0 |
| GRT | 150 | 0 | 0 | 143 | 13:18 | 0 | 06:00 | 0.97 | 0.97 | 40 |
| HIRIYUR_ZREPL_S | 94 | 0 | 0 | 83 | 12:49 | 0 | 06:00 | 0.57 | 0.57 | 24 |
| KOPPAL_Kleio_S | 105 | 0 | 0 | 95 | 12:22 | 0 | 06:00 | 0.47 | 0.47 | 20 |
| KOPPAL_RenewOjas_S | 81 | 0 | 0 | 69 | 10:25 | 0 | 06:00 | 0.37 | 0.37 | 15 |
| KOPPAL_SRI1PL_S | 188 | 0 | 0 | 188 | 15:50 | 0 | 06:00 | 1.11 | 1.11 | 46 |
| KOPPAL_TPSAURYA_S | 131 | 0 | 0 | 207 | 15:44 | 0 | 06:00 | 1.09 | 1.09 | 45 |
| Kurnool3_SAEL1_S | 300 | 0 | 0 | 302 | 12:30 | 0 | 06:00 | 2.64 | 2.64 | 110 |
| Kurnool3_SAEL2_S | 300 | 0 | 0 | 302 | 11:37 | 0 | 06:00 | 2.43 | 2.43 | 101 |
| Kurnool_AMGreen_S | 599 | 0 | 0 | 549 | 12:18 | 6 | 06:00 | 4.09 | 4.09 | 170 |
| Kurnool_Greenko_S | 300 | 0 | 0 | 470 | 12:01 | 6 | 06:00 | 3.53 | 3.53 | 147 |
| NTPC ETTAYAPURAM SOLAR PLANT | 230 | 0 | 0 | 233 | 13:50 | 0 | 06:00 | 1.64 | 1.64 | 68 |
| RAMANGUNDAM (SOLAR) | 100 | 0 | 0 | 95 | 12:13 | 4 | 17:56 | 0.69 | 0.69 | 29 |
| SIMHADRI (SOLAR) | 25 | 0 | 0 | 24 | 11:41 | 0 | 17:59 | 0.15 | 0.15 | 6 |
| Total OTHER | 2703 | 0 | 0 | - | - | - | - | 20.68 | 20.68 | 860 |
| Total RENEWABLE SOLAR | 6378 | 0 | 0 | - | - | - | - | 45.33 | 45.33 | 1888 |

RENEWABLE BESS

| Station/Constituents | Inst. Capacity | 19:00 | 03:00 | Day Peak | | Min Generation (06:00 to 18:00) | | Day Energy | | Avg |
|---|---|---|---|---|---|---|---|---|---|---|
| | (MW) | Peak MW | Off Peak MW | (MW) | Hrs | (MW) | Hrs | Gross (MU) | Net (MU) | (MW) |
| KOPPAL_RenewOjas_BESS (Discharge) | 75 | 75 | 0 | 75 | 22:54 | 0 | 06:02 | 0.23 | 0.23 | 10 |
| KOPPAL_RenewOjas_BESS (Charge) | 75 | 0 | 0 | 53 | 10:46 | 0 | 06:13 | 0.16 | 0.16 | 7 |
| Total SR_BESS | 75 | 75 | 0 | - | - | - | - | 0.23 | 0.23 | 10 |
| Total RENEWABLE BESS | 75 | 75 | 0 | - | - | - | - | 0.23 | 0.23 | 10 |

| | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| Total ISGS IPP Thermal | 22470 | 15554 | 16964 | - | - | - | - | 362.1 | 336.27 | 14012 |
| Total State Thermal | 30742 | 17731 | 17843 | - | - | - | - | 426.69 | 393.61 | 16401 |
| Total ISGS IPP Hydro | 1680 | 1177 | 415 | - | - | - | - | 10.56 | 10.51 | 438 |
| Total State Hydro | 14298 | 1743 | 1506 | - | - | - | - | 42.75 | 42.35 | 1770 |
| Total Gas/Naptha/Diesel | 6423 | 130 | 119 | - | - | - | - | 4.72 | 4.43 | 184 |
| Total Nuclear | 3320 | 2854 | 2867 | - | - | - | - | 70.49 | 64.86 | 2703 |
| Total Wind | 24146 | 9835 | 7322 | - | - | - | - | 177.37 | 177.37 | 7393 |
| Total Solar | 35435 | 12 | 2 | - | - | - | - | 174.16 | 174.16 | 7256 |
| Total Others | 4752 | 935 | 926 | - | - | - | - | 16.57 | 16.57 | 691 |
| Total BESS | 75 | 75 | 0 | - | - | - | - | 0.23 | 0.23 | 10 |

### 4(A) INTER-REGIONAL EXCHANGES (Import=(+ve) /Export =(-ve))

| SL.No. | Element | 20:00 | 03:00 | Maximum Interchange (MW) | | Import in MU | Export in MU | NET |
|---|---|---|---|---|---|---|---|---|
| | | MW | MW | Import | Export | | | |
| Import/Export between SOUTH REGION and EAST REGION | | | | | | | | |
| 1 | 220KV-UPPER_SILERU-BALIMELA | 0 | 0 | 0.0 | - | 0 | 0 | 0 |
| 2 | 400KV-GAZUWAKA-JEYPORE | 0 | 0 | 0.0 | - | 0 | 0 | 0 |
| 3 | 765KV-SRIKAKULAM-ANGUL | 2296 | 1766 | 2524.0 | - | 44.51 | 0 | 44.51 |
| 4 | HVDC500KV-TALCHER-KOLAR_DC | 1496 | 1849 | 1855.0 | - | 38.57 | 0 | 38.57 |
| Sub-Total EAST REGION | | 3792 | 3615 | - | - | 83.08 | 0 | 83.08 |
| Import/Export between SOUTH REGION and WEST REGION | | | | | | | | |
| 1 | 220KV-AMBEWADI-PONDA | 0 | 0 | 0.0 | - | 0 | 0 | 0 |
| 2 | 220KV-AMBEWADI-XELDEM | 102 | 80 | - | 107.0 | 0 | 2.11 | -2.11 |
| 3 | 220KV-CHIKKODI-MUDASANGI | 0 | 0 | 0.0 | - | 0 | 0 | 0 |
| 4 | 220KV-CHIKKODI-TALANGADE | 0 | 0 | 0.0 | - | 0 | 0 | 0 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| 5 | 220KV-LOWER_SILERU-BARSUR | 0 | 0 | 0.0 | - | 0 | 0 | 0 |
| 6 | 400KV-BHADRAVTAHI-RAMAGUNDAM | 513 | 512 | - | 514.0 | 0 | 12.3 | -12.3 |
| 7 | 400KV-KUDGI_PG-KHOLAPUR_PG | 1024 | 1494 | - | 1697.0 | 0 | 29.36 | -29.36 |
| 8 | 765KV-NIZAMABAD-WARDHA | 1784 | 725 | 2250.0 | - | 30.08 | 0 | 30.08 |
| 9 | 765KV-RAICHUR_PG-SHOLAPUR | 679 | 622 | 1308.0 | - | 1.4 | 0 | 1.4 |
| 10 | 765KV-WARANGAL(NEW)-WARORA | 2001 | 1044 | 2468.0 | - | 35.68 | 0 | 35.68 |
| 11 | HVDC800KV-RAIGARH HVDC-PUGALUR HVDC | 564 | 564 | 573.0 | - | 13.81 | 0 | 13.81 |
| Sub-Total WEST REGION | | 6667 | 5041 | - | - | 80.97 | 43.77 | 37.2 |
| TOTAL IR EXCHANGE | | 10459 | 8656 | - | - | 164.05 | 43.77 | 120.28 |

### 4(B) Inter Regional Schedule & Actual Exchange (Import=(+ve) /Export =(-ve)) in MU

| Link | ISGS+URS+GNA | TGNA | GDAM | DAM | HPDAM | RTM | Total IR Schedule | Total IR Actual | Net UI |
|---|---|---|---|---|---|---|---|---|---|
| East-South | 27.38 | -8.39 | 0 | 0 | 0 | 0 | -21.46 | 43.54 | 65 |
| West-South | 56.39 | 6.22 | -0.23 | 8.23 | 0 | 38.27 | 102.56 | 37.2 | -65.36 |
| Total | 83.77 | -2.17 | -0.23 | 8.23 | 0 | 38.27 | 81.1 | 80.74 | -0.36 |

### 5. Frequency Profile

| RANGE(Hz) | < 48.8 | < 49 | < 49.2 | < 49.5 | < 49.7 | < 49.9 | >= 49.9 - <= 50.05 | > 50 | > 50.05 |
|---|---|---|---|---|---|---|---|---|---|
| % | 0 | 0 | 0 | 0 | 0 | 2.65 | 78.53 | 55.278 | 18.819 |

| Max Freq | | Min Freq | | Avg Freq | Freq Variation Index | Standard Deviation | Freq in 15 mnt blk | |
|---|---|---|---|---|---|---|---|---|
| Freq (HZ) | Time | Freq (HZ) | Time | | | | Max (Hz) | Min (Hz) |
| 50.175 | 15:04:20 | 49.824 | 18:26:30 | 50.005 | 0.029 | 0.054 | 50.12 | 49.89 |

### 6(A). Voltage Profile: 765 kV

| Station | Max | | Min | | Voltage (in %) | | | |
|---|---|---|---|---|---|---|---|---|
| | Voltage | Time | Voltage | Time | < 720 | < 750 | > 780 | > 800 |
| KURNOOL - 765KV | 800 | 02:28 | 777 | 14:44 | 0 | 0 | 92.22 | 0 |
| NIZAMABAD - 765KV | 800 | 02:28 | 778 | 15:52 | 0 | 0 | 97.43 | 0 |
| RAICHUR_PG - 765KV | 794 | 03:09 | 770 | 12:21 | 0 | 0 | 59.17 | 0 |
| SRIKAKULAM - 765KV | 793 | 09:57 | 770 | 14:42 | 0 | 0 | 85.07 | 0 |

### 6(B). Voltage Profile: 400 kV

| Station | Max | | Min | | Voltage (in %) | | | |
|---|---|---|---|---|---|---|---|---|
| | Voltage | Time | Voltage | Time | < 380 | < 390 | > 420 | > 430 |
| GHANAPUR - 400KV | 423 | 02:29 | 407 | 14:42 | 0 | 0 | 29.38 | 0 |
| GOOTY - 400KV | 423 | 23:58 | 401 | 12:27 | 0 | 0 | 15.42 | 0 |
| HIRIYUR - 400KV | 425 | 23:56 | 404 | 10:35 | 0 | 0 | 28.61 | 0 |
| KAIGA - 400KV | 426 | 23:58 | 400 | 11:59 | 0 | 0 | 27.99 | 0 |
| KOLAR_AC - 400KV | 421 | 03:04 | 396 | 10:36 | 0 | 0 | 2.92 | 0 |
| KUDANKULAM - 400KV | 416 | 05:29 | 397 | 12:36 | 0 | 0 | 0 | 0 |
| SHANKARAPALLY - 400KV | 421 | 02:29 | 411 | 15:52 | 0 | 0 | 12.57 | 0 |
| SOMANAHALLI - 400KV | 424 | 03:01 | 396 | 10:35 | 0 | 0 | 21.04 | 0 |
| SRIPERUMBADUR - 400KV | 417 | 01:41 | 397 | 12:30 | 0 | 0 | 0 | 0 |
| TRICHY - 400KV | 411 | 01:32 | 392 | 13:39 | 0 | 0 | 0 | 0 |
| TRIVANDRUM - 400KV | 419 | 01:36 | 396 | 12:36 | 0 | 0 | 0 | 0 |
| VIJAYAWADA - 400KV | 419 | 02:29 | 404 | 14:55 | 0 | 0 | 0 | 0 |

### 6(C). Voltage Profile: 220 kV

| Station | Max | | Min | | Voltage (in %) | | | |
|---|---|---|---|---|---|---|---|---|
| | Voltage | Time | Voltage | Time | < 198 | < 210 | > 235 | > 245 |
| GHANAPUR - 220KV | 231 | 02:13 | 220 | 14:55 | 0 | 0 | 0 | 0 |
| GOOTY - 220KV | 232 | 02:35 | 222 | 11:55 | 0 | 0 | 0 | 0 |
| HIRIYUR - 220KV | 235 | 21:01 | 216 | 09:25 | 0 | 0 | 0.28 | 0 |
| KAIGA - 220KV | 234 | 16:42 | 222 | 08:32 | 0 | 0 | 0 | 0 |
| KOLAR_AC - 220KV | 229 | 03:02 | 213 | 10:36 | 0 | 0 | 0 | 0 |
| SOMANAHALLI - 220KV | 238 | 03:02 | 219 | 10:41 | 0 | 0 | 25.49 | 0 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| SRIPERUMBADUR - 220KV | 227 | 02:53 | 213 | 21:50 | 0 | 0 | 0 | 0 |
| TRICHY - 220KV | 227 | 21:04 | 208 | 12:36 | 0 | 0.21 | 0 | 0 |
| TRIVANDRUM - 220KV | 232 | 05:23 | 229 | 20:26 | 0 | 0 | 0 | 0 |
| VIJAYAWADA - 220KV | 237 | 18:16 | 218 | 14:55 | 0 | 0 | 0.76 | 0 |

### 7. Major Reservoir Particulars

| RESERVOIR | DESIGNED | | | PRESENT | | LAST YEAR | | LAST DAY | | MONTH | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| | MDDL (m) | FRL (m) | Energy (MU) | Level (m) | Energy (MU) | Level (m) | Energy (MU) | Inflow (MU) | Usage (MU) | Prog Inflow (MU) | Prog Usage (MU) |
| IDUKKI | 694.94 | 732.43 | 2148 | 706.26 | 461 | 714.35 | 889 | 8.16 | 4.6 | 17.35 | 27.66 |
| JALAPUT | 818.39 | 838.4 | 534 | 825.34 | 128 | 831.59 | 275 | 0.26 | 0 | 1.79 | 0 |
| KAKKI | 908.3 | 981.45 | 916 | 939.31 | 122 | 963.09 | 421 | 6.09 | 1.53 | 18.3 | 9.5 |
| LINGANAMAKKI | 522.73 | 554.5 | 4557 | 533.49 | 555 | 538.08 | 1012 | 4.85 | 10.58 | 4.85 | 54.99 |
| N.SAGAR | 149.3 | 179.9 | 1398 | 158.25 | 89 | 155.94 | 15 | 2.45 | 2.86 | 17.13 | 12 |
| NILAGIRIS | 0 | 0 | 1504 | 0 | 474 | 0 | 705 | 0.28 | 3.9 | 6.08 | 25.78 |
| SRISAILAM | 243.84 | 270.7 | 1392 | 249.54 | 60 | 254.6 | 145 | 0 | 0 | 0 | 0 |
| SUPA | 495 | 564 | 3159 | 526.19 | 677 | 529.88 | 835 | 0.35 | 4.94 | 0.67 | 29.55 |
| Total | - | - | 15608 | - | 2566 | - | 4297 | 22.44 | 28.41 | 66.17 | 159.48 |

### 8(A). Short-Term Open Access Details

| State | Off- Peak Hours (03:00) | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | TGNA | IEX GDAM | IEX DAM | IEX HPDAM | IEX RTM | PXIL GDAM | PXIL DAM | PXIL HPDAM | PXIL RTM | HPX GDAM | HPX DAM | HPX HPDAM | HPX RTM |
| Andhra Pradesh | -28.41 | -4.7 | -49.6 | 0 | 45.27 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Karnataka | -405.03 | -79.59 | 52.8 | 0 | -36.2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Kerala | 0 | 0 | -10.1 | 0 | 317.25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Puducherry | 52.24 | 0 | -75 | 0 | -40 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Tamil Nadu | 1508.03 | 0 | -9 | 0 | 1147.89 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Telangana | -35.92 | 0.19 | 144.88 | 0 | 513.28 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Total | 1090.91 | -84.1 | 53.98 | 0 | 1947.49 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

| State | Peak Hours (20:00) | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | TGNA | IEX GDAM | IEX DAM | IEX HPDAM | IEX RTM | PXIL GDAM | PXIL DAM | PXIL HPDAM | PXIL RTM | HPX GDAM | HPX DAM | HPX HPDAM | HPX RTM |
| Andhra Pradesh | -29.97 | -3.5 | 443.4 | 0 | 229.47 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Karnataka | -865.47 | -72.72 | 35.6 | 0 | -32.77 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Kerala | 0 | 0 | -10.1 | 0 | 1217.56 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Puducherry | 56.01 | 0 | 0 | 0 | -66 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Tamil Nadu | 4589.06 | 0 | -14 | 0 | 417.52 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Telangana | -33.25 | 0.19 | 731.95 | 0 | -7.5 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Total | 3716.38 | -76.03 | 1186.85 | 0 | 1758.28 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

| State | Day Energy (MU) | | | | | | |
|---|---|---|---|---|---|---|---|
| | ISGS+GNA | TGNA | GDAM | DAM | HPDAM | RTM | Total |
| Andhra Pradesh | 59.62 | 0.17 | 0.94 | 9.53 | 0 | 11.9 | 82.16 |
| Karnataka | 111.97 | -8.34 | -0.9 | 0.87 | 0 | 1.49 | 105.09 |
| Kerala | 56.44 | 1.35 | 0.56 | 6.44 | 0 | 8.41 | 73.2 |
| Puducherry | 11.99 | 1.64 | 0 | -1.17 | 0 | -1.03 | 11.43 |
| Tamil Nadu | 182.94 | 46.53 | 1.35 | -17.76 | 0 | -7.39 | 205.67 |
| Telangana | 78.97 | 0.15 | 0.45 | 4.87 | 0 | 14.81 | 99.25 |
| Total | 501.93 | 41.5 | 2.4 | 2.78 | 0 | 28.19 | 576.8 |

### 8(B). Short-Term Open Access Details

| State | ISGS+GNA | | TGNA | | IEX GDAM | | PXI GDAM | | HPX GDAM | | IEX DAM | | PXI DAM | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Max | Min | Max | Min | Max | Min | Max | Min | Max | Min | Max | Min | Max | Min |
| Andhra Pradesh | 3500.06 | 1740.54 | 66.72 | -45.01 | 165.52 | -10.46 | 0 | 0 | 0 | 0 | 953.51 | -54.2 | 0 | 0 |
| Karnataka | 5574.17 | 4050.5 | -104.22 | -867.22 | 54.18 | -100.31 | 0 | 0 | 0 | 0 | 91.15 | -35.84 | 0 | 0 |
| Kerala | 2688.91 | 1741.43 | 378.5 | 0 | 67.71 | 0 | 0 | 0 | 0 | 0 | 743.5 | -10.1 | 0 | 0 |
| Puducherry | 579.82 | 405.44 | 89.2 | 51.66 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | -98 | 0 | 0 |
| Tamil Nadu | 8422.04 | 6494.06 | 4939.59 | 250.6 | 159.47 | 0 | 0 | 0 | 0 | 0 | 513.86 | -3760.95 | 0 | 0 |

| | | | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Telangana | 4872.5 | 2379.05 | 56.23 | -37.19 | 66.31 | -0.91 | 0 | 0 | 0 | 0 | 1330.04 | -43 | 0 | 0 |

| State | HPX DAM | | IEX HPDAM | | PXI HPDAM | | HPX HPDAM | | IEX RTM | | PXI RTM | | HPX RTM | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Max | Min | Max | Min | Max | Min | Max | Min | Max | Min | Max | Min | Max | Min |
| Andhra Pradesh | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1715.28 | -226.4 | 0 | 0 | 0 | 0 |
| Karnataka | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 813.66 | -253.05 | 0 | 0 | 0 | 0 |
| Kerala | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1240.07 | -1.7 | 0 | 0 | 0 | 0 |
| Puducherry | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 6.76 | -135 | 0 | 0 | 0 | 0 |
| Tamil Nadu | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2335.41 | -2733.52 | 0 | 0 | 0 | 0 |
| Telangana | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1661.15 | -207.88 | 0 | 0 | 0 | 0 |

### 9. Synchronisation of new generating units:

| SL.NO | Station Name | Owner | Inst. Capacity (MW) | Date | Time |
|---|---|---|---|---|---|

### 10. Synchronisation of new 220 / 400 / 765 KV Transmission elements and energising of bus /substation:

### 11. Significant events (If any):

1) While charging LV side of Transformer-1, master trip relay operated and 220KV-KOPPAL-Renew_Surya_Koppal-1 tripped at 13:42Hrs and 220kV Station became dead. Generation loss of 50MW occurred. Line charged at 14:24Hrs.
2) At15:07 , Bus bar protection operated on 220 KV Kalaburagi Bus-1 and 2 due to B-N fault in 220 KV Kalaburagi -Shahpura-1 which lead to tripping of all the elements connected to 220kV Kalabuargi.No Load loss reported as informed by KPTCL.All the elments connected to 220 KV Kalaburagi have been charged except 220 KV Kalaburagi-shahpura -1 . Patrolling is being done on the 220 KV Kalaburagi-Shahpura-1. 3) At 18:58Hrs while charging SEPC Bus reactor, 400kV SEPC-Ottapidam-2 got tripped(Line-1 is already under outage), station became dead. No generation loss as unit-1 is out.

### 12. Constraints and instances of congestion in the transmission system

1) 400KV-KALPAKKA-KHAMMAM_PG-1 & 400KV-KALPAKKA-ASUPAKA-1 Lines Under S/D for replacement of badly damaged rusted towers from Loc No.1 to 11 in 400KV Kalapaka – Khammam along with stringing of conductor at 400kv SS Kalapaka. S/D availed on 05-05-2026 ,Expected to be restored on 26-06-2026.
2) 400KV Kaiga-Guttur 1&2 tripped on 14.05.2026 at 17:39Hrs due to the tower collapse in multiple locations.
3) 400KV-GAZUWAKA-JEYPORE-1,2 under shutdown for NH-130CD Diversion works (Between 130-133/150-153/179-180) availed on 15-05-2026 at 09:36 Hrs. Expected to restore by 16.06.2026 18:00 Hrs.
4) 400KV-PAVAGADA_PG-TUMKUR-1&2 availed S/D on 17.05.2026 at 10:17Hrs for Conductor Release, Existing tower dismantle, New Tower erection, and stringing of the conductor for the work of Shifting/Heightening/Modification by providing 01 No. of 400KV DD+18 type tower,400kV Pavagada-Tumkur-1&2 lines charged at 17:22 & 18:06 hrs
5) 220KV-GADAG_PSS-Vena_GadagPS-1 and 220KV-GADAG_PSS-Green Infra_GadagPS-1 tripped on 17-05-2026 at 16:14 Hrs due to the tower collapse Loc. No.32-36. Generation affected 237MW(I.C)
6) At 18:13 hrs of 23-05-2026, 400KV-GADAG_PSS-KOPPAL D/C tripped on Y-B fault due to tower collapse. total 15 number of tower Collapsed (Tower location number 52-66).
7) 400KV-NAGAPATTNAM_PS-TRICHY-1&2 tripped on 31.05.2026 at 17:05Hrs due to the tower collapse at loc. 437(DA), 438(DA), 439(DB) towers are collapsed and 435(DA),436(DA),440(DA), 441(DA) towers are found cross arm/earth peak damaged.
8) 400/220kV SOMANAHALLI ICT-1 tripped at 20:07 hours of 31-05-2026 due to REF, Differential & body protections.
9) 400KV/220KV VIJAYAWADA-ICT-2 tripped on 25.05.2026 due to the failure of 220kV B-ph bushing. Expected charging on 15.06.2026

### 13. Weather Condition

Kerala :Moderate rains reported through out the state. Karnataka: Moderate Rains reported in Bangalore,Mysore,Hassan Mangalore,Uduppi and Karwar area.

### 14. RE/Load Curtailment details

| State | Load Curtailment (Shortage) | | | RE Curtailment | | | | |
|---|---|---|---|---|---|---|---|---|
| | Energy (MU) | Max (MW) | At the time of maximum demand | Wind Max (MW) | Wind Energy (MU) | Solar Max (MW) | Solar Energy (MU) | Reason |
| Andhra Pradesh | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Karnataka | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Kerala | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Puducherry | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Tamil Nadu | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Telangana | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

### 15.Instances of persistant/significant non-complaint with grid code

| State | Frequency and Deviation | | | | Voltage | | | | ICT loading | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Alert | Emergency | Extreme Emergency | Non Compliance | Alert | Emergency | Extreme Emergency | Non Compliance | Alert | Emergency | Extreme Emergency | Non Compliance |
| Andhra Pradesh | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 4 | 8 | 1 | 0 |
| Karnataka | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 7 | 1 | 0 | 0 |
| Kerala | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Puducherry | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Tamil Nadu | 2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2 | 10 | 0 | 0 |
| Telangana | 0 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |