ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
GRID CONTROLLER OF INDIA LIMITED
क्षेत्रीय लोड प्रेषण केन्द्र
SOUTHERN REGIONAL LOAD DESPATCH CENTER

Date of Reporting: 08-Jun-2026

Power Supply Position Report For

07-Jun-2026

1. Regional Availability/Demand:

Evening Peak (20:00) MW				Off-Peak (03:00) MW				Day Energy (Net MU)	
Demand Met	Shortage	Requirement	Freq (Hz)	Demand Met	Shortage	Requirement	Freq (Hz)	Demand Met	Shortage #
49042	0	49042	50	48822	0	48822	50.04	1205.27	0

2(A) State's Load Deails (At State Periphery) in MUs:

State	State's Control Area Generation (Net MU)						Net SCH	Drawal	UI	Availability	Demand Met	Shortage #
	THERMAL	HYDRO	GAS/DIESEL /NAPTHA	WIND	SOLAR	OTHERS	(Net Mu)	(Net Mu)	(Net Mu)	(Net Mu)	(Net Mu)	(Net Mu)
Andhra Pradesh	131.76	4.57	0	27.77	18.26	2.26	81.84	81.24	-0.6	266.46	265.86	0
Karnataka	78.78	15.99	0	26.26	24.84	5.89	84.33	81.51	-2.82	236.09	233.27	0
Kerala	0	8.53	0	0.46	0.91	0.3	68.17	67.17	-1	78.37	77.37	0
Puducherry	0	0	0.35	0	0.06	0	11.05	10.45	-0.6	11.46	10.86	0
Tamil Nadu	75.15	5.02	3.3	66.43	54.3	6.08	188.93	183.93	-5	399.21	394.21	0
Telangana	101.6	2.49	0	0.85	21.31	4.75	93.05	92.7	-0.35	224.05	223.7	0
Total	387.29	36.6	3.65	121.77	119.68	19.28	527.37	517	-10.37	1215.64	1205.27	0

2(B) State's Demand Met in MWs and day energy forecast and deviation particulars

State	Evening Peak (20:00) MW			Off-Peak (03:00) MW			Average Demand	Day Energy (Net MU)	
	Demand Met	Shortage	Requirement	Demand Met	Shortage	Requirement	(MW)	Forecast (LGBR)	Deviation [Forecast - Consumption]
Andhra Pradesh	10332	0	10332	10590	0	10590	11115	263	2.86
Karnataka	8964	0	8964	8562	0	8562	9709	245.52	-12.25
Kerala	4032	0	4032	3012	0	3012	3287	79.24	-1.87
Puducherry	470	0	470	455	0	455	443	11.3	-0.44
Tamil Nadu	16554	0	16554	17729	0	17729	17152	401	-6.79
Telangana	8690	0	8690	8474	0	8474	9460	223	0.7
Total	49042	0	49042	48822	0	48822	51166	1223.06	-17.79

2(C) State's Demand Met in MWs (maximum demand met and Maximum requirement of the day details)

State	Maximum Demand, corresponding shortage and requirement details for the day				Maximum requirement, corresponding shortage and demand details for the day				ACE			
	Maximum Demand Met	Time	Shortage at maximum demand	Requirement at the max demand met	Demand Met at maximum requiremnet	Time	Shortage at maximum Requirement	Maximum Requirement	Maximum ACE(MW)	Time	Minimum ACE(MW)	Time
Andhra Pradesh	13604	14:56	0	13604	13604	14:56	0	13604	872.46	20:54	-632.84	14:25
Karnataka	11623	10:00	0	11623	11623	10:00	0	11623	937.35	17:06	-540.4	14:37
Kerala	4102	19:35	0	4102	4102	19:35	0	4102	498.15	15:31	-249.39	10:33
Puducherry	543	22:15	0	543	543	22:15	0	543	53.22	19:49	-112.3	17:17
Tamil Nadu	18654	21:30	0	18654	18654	21:30	0	18654	1503.44	08:46	-925.68	15:00
Telangana	10867	15:34	0	10867	10867	15:34	0	10867	851.8	14:57	-438.82	07:02
Region	56349	00:17	0	56349	56349	00:17	0	56349	2751.27	15:02	-3806.04	11:07

3(A) State Entities Generation:

ANDHRA PRADESH

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
HINDUJA POWER CORPORATION LTD (2*520)	1040	1016	1020	1030	22:50	556	09:42	21.91	20.64	860
KRISHNAPATTANAM (3*800)	2400	1545	1512	1924	01:29	1343	08:46	37.03	34.75	1448
RAYALASEEMA TPP (5*210 + 600)	1650	951	1096	1274	01:39	914	11:42	25.72	22.93	955
SEIL P2 Unit-2 (1*660)	660	621	624	632	23:24	340	11:08	14.72	13.93	580
VIJAYAWADA TPS (6*210 + 500 + 800)	2560	1707	2069	2159	00:00	1360	07:53	43.04	39.5	1646
Total Thermal	8310	5840	6321	-	-	-	-	142.42	131.75	5489

DONKARAYI (1*25)	25	0	0	0	00:00	0	06:00	0	0	0
HAMPI & T.B.DAM (8 * 9)	57	0	0	0	00:00	0	06:00	0	0	0
LOWER SILERU (4*115)	460	13	210	406	00:34	13	08:13	3.4	3.39	141
MACHKUND (3 * 17 + 3 * 23)	84	0	0	0	00:00	0	06:00	0	0	0
NAGARJUNASAGAR TAILPOND (2*25)	50	0	0	0	00:00	0	06:00	0	0	0
NSR RT.CANAL.P.H (3*30)	90	0	0	0	00:00	0	06:00	0	0	0
SRISAILAM RBPH (7*110)	770	0	0	0	00:00	0	06:00	0	0	0
UPPER SILERU (4*60)	240	0	113	160	00:56	0	08:04	1.57	1.19	50
OTHER HYDEL	124	0	0	0	00:00	0	06:00	0	0	0
Total Hydro	1900	13	323	-	-	-	-	4.97	4.58	191
GAUTAMI CCPP (2*145 + 174)	464	0	0	0	00:00	0	06:00	0	0	0
GMR (BARG) (1 * 237)	237	0	0	0	00:00	0	06:00	0	0	0
JEGURUPADU (GAS) (2*45.8 + 49.9 + 75.5)	217	0	0	0	00:00	0	06:00	0	0	0
Jegrupadu Ext. (1 * 220)	220	0	0	0	00:00	0	06:00	0	0	0
KONASEEMA CCPP (145 + 140 + 165)	450	0	0	0	00:00	0	06:00	0	0	0
LANCO (GAS) (2*115 + 121)	351	0	0	0	00:00	0	06:00	0	0	0
RELIANCE ENERGY LTD. (GAS) (140 + 80)	220	0	0	0	00:00	0	06:00	0	0	0
SPECTRUM (GAS) (46.8 + 2*46.1 + 68.8)	208	0	0	0	00:00	0	06:00	0	0	0
VEMAGIRI POWER GENERATION LTD.(GAS) (233 + 137)	370	0	0	0	00:00	0	06:00	0	0	0
VIJJESWARAM GTS (2*33 + 34 + 112.5 + 59.5)	272	0	0	0	00:00	0	06:00	0	0	0
OTHER GAS/NAPTHA/DIESEL	27	0	0	0	00:00	0	06:00	0	0	0
Total Gas	3036	0	0	-	-	-	-	0	0	0
WIND	4102	1733	1409	2781	22:01	564	17:50	27.77	27.77	1157
SOLAR	3965	1	0	2397	11:38	13	06:00	18.26	18.26	761
OTHERS	619	128	110	163	13:40	115	12:19	2.26	2.26	94
Total ANDHRA PRADESH	21932	7715	8163	-	-	-	-	195.68	184.62	7692

TELANGANA

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
BHADRADRI TPS (4*270)	1080	790	828	887	04:40	514	10:58	18.42	16.56	690
KAKATIYA ST1&ST2 (500 + 600)	1100	1009	1038	1052	06:48	539	12:31	21.88	20.58	858
KOTHAGUDEM TPS (2*250 + 500 + 800)	1800	1150	1296	1478	06:22	909	16:04	29.08	26.98	1124
RAMAGUNDAM-B (1*62.5)	63	0	0	0	00:00	0	06:00	0	0	0
SINGARENI TPS (2*600)	1200	1120	1108	1143	20:53	580	10:05	23.18	21.77	907
YADADRI (4*800)	3200	688	645	760	15:58	611	10:39	17.61	15.72	655
Total Thermal	8443	4757	4915	-	-	-	-	110.17	101.61	4234
L JURALA (6*40)	240	0	0	0	00:00	0	06:00	0	0	0
NAGARJUNA SAGAR (110 + 7*100.8)	816	0	463	548	23:27	0	06:00	2.51	2.49	104
NAGARJUNA SAGAR (Pump) (110 + 7*100.8)	816	107	0	438	09:44	0	06:01	3.16	3.16	132
NIZAMSAGAR (2*5)	10	0	0	0	00:00	0	06:00	0	0	0
NSR LT.CANAL.P.H (2*30)	60	0	0	0	00:00	0	06:00	0	0	0
POCHAMPAD (4*9)	36	0	0	0	00:00	0	06:00	0	0	0
PULICHINTALA (4*30)	120	0	0	0	00:00	0	06:00	0	0	0
SINGUR (2*7.5)	15	0	0	0	00:00	0	06:00	0	0	0
SRISAILAM LBPH (6*150)	900	0	0	0	00:00	0	06:00	0	0	0
SRISAILAM LBPH(Pump) (6*150)	900	0	0	0	00:00	0	06:00	0	0	0
U JURALA (6*39)	234	0	0	0	00:00	0	06:00	0	0	0
OTHER HYDEL	51	0	0	0	00:00	0	06:00	0	0	0
Total Hydro	2482	0	463	-	-	-	-	2.51	2.49	104
WIND	128	0	84	109	02:06	1	15:01	0.85	0.85	35
SOLAR	3848	0	0	2465	12:07	31	06:00	21.31	21.31	888
OTHERS	252	198	198	198	00:00	198	06:00	4.75	4.75	198
Total TELANGANA	15153	4955	5660	-	-	-	-	139.59	131.01	5459

KARNATAKA

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak	Min Generation (06:00 to 18:00)	Day Energy	Avg

	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
Bellary TPS (2*500 + 700)	1700	918	1434	1474	06:30	894	13:34	29.31	27.46	1144
JINDAL (2*130 + 4*300)	1460	708	1033	1160	00:02	782	10:27	23.52	21.57	899
Jindal (Excl. Captive Consumption) (2 * 130 + 4 * 300)	1460	60	108	256	21:39	0	06:25	1.4	1.4	58
Raichur TPS (7*210 + 250)	1720	875	1040	1063	06:42	861	17:20	24.76	22.18	924
UPCL (2*600)	1200	611	613	1128	00:09	582	15:58	16.57	15.44	643
YERAMARAS TPS (2*800)	1600	479	646	676	00:35	419	07:54	13.41	12.3	513
Total Thermal	7680	2943	3841	-	-	-	-	85.45	78.78	3282
Almatty (15 + 5*55)	290	0	0	0	00:00	0	06:00	0	0	0
Bhadra (2*12.1 + 7 + 2 + 6)	39	0	0	0	18:29	0	06:33	0	0	0
Ghataprabha (2*16)	32	0	0	0	00:00	0	06:00	0	0	0
JOG (MGHES) (4*21.6 + 4*13.2)	139	51	60	60	00:27	51	16:55	1.38	1.36	57
LINGANAMAKKI.P.H. (2*27.5)	55	8	8	8	07:47	8	07:13	0.2	0.18	8
Kadra (3*50)	150	0	0	138	06:05	0	09:47	0.74	0.72	30
Kodasalli (3*40)	120	0	0	75	22:31	0	06:00	0.42	0.4	17
MANI DAM.P.H. (2*4.5)	9	1	1	1	00:01	0	17:31	0.04	0.04	2
Munirabad (3*9 + 10)	37	0	0	0	00:00	0	06:00	0	0	0
NAGJHERI (135 + 5*150)	885	571	0	587	20:30	0	06:05	3.13	3.08	128
SHARAVATHI (10*103.5)	1035	297	263	732	23:02	251	13:31	7.98	7.88	328
Sharavati Tail Race (4*60)	240	0	0	158	06:31	0	06:00	0.47	0.46	19
SIVANSAMUDRAM (6*3 + 4*6)	42	1	1	1	00:00	1	06:00	0.05	0.04	2
Supa (2*50)	100	0	30	30	00:00	0	07:24	0.22	0.21	9
U JURALA (6*39)	234	0	0	0	00:00	0	06:00	0	0	0
Varahi UGPH (4*115)	460	58	54	317	22:11	45	08:54	1.65	1.62	68
OTHER HYDEL	143	0	0	0	00:00	0	06:00	0	0	0
Total Hydro	4010	987	417	-	-	-	-	16.28	15.99	668
OTHER GAS/NAPTHA/DIESEL	126	0	0	0	00:00	0	06:00	0	0	0
Total Gas	126	0	0	-	-	-	-	0	0	0
WIND	5676	2136	1031	2274	19:03	441	14:48	26.26	26.26	1094
SOLAR	7171	5	10	3480	12:37	10	06:00	24.84	24.84	1035
OTHERS	1832	88	85	123	14:55	76	10:11	5.89	5.89	245
Total KARNATAKA	26495	6159	5384	-	-	-	-	158.72	151.76	6324

KERALA

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
Idamalayar (2*37.5)	75	0	0	0	00:00	0	06:00	0	0	0
Iddukki (6*130)	780	252	30	385	22:39	28	09:06	1.4	1.38	58
Kakkad (2*25)	50	36	24	39	19:27	0	07:22	0.35	0.35	15
KALLADA (2*7.5)	15	7	7	8	21:10	4	15:24	0.11	0.11	5
Kuttiyadi (3*25)	75	192	0	197	20:20	0	06:00	0.89	0.88	37
Lower Periyar (3*60)	180	58	116	163	23:41	0	06:00	0.97	0.96	40
Neriamangalam (3*17.5 + 25)	78	70	36	71	20:22	0	07:26	0.68	0.68	28
PALLIVASAL (3*5 + 3*7.5)	38	0	0	0	00:00	0	06:00	0	0	0
PALLIVASAL EXTENSION SCHEME (2*30)	60	58	20	60	00:24	18	06:00	0.56	0.56	23
Panniar (2*16.2)	32	0	0	0	00:00	0	06:00	0.04	0.04	2
PORINGALKUTHU (4*9)	36	16	0	16	23:58	0	06:00	0.09	0.09	4
Sengulam (4*12.8)	51	50	26	50	19:48	13	13:56	0.73	0.73	30
Sholayar (3*18)	54	35	0	53	00:12	0	06:00	0.18	0.18	8
Sabarigiri (4*55 + 2*60)	340	111	25	141	00:02	0	08:30	0.7	0.7	29
THOTTIYAR HEP (2*20)	40	10	38	40	21:08	4	06:30	0.51	0.51	21
OTHER HYDEL	230	111	0	112	19:40	0	06:17	1.37	1.37	57
Total Hydro	2134	1006	322	-	-	-	-	8.58	8.54	357
BRAHMAPURAM DGPP (DIESEL) (3*21.32)	64	0	0	0	00:00	0	06:00	0	0	0
BSES (NAPTHA) (3*40.5 + 35.5)	157	0	0	0	00:00	0	06:00	0	0	0
KOZHIKODE DPP (DIESEL) (6*16)	96	0	0	0	00:00	0	06:00	0	0	0
MPS STEEL CASTINGS (1 * 10)	10	0	0	0	00:00	0	06:00	0	0	0

RGCCPP KAYAMKULAM (KSEB) - NTPC (2*116.6 + 126.38)	360	0	0	0	00:00	0	06:00	0	0	0
OTHER GAS/NAPTHA/DIESEL	22	0	0	0	00:00	0	06:00	0	0	0
Total Gas	709	0	0	-	-	-	-	0	0	0
WIND	70	4	4	18	15:31	0	06:48	0.46	0.46	19
SOLAR	1988	0	0	153	11:31	0	06:13	0.91	0.91	38
OTHERS	20	4	5	158	11:31	1	06:01	0.3	0.3	13
Total KERALA	4921	1014	331	-	-	-	-	10.25	10.21	427

TAMIL NADU

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
Mettur TPS (4*210 + 600)	1440	790	813	1077	23:45	465	13:29	25.99	23.8	992
NORTH CHENNAI TPS STG-III (1*800)	800	0	0	0	00:00	0	06:00	0	0	0
NORTH CHENNAI TPS STG-II (2*600)	1200	617	718	722	06:51	599	12:22	17.25	15.84	660
North Chennai TPS (3*210)	630	404	487	502	12:06	388	16:02	11.86	10.64	443
UDANGUDI(Infirm - 660MW)	0	169	169	169	00:00	169	06:00	4.71	4.05	169
OPG PGPL (2*77 + 80 + 180)	414	101	272	297	00:00	81	12:43	4.25	3.83	160
SEPC (1*525)	525	0	0	0	00:00	0	06:00	0	0	0
ST - CMS (1*250)	250	218	209	226	08:05	143	11:14	5.48	5.04	210
Tuticorin (5*210)	1050	447	567	585	23:01	0	13:26	13.17	11.95	498
Total Thermal	6309	2746	3235	-	-	-	-	82.71	75.15	3132
Kadamparai (4*100)	400	0	0	100	20:12	0	06:00	0.19	0.18	8
Kadamparai (Pump) (4*100)	400	0	0	112	09:03	0	06:31	0.26	0.26	11
Kodayar I (1*60)	60	0	0	0	00:00	0	06:00	0	0	0
Kodayar II (1*40)	40	40	22	40	00:00	0	06:45	0.79	0.78	33
Kundah I (3*20)	60	5	4	52	23:21	1	09:41	0.29	0.29	12
Kundah II (5*35)	175	27	25	176	05:59	12	13:13	0.9	0.89	37
Kundah III (3*60)	180	9	6	139	11:03	6	06:17	0.66	0.65	27
Kundah IV (2*50)	100	0	0	0	00:00	0	06:00	0	0	0
Kundah V (2*20)	40	9	0	27	11:30	10	16:13	0.32	0.32	13
Kundah VI (1*30)	30	0	0	0	00:00	0	06:00	0	0	0
Mettur Dam (4*12.5)	50	0	0	0	14:19	0	06:00	0.21	0.21	9
Mettur Tunnel (4*50)	200	0	0	0	00:00	0	06:00	0	0	0
Moyar (3*12)	36	4	16	28	11:04	0	06:44	0.17	0.17	7
PAPANASAM (4*8)	32	0	0	28	00:34	0	06:00	0.14	0.14	6
Periyar (4*35)	140	24	27	27	12:06	24	16:05	0.62	0.61	25
Pykara (3*6.65 + 11 + 2*14)	59	0	0	0	00:00	0	06:00	0	0	0
PYKARA ULTIMATE (3*50)	150	0	0	151	23:20	0	06:00	0.23	0.23	10
Sarkarpathy (1*30)	30	12	12	13	20:47	12	09:29	0.3	0.3	13
Servalar (1*20)	20	0	0	15	19:04	0	06:00	0.04	0.03	1
Sholayar I (2*42)	84	0	0	0	00:00	0	06:00	0	0	0
Sholayar II (1*25)	25	0	0	0	00:00	0	06:00	0	0	0
Suruliyar (1*35)	35	0	0	0	00:00	0	06:00	0	0	0
OTHER HYDEL	1826	101	61	215	00:56	0	11:41	0.21	0.21	9
Total Hydro	3772	231	173	-	-	-	-	5.07	5.01	210
BASIN BRIDGE (NAPTHA) (4*30)	120	0	0	0	00:00	0	06:00	0	0	0
KOVIL KALAPPAL (GAS) (70 + 37.88)	108	0	0	0	00:00	0	06:00	0	0	0
KUTTALAM (GAS) (64 + 37)	101	84	68	86	06:26	77	15:46	1.87	1.74	73
MADURAI POWER CL (DIESEL) (1 * 106)	106	0	0	0	00:00	0	06:00	0	0	0
P P NALLUR (NAPTHA) (1 * 330.5)	331	0	0	0	00:00	0	06:00	0	0	0
SAMALPATTY (DIESEL) (7 * 15.1)	106	0	0	0	00:00	0	06:00	0	0	0
VALATTUR(STG1&STG2) (2*60 + 35 + 32)	187	29	33	62	11:51	34	17:59	1.68	1.56	65
OTHER GAS/NAPTHA/DIESEL	362	0	0	0	00:00	0	06:00	0	0	0
Total Gas	1421	113	101	-	-	-	-	3.55	3.3	138
WIND	9495	2930	2305	4595	15:21	1225	06:53	66.43	66.43	2768
SOLAR	12065	0	0	7353	11:53	52	06:00	54.3	54.3	2263
OTHERS	2029	536	786	787	01:27	500	13:05	6.08	6.08	253

Total TAMIL NADU	35091	6556	6600	-	-	-	-	218.14	210.27	8764

PUDUCHERRY

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
KARAIKAL POWER PLANT (GAS) (1 * 22.9 + 1 * 9.6)	33	15	15	15	00:00	15	06:00	0.38	0.35	15
Total Gas	33	15	15	-	-	-	-	0.38	0.35	15
SOLAR	20	0	0	9	12:22	0	06:00	0.06	0.06	3
Total PUDUCHERRY	53	15	15	-	-	-	-	0.44	0.41	18

3(B) Regional Entities Generation:

ISGS

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
KUDGI (3*800)	2400	1337	1265	2303	21:31	1243	09:03	36.03	33.4	1392
Neyveli TS I Expn (2*210)	420	579	635	644	03:38	288	12:24	7.48	6.67	278
Neyveli TS II (7*210)	1470	562	586	607	16:51	457	14:39	14.85	11.96	498
Neyveli TS II Expn (2*250)	500	145	120	199	22:12	95	13:33	3.94	3.28	137
NNTPS (2*500)	1000	659	661	721	05:14	500	12:45	15.6	13.66	569
NTPC-TELANGANA STPP (2*800)	1600	1475	1457	1531	20:53	781	09:07	30.12	28.08	1170
Ramagundam (3*200 + 4*500)	2600	1551	2220	2448	23:42	1321	09:34	44.92	41.81	1742
Simhadri Stage I (2*500)	1000	915	917	939	20:36	488	17:05	18.68	17.28	720
Simhadri Stage II (2*500)	1000	948	959	963	20:49	510	15:27	18.86	17.55	731
TALCHER ST2 (4*500)	2000	1863	1860	1887	20:32	1004	08:59	39.57	37.16	1548
Total Thermal	13990	10034	10680	-	-	-	-	230.05	210.85	8785
KAIGA STG1 (2*220)	440	202	205	207	02:25	195	07:26	4.97	4.47	186
KAIGA STG2 (2*220)	440	443	443	450	09:07	441	10:10	11.32	10.37	432
KUDANKULAM (2*1000)	2000	1986	2003	2019	10:02	1972	13:31	49.05	46.16	1923
MAPS (2*220)	440	207	213	215	05:29	206	15:19	5.09	4.21	175
Total Nuclear	3320	2838	2864	-	-	-	-	70.43	65.21	2716
Total ISGS	17310	12872	13544	-	-	-	-	300.48	276.06	11501

JOINT VENTURE

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
NTPL (2*500)	1000	587	533	939	23:11	488	09:56	15.9	14.95	623
Vallur TPS (3*500)	1500	1372	1356	1408	20:17	739	17:56	28.1	25.99	1083
Total Thermal	2500	1959	1889	-	-	-	-	44	40.94	1706
Total JOINT VENTURE	2500	1959	1889	-	-	-	-	44	40.94	1706

IPP UNDER OPEN ACCESS

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
COASTAL ENERGEN (2*600)	1200	0	1134	1147	03:25	582	10:38	22.26	20.66	861
IL&FS (2*600)	1200	995	594	1014	18:15	592	14:35	21.09	19.78	824
JINDAL POWER LIMITED (Simhapuri Unit) (4*150)	600	299	308	539	22:52	244	14:00	8.79	8.04	335
MEENAKSHI ENERGY LTD STAGE1 (2*150)	300	91	93	94	02:19	86	12:23	2.34	2.09	87
MEENAKSHI ENERGY LTD STAGE2 (2*350)	700	0	0	0	00:00	0	06:00	0	0	0
SEIL (2*660)	1320	1267	1267	1274	23:33	619	12:17	26.58	25.09	1045
SEIL-PROJECT2 (1*660)	660	622	627	630	02:05	272	09:24	13.22	12.51	521
Total Thermal	5980	3274	4023	-	-	-	-	94.28	88.17	3673
Greenko (6 * 240 + 2 * 120)	1680	1090	401	1228	23:37	0	07:32	10.03	9.97	415
GREENKO(Pump) (6 * 240 + 2 * 120)	1680	0	0	1580	08:58	0	06:00	12.6	12.63	526
Total Hydro	1680	1090	401	-	-	-	-	10.03	9.97	415
LKPPL ST2 (233 + 133)	366	0	0	0	00:00	0	06:00	0	0	0
LKPPL ST3 (2*233 + 2*133)	732	0	0	0	00:00	0	06:00	0	0	0

Total Gas	1098	0	0	-	-	-	-	0	0	0
Total IPP UNDER OPEN ACCESS	8758	4364	4424	-	-	-	-	104.31	98.14	4088

RENEWABLE WIND

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
GADAG_GreenInfra_W	55	0	0	0	00:00	0	06:00	0	0	0
GADAG_RSPPL_W	202	151	92	270	18:24	13	12:08	2.09	2.09	87
GADAG_Serentica3_W	52	86	44	184	18:33	0	15:20	1.28	1.28	53
GADAG_VENA_W	133	0	0	0	00:00	0	06:00	0	0	0
GREEN INFRA	250	174	62	231	16:53	21	08:48	2.2	2.2	92
Hiriyur_Ostro	300	175	92	234	18:58	29	09:58	1.89	1.89	79
HIRIYUR_ZREPL_W	66	89	49	112	19:04	14	15:03	0.98	0.98	41
JSW RENEW ENERGY TWO LTD	300	276	220	278	18:13	112	11:01	4.94	4.94	206
KARUR_JSWRENEW_W	162	133	100	153	16:24	11	07:36	2.02	2.02	84
Karur_JSWRETwo_W	150	127	109	136	16:11	30	07:34	2.25	2.25	94
KARUR_TPVARDHAMAN_W	50	182	173	190	20:16	54	07:53	3.55	3.55	148
KOPPAL_AyanaSix_W	300	217	102	259	17:41	11	12:36	1.87	1.87	78
KOPPAL_Kleio_W	101	40	6	68	17:45	9	08:20	0.5	0.5	21
Koppal_RenewOjas_W	322	177	58	273	18:11	1	16:20	1.8	1.8	75
Koppal_RenewRoshni_W	286	113	67	255	18:02	9	12:42	1.95	1.95	81
KOPPAL_SRI1PL_W	79	109	18	173	18:31	10	16:22	1.62	1.62	68
Kurnool_AMGreeen_W	304	196	119	286	22:41	30	11:21	2.6	2.6	108
MYTRA	250	157	140	209	16:54	75	09:53	3.44	3.44	143
ORANGE	200	128	45	183	16:59	17	07:10	1.9	1.9	79
PGLR_SAUPL_W	53	30	17	47	16:17	0	07:48	0.54	0.54	23
PGLR_SREPL	300	255	146	310	16:29	11	07:34	3.97	3.97	165
TuticorinJSWRenewW	540	481	460	488	18:12	219	10:00	9.8	9.8	408
VIVID SOLAIRE (BEETAM)	220	143	105	220	16:39	47	08:33	2.95	2.95	123
Total SR_Wind	4675	3439	2224	-	-	-	-	54.14	54.14	2256
Total RENEWABLE WIND	4675	3439	2224	-	-	-	-	54.14	54.14	2256

RENEWABLE SOLAR

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
ANP_AdaniAPSeven	250	0	0	239	14:54	1	06:00	1.26	1.26	53
ANP_ATHENA BIWADI	50	0	0	43	11:51	1	06:00	0.23	0.23	10
ANP_ATHENA HISAR	50	0	0	52	12:26	0	06:00	0.28	0.28	12
ANP_ATHENA KARNAL	50	0	0	46	12:26	0	06:00	0.27	0.27	11
ANP_AYANA	250	0	0	234	14:41	2	06:00	1.36	1.36	57
ANP_AZURE	50	0	0	45	12:32	0	06:04	0.26	0.26	11
ANP_IGS1	50	0	0	48	12:22	0	06:00	0.28	0.28	12
ANP_IGS2	50	0	0	49	14:29	0	06:00	0.32	0.32	13
ANP_NTPC	250	0	0	150	14:29	0	06:08	0.86	0.86	36
ANP_TATA	100	0	0	81	14:27	0	06:00	0.35	0.35	15
SPRING ANG ITRA	250	0	0	257	14:32	1	06:00	1.37	1.37	57
Total NP_KUNTA	1400	0	0	-	-	-	-	6.84	6.84	287
PVG_ADYAH	300	0	0	238	14:19	0	06:00	1.24	1.24	52
PVG_AMPLUS PAVAGADA	50	0	0	49	14:48	0	06:00	0.3	0.3	13
PVG_AMPLUS TUMKUR	50	0	0	49	10:25	0	06:00	0.3	0.3	13
PVG_AVAADA SOLAR	150	0	0	135	14:14	0	06:00	0.7	0.7	29
PVG_AVAADA SOLARISE	150	0	0	133	14:46	1	06:00	0.7	0.7	29
PVG_AZURE POWER EARTH	100	0	0	93	14:22	0	06:00	0.5	0.5	21
PVG_FORTUM FIN SURYA	100	0	0	79	14:49	0	06:00	0.41	0.41	17
PVG_IRCON_S	225	0	0	364	14:55	0	06:00	2.07	2.07	86
PVG_KREDL	50	0	0	41	13:29	0	06:00	0.27	0.27	11
PVG_PARAMPUJYA	150	0	0	123	14:46	1	06:00	0.67	0.67	28

PVG_RENEW TN2	50	0	0	46	14:49	0	06:00	0.31	0.31	13
PVG_SBG ENERGY	200	0	0	155	14:54	0	06:00	0.8	0.8	33
PVG_SPRING SOLAR INDIA	250	0	0	202	14:19	0	06:00	1.23	1.23	51
PVG_TATA RENEWABLES	400	0	0	303	14:58	0	06:00	1.77	1.77	74
PVG_YARROW	50	0	0	39	10:30	0	06:00	0.25	0.25	10
Total PAVAGADA	2275	0	0	-	-	-	-	11.52	11.52	480
GADAG_Serentica3_S	69	0	0	132	15:31	0	06:04	0.8	0.8	33
GADAG_VENA_S	31	0	0	0	00:00	0	06:00	0	0	0
GRT	150	0	0	136	14:02	0	06:00	0.83	0.83	35
HIRIYUR_ZREPL_S	94	0	0	75	14:56	0	06:00	0.48	0.48	20
KOPPAL_Kleio_S	105	0	0	74	15:43	0	06:01	0.38	0.38	16
KOPPAL_RenewOjas_S	81	0	0	68	09:18	0	06:00	0.41	0.41	17
KOPPAL_SRI1PL_S	188	0	0	180	15:28	0	17:36	0.99	0.99	41
KOPPAL_TPSAURYA_S	131	0	0	151	15:29	0	17:38	0.81	0.81	34
Kurnool3_SAEL1_S	300	0	0	294	10:23	0	06:00	2.01	2.01	84
Kurnool3_SAEL2_S	300	0	0	299	10:19	3	06:06	2.11	2.11	88
Kurnool_AMGreen_S	599	0	0	507	13:57	7	06:00	3.09	3.09	129
Kurnool_Greenko_S	300	0	0	470	12:32	5	06:00	2.92	2.92	122
NTPC ETTAYAPURAM SOLAR PLANT	230	0	0	221	13:40	0	06:00	1.4	1.4	58
RAMANGUNDAM (SOLAR)	100	0	0	96	10:45	0	17:48	0.64	0.64	27
SIMHADRI (SOLAR)	25	0	0	0	00:00	0	06:00	0	0	0
Total OTHER	2703	0	0	-	-	-	-	16.87	16.87	704
Total RENEWABLE SOLAR	6378	0	0	-	-	-	-	35.23	35.23	1471

RENEWABLE BESS

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
KOPPAL_RenewOjas_BESS (Discharge)	75	27	0	68	20:13	0	07:35	0.19	0.19	8
KOPPAL_RenewOjas_BESS (Charge)	75	0	46	75	03:30	0	06:00	0.25	0.25	10
Total SR_BESS	75	27	0	-	-	-	-	0.19	0.19	8
Total RENEWABLE BESS	75	27	0	-	-	-	-	0.19	0.19	8

Total ISGS IPP Thermal	22470	15267	16592	-	-	-	-	368.33	339.96	14164
Total State Thermal	30742	16286	18312	-	-	-	-	420.75	387.29	16137
Total ISGS IPP Hydro	1680	1090	401	-	-	-	-	10.03	9.97	415
Total State Hydro	14298	2237	1698	-	-	-	-	37.41	36.61	1530
Total Gas/Naptha/Diesel	6423	128	116	-	-	-	-	3.93	3.65	153
Total Nuclear	3320	2838	2864	-	-	-	-	70.43	65.21	2716
Total Wind	24146	10242	7057	-	-	-	-	175.91	175.91	7329
Total Solar	35435	6	10	-	-	-	-	154.91	154.91	6459
Total Others	4752	954	1184	-	-	-	-	19.28	19.28	803
Total BESS	75	27	0	-	-	-	-	0.19	0.19	8

4(A) INTER-REGIONAL EXCHANGES (Import=(+ve) /Export =(-ve))

SL.No.	Element	20:00	03:00	Maximum Interchange (MW)		Import in MU	Export in MU	NET
		MW	MW	Import	Export			
Import/Export between SOUTH REGION and EAST REGION								
1	220KV-UPPER_SILERU-BALIMELA	0	0	0.0	-	0	0	0
2	400KV-GAZUWAKA-JEYPORE	0	0	0.0	-	0	0	0
3	765KV-SRIKAKULAM-ANGUL	1819	1787	2185.0	-	37.96	0	37.96
4	HVDC500KV-TALCHER-KOLAR_DC	1136	1849	1855.0	-	36.82	0	36.82
Sub-Total EAST REGION		2955	3636	-	-	74.78	0	74.78
Import/Export between SOUTH REGION and WEST REGION								
1	220KV-AMBEWADI-PONDA	0	0	0.0	-	0	0	0
2	220KV-AMBEWADI-XELDEM	92	80	-	103.0	0	1.76	-1.76
3	220KV-CHIKKODI-MUDASANGI	0	0	0.0	-	0	0	0
4	220KV-CHIKKODI-TALANGADE	0	0	0.0	-	0	0	0

5	220KV-LOWER_SILERU-BARSUR	0	0	0.0	-	0	0	0
6	400KV-BHADRAVTAHI-RAMAGUNDAM	513	512	-	693.0	0	12.32	-12.32
7	400KV-KUDGI_PG-KHOLAPUR_PG	1464	1143	-	1902.0	0	33.44	-33.44
8	765KV-NIZAMABAD-WARDHA	860	660	1646.0	-	19.55	0	19.55
9	765KV-RAICHUR_PG-SHOLAPUR	518	495	-	1279.0	0	11.73	-11.73
10	765KV-WARANGAL(NEW)-WARORA	1006	982	1680.0	-	24.04	0	24.04
11	HVDC800KV-RAIGARH HVDC-PUGALUR HVDC	562	566	578.0	-	13.82	0	13.82
Sub-Total WEST REGION		5015	4438	-	-	57.41	59.25	-1.84
TOTAL IR EXCHANGE		7970	8074	-	-	132.19	59.25	72.94

4(B) Inter Regional Schedule & Actual Exchange (Import=(+ve) /Export =(-ve)) in MU

Link	ISGS+URS+GNA	TGNA	GDAM	DAM	HPDAM	RTM	Total IR Schedule	Total IR Actual	Net UI
East-South	26.4	-9.86	0	0	0	-0.19	-24.24	37.62	61.86
West-South	51.5	-2.22	-0.04	7.81	0	14.51	46.99	-1.84	-48.83
Total	77.9	-12.08	-0.04	7.81	0	14.32	22.75	35.78	13.03

5. Frequency Profile

RANGE(Hz)	< 48.8	< 49	< 49.2	< 49.5	< 49.7	< 49.9	>= 49.9 - <= 50.05	> 50	> 50.05
%	0	0	0	0	0.023	7.269	74.988	48.808	17.743

Max Freq		Min Freq		Avg Freq	Freq Variation Index	Standard Deviation	Freq in 15 mnt blk	
Freq (HZ)	Time	Freq (HZ)	Time				Max (Hz)	Min (Hz)
50.273	08:57:40	49.695	07:48:00	49.998	0.052	0.072	50.23	49.85

6(A). Voltage Profile: 765 kV

Station	Max		Min		Voltage (in %)			
	Voltage	Time	Voltage	Time	< 720	< 750	> 780	> 800
KURNOOL - 765KV	802	02:50	782	22:16	0	0	100	5.97
NIZAMABAD - 765KV	801	02:29	787	06:20	0	0	100	13.96
RAICHUR_PG - 765KV	796	02:30	777	14:23	0	0	85.14	0
SRIKAKULAM - 765KV	796	17:07	780	14:39	0	0	94.24	0

6(B). Voltage Profile: 400 kV

Station	Max		Min		Voltage (in %)			
	Voltage	Time	Voltage	Time	< 380	< 390	> 420	> 430
GHANAPUR - 400KV	426	18:04	415	14:44	0	0	51.46	0
GOOTY - 400KV	426	02:29	408	13:40	0	0	26.94	0
HIRIYUR - 400KV	428	02:29	410	12:49	0	0	37.22	0
KAIGA - 400KV	429	02:01	403	09:34	0	0	21.88	0
KOLAR_AC - 400KV	423	02:56	405	11:16	0	0	14.79	0
KUDANKULAM - 400KV	416	23:55	397	11:16	0	0	0	0
SHANKARAPALLY - 400KV	424	18:04	416	06:21	0	0	49.17	0
SOMANAHALLI - 400KV	427	02:45	405	11:16	0	0	26.94	0
SRIPERUMBADUR - 400KV	417	02:29	405	14:57	0	0	0	0
TRICHY - 400KV	412	23:36	400	09:02	0	0	0	0
TRIVANDRUM - 400KV	418	03:44	391	12:38	0	0	0	0
VIJAYAWADA - 400KV	423	18:04	406	14:57	0	0	8.06	0

6(C). Voltage Profile: 220 kV

Station	Max		Min		Voltage (in %)			
	Voltage	Time	Voltage	Time	< 198	< 210	> 235	> 245
GHANAPUR - 220KV	232	18:04	226	15:36	0	0	0	0
GOOTY - 220KV	233	02:40	225	12:53	0	0	0	0
HIRIYUR - 220KV	232	02:01	220	12:51	0	0	0	0
KAIGA - 220KV	237	02:03	221	12:53	0	0	9.93	0
KOLAR_AC - 220KV	231	06:05	221	08:35	0	0	0	0
SOMANAHALLI - 220KV	240	03:00	226	11:17	0	0	30.97	0

SRIPERUMBADUR - 220KV	230	07:58	218	00:01	0	0	0	0
TRICHY - 220KV	231	00:34	206	11:17	0	4.86	0	0
TRIVANDRUM - 220KV	231	03:54	229	00:00	0	0	0	0
VIJAYAWADA - 220KV	238	07:09	219	14:55	0	0	2.22	0

7. Major Reservoir Particulars

RESERVOIR	DESIGNED			PRESENT		LAST YEAR		LAST DAY		MONTH	
	MDDL (m)	FRL (m)	Energy (MU)	Level (m)	Energy (MU)	Level (m)	Energy (MU)	Inflow (MU)	Usage (MU)	Prog Inflow (MU)	Prog Usage (MU)
IDUKKI	694.94	732.43	2148	706.34	465	714.23	881	7.62	4.06	24.97	29.04
JALAPUT	818.39	838.4	534	825.34	128	831.52	273	0	0	1.79	0
KAKKI	908.3	981.45	916	939.81	125	962.99	403	4.43	1.33	22.74	10.2
LINGANAMAKKI	522.73	554.5	4557	533.43	550	537.9	990	3.76	8.16	8.61	62.87
N.SAGAR	149.3	179.9	1398	158.16	86	155.94	15	2.39	1.91	19.52	14.49
NILAGIRIS	0	0	1504	0	375	0	704	4.4	4.97	10.21	28.33
SRISAILAM	243.84	270.7	1392	249.54	60	254.63	146	0	0	0	0
SUPA	495	564	3159	526.1	673	529.76	829	0.62	4.54	1.29	32.84
Total	-	-	15608	-	2462	-	4241	23.22	24.97	89.13	177.77

8(A). Short-Term Open Access Details

State	Off- Peak Hours (03:00)												
	TGNA	IEX GDAM	IEX DAM	IEX HPDAM	IEX RTM	PXIL GDAM	PXIL DAM	PXIL HPDAM	PXIL RTM	HPX GDAM	HPX DAM	HPX HPDAM	HPX RTM
Andhra Pradesh	-18.76	-4.8	-47.6	0	6.18	0	0	0	0	0	0	0	0
Karnataka	-705.03	-76.6	-9.2	0	38.95	0	0	0	0	0	0	0	0
Kerala	0	0	-10.2	0	46.7	0	0	0	0	0	0	0	0
Puducherry	50.04	0	-83.1	0	-61	0	0	0	0	0	0	0	0
Tamil Nadu	3058.69	0	479.75	0	110.5	0	0	0	0	0	0	0	0
Telangana	-82.68	0	0.1	0	296.28	0	0	0	0	0	0	0	0
Total	2302.26	-81.4	329.75	0	437.61	0	0	0	0	0	0	0	0

State	Peak Hours (20:00)												
	TGNA	IEX GDAM	IEX DAM	IEX HPDAM	IEX RTM	PXIL GDAM	PXIL DAM	PXIL HPDAM	PXIL RTM	HPX GDAM	HPX DAM	HPX HPDAM	HPX RTM
Andhra Pradesh	-26.97	-3.8	255.03	0	494.87	0	0	0	0	0	0	0	0
Karnataka	-969.24	-90.5	57.46	0	-40.33	0	0	0	0	0	0	0	0
Kerala	0	0	57.61	0	463	0	0	0	0	0	0	0	0
Puducherry	57.96	0	0	0	-127	0	0	0	0	0	0	0	0
Tamil Nadu	2993.95	19.32	286.73	0	-1228.89	0	0	0	0	0	0	0	0
Telangana	-162.8	0	434.75	0	288.08	0	0	0	0	0	0	0	0
Total	1892.9	-74.98	1091.58	0	-150.27	0	0	0	0	0	0	0	0

State	Day Energy (MU)						
	ISGS+GNA	TGNA	GDAM	DAM	HPDAM	RTM	Total
Andhra Pradesh	55.77	0.36	1.03	10.08	0	14.6	81.84
Karnataka	94.03	-10.31	-1.43	0.41	0	1.63	84.33
Kerala	57.48	1.34	0.68	4.12	0	4.55	68.17
Puducherry	11.95	1.69	0	-1.61	0	-0.97	11.06
Tamil Nadu	191.63	42.22	1.27	-13.92	0	-32.27	188.93
Telangana	72.26	-0.88	0.39	2.52	0	18.76	93.05
Total	483.12	34.42	1.94	1.6	0	6.3	527.38

8(B). Short-Term Open Access Details

State	ISGS+GNA		TGNA		IEX GDAM		PXI GDAM		HPX GDAM		IEX DAM		PXI DAM	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
Andhra Pradesh	2992.19	1668.18	77.51	-44.53	145.02	-6.1	0	0	0	0	929.31	-422.43	0	0
Karnataka	5186.76	3118.25	-88.64	-975.24	28.97	-118	0	0	0	0	80.33	-39.8	0	0
Kerala	2946.13	1553.22	384.73	0	84.9	0	0	0	0	0	597.35	-10.2	0	0
Puducherry	592.69	356.27	91.09	48.21	0	0	0	0	0	0	0	-124	0	0
Tamil Nadu	8882.1	7051.49	3469.84	250.6	167.68	0	0	0	0	0	1109.9	-3782	0	0

Telangana	3766.77	1858.8	40.12	-162.8	37.63	-1.1	0	0	0	0	651.98	-50.9	0	0

State	HPX DAM		IEX HPDAM		PXI HPDAM		HPX HPDAM		IEX RTM		PXI RTM		HPX RTM	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
Andhra Pradesh	0	0	0	0	0	0	0	0	2010.89	-35.5	0	0	0	0
Karnataka	0	0	0	0	0	0	0	0	866.85	-405.73	0	0	0	0
Kerala	0	0	0	0	0	0	0	0	693.18	-1.6	0	0	0	0
Puducherry	0	0	0	0	0	0	0	0	100.45	-135	0	0	0	0
Tamil Nadu	0	0	0	0	0	0	0	0	539.03	-4260.95	0	0	0	0
Telangana	0	0	0	0	0	0	0	0	2578.66	-251.5	0	0	0	0

9. Synchronisation of new generating units:

SL.NO	Station Name	Owner	Inst. Capacity (MW)	Date	Time

10. Synchronisation of new 220 / 400 / 765 KV Transmission elements and energising of bus /substation:

11. Significant events (If any):

Nil

12. Constraints and instances of congestion in the transmission system

1) 400KV-KALPAKKA-KHAMMAM_PG-1 & 400KV-KALPAKKA-ASUPAKA-1 Lines Under S/D for replacement of badly damaged rusted towers from Loc No.1 to 11 in 400KV Kalapaka – Khammam along with stringing of conductor at 400kv SS Kalapaka. S/D availed on 05-05-2026 ,Expected to be restored on 26-06-2026.
2) 400KV Kaiga-Guttur 1&2 tripped on 14.05.2026 at 17:39Hrs due to the tower collapse in multiple locations.
3) 400KV-GAZUWAKA-JEYPORE-1,2 under shutdown for NH-130CD Diversion works (Between 130-133/150-153/179-180) availed on 15-05-2026 at 09:36 Hrs. Expected to restore by 16.06.2026 18:00 Hrs.
4) 220KV-GADAG_PSS-Vena_GadagPS-1 and 220KV-GADAG_PSS-Green Infra_GadagPS-1 tripped on 17-05-2026 at 16:14 Hrs due to the tower collapse Loc. No.32-36. Generation affected 237MW(I.C)
5) At 18:13 hrs of 23-05-2026, 400KV-GADAG_PSS-KOPPAL D/C tripped on Y-B fault due to tower collapse. total 15 number of tower Collapsed (Tower location number 52-66).
6) 400KV-NAGAPATTNAM_PS-TRICHY-1&2 tripped on 31.05.2026 at 17:05Hrs due to the tower collapse at loc. 437(DA), 438(DA), 439(DB) towers are collapsed and 435(DA),436(DA),440(DA), 441(DA) towers are found cross arm/earth peak damaged.
7) 400/220kV SOMANAHALLI ICT-1 tripped at 20:07 hours of 31-05-2026 due to REF, Differential & body protections.
8) 400KV/220KV VIJAYAWADA-ICT-2 tripped on 25.05.2026 due to the failure of 220kV B-ph bushing. Expected charging on 15.06.2026

13. Weather Condition

Andhra Pradesh: Rains reported in Guntur. Kerala: Rains reported throughout the state Tamil Nadu: Rains reported in Madurai area. Karnataka: Rains reported in coastal part and Bangalore.

14. RE/Load Curtailment details

State	Load Curtailment (Shortage)			RE Curtailment				
	Energy (MU)	Max (MW)	At the time of maximum demand	Wind Max (MW)	Wind Energy (MU)	Solar Max (MW)	Solar Energy (MU)	Reason
Andhra Pradesh	0	0	0	0	0	0	0	0
Karnataka	0	0	0	0	0	0	0	0
Kerala	0	0	0	0	0	0	0	0
Puducherry	0	0	0	0	0	0	0	0
Tamil Nadu	0	0	0	0	0	0	0	0
Telangana	0	0	0	0	0	0	0	0

15.Instances of persistant/significant non-complaint with grid code

State	Frequency and Deviation				Voltage				ICT loading			
	Alert	Emergency	Extreme Emergency	Non Compliance	Alert	Emergency	Extreme Emergency	Non Compliance	Alert	Emergency	Extreme Emergency	Non Compliance
Andhra Pradesh	0	0	0	0	3	0	0	0	0	0	0	0
Karnataka	1	1	0	0	2	0	0	0	0	0	0	0
Kerala	0	0	0	0	0	0	0	0	0	0	0	0
Puducherry	0	0	0	0	0	0	0	0	0	0	0	0
Tamil Nadu	1	2	0	1	1	5	0	0	0	2	0	0
Telangana	1	1	0	0	19	0	0	0	0	0	0	0