ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
GRID CONTROLLER OF INDIA LIMITED
क्षेत्रीय लोड प्रेषण केन्द्र
SOUTHERN REGIONAL LOAD DESPATCH CENTER

Date of Reporting: 09-Jun-2026

Power Supply Position Report For

08-Jun-2026

1. Regional Availability/Demand:

Evening Peak (20:00) MW				Off-Peak (03:00) MW				Day Energy (Net MU)	
Demand Met	Shortage	Requirement	Freq (Hz)	Demand Met	Shortage	Requirement	Freq (Hz)	Demand Met	Shortage #
54946	0	54946	50.1	44965	0	44965	50.04	1261.4	0

2(A) State's Load Deails (At State Periphery) in MUs:

State	State's Control Area Generation (Net MU)						Net SCH	Drawal	UI	Availability	Demand Met	Shortage #
	THERMAL	HYDRO	GAS/DIESEL /NAPTHA	WIND	SOLAR	OTHERS	(Net Mu)	(Net Mu)	(Net Mu)	(Net Mu)	(Net Mu)	(Net Mu)
Andhra Pradesh	134.29	4.58	0	29.97	17.12	2.4	74.37	72.54	-1.83	262.73	260.9	0
Karnataka	83.62	17.52	0	29.19	26.05	7.2	89.29	86.6	-2.69	252.87	250.18	0
Kerala	0	14.7	0	0.36	0.76	0.3	69.21	69.1	-0.11	85.33	85.22	0
Puducherry	0	0	0.36	0	0.07	0	11.45	11.39	-0.06	11.88	11.82	0
Tamil Nadu	86.03	6.21	3.36	78.4	47	8.53	199.71	195.59	-4.12	429.24	425.12	0
Telangana	100.17	2.21	0	0.88	19.55	5.46	101.18	99.89	-1.29	229.45	228.16	0
Total	404.11	45.22	3.72	138.8	110.55	23.89	545.21	535.11	-10.1	1271.5	1261.4	0

2(B) State's Demand Met in MWs and day energy forecast and deviation particulars

State	Evening Peak (20:00) MW			Off-Peak (03:00) MW			Average Demand	Day Energy (Net MU)	
	Demand Met	Shortage	Requirement	Demand Met	Shortage	Requirement	(MW)	Forecast (LGBR)	Deviation [Forecast - Consumption]
Andhra Pradesh	10630	0	10630	10353	0	10353	10882	269	-8.1
Karnataka	10883	0	10883	7602	0	7602	10396	264.87	-14.69
Kerala	4398	0	4398	2934	0	2934	3613	87.82	-2.6
Puducherry	543	0	543	438	0	438	481	11.8	0.02
Tamil Nadu	19122	0	19122	15656	0	15656	18088	430	-4.88
Telangana	9370	0	9370	7982	0	7982	9661	236	-7.84
Total	54946	0	54946	44965	0	44965	53121	1299.49	-38.09

2(C) State's Demand Met in MWs (maximum demand met and Maximum requirement of the day details)

State	Maximum Demand, corresponding shortage and requirement details for the day				Maximum requirement, corresponding shortage and demand details for the day				ACE			
	Maximum Demand Met	Time	Shortage at maximum demand	Requirement at the max demand met	Demand Met at maximum requiremnet	Time	Shortage at maximum Requirement	Maximum Requirement	Maximum ACE(MW)	Time	Minimum ACE(MW)	Time
Andhra Pradesh	13014	14:57	0	13014	13014	14:57	0	13014	1113.19	18:01	-379.33	18:52
Karnataka	12704	10:00	0	12704	12704	10:00	0	12704	967.02	23:22	-571.15	09:21
Kerala	4476	19:30	0	4476	4476	19:30	0	4476	682.31	14:56	-321.51	17:30
Puducherry	571	21:45	0	571	571	21:45	0	571	54.23	00:03	-32.79	15:25
Tamil Nadu	20332	22:30	0	20332	20332	22:30	0	20332	1576.04	08:01	-1477.65	09:32
Telangana	11376	15:12	0	11376	11376	15:12	0	11376	576.44	18:02	-664.63	22:28
Region	58916	15:15	0	58916	58916	15:15	0	58916	3555.14	23:59	-2789.81	18:38

3(A) State Entities Generation:

ANDHRA PRADESH

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
HINDUJA POWER CORPORATION LTD (2*520)	1040	992	1006	1025	07:04	541	12:04	21.28	20.04	835
KRISHNAPATTANAM (3*800)	2400	1986	1551	2013	20:28	1341	13:07	39.48	37.2	1550
RAYALASEEMA TPP (5*210 + 600)	1650	1256	937	1306	23:15	812	16:32	25.77	23.14	964
SEIL P2 Unit-2 (1*660)	660	625	625	632	13:46	340	09:38	14.56	13.77	574
VIJAYAWADA TPS (6*210 + 500 + 800)	2560	2003	1867	2074	22:47	1266	08:21	43.77	40.14	1673
Total Thermal	8310	6862	5986	-	-	-	-	144.86	134.29	5596

DONKARAYI (1*25)	25	0	0	0	00:00	0	06:00	0	0	0
HAMPI & T.B.DAM (8 * 9)	57	0	0	0	00:00	0	06:00	0	0	0
LOWER SILERU (4*115)	460	261	310	412	18:48	13	10:17	3.75	3.73	155
MACHKUND (3 * 17 + 3 * 23)	84	0	0	0	00:00	0	06:00	0	0	0
NAGARJUNASAGAR TAILPOND (2*25)	50	0	0	0	00:00	0	06:00	0	0	0
NSR RT.CANAL.P.H (3*30)	90	0	0	0	00:00	0	06:00	0	0	0
SRISAILAM RBPH (7*110)	770	0	0	0	00:00	0	06:00	0	0	0
UPPER SILERU (4*60)	240	0	54	144	12:41	0	08:26	0.85	0.84	35
OTHER HYDEL	124	0	0	0	00:00	0	06:00	0	0	0
Total Hydro	1900	261	364	-	-	-	-	4.6	4.57	190
GAUTAMI CCPP (2*145 + 174)	464	0	0	0	00:00	0	06:00	0	0	0
GMR (BARG) (1 * 237)	237	0	0	0	00:00	0	06:00	0	0	0
JEGURUPADU (GAS) (2*45.8 + 49.9 + 75.5)	217	0	0	0	00:00	0	06:00	0	0	0
Jegrupadu Ext. (1 * 220)	220	0	0	0	00:00	0	06:00	0	0	0
KONASEEMA CCPP (145 + 140 + 165)	450	0	0	0	00:00	0	06:00	0	0	0
LANCO (GAS) (2*115 + 121)	351	0	0	0	00:00	0	06:00	0	0	0
RELIANCE ENERGY LTD. (GAS) (140 + 80)	220	0	0	0	00:00	0	06:00	0	0	0
SPECTRUM (GAS) (46.8 + 2*46.1 + 68.8)	208	0	0	0	00:00	0	06:00	0	0	0
VEMAGIRI POWER GENERATION LTD.(GAS) (233 + 137)	370	0	0	0	00:00	0	06:00	0	0	0
VIJJESWARAM GTS (2*33 + 34 + 112.5 + 59.5)	272	0	0	0	00:00	0	06:00	0	0	0
OTHER GAS/NAPTHA/DIESEL	27	0	0	0	00:00	0	06:00	0	0	0
Total Gas	3036	0	0	-	-	-	-	0	0	0
WIND	4102	1471	1261	2208	17:56	467	06:32	29.97	29.97	1249
SOLAR	3965	2	1	2487	11:39	1	06:00	17.12	17.12	713
OTHERS	619	121	124	156	13:50	119	11:23	2.4	2.4	100
Total ANDHRA PRADESH	21932	8717	7736	-	-	-	-	198.95	188.35	7848

TELANGANA

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
BHADRADRI TPS (4*270)	1080	810	747	826	23:57	516	09:44	18.5	16.64	693
KAKATIYA ST1&ST2 (500 + 600)	1100	980	974	1046	17:30	534	12:36	22.55	21.26	886
KOTHAGUDEM TPS (2*250 + 500 + 800)	1800	1427	1067	1462	07:22	914	13:16	28.89	26.92	1122
RAMAGUNDAM-B (1*62.5)	63	0	0	0	00:00	0	06:00	0	0	0
SINGARENI TPS (2*600)	1200	1097	1100	1155	07:31	575	13:59	23.93	22.44	935
YADADRI (4*800)	3200	527	691	784	08:18	346	13:31	14.54	12.9	538
Total Thermal	8443	4841	4579	-	-	-	-	108.41	100.16	4174
L JURALA (6*40)	240	0	0	0	00:00	0	06:00	0	0	0
NAGARJUNA SAGAR (110 + 7*100.8)	816	0	0	619	22:13	0	06:00	2.23	2.21	92
NAGARJUNA SAGAR (Pump) (110 + 7*100.8)	816	108	0	434	07:25	107	06:00	3.36	3.36	140
NIZAMSAGAR (2*5)	10	0	0	0	00:00	0	06:00	0	0	0
NSR LT.CANAL.P.H (2*30)	60	0	0	0	00:00	0	06:00	0	0	0
POCHAMPAD (4*9)	36	0	0	0	00:00	0	06:00	0	0	0
PULICHINTALA (4*30)	120	0	0	0	00:00	0	06:00	0	0	0
SINGUR (2*7.5)	15	0	0	0	00:00	0	06:00	0	0	0
SRISAILAM LBPH (6*150)	900	0	0	0	00:00	0	06:00	0	0	0
SRISAILAM LBPH(Pump) (6*150)	900	0	0	0	00:00	0	06:00	0	0	0
U JURALA (6*39)	234	0	0	0	00:00	0	06:00	0	0	0
OTHER HYDEL	51	0	0	0	00:00	0	06:00	0	0	0
Total Hydro	2482	0	0	-	-	-	-	2.23	2.21	92
WIND	128	41	81	113	00:26	0	10:38	0.88	0.88	37
SOLAR	3848	0	0	2338	12:58	11	06:00	19.55	19.55	815
OTHERS	252	227	227	227	00:00	227	06:00	5.46	5.46	228
Total TELANGANA	15153	5109	4887	-	-	-	-	136.53	128.26	5346

KARNATAKA

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak	Min Generation (06:00 to 18:00)	Day Energy	Avg

	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
Bellary TPS (2*500 + 700)	1700	1488	935	1560	18:25	887	12:01	32.08	30.09	1254
JINDAL (2*130 + 4*300)	1460	943	822	1174	21:40	697	10:45	22.45	20.46	853
Jindal (Excl. Captive Consumption) (2 * 130 + 4 * 300)	1460	127	121	340	21:44	0	06:00	2.15	2.15	90
Raichur TPS (7*210 + 250)	1720	794	882	1054	06:29	723	11:49	22.81	20.38	849
UPCL (2*600)	1200	1117	614	1125	23:18	571	11:02	19.23	17.99	750
YERAMARAS TPS (2*800)	1600	597	470	909	21:48	421	11:32	14.39	13	542
Total Thermal	7680	4123	3022	-	-	-	-	90.66	83.61	3485
Almatty (15 + 5*55)	290	0	0	0	00:00	0	06:00	0	0	0
Bhadra (2*12.1 + 7 + 2 + 6)	39	0	0	0	00:00	0	06:00	0	0	0
Ghataprabha (2*16)	32	0	0	0	00:00	0	06:00	0	0	0
JOG (MGHES) (4*21.6 + 4*13.2)	139	56	51	64	08:05	35	17:29	1.25	1.23	51
LINGANAMAKKI.P.H. (2*27.5)	55	8	8	8	19:04	0	10:31	0.2	0.18	8
Kadra (3*50)	150	144	0	145	19:24	0	07:49	0.72	0.7	29
Kodasalli (3*40)	120	107	25	109	06:13	0	10:21	0.82	0.79	33
MANI DAM.P.H. (2*4.5)	9	1	1	1	11:21	1	14:50	0.04	0.03	1
Munirabad (3*9 + 10)	37	0	0	0	00:00	0	06:00	0	0	0
NAGJHERI (135 + 5*150)	885	417	123	446	21:24	0	10:05	3.1	3.04	127
SHARAVATHI (10*103.5)	1035	751	356	756	19:07	273	10:07	8.68	8.59	358
Sharavati Tail Race (4*60)	240	211	0	213	19:14	0	06:00	1.04	1.02	43
SIVANSAMUDRAM (6*3 + 4*6)	42	1	1	1	00:00	1	06:00	0.02	0.02	1
Supa (2*50)	100	0	0	0	00:00	0	06:00	0	0	0
U JURALA (6*39)	234	0	0	0	00:00	0	06:00	0	0	0
Varahi UGPH (4*115)	460	388	55	401	19:12	45	16:03	1.95	1.91	80
OTHER HYDEL	143	0	0	0	00:00	0	06:00	0	0	0
Total Hydro	4010	2084	620	-	-	-	-	17.82	17.51	731
OTHER GAS/NAPTHA/DIESEL	126	0	0	0	00:00	0	06:00	0	0	0
Total Gas	126	0	0	-	-	-	-	0	0	0
WIND	5676	1272	1376	2038	23:59	593	08:36	29.19	29.19	1216
SOLAR	7171	71	5	3689	11:52	5	06:00	26.05	26.05	1085
OTHERS	1832	100	87	119	09:30	58	12:56	7.2	7.2	300
Total KARNATAKA	26495	7650	5110	-	-	-	-	170.92	163.56	6817

KERALA

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
Idamalayar (2*37.5)	75	49	0	51	21:24	0	06:00	0.24	0.24	10
Iddukki (6*130)	780	592	30	760	20:35	29	14:39	3.09	3.07	128
Kakkad (2*25)	50	24	35	36	01:02	17	14:30	0.59	0.58	24
KALLADA (2*7.5)	15	3	7	8	08:21	1	09:58	0.04	0.04	2
Kuttiyadi (3*25)	75	197	0	198	19:36	0	06:00	1.06	1.05	44
Lower Periyar (3*60)	180	162	116	171	20:03	0	12:12	1.88	1.88	78
Neriamangalam (3*17.5 + 25)	78	70	70	71	16:38	16	14:48	1.48	1.47	61
PALLIVASAL (3*5 + 3*7.5)	38	0	0	0	00:00	0	06:00	0	0	0
PALLIVASAL EXTENSION SCHEME (2*30)	60	28	58	60	00:01	17	14:08	1.07	1.07	45
Panniar (2*16.2)	32	0	0	0	00:00	0	06:00	0.12	0.12	5
PORINGALKUTHU (4*9)	36	51	16	52	18:05	0	11:07	0.62	0.62	26
Sengulam (4*12.8)	51	37	32	51	08:48	6	13:29	0.72	0.72	30
Sholayar (3*18)	54	53	0	53	22:26	0	06:00	0.36	0.36	15
Sabarigiri (4*55 + 2*60)	340	177	25	213	22:36	0	07:29	1.16	1.16	48
THOTTIYAR HEP (2*20)	40	38	10	40	09:27	9	07:53	0.71	0.71	30
OTHER HYDEL	230	173	34	228	22:08	0	06:00	1.61	1.61	67
Total Hydro	2134	1654	433	-	-	-	-	14.75	14.7	613
BRAHMAPURAM DGPP (DIESEL) (3*21.32)	64	0	0	0	00:00	0	06:00	0	0	0
BSES (NAPTHA) (3*40.5 + 35.5)	157	0	0	0	00:00	0	06:00	0	0	0
KOZHIKODE DPP (DIESEL) (6*16)	96	0	0	0	00:00	0	06:00	0	0	0
MPS STEEL CASTINGS (1 * 10)	10	0	0	0	00:00	0	06:00	0	0	0

RGCCPP KAYAMKULAM (KSEB) - NTPC (2*116.6 + 126.38)	360	0	0	0	00:00	0	06:00	0	0	0
OTHER GAS/NAPTHA/DIESEL	22	0	0	0	00:00	0	06:00	0	0	0
Total Gas	709	0	0	-	-	-	-	0	0	0
WIND	70	9	2	21	20:59	2	09:09	0.36	0.36	15
SOLAR	1988	0	0	138	13:56	0	06:09	0.76	0.76	32
OTHERS	20	10	3	154	13:56	7	06:20	0.3	0.3	13
Total KERALA	4921	1673	438	-	-	-	-	16.17	16.12	673

TAMIL NADU

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
Mettur TPS (4*210 + 600)	1440	788	996	1155	23:00	768	15:32	27.3	25.04	1043
NORTH CHENNAI TPS STG-III (1*800)	800	475	28	529	12:46	2	07:45	7.6	6.83	285
NORTH CHENNAI TPS STG-II (2*600)	1200	613	623	750	22:45	591	11:24	16.78	15.4	642
North Chennai TPS (3*210)	630	366	403	497	01:46	352	10:25	11.18	10.64	443
UDANGUDI(Infirm - 660MW)	0	221	221	221	00:00	221	06:00	5.98	5.3	221
OPG PGPL (2*77 + 80 + 180)	414	300	253	335	23:34	299	08:36	6.79	6.16	257
SEPC (1*525)	525	0	0	0	00:00	0	06:00	0	0	0
ST - CMS (1*250)	250	210	213	225	21:52	74	16:18	5.38	4.94	206
Tuticorin (5*210)	1050	437	565	586	11:01	434	16:25	12.9	11.72	488
Total Thermal	6309	3410	3302	-	-	-	-	93.91	86.03	3585
Kadamparai (4*100)	400	0	0	40	15:50	0	06:00	0	0	0
Kadamparai (Pump) (4*100)	400	0	1	110	08:36	0	06:14	0.34	0.34	14
Kodayar I (1*60)	60	0	0	0	00:00	0	06:00	0	0	0
Kodayar II (1*40)	40	40	40	40	00:00	40	06:00	0.87	0.86	36
Kundah I (3*20)	60	1	35	53	06:09	2	08:02	0.51	0.51	21
Kundah II (5*35)	175	16	107	175	10:33	16	17:11	1.18	1.17	49
Kundah III (3*60)	180	12	72	112	10:21	6	12:08	0.87	0.86	36
Kundah IV (2*50)	100	0	0	0	00:00	0	06:00	0.05	0.05	2
Kundah V (2*20)	40	20	3	23	06:38	3	06:00	0.35	0.34	14
Kundah VI (1*30)	30	0	0	0	00:00	0	06:00	0	0	0
Mettur Dam (4*12.5)	50	0	0	0	08:22	0	06:00	0.21	0.2	8
Mettur Tunnel (4*50)	200	0	0	0	00:00	0	06:00	0	0	0
Moyar (3*12)	36	4	4	28	09:57	4	11:31	0.14	0.14	6
PAPANASAM (4*8)	32	6	6	30	10:23	6	06:00	0.17	0.17	7
Periyar (4*35)	140	28	24	29	23:33	24	06:25	0.64	0.63	26
Pykara (3*6.65 + 11 + 2*14)	59	8	2	10	12:05	2	06:00	0.09	0.09	4
PYKARA ULTIMATE (3*50)	150	0	0	151	10:21	0	06:00	0.53	0.52	22
Sarkarpathy (1*30)	30	12	13	13	08:36	12	15:12	0.3	0.3	13
Servalar (1*20)	20	16	0	16	18:20	0	06:00	0.06	0.06	3
Sholayar I (2*42)	84	0	0	0	00:00	0	06:00	0	0	0
Sholayar II (1*25)	25	0	0	0	00:00	0	06:00	0	0	0
Suruliyar (1*35)	35	0	0	0	00:00	0	06:00	0	0	0
OTHER HYDEL	1826	80	5	395	12:38	2	06:08	0.29	0.29	12
Total Hydro	3772	243	311	-	-	-	-	6.26	6.19	259
BASIN BRIDGE (NAPTHA) (4*30)	120	0	0	0	00:00	0	06:00	0	0	0
KOVIL KALAPPAL (GAS) (70 + 37.88)	108	0	0	0	00:00	0	06:00	0	0	0
KUTTALAM (GAS) (64 + 37)	101	77	86	86	06:44	73	13:12	1.94	1.81	75
MADURAI POWER CL (DIESEL) (1 * 106)	106	0	0	0	00:00	0	06:00	0	0	0
P P NALLUR (NAPTHA) (1 * 330.5)	331	0	0	0	00:00	0	06:00	0	0	0
SAMALPATTY (DIESEL) (7 * 15.1)	106	0	0	0	00:00	0	06:00	0	0	0
VALATTUR(STG1&STG2) (2*60 + 35 + 32)	187	28	8	56	13:52	12	06:21	1.67	1.55	65
OTHER GAS/NAPTHA/DIESEL	362	0	0	0	00:00	0	06:00	0	0	0
Total Gas	1421	105	94	-	-	-	-	3.61	3.36	140
WIND	9495	3148	1272	4547	15:07	2028	06:00	78.4	78.4	3267
SOLAR	12065	0	0	6342	12:43	56	06:01	47	47	1958
OTHERS	2029	637	537	654	16:15	521	06:12	8.53	8.53	355

Total TAMIL NADU	35091	7543	5516	-	-	-	-	237.71	229.51	9564

PUDUCHERRY

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
KARAIKAL POWER PLANT (GAS) (1 * 22.9 + 1 * 9.6)	33	15	15	15	00:00	15	06:00	0.38	0.36	15
Total Gas	33	15	15	-	-	-	-	0.38	0.36	15
SOLAR	20	0	0	10	12:31	0	06:00	0.07	0.07	3
Total PUDUCHERRY	53	15	15	-	-	-	-	0.45	0.43	18

3(B) Regional Entities Generation:

ISGS

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
KUDGI (3*800)	2400	2023	1349	2278	22:40	1243	06:50	36.32	33.87	1411
Neyveli TS I Expn (2*210)	420	685	620	743	18:34	125	14:24	7.52	6.68	278
Neyveli TS II (7*210)	1470	752	565	766	19:11	562	10:37	17.55	14.26	594
Neyveli TS II Expn (2*250)	500	170	194	216	06:17	96	14:54	4.36	3.65	152
NNTPS (2*500)	1000	632	670	708	05:47	451	13:47	15.51	13.38	558
NTPC-TELANGANA STPP (2*800)	1600	1420	1489	1534	02:43	791	14:42	30.98	28.91	1205
Ramagundam (3*200 + 4*500)	2600	2301	2290	2436	21:43	1320	14:53	46.36	43.15	1798
Simhadri Stage I (2*500)	1000	915	901	938	01:56	488	16:11	19.33	17.92	747
Simhadri Stage II (2*500)	1000	888	928	967	01:52	505	14:40	19.3	17.99	750
TALCHER ST2 (4*500)	2000	1820	1858	1893	02:09	996	11:58	42.38	39.91	1663
Total Thermal	13990	11606	10864	-	-	-	-	239.61	219.72	9156
KAIGA STG1 (2*220)	440	205	199	207	07:27	195	07:35	4.98	4.48	187
KAIGA STG2 (2*220)	440	449	442	451	22:09	434	12:39	11.29	10.34	431
KUDANKULAM (2*1000)	2000	1995	1991	2015	17:09	1971	12:46	49.12	46.08	1920
MAPS (2*220)	440	210	209	216	23:54	193	10:07	5.05	4.1	171
Total Nuclear	3320	2859	2841	-	-	-	-	70.44	65	2709
Total ISGS	17310	14465	13705	-	-	-	-	310.05	284.72	11865

JOINT VENTURE

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
NTPL (2*500)	1000	870	503	949	23:13	492	14:48	15.79	14.86	619
Vallur TPS (3*500)	1500	1281	1352	1383	05:04	721	15:53	29.09	26.94	1123
Total Thermal	2500	2151	1855	-	-	-	-	44.88	41.8	1742
Total JOINT VENTURE	2500	2151	1855	-	-	-	-	44.88	41.8	1742

IPP UNDER OPEN ACCESS

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
COASTAL ENERGEN (2*600)	1200	1131	0	1152	20:03	0	06:00	23.74	22.11	921
IL&FS (2*600)	1200	992	992	1006	05:52	591	10:03	21.04	19.72	822
JINDAL POWER LIMITED (Simhapuri Unit) (4*150)	600	530	467	544	20:24	249	11:26	10.04	9.19	383
MEENAKSHI ENERGY LTD STAGE1 (2*150)	300	94	93	95	22:52	63	12:31	2.25	2.02	84
MEENAKSHI ENERGY LTD STAGE2 (2*350)	700	288	14	302	23:50	117	06:13	4.5	4.16	173
SEIL (2*660)	1320	1250	1063	1274	01:46	603	11:00	27.79	26.36	1098
SEIL-PROJECT2 (1*660)	660	629	619	631	01:58	269	09:03	13.44	12.71	530
Total Thermal	5980	4914	3248	-	-	-	-	102.8	96.27	4011
Greenko (6 * 240 + 2 * 120)	1680	1162	423	1273	23:03	0	07:29	10.85	10.85	452
GREENKO(Pump) (6 * 240 + 2 * 120)	1680	0	0	1569	08:29	0	06:00	12.24	12.26	511
Total Hydro	1680	1162	423	-	-	-	-	10.85	10.85	452
LKPPL ST2 (233 + 133)	366	0	0	0	00:00	0	06:00	0	0	0
LKPPL ST3 (2*233 + 2*133)	732	0	0	0	00:00	0	06:00	0	0	0

Total Gas	1098	0	0	-	-	-	-	0	0	0
Total IPP UNDER OPEN ACCESS	8758	6076	3671	-	-	-	-	113.65	107.12	4463

RENEWABLE WIND

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
GADAG_GreenInfra_W	55	0	0	0	00:00	0	06:00	0	0	0
GADAG_RSPPL_W	202	56	78	266	17:11	5	15:03	2.11	2.11	88
GADAG_Serentica3_W	52	27	49	170	17:38	5	15:21	1.26	1.26	53
GADAG_VENA_W	133	0	0	0	00:00	0	06:00	0	0	0
GREEN INFRA	250	183	16	243	10:45	28	06:14	3.46	3.46	144
Hiriyur_Ostro	300	0	112	166	01:34	0	07:50	1.07	1.07	45
HIRIYUR_ZREPL_W	66	60	63	112	16:34	21	12:02	1.29	1.29	54
JSW RENEW ENERGY TWO LTD	300	273	51	283	18:38	128	06:01	5.15	5.15	215
KARUR_JSWRENEW_W	162	145	54	154	12:54	24	06:01	2.69	2.69	112
Karur_JSWRETwo_W	150	132	86	136	15:09	53	06:44	2.59	2.59	108
KARUR_TPVARDHAMAN_W	50	181	83	191	23:52	71	06:02	3.7	3.7	154
KOPPAL_AyanaSix_W	300	58	81	229	18:23	21	07:54	2.23	2.23	93
KOPPAL_Kleio_W	101	20	33	57	18:09	7	07:37	0.7	0.7	29
Koppal_RenewOjas_W	322	56	45	233	18:01	20	14:58	1.64	1.64	68
Koppal_RenewRoshni_W	286	52	39	253	16:58	6	15:05	1.9	1.9	79
KOPPAL_SRI1PL_W	79	95	122	154	23:52	27	14:00	1.94	1.94	81
Kurnool_AMGreeen_W	304	272	18	279	19:52	31	06:25	3.03	3.03	126
MYTRA	250	181	26	220	10:30	128	06:01	3.64	3.64	152
ORANGE	200	124	8	183	10:42	26	06:14	2.49	2.49	104
PGLR_SAUPL_W	53	23	6	47	11:58	6	07:06	0.62	0.62	26
PGLR_SREPL	300	235	66	309	13:44	40	06:01	4.96	4.96	207
TuticorinJSWRenewW	540	484	316	490	20:15	404	06:06	10.41	10.41	434
VIVID SOLAIRE (BEETAM)	220	170	9	220	10:37	64	06:00	3.13	3.13	130
Total SR_Wind	4675	2827	1361	-	-	-	-	60.01	60.01	2502
Total RENEWABLE WIND	4675	2827	1361	-	-	-	-	60.01	60.01	2502

RENEWABLE SOLAR

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
ANP_AdaniAPSeven	250	0	0	229	11:18	0	06:00	1.31	1.31	55
ANP_ATHENA BIWADI	50	0	0	40	10:22	0	06:00	0.23	0.23	10
ANP_ATHENA HISAR	50	0	0	49	11:07	0	06:02	0.26	0.26	11
ANP_ATHENA KARNAL	50	0	0	45	13:32	0	06:02	0.23	0.23	10
ANP_AYANA	250	0	0	218	11:18	1	06:00	1.35	1.35	56
ANP_AZURE	50	0	0	40	11:17	0	06:00	0.29	0.29	12
ANP_IGS1	50	0	0	45	13:30	0	06:00	0.23	0.23	10
ANP_IGS2	50	0	0	50	10:23	0	06:00	0.26	0.26	11
ANP_NTPC	250	0	0	128	11:15	0	06:15	0.81	0.81	34
ANP_TATA	100	0	0	86	11:13	0	06:00	0.46	0.46	19
SPRING ANG ITRA	250	0	0	257	11:14	1	06:00	1.29	1.29	54
Total NP_KUNTA	1400	0	0	-	-	-	-	6.72	6.72	282
PVG_ADYAH	300	0	0	277	11:17	6	06:00	1.59	1.59	66
PVG_AMPLUS PAVAGADA	50	0	0	52	11:02	1	06:00	0.31	0.31	13
PVG_AMPLUS TUMKUR	50	0	0	53	11:18	1	06:00	0.31	0.31	13
PVG_AVAADA SOLAR	150	0	0	149	12:24	1	06:00	0.83	0.83	35
PVG_AVAADA SOLARISE	150	0	0	153	12:21	1	06:00	0.84	0.84	35
PVG_AZURE POWER EARTH	100	0	0	100	11:59	0	06:00	0.56	0.56	23
PVG_FORTUM FIN SURYA	100	0	0	97	12:33	0	06:00	0.54	0.54	23
PVG_IRCON_S	225	0	0	396	12:18	0	06:00	2.4	2.4	100
PVG_KREDL	50	0	0	45	12:04	0	06:00	0.26	0.26	11
PVG_PARAMPUJYA	150	0	0	126	13:13	1	06:00	0.81	0.81	34

PVG_RENEW TN2	50	0	0	50	12:15	0	06:00	0.31	0.31	13
PVG_SBG ENERGY	200	0	0	182	11:52	0	06:00	1.11	1.11	46
PVG_SPRING SOLAR INDIA	250	0	0	243	12:20	0	06:00	1.39	1.39	58
PVG_TATA RENEWABLES	400	0	0	341	12:24	1	06:00	2.15	2.15	90
PVG_YARROW	50	0	0	47	11:33	0	06:00	0.25	0.25	10
Total PAVAGADA	2275	0	0	-	-	-	-	13.66	13.66	570
GADAG_Serentica3_S	69	0	0	155	13:05	0	06:01	0.86	0.86	36
GADAG_VENA_S	31	0	0	0	00:00	0	06:00	0	0	0
GRT	150	0	0	153	13:18	0	06:00	0.87	0.87	36
HIRIYUR_ZREPL_S	94	0	0	87	12:08	0	06:00	0.52	0.52	22
KOPPAL_Kleio_S	105	0	0	92	11:04	0	06:09	0.45	0.45	19
KOPPAL_RenewOjas_S	81	0	0	71	12:22	0	06:00	0.41	0.41	17
KOPPAL_SRI1PL_S	188	0	0	181	11:05	0	06:03	0.85	0.85	35
KOPPAL_TPSAURYA_S	131	0	0	190	11:07	0	06:02	0.91	0.91	38
Kurnool3_SAEL1_S	300	0	0	304	12:06	0	06:00	1.69	1.69	70
Kurnool3_SAEL2_S	300	0	0	292	12:13	0	06:00	1.84	1.84	77
Kurnool_AMGreen_S	599	0	0	554	12:22	0	06:03	3.76	3.76	157
Kurnool_Greenko_S	300	0	0	471	10:53	0	06:00	3.07	3.07	128
NTPC ETTAYAPURAM SOLAR PLANT	230	0	0	234	09:44	0	06:00	1.36	1.36	57
RAMANGUNDAM (SOLAR)	100	0	0	97	11:46	0	06:05	0.66	0.66	28
SIMHADRI (SOLAR)	25	0	0	0	00:00	0	06:00	0	0	0
Total OTHER	2703	0	0	-	-	-	-	17.25	17.25	720
Total RENEWABLE SOLAR	6378	0	0	-	-	-	-	37.63	37.63	1572

RENEWABLE BESS

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
KOPPAL_RenewOjas_BESS (Discharge)	75	57	0	76	19:31	0	07:33	0.22	0.22	9
KOPPAL_RenewOjas_BESS (Charge)	75	0	46	75	23:55	0	06:00	0.29	0.29	12
Total SR_BESS	75	57	0	-	-	-	-	0.22	0.22	9
Total RENEWABLE BESS	75	57	0	-	-	-	-	0.22	0.22	9

Total ISGS IPP Thermal	22470	18671	15967	-	-	-	-	387.29	357.79	14909
Total State Thermal	30742	19236	16889	-	-	-	-	437.84	404.09	16840
Total ISGS IPP Hydro	1680	1162	423	-	-	-	-	10.85	10.85	452
Total State Hydro	14298	4242	1728	-	-	-	-	45.66	45.18	1885
Total Gas/Naptha/Diesel	6423	120	109	-	-	-	-	3.99	3.72	155
Total Nuclear	3320	2859	2841	-	-	-	-	70.44	65	2709
Total Wind	24146	8768	5353	-	-	-	-	198.81	198.81	8286
Total Solar	35435	73	6	-	-	-	-	148.18	148.18	6178
Total Others	4752	1095	978	-	-	-	-	23.89	23.89	996
Total BESS	75	57	0	-	-	-	-	0.22	0.22	9

4(A) INTER-REGIONAL EXCHANGES (Import=(+ve) /Export =(-ve))

SL.No.	Element	20:00	03:00	Maximum Interchange (MW)		Import in MU	Export in MU	NET
		MW	MW	Import	Export			
Import/Export between SOUTH REGION and EAST REGION								
1	220KV-UPPER_SILERU-BALIMELA	0	0	0.0	-	0	0	0
2	400KV-GAZUWAKA-JEYPORE	0	0	0.0	-	0	0	0
3	765KV-SRIKAKULAM-ANGUL	1569	1847	2337.0	-	38.52	0	38.52
4	HVDC500KV-TALCHER-KOLAR_DC	1847	1849	1857.0	-	40.66	0	40.66
Sub-Total EAST REGION		3416	3696	-	-	79.18	0	79.18
Import/Export between SOUTH REGION and WEST REGION								
1	220KV-AMBEWADI-PONDA	0	0	0.0	-	0	0	0
2	220KV-AMBEWADI-XELDEM	92	75	-	97.0	0	1.84	-1.84
3	220KV-CHIKKODI-MUDASANGI	0	0	0.0	-	0	0	0
4	220KV-CHIKKODI-TALANGADE	0	0	0.0	-	0	0	0

5	220KV-LOWER_SILERU-BARSUR	0	0	0.0	-	0	0	0
6	400KV-BHADRAVTAHI-RAMAGUNDAM	930	988	-	990.0	0	22.65	-22.65
7	400KV-KUDGI_PG-KHOLAPUR_PG	1448	1268	-	2049.0	0	33.61	-33.61
8	765KV-NIZAMABAD-WARDHA	669	734	1887.0	-	20.43	0	20.43
9	765KV-RAICHUR_PG-SHOLAPUR	564	333	-	1890.0	0	11.7	-11.7
10	765KV-WARANGAL(NEW)-WARORA	842	1056	2056.0	-	24.44	0	24.44
11	HVDC800KV-RAIGARH HVDC-PUGALUR HVDC	561	561	576.0	-	13.97	0	13.97
Sub-Total WEST REGION		5106	5015	-	-	58.84	69.8	-10.96
TOTAL IR EXCHANGE		8522	8711	-	-	138.02	69.8	68.22

4(B) Inter Regional Schedule & Actual Exchange (Import=(+ve) /Export =(-ve)) in MU

Link	ISGS+URS+GNA	TGNA	GDAM	DAM	HPDAM	RTM	Total IR Schedule	Total IR Actual	Net UI
East-South	28.55	-7.8	0	0	0	0	-20.99	39.27	60.26
West-South	52.46	-0.98	1.97	19.55	0	-6.16	53.09	-10.96	-64.05
Total	81.01	-8.78	1.97	19.55	0	-6.16	32.1	28.31	-3.79

5. Frequency Profile

RANGE(Hz)	< 48.8	< 49	< 49.2	< 49.5	< 49.7	< 49.9	>= 49.9 - <= 50.05	> 50	> 50.05
%	0	0	0	0	0.15	4.56	72.581	61.088	22.859

Max Freq		Min Freq		Avg Freq	Freq Variation Index	Standard Deviation	Freq in 15 mnt blk	
Freq (HZ)	Time	Freq (HZ)	Time				Max (Hz)	Min (Hz)
50.183	08:00:00	49.672	12:40:30	50.01	0.039	0.062	50.14	49.76

6(A). Voltage Profile: 765 kV

Station	Max		Min		Voltage (in %)			
	Voltage	Time	Voltage	Time	< 720	< 750	> 780	> 800
KURNOOL - 765KV	798	03:58	775	10:17	0	0	92.57	0
NIZAMABAD - 765KV	795	03:58	779	06:36	0	0	90.76	0
RAICHUR_PG - 765KV	791	03:54	768	10:16	0	0	57.85	0
SRIKAKULAM - 765KV	795	18:02	770	15:15	0	0	83.33	0

6(B). Voltage Profile: 400 kV

Station	Max		Min		Voltage (in %)			
	Voltage	Time	Voltage	Time	< 380	< 390	> 420	> 430
GHANAPUR - 400KV	425	03:35	407	15:38	0	0	22.71	0
GOOTY - 400KV	424	03:54	403	10:16	0	0	19.58	0
HIRIYUR - 400KV	427	03:03	407	09:46	0	0	30.56	0
KAIGA - 400KV	425	03:02	409	11:53	0	0	22.78	0
KOLAR_AC - 400KV	422	03:54	394	09:51	0	0	2.92	0
KUDANKULAM - 400KV	416	02:18	397	10:24	0	0	0	0
SHANKARAPALLY - 400KV	423	03:58	413	14:59	0	0	17.64	0
SOMANAHALLI - 400KV	425	04:00	394	10:00	0	0	20	0
SRIPERUMBADUR - 400KV	418	02:55	399	10:16	0	0	0	0
TRICHY - 400KV	412	03:03	400	07:13	0	0	0	0
TRIVANDRUM - 400KV	420	03:09	391	10:18	0	0	0	0
VIJAYAWADA - 400KV	420	03:53	406	15:29	0	0	0.69	0

6(C). Voltage Profile: 220 kV

Station	Max		Min		Voltage (in %)			
	Voltage	Time	Voltage	Time	< 198	< 210	> 235	> 245
GHANAPUR - 220KV	232	03:59	221	15:29	0	0	0	0
GOOTY - 220KV	233	04:02	223	10:04	0	0	0	0
HIRIYUR - 220KV	231	03:03	219	10:12	0	0	0	0
KAIGA - 220KV	235	08:04	223	06:42	0	0	0.69	0
KOLAR_AC - 220KV	230	03:02	214	10:23	0	0	0	0
SOMANAHALLI - 220KV	240	03:03	218	10:01	0	0	27.36	0

SRIPERUMBADUR - 220KV	230	03:29	212	14:41	0	0	0	0
TRICHY - 220KV	229	18:03	211	10:22	0	0	0	0
TRIVANDRUM - 220KV	232	03:04	229	06:18	0	0	0	0
VIJAYAWADA - 220KV	239	18:04	220	22:26	0	0	1.18	0

7. Major Reservoir Particulars

RESERVOIR	DESIGNED			PRESENT		LAST YEAR		LAST DAY		MONTH	
	MDDL (m)	FRL (m)	Energy (MU)	Level (m)	Energy (MU)	Level (m)	Energy (MU)	Inflow (MU)	Usage (MU)	Prog Inflow (MU)	Prog Usage (MU)
IDUKKI	694.94	732.43	2148	706.49	472	714.09	873	8.22	1.38	33.19	32.11
JALAPUT	818.39	838.4	534	825.37	129	831.46	271	0.51	0	2.3	0
KAKKI	908.3	981.45	916	940.99	135	962.77	398	10.48	0.7	33.22	11.36
LINGANAMAKKI	522.73	554.5	4557	533.38	546	537.77	977	4.74	7.88	14.33	71.46
N.SAGAR	149.3	179.9	1398	158.07	83	179.07	958	2.26	2.49	21.78	16.7
NILAGIRIS	0	0	1504	0	476	0	702	3.81	2.55	14.01	32.02
SRISAILAM	243.84	270.7	1392	249.63	61	268.53	904	1.08	0	1.08	0
SUPA	495	564	3159	526.11	674	529.63	824	0.59	3.29	1.84	35.88
Total	-	-	15608	-	2576	-	5907	31.69	18.29	121.75	199.53

8(A). Short-Term Open Access Details

State	Off- Peak Hours (03:00)												
	TGNA	IEX GDAM	IEX DAM	IEX HPDAM	IEX RTM	PXIL GDAM	PXIL DAM	PXIL HPDAM	PXIL RTM	HPX GDAM	HPX DAM	HPX HPDAM	HPX RTM
Andhra Pradesh	-59.17	-5.7	-24.7	0	403.65	0	0	0	0	0	0	0	0
Karnataka	-936.24	-7.33	-15.9	0	-18.86	0	0	0	0	0	0	0	0
Kerala	0	0	-10.7	0	38.94	0	0	0	0	0	0	0	0
Puducherry	57.89	0	-106	0	-14	0	0	0	0	0	0	0	0
Tamil Nadu	2563.88	0	-24.5	0	300.88	0	0	0	0	0	0	0	0
Telangana	-160.48	0	329.83	0	223.47	0	0	0	0	0	0	0	0
Total	1465.88	-13.03	148.03	0	934.08	0	0	0	0	0	0	0	0

State	Peak Hours (20:00)												
	TGNA	IEX GDAM	IEX DAM	IEX HPDAM	IEX RTM	PXIL GDAM	PXIL DAM	PXIL HPDAM	PXIL RTM	HPX GDAM	HPX DAM	HPX HPDAM	HPX RTM
Andhra Pradesh	-54.57	-4.9	71.52	0	-541.4	0	0	0	0	0	0	0	0
Karnataka	-1177.94	-90.65	-17.42	0	-89.39	0	0	0	0	0	0	0	0
Kerala	71.63	0	-10.7	0	123.74	0	0	0	0	0	0	0	0
Puducherry	57.89	0	0	0	-53	0	0	0	0	0	0	0	0
Tamil Nadu	3678.61	8.88	540.8	0	-431.39	0	0	0	0	0	0	0	0
Telangana	-162.31	0	364.02	0	866.33	0	0	0	0	0	0	0	0
Total	2413.31	-86.67	948.22	0	-125.11	0	0	0	0	0	0	0	0

State	Day Energy (MU)						
	ISGS+GNA	TGNA	GDAM	DAM	HPDAM	RTM	Total
Andhra Pradesh	56.62	0.04	0.96	13.77	0	2.98	74.37
Karnataka	104.5	-14	-1.56	0.66	0	-0.3	89.3
Kerala	57.66	1.9	0.67	5.35	0	3.63	69.21
Puducherry	12.16	1.72	0	-1.47	0	-0.97	11.44
Tamil Nadu	192.67	45.36	1.82	-13.45	0	-26.68	199.72
Telangana	77.6	-1.17	0.64	7.05	0	17.05	101.17
Total	501.21	33.85	2.53	11.91	0	-4.29	545.21

8(B). Short-Term Open Access Details

State	ISGS+GNA		TGNA		IEX GDAM		PXI GDAM		HPX GDAM		IEX DAM		PXI DAM	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
Andhra Pradesh	3134.42	1860.92	78.65	-68.03	162.99	-6.1	0	0	0	0	1317.95	-408.34	0	0
Karnataka	5594.2	3197	-86.1	-1181.34	8.94	-117.27	0	0	0	0	93.83	-34.7	0	0
Kerala	2671.93	1722.52	378.73	0	73.41	0	0	0	0	0	611.05	-10.7	0	0
Puducherry	562.3	388.38	91.06	57.89	0	0	0	0	0	0	0	-123	0	0
Tamil Nadu	9074.77	6910.55	4046.5	263.49	203.94	0	0	0	0	0	1417.71	-3319.82	0	0

Telangana	4712.81	2253.71	55.01	-162.31	87.51	-0.7	0	0	0	0	1535.61	-46	0	0

State	HPX DAM		IEX HPDAM		PXI HPDAM		HPX HPDAM		IEX RTM		PXI RTM		HPX RTM	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
Andhra Pradesh	0	0	0	0	0	0	0	0	668.66	-742.8	0	0	0	0
Karnataka	0	0	0	0	0	0	0	0	471.83	-344.65	0	0	0	0
Kerala	0	0	0	0	0	0	0	0	929.55	-2	0	0	0	0
Puducherry	0	0	0	0	0	0	0	0	0	-117	0	0	0	0
Tamil Nadu	0	0	0	0	0	0	0	0	307.64	-3482.85	0	0	0	0
Telangana	0	0	0	0	0	0	0	0	1587.57	-101.8	0	0	0	0

9. Synchronisation of new generating units:

SL.NO	Station Name	Owner	Inst. Capacity (MW)	Date	Time

10. Synchronisation of new 220 / 400 / 765 KV Transmission elements and energising of bus /substation:

11. Significant events (If any):

At 07:49 hours, 220kV Ostro_Kannada-Hiriyur line got tripped on R-N Fault due to heavy rain and lightning, resulting in loss of power supply to 220kV Ostro_Kannada S/S.

12. Constraints and instances of congestion in the transmission system

1) 400KV-KALPAKKA-KHAMMAM_PG-1 & 400KV-KALPAKKA-ASUPAKA-1 Lines Under S/D for replacement of badly damaged rusted towers from Loc No.1 to 11 in 400KV Kalapaka – Khammam along with stringing of conductor at 400kv SS Kalapaka. S/D availed on 05-05-2026 ,Expected to be restored on 26-06-2026.
2) 400KV Kaiga-Guttur 1&2 tripped on 14.05.2026 at 17:39Hrs due to the tower collapse in multiple locations.
3) 400KV-GAZUWAKA-JEYPORE-1,2 under shutdown for NH-130CD Diversion works (Between 130-133/150-153/179-180) availed on 15-05-2026 at 09:36 Hrs. Expected to restore by 16.06.2026 18:00 Hrs.
4) 220KV-GADAG_PSS-Vena_GadagPS-1 and 220KV-GADAG_PSS-Green Infra_GadagPS-1 tripped on 17-05-2026 at 16:14 Hrs due to the tower collapse Loc. No.32-36. Generation affected 237MW(I.C)
5) At 18:13 hrs of 23-05-2026, 400KV-GADAG_PSS-KOPPAL D/C tripped on Y-B fault due to tower collapse. total 15 number of tower Collapsed (Tower location number 52-66).
6) 400KV-NAGAPATTNAM_PS-TRICHY-1&2 tripped on 31.05.2026 at 17:05Hrs due to the tower collapse at loc. 437(DA), 438(DA), 439(DB) towers are collapsed and 435(DA),436(DA),440(DA), 441(DA) towers are found cross arm/earth peak damaged.
7) 400/220kV SOMANAHALLI ICT-1 tripped at 20:07 hours of 31-05-2026 due to REF, Differential & body protections.
8) 400KV/220KV VIJAYAWADA-ICT-2 tripped on 25.05.2026 due to the failure of 220kV B-ph bushing. Expected charging on 15.06.2026

13. Weather Condition

Andhra Pradesh: Moderate rains reported in Kurnool area.
Karnataka: Moderate rains reported in Coastal part, Belagom, Raichur, Manvi area.

14. RE/Load Curtailment details

State	Load Curtailment (Shortage)			RE Curtailment				
	Energy (MU)	Max (MW)	At the time of maximum demand	Wind Max (MW)	Wind Energy (MU)	Solar Max (MW)	Solar Energy (MU)	Reason
Andhra Pradesh	0	0	0	0	0	0	0	0
Karnataka	0	0	0	0	0	0	0	0
Kerala	0	0	0	0	0	0	0	0
Puducherry	0	0	0	0	0	0	0	0
Tamil Nadu	0	0	0	0	0	0	0	0
Telangana	0	0	0	0	0	0	0	0

15.Instances of persistant/significant non-complaint with grid code

State	Frequency and Deviation				Voltage				ICT loading			
	Alert	Emergency	Extreme Emergency	Non Compliance	Alert	Emergency	Extreme Emergency	Non Compliance	Alert	Emergency	Extreme Emergency	Non Compliance
Andhra Pradesh	0	0	0	0	0	0	0	0	5	7	0	0
Karnataka	0	1	0	0	0	0	0	0	11	5	0	0
Kerala	0	0	0	0	0	0	0	0	0	0	0	0
Puducherry	0	0	0	0	0	0	0	0	0	0	0	0
Tamil Nadu	0	0	0	0	9	3	0	0	6	10	0	0
Telangana	0	1	0	0	0	0	0	0	0	0	0	0