GRID CONTROLLER OF INDIA LIMITED
SOUTHERN REGIONAL LOAD DESPATCH CENTRE
DAILY OPERATION REPORT OF SOUTHERN REGION

Power Supply Position in Southern Region For 02-Jun-2026

Date of Reporting:03-Jun-2026

1. Regional Availability/Demand:

Evening Peak (20:00) MW				Off-Peak (03:00) MW				Day Energy(Net MU)	
Demand Met	Shortage(-)/Surplus(+) #	Requirement	Freq (Hz)	Demand Met	Shortage(-)/Surplus(+) #	Requirement	Freq (Hz)	Demand Met	Shortage #
54,543	0	54,543	49.91	49,052	0	49,052	50.05	1,304.2	0.37

* MW Availabilty indicated above includes SR ISTS Loss.

2(A)State's Load Deails (At State Periphery) in MUs:

STATE	State's Control Area Generation (Net MU)						Net SCH	Drawal	UI	Availability	Demand Met	Shortage #
	THERMAL	HYDRO	GAS/DIESEL/ NAPTHA	WIND	SOLAR	OTHERS	(Net Mu)	(Net Mu)	(Net Mu)	(Net MU)	(Net MU)	(Net MU)
ANDHRA PRADESH	142.99	4.94	0	16.91	18.91	2.27	69.37	67.88	-1.49	255.39	253.9	0
KARNATAKA	90.79	27.4	0	25.89	32.88	8.28	96.36	94.43	-1.94	281.6	279.67	0
KERALA	0	19.6	0	0.36	1.13	0.3	72.44	74.12	1.68	93.83	95.51	0.37
PONDICHERRY	0	0	0.36	0	0.06	0	11.15	11.24	0.09	11.57	11.65	0
TAMILNADU	86.34	9.25	3.32	26.01	51.3	8.3	234.78	237.58	2.8	419.3	422.1	0
TELANGANA	95.85	3.3	0	0.25	23.5	3.82	114.89	114.65	-0.24	241.61	241.37	0
Region	415.97	64.49	3.68	69.42	127.78	22.97	598.99	599.9	0.9	1,303.3	1,304.2	0.37

The accuracy of shortage computation depends on timely load shedding details furnished in the web directly by constituents

2(B)State's Demand Met in MWs and day energy forecast and deviation particulars

State	Evening Peak (20:00) MW			Off-Peak (03:00) MW			Average Demand	Day Energy(Net MU)	
	Demand Met	Shortage(-)/Surplus(+) #	Requirement at Evening peak	Demand Met	Shortage(-)/Surplus(+) #	Requirement at Off-Peak	(MW)	ForeCast (LGBR) (mus)	Deviation[Forecast(LGBR) -Consumption] (mus)
ANDHRA PRADESH	10,477	0	10,477	9,820	0	9,820	10,612	254	-0.1
KARNATAKA	10,862	0	10,862	9,042	0	9,042	11,567	270.11	9.56
KERALA	4,722	0	4,722	3,659	0	3,659	4,091	93.11	2.77
PONDICHERRY	512	0	512	447	0	447	475	11.8	-0.15
TAMILNADU	18,445	0	18,445	17,048	0	17,048	17,966	412	10.1
TELANGANA	9,525	0	9,525	9,036	0	9,036	10,272	239	2.37
Region	54,543	0	54,543	49,052	0	49,052	54,983	1,280.02	24.55

2(C)State's Demand Met in MWs (maximum demand met and Maximum requirement of the day details)

State	Maximum Demand, corresponding shortage and requirement details for the day				Maximum requirement, corresponding shortage and demand details for the day				ACE			
	Maximum Demand Met of the day	Time	Shortage(-) /Surplus(+) during at maximum demand	Requirement at the max demand met of the day	Demand Met at maximum requiremnet	Time	Shortage(-) /Surplus(+) during at maximum Requirement	Maximum Requirement of the day	Maximum ACE(MW)	Time	Minimum ACE(MW)	Time
AP	13,018	14:52	0	13,018	13,018	14:52	0	13,018	843.71	08:01	-1,138.23	10:43
KAR	13,848	15:00	-	13,848	13,848	15:00	-	13,848	939.87	11:04	-612.39	18:01
KER	4,863	19:18	0	4,863	4,863	19:18	0	4,863	220.41	19:17	-695.86	18:58
PONDY	552	22:30	0	552	552	22:30	0	552	77.26	10:58	-43.46	21:45
TN	19,198	22:00	0	19,198	19,198	22:00	0	19,198	1,676.43	16:01	-2,040.06	22:17
TG	12,074	15:33	0	12,074	12,074	15:33	0	12,074	701.19	20:32	-732.3	22:17
Region	62,957	14:53:28	0	62,957	62,957	14:53:28	0	62,957	2,389.2	11:02	-3,971.54	22:17

3(A) State Entities Generation:

ANDHRA PRADESH

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
HINDUJA POWER CORPORATION LTD(2 * 520)	1,040	1,032	1,035	1,049	00:08	576	10:26	21.93	20.76	865
KRISHNAPATTANAM (3 * 800)	2,400	1,808	1,492	1,939	01:20	1,337	16:34	39.47	37.14	1,548
RAYALASEEMA TPP(1 * 600 + 5 * 210)	1,650	1,433	1,156	1,482	20:21	892	11:24	28.89	26.14	1,089
SEIL P2 UNIT-2(1 * 660)	660	623	627	635	10:13	337	08:20	15.31	14.48	603
VIJAYAWADA TPS(1 * 800 + 1 * 500 + 6 * 210)	2,560	2,156	2,094	2,178	22:54	1,464	13:00	48.14	44.46	1,853
OTHER THERMAL	0	0	0	0	00:00	0	-	-	-	-
Total THERMAL	8,310	7,052	6,404	-	-	-	-	153.74	142.98	5,958
HAMPI	36	0	0	0	00:00	0	-	0	0	0
LOWER SILERU(4 * 115)	460	410	10	411	19:56	9	02:10	3.34	3.32	138
SRISAILAM RBPH(7 * 110)	770	0	0	0	00:00	0	01:17	0	0	0
UPPER SILERU(4 * 60)	240	0	0	164	11:17	0	08:40	1.58	1.57	65
OTHER HYDEL	431	2	1	2	00:00	0	-	0.04	0.04	2
Total HYDEL	1,937	412	11	-	-	-	-	4.96	4.93	205
GAUTAMI CCPP(1 * 174 + 2 * 145)	464	0	0	0	00:00	0	00:00	0	0	0
GMR (BARG)(1 * 237)	237	0	0	0	00:00	0	00:00	0	0	0
JEGURUPADU (GAS)(1 * 49.9 + 1 * 75.5 + 2 * 45.8)	217	0	0	0	00:00	0	00:00	0	0	0
JEGRUPADU EXT.(1 * 220)	220	0	0	0	00:00	0	-	-	-	-
KONASEEMA CCPP(1 * 140 + 1 * 145 + 1 * 165)	450	0	0	0	00:00	0	00:00	0	0	0
LANCO (GAS)(1 * 121 + 2 * 115)	351	0	0	0	00:00	0	00:00	0	0	0
RELIANCE ENERGY LTD. (GAS)(1 * 140 + 1 * 80)	220	0	0	0	00:00	0	00:00	0	0	0
SPECTRUM (GAS)(1 * 46.8 + 1 * 68.8 + 2 * 46.1)	208	0	0	0	00:00	0	00:00	0	0	0
VEMAGIRI POWER GENERATION LTD.(GAS)(1 * 137 + 1 * 233)	370	0	0	0	00:00	0	-	0	0	0

VIJJESWARAM GTS(1 * 112.5 + 1 * 34 + 1 * 59.5 + 2 * 33)	272	0	0	0	00:00	0	00:00	0	0	0
OTHER GAS/NAPTHA/DIESEL	27	0	0	0	00:00	0	-	-	-	-
Total GAS/NAPTHA/DIESEL	3,036	0	0	-	-	-	-	0	0	0
WIND	4,084	777	1,256	1,945	23:48	229	15:09	16.91	16.91	705
SOLAR	3,356	0	0	2,550	11:23	0	23:07	18.91	18.91	788
OTHERS	619	121	125	164	01:08	119	00:00	2.27	2.27	95
Total AP	21,342	8,362	7,796	-	-	-	-	196.79	186	7,751

TELANGANA

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
BHADRADRI TPS(4 * 270)	1,080	866	810	911	23:52	515	13:39	19.55	17.67	736
KAKATIYA ST1&ST2(1 * 500 + 1 * 600)	1,100	1,004	1,020	1,068	07:58	549	12:03	22.96	21.65	902
KOTHAGUDEM TPS(1 * 500 + 1 * 800 + 2 * 250)	1,800	1,247	1,083	1,285	22:22	795	09:23	29.63	27.59	1,150
RAMAGUNDAM-B(1 * 62.5)	63	0	0	0	00:00	0	00:00	0	0	0
SINGARENI TPS(2 * 600)	1,200	555	566	604	23:36	315	09:17	12.08	11.03	460
YADADRI(4 * 800)	3,200	880	758	1,082	22:41	721	06:30	19.5	17.91	746
Total THERMAL	8,443	4,552	4,237					103.72	95.85	3,994
NAGARJUNA SAGAR(1 * 110 + 7 * 100.8)	816	0	0	137	00:00	0	00:00	3.32	3.3	138
NAGARJUNA SAGAR (PUMP)(1 * 110 + 7 * 100.8)	816	0	0	150	00:00	0	00:00	0	3.6	150
SRISAILAM LBPH(6 * 150)	900	0	0	0	00:00	1	18:39	0	0	0
SRISAILAM LBPH(PUMP)(6 * 150)	900	0	0	0	00:00	1	23:34	0	0	0
OTHER HYDEL	957	0	0	0	00:00	0	00:00	0	0	0
Total HYDEL	2,673	0	0					3.32	3.3	138
WIND	128	0	0	10	00:00	0	-	0.25	0.25	10
SOLAR	3,818	0	0	2,734	12:00	0	00:00	23.5	23.5	979
OTHERS	252	0	0	159	00:00	0	-	3.82	3.82	159
Total TG	15,314	4,552	4,237					134.61	126.72	5,280

KARNATAKA

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
BELLARY TPS(1 * 700 + 2 * 500)	1,700	1,489	1,318	1,504	20:35	899	11:31	33.44	31.39	1,308
JINDAL(2 * 130 + 4 * 300)	1,460	0	0	289	02:36	0	-	22.12	20.26	70
JINDAL (EXCL. CAPTIVE CONSUMPTION)(2 * 130 + 4 * 300)	1,460	149	124	289	02:36	0	03:47	1.69	1.69	70
RAICHUR TPS(1 * 250 + 7 * 210)	1,720	898	820	935	23:58	722	12:17	21.85	19.53	814
UPCL(2 * 600)	1,200	1,104	790	1,137	18:31	590	14:55	24.79	23.37	974
YERAMARAS TPS(2 * 800)	1,600	647	644	699	16:21	428	12:14	15.86	14.8	617
Total THERMAL	7,680	4,287	3,696	-	-	-	-	97.63	90.78	3,009
NAGJHERI(1 * 135 + 5 * 150)	885	437	141	444	09:33	132	15:21	6.89	6.79	283
SHARAVATHI(10 * 103.5)	1,035	793	377	863	07:05	299	11:12	12.68	12.62	526
VARAHI UGPH(4 * 115)	460	75	54	398	07:05	44	08:00	2.35	2.31	96
OTHER HYDEL	2,137	493	162	493	00:49	105	00:43	5.81	5.69	237
Total HYDEL	4,517	1,798	734	-	-	-	-	27.73	27.41	1,142
OTHER GAS/NAPTHA/DIESEL	126	0	0	0	00:00	1	00:00	0	0	0
Total GAS/NAPTHA/DIESEL	126	0	0	-	-	-	-	0	0	0
WIND	5,440	1,418	1,449	2,088	21:37	345	14:14	25.89	25.89	1,079
SOLAR	6,571	0	0	4,428	11:14	6	18:42	32.88	32.88	1,370
OTHERS	1,832	87	41	1,715	13:15	31	08:45	8.28	8.28	1,715
Total KAR	26,166	7,590	5,920	-	-	-	-	192.41	185.24	8,315

KERALA

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
IDDUKKI(6 * 130)	780	634	751	758	00:07	28	08:44	9.25	9.22	384
LOWER PERIYAR (3 * 60)	180	44	0	170	21:11	0	02:10	0.86	0.86	36
SABARIGIRI(2 * 60 + 4 * 55)	340	212	232	239	00:08	0	06:39	2.72	2.71	113
OTHER HYDEL	834	450	140	450	01:08	91	00:00	6.83	6.81	284
Total HYDEL	2,134	1,340	1,123	-	-	-	-	19.66	19.6	817
BRAHMAPURAM DGPP (DIESEL)(3 * 21.32)	64	0	0	0	00:00	3	10:32	0	0	0
BSES (NAPTHA)(1 * 35.5 + 3 * 40.5)	157	0	0	0	00:00	0	00:00	-	-	-
KOZHIKODE DPP (DIESEL)(6 * 16)	96	0	0	0	00:00	0	00:00	0	0	0
MPS STEEL CASTINGS(1 * 10)	10	0	0	0	00:00	0	-	-	-	-
RGCCPP KAYAMKULAM (KSEB) - NTPC(1 * 126.38 + 2 * 116.6)	360	0	0	0	00:00	1	13:24	0	0	0
OTHER GAS/NAPTHA/DIESEL	22	0	0	0	00:00	0	00:00	-	-	-
Total GAS/NAPTHA/DIESEL	709	0	0	-	-	-	-	0	0	0
WIND	70	0	0	15	00:00	0	-	0.36	0.36	15
SOLAR	1,988	0	0	47	00:00	0	-	1.13	1.13	47
OTHERS	20	0	0	13	00:00	0	-	0.3	0.3	13
Total KER	4,921	1,340	1,123	-	-	-	-	21.45	21.39	892

TAMIL NADU

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
METTUR TPS(1 * 600 + 4 * 210)	1,440	1,372	1,367	1,390	06:56	1,000	15:51	29.19	26.9	1,121
NORTH CHENNAI TPS STG-II(2 * 600)	1,200	689	678	803	17:50	634	00:36	17.83	16.44	685
NORTH CHENNAI TPS STG-III(1*800)	800	509	596	521	20:00	0	-	13.29	12.5	521
NORTH CHENNAI TPS(3 * 210)	630	475	469	489	18:09	376	10:54	12	9.7	404
OPG PGPL(2*77+80+180)	414	303	333	303	20:00	0	-	7.07	6.43	268
SEPC(1 * 525)	525	0	0	0	00:00	8	00:12	0	0	0
ST - CMS(1 * 250)	250	250	250	250	01:08	190	08:06	5.34	4.9	204
TUTICORIN(5 * 210)	1,050	569	376	577	23:06	0	00:00	10.55	9.47	395
UDANGUDI(INFIRM*660)	0	0	0	0	00:00	0	-	0	0	0
Total THERMAL	6,309	4,167	4,069					95.27	86.34	3,598
KADAMPARAI (4 * 100)	400	0	0	40	00:00	0	15:57	0.97	0.96	40
KADAMPARAI (PUMP)(4 * 100)	400	0	0	0	00:00	0	08:43	0	0	0
OTHER HYDEL	1,826	301	204	345	09:22	28	01:07	8.37	8.29	345
Total HYDEL	2,226	301	204					9.34	9.25	385
BASIN BRIDGE (NAPTHA)(4 * 30)	120	0	0	0	00:00	0	00:00	0	0	0
KOVIL KALAPPAL (GAS)(1 * 37.8 + 1 * 70)	108	0	0	0	00:00	0	00:31	0	0	0
KUTTALAM (GAS)(1 * 37 + 1 * 64)	101	70	70	73	01:08	70	00:00	1.89	1.76	73
MADURAI POWER CL (DIESEL)(1 * 106)	106	0	0	0	00:00	0	00:00	0	0	0
P P NALLUR (NAPTHA)(1 * 330.5)	331	0	0	0	00:00	0	00:00	0	0	0
SAMALPATTY (DIESEL)(7 * 15.1)	106	0	0	0	00:00	0	00:00	0	0	0
VALATTUR(STG1&STG2)(1 * 32 + 1 * 35 + 2 * 60)	187	29	33	66	11:57	25	21:38	1.69	1.57	65
OTHER GAS/NAPTHA/DIESEL	196	0	0	0	00:00	0	-	0	0	0
OTHER GAS/NAPTHA/DIESEL	166	0	0	0	00:00	0	00:00	0	0	0
Total GAS/NAPTHA/DIESEL	1,421	99	103					3.58	3.33	138
WIND	9,392	1,163	944	2,724	15:51	387	07:25	26.01	26.01	1,084
SOLAR	9,555	0	0	8,247	12:04	0	00:00	51.3	51.3	2,138
OTHERS	2,029	650	700	700	01:08	620	00:00	8.3	8.3	346
Total TN	30,932	6,380	6,020					193.8	184.53	7,689

3(B) Regional Entities Generation

ISGS

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Get(MU)	
KUDGI(3 * 800)	2,400	1,617	1,370	1,637	22:34	853	06:35	28.87	26.82	1,118
NEYVELI TS I EXPN (2 * 210)	420	157	157	157	05:29	157	00:00	3.89	3.51	146
NEYVELI TS II(7 * 210)	1,470	685	542	724	22:22	512	08:39	17.65	14.09	587
NEYVELI TS II EXPN (2 * 250)	500	0	0	0	00:00	9	00:00	0	0	0
NNTPS(2 * 500)	1,000	346	683	707	00:22	289	18:33	13.93	11.86	494
NTPC-TELANGANA STPP(2*800)	1,600	1,538	1,471	1,538	20:00	0	-	32.75	30.65	1,277
RAMAGUNDAM(3 * 200 + 4 * 500)	2,600	1,887	847	2,427	23:45	591	07:06	28.95	26.56	1,107
SIMHADRI STAGE I(2 * 500)	1,000	939	890	950	21:44	485	08:24	20.32	18.93	789
SIMHADRI STAGE II(2 * 500)	1,000	949	892	971	21:42	500	08:14	20.54	19.18	799
TALCHER ST2(4 * 500)	2,000	1,885	1,860	1,907	18:23	1,058	11:24	43.08	40.66	1,694
Total THERMAL	13,990	10,003	8,712	-	-	-	-	209.98	192.26	8,011
KAIGA STG1(2 * 220)	440	187	189	194	02:18	180	09:13	4.99	4.49	187
KAIGA STG2(2 * 220)	440	420	424	434	18:06	416	00:07	11.35	10.41	434
KUDANKULAM(2 * 1000)	2,000	2,037	2,042	2,060	19:17	2,022	09:45	49.09	46.2	1,925
MAPS(2 * 220)	440	171	171	177	08:11	132	14:48	5.03	4.08	170
Total NUCLEAR	3,320	2,815	2,826	-	-	-	-	70.46	65.18	2,716
Total ISGS	17,310	12,818	11,538					280.44	257.44	10,727

JOINT VENTURE

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Get(MU)	
NTPL(2 * 500)	1,000	452	855	942	01:40	423	19:19	16.18	15.25	635
VALLUR TPS(3 * 500)	1,500	1,338	1,334	1,406	00:10	745	07:55	30.27	28.23	1,176
Total THERMAL	2,500	1,790	2,189	-	-	-	-	46.45	43.48	1,811
Total JOINT_VENTURE	2,500	1,790	2,189					46.45	43.48	1,811

IPP UNDER OPEN ACCESS

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Get(MU)	
COASTAL ENERGEN(2 * 600)	1,200	1,143	1,041	1,158	23:33	674	08:22	24.13	22.51	938
IL&FS(2 * 600)	1,200	561	517	573	22:28	299	15:56	11.77	11	458
JINDAL POWER LIMITED (SIMHAPURI UNIT)(4 * 150)	600	524	528	542	22:39	252	10:05	10.98	9.81	409
MEENAKSHI ENERGY LTD STAGE1(2 * 150)	300	149	150	152	02:42	61	12:44	2.18	1.96	82
MEENAKSHI ENERGY LTD STAGE2(2 * 350)	700	0	0	241	00:00	0	-	6.37	5.79	241
SEIL P1(2 * 660)	1,320	1,254	1,253	1,270	18:09	733	09:52	28.88	27.4	1,142
SEIL P2 UNIT-1(1 * 660)	660	629	626	633	23:34	298	08:59	13.88	13.11	546
Total THERMAL	5,980	4,260	4,115	-	-	-	-	98.19	91.58	3,816
GREENKO	1,200	0	0	436	00:00	21	08:27	10.41	10.47	436
GREENKO(PUMP)	1,200	0	0	0	17:37	27	07:46	12.32	12.34	514
Total HYDEL	1,200	0	0	-	-	-	-	10.41	10.47	436
LKPPL ST2(1 * 133 + 1 * 233)	366	4	4	339	01:12	6	02:16	0.59	0.58	24
LKPPL ST3(2 * 133 + 2 * 233)	732	0	0	0	00:00	0	-	0	0	0
Total GAS/NAPTHA/DIESEL	1,098	4	4	-	-	-	-	0.59	0.58	24
Total REGIONAL_IPP	8,278	4,264	4,119					109.19	102.63	4,276

RENEWABLE WIND

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Get(MU)	
GADAG_GREENINFRA_W	55	0	0	0	00:00	0	00:00	0	0	0
GADAG_RSPPL_W	175	89	101	84	20:00	236	21:33	2.01	2.01	84
GADAG_SERENTICA3_W	52	0	0	62	00:00	0	-	1.48	1.48	62
GADAG_VENA_W	133	0	0	0	00:00	0	-	0	0	0
GREEN INFRA(1 * 249.90)	250	0	0	105	21:28	1	20:26	0.28	0.28	12
HIRIYUR_OSTRO(1 *300.3)	300	0	0	101	00:00	0	00:00	2.43	2.43	101
HIRIYUR_ZREPL_W	66	77	71	77	20:00	0	-	1.03	1.03	43
JSW RENEW ENERGY TWO LTD	300	126	3	269	17:06	0	03:49	1.85	1.85	77
KARUR_JSWRENEW_W	162	9	10	13	20:00	0	-	0.31	0.31	13
KARUR_JSWRETWO_W	150	0	0	8	00:00	0	-	0.19	0.19	8
KARUR_TPVARDHAMAN_W	50	17	1	17	20:00	0	-	0.18	0.18	8
KOPPAL_AYANASIX_W	300	112	154	112	20:00	0	-	2.45	2.45	102
KOPPAL_KLEIO_W	101	27	40	27	20:00	0	-	0.56	0.56	23
KOPPAL_RENEWOJAS_W	319	0	101	218	23:13	5	17:50	2	2	83
KOPPAL_RENEWROSHNI_W	291	50	81	237	17:16	3	13:51	1.67	1.67	70
KOPPAL_SRI1PL_W	79	111	147	111	20:00	0	-	1.82	1.82	76
KURNOOL_AMGREEEN_W	304	0	0	112	00:00	0	00:00	2.68	2.68	112
MYTRA(1 * 250)	250	48	15	180	16:48	0	06:15	0.95	0.95	40
ORANGE(1 * 200)	200	111	0	185	16:50	2	04:08	1.64	1.64	68
PGLR_SAUPL_W	53	0	1	2	03:00	0	-	0.05	0.05	2
PGLR_SREPL(1 * 300)	300	0	0	14	00:00	0	00:00	0.33	0.33	14
TUTICORINJSWRENEWW(1 * 51.3)	540	201	73	201	20:00	0	-	4.31	4.31	180
VIVID SOLAIRE (BEETAM)(1 * 220)	220	76	3	210	17:27	1	07:51	1.38	1.38	58
Total RENEWABLE_WIND	4,650	1,054	801					29.6	29.6	1,236

RENEWABLE SOLAR

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Get(MU)	
NP_KUNTA										
ANP_ADANIAPSEVEN(5 * 50)	250	0	0	255	11:24	1	18:46	1.84	1.84	153
ANP_ATHENA BIWADI(1 * 50)	50	0	0	50	12:13	0	18:46	0.29	0.29	24
ANP_ATHENA HISAR(1 * 50)	50	0	0	50	10:55	0	18:46	0.34	0.34	28
ANP_ATHENA KARNAL(1 * 50)	50	0	0	45	10:43	0	18:46	0.31	0.31	26
ANP_AYANA(1 * 250)	250	0	0	260	12:32	1	18:46	1.79	1.79	149
ANP_AZURE(1 * 50)	50	0	0	13	00:00	0	00:00	0.3	0.3	25
ANP_IGS1(1 * 50)	50	0	0	46	10:44	39	11:53	0.32	0.32	27
ANP_IGS2(1 * 50)	50	0	0	51	12:13	0	00:00	0.36	0.36	30
ANP_NTPC(5 * 50)	250	0	0	165	10:53	1	18:42	1.13	1.13	94
ANP_TATA(2 * 50)	100	0	0	91	10:52	0	18:36	0.61	0.61	51
SPRING ANG ITRA(1 * 250)	250	0	0	266	10:45	1	18:55	1.73	1.73	144
PAVAGADA										
PVG_ADYAH(6 * 50)	300	0	0	80	00:00	0	00:00	1.93	1.93	161
PVG_AMPLUS PAVAGADA(1 * 50)	50	0	0	52	11:58	1	06:02	0.37	0.37	31
PVG_AMPLUS TUMKUR(1 * 50)	50	0	0	52	12:18	1	00:00	0.35	0.35	29
PVG_AVAADA SOLAR(3 * 50)	150	0	0	146	12:10	1	00:00	1.02	1.02	85
PVG_AVAADA SOLARISE(3 * 50)	150	0	0	146	12:26	0	06:02	0.98	0.98	82
PVG_AZURE POWER EARTH (2 * 50)	100	0	0	99	12:08	1	00:00	0.71	0.71	59
PVG_FORTUM FIN SURYA(2 * 50)	100	0	0	92	12:29	1	00:00	0.62	0.62	52
PVG_IRCON_S	225	0	0	123	00:00	0	-	2.96	2.96	247
PVG_KREDL(1 * 50)	50	0	0	44	11:55	1	00:00	0.3	0.3	25
PVG_PARAMPUJYA(3 * 50)	150	0	0	128	12:24	1	00:00	0.95	0.95	79
PVG_RENEW TN2(1 * 50)	50	0	0	45	08:40	1	00:00	0.36	0.36	30
PVG_SBG ENERGY(4 * 50)	200	0	0	149	12:37	1	06:02	1.02	1.02	85
PVG_SPRING SOLAR INDIA(5 * 50)	250	0	0	251	11:53	1	00:00	1.69	1.69	141
PVG_TATA RENEWABLES(8 * 50)	400	0	0	363	12:34	1	00:00	2.27	2.27	189
PVG_YARROW(1 * 50)	50	0	0	44	12:35	1	06:02	0.29	0.29	24
OTHER										
GADAG_SERENTICA3_S	69	0	0	47	00:00	0	-	1.12	1.12	93
GADAG_VENA_S	31	0	0	0	00:00	0	-	0	0	0
GRT(1 * 150)	150	0	0	145	11:20	0	00:00	0.88	0.88	73
HIRIYUR_ZREPL_S	94	0	0	29	00:00	0	-	0.7	0.7	58
KOPPAL_KLEIO_S	105	0	0	25	00:00	0	-	0.61	0.61	51
KOPPAL_RENEWOJAS_S	81	0	0	22	00:00	0	00:00	0.53	0.53	44
KOPPAL_SRI1PL_S	188	111	147	111	20:00	0	-	1.35	1.35	113
KOPPAL_TPSAURYA_S	131	0	0	71	00:00	0	-	1.7	1.7	142
KURNOOL3_SAEL1_S	201	0	0	92	00:00	0	-	2.2	2.2	183
KURNOOL3_SAEL2_S	157	0	0	99	00:00	0	-	2.38	2.38	198
KURNOOL_AMGREEN_S	599	0	0	110	00:00	0	-	2.65	2.65	221
KURNOOL_GREENKO_S	249	0	0	111	00:00	0	-	2.67	2.67	223
NTPC ETTAYAPURAM SOLAR PLANT	230	0	0	235	11:29	1	00:00	1.49	1.49	124
RAMANGUNDAM (SOLAR)(1 * 100)	100	76	76	96	12:28	0	03:25	0.67	0.67	56
SIMHADRI (SOLAR)(1 * 25)	25	1	0	6	20:00	0	00:00	0.15	0.15	13
Total	6,085	188	223					43.94	43.94	3,662

Total ISGS IPP Thermal	22,470	16,053	15,016					354.62	327.32	
STATE THERMAL	30,742	20,058	18,406					450.36	415.95	
Total CPP Import										
Total ISGS & IPP Hydro	2,400	0	0					10.41	10.47	436
HYDEL	15,887	3,851	2,072	-	-	-	-	75.42	74.96	
GAS/NAPTHA/DIESEL	6,826	103	107	-	-	-	-	4.55	4.27	
NUCLEAR	3,320	2,816	2,826	-	-	-	-	70.47	65.18	
WIND	23,764	4,412	4,450	-	-	-	-	99.02	99.02	
SOLAR	31,475	188	223	-	-	-	-	171.72	171.72	
OTHERS	4,752	858	866	-	-	-	-	22.97	22.97	

4(A) INTER-REGIONAL EXCHANGES (Import=(+ve) /Export =(-ve))

SL.No.	Element	20:00	03:00	Maximum Interchange (MW)		Import in MU	Export in MU	NET
		(MW)	MW	Import (MW)	Export (MW)			
	Import/Export between SOUTH REGION and EAST REGION							
1	220KV-UPPER_SILERU-BALIMELA	2	2	3	-	0	0	0
2	400KV-GAZUWAKA-JEYPORE	0	0	0	-	0	0	0
3	765KV-SRIKAKULAM-ANGUL	1,611	1,768	2,528	-	43.25	0	43.25
4	HVDC500KV-TALCHER-KOLAR_DC	1,964	1,964	1,971	-	42.62	0	42.62
	Sub-Total EAST REGION	3,577	3,734	4,502	0	85.87	0	85.87
	Import/Export between SOUTH REGION and WEST REGION							
1	220KV-AMBEWADI-PONDA	0	0	-	-	0	0	0
2	220KV-AMBEWADI-XELDEM	106	103	-	113	0	2.37	-2.37
3	220KV-CHIKKODI-MUDASANGI	0	0	0	-	-	-	-
4	220KV-CHIKKODI-TALANGADE	-	-	-	-	-	-	-

5	220KV-LOWER_SILERU-BARSUR	-	-	-	-	-	-	-
6	400KV-BHADRAVTAHI-RAMAGUNDAM	298	298	320	-	7.16	0	7.16
7	400KV-KUDGI_PG-KHOLAPUR_PG	1,472	1,300	-	1,863	0	29.6	-29.6
8	765KV-NIZAMABAD-WARDHA	539	849	2,220	-	26.76	0	26.76
9	765KV-RAICHUR_PG-SHOLAPUR	826	604	-	1,615	0	5.66	-5.66
10	765KV-WARANGAL(NEW)-WARORA	686	965	2,274	-	28.76	0	28.76
11	HVDC800KV-RAIGARH HVDC-PUGALUR HVDC	2,287	1,431	-	561	72.18	0	72.18
Sub-Total WEST REGION		6,214	5,550	4,814	4,152	134.86	37.63	97.23
TOTAL IR EXCHANGE		9,791	9,284	9,316	4,152	220.73	37.63	183.1

4(B) Inter Regional Schedule & Actual Exchange (Import=(+ve) /Export =(-ve)) in MU

	ISGS+GNA+URS Schedule	T-GNA Bilateral	GDAM Schedule	DAM Schedule	HPDAM Schedule	RTM Schedule	Total IR Schedule	Total IR Actual	NET IR UI
SR-ER	40.713	-4.128	0	0	0	-0.474	-4.686	45.207	49.893
SR-WR	76.434	3.4	0.752	18.398	0	56.39	153.262	97.223	-56.039
Total	117.147	-0.728	0.752	18.398	0	55.916	148.576	142.43	-6.146

5.Frequency Profile

RANGE(Hz)	< 48.8	< 49	< 49.2	< 49.5	< 49.7	< 49.9	>= 49.9 - <= 50.05	> 50	> 50.05
%	0	0	0	.671	7.373	23.796	56.458	49.294	19.745

<----------Frequency (Hz)---------->

Maximum		Minimum		Average	Freq Variation	Standard	Freq. in 15 mnt blk	
Frequency	Time	Frequency	Time	Frequency	Index	Deviation	Max.	Min.
50.229	08:02:20	49.458	22:16:50	49.956	0.205	0.136	50.18	49.54

6.Voltage Profile: 400kV

	Maximum		Minimum		Voltage (in %)			
STATION	VOLTAGE	TIME	VOLTAGE	TIME	< 380	< 390	> 420	> 430
GHANAPUR - 400KV	417	01:48	401	14:18	0	0	0	0
GOOTY - 400KV	419	02:06	400	10:25	0	0	0	0
HIRIYUR - 400KV	418	02:01	395	10:49	0	0	0	0
KAIGA - 400KV	419	18:04	385	11:46	0	8.264	0	0
KOLAR_AC - 400KV	422	03:08	394	09:28	0	0	8.958	0
KUDANKULAM - 400KV	415	23:07	404	14:48	0	0	0	0
SHANKARAPALLY - 400KV	411	01:58	398	14:02	0	0	0	0
SOMANAHALLI - 400KV	418	02:05	389	10:25	0	1.806	0	0
SRIPERUMBADUR - 400KV	407	03:24	384	14:44	0	18.958	0	0
TRICHY - 400KV	415	23:08	393	10:04	0	0	0	0
TRIVANDRUM - 400KV	420	03:38	401	15:54	0	0	0	0
VIJAYAWADA - 400KV	413	02:12	393	14:29	0	0	0	0

6.1 Voltage Profile: 220kV

	Maximum		Minimum		Voltage (in %)			
STATION	VOLTAGE	TIME	VOLTAGE	TIME	< 198	< 210	> 235	> 245
GHANAPUR - 220KV	231	02:14	220	14:26	0	0	0	0
GOOTY - 220KV	230	03:02	218	11:35	0	0	0	0
HIRIYUR - 220KV	227	17:19	211	10:46	0	0	0	0
KAIGA - 220KV	237	18:03	217	11:47	0	0	.903	0
KOLAR_AC - 220KV	230	03:02	212	09:41	0	0	0	0
SOMANAHALLI - 220KV	232	03:02	213	10:20	0	0	0	0
SRIPERUMBADUR - 220KV	231	03:38	231	03:38	0	0	0	0
TRICHY - 220KV	229	22:33	229	22:33	0	0	0	0
TRIVANDRUM - 220KV	232	04:02	221	15:55	0	0	0	0
VIJAYAWADA - 220KV	228	17:33	220	14:43	0	0	0	0

6.2 Voltage Profile: 765kV

	Maximum		Minimum		Voltage (in %)			
STATION	VOLTAGE	TIME	VOLTAGE	TIME	< 720	< 750	> 780	> 800
KURNOOL - 765KV	791	18:03	763	14:15	0	0	66.32	0
NIZAMABAD - 765KV	800	01:45	773	14:16	0	0	92.36	0
RAICHUR_PG - 765KV	795	02:30	765	14:16	0	0	56.25	0
SRIKAKULAM - 765KV	798	01:48	761	14:18	0	0	61.94	0

7.Major Reservoir Particulars

RESERVOIR	DESIGNED			PRESENT		LAST YEAR		LAST DAY		MONTH	
	MDDL (Mts)	FRL (Mts)	Energy (MU)	Level (Mts)	Energy (MU)	Level (Mts)	Energy (MU)	Inflow (Mus)	Usage (Mus)	"Prog. Inflow (Mus)"	"Prog. Usage (Mus)"
NILAGIRIS	0	0	1,504	0	490	0	715	1.21	4.37	1.21	6.48
IDUKKI	694.94	732.43	2,148	706.18	458	714.69	909	0	6.86	0	9.22
JALAPUT	818.39	838.4	534	825.29	127	831.83	424	0.51	0	0.51	0
N.SAGAR	155.45	179.9	1,398	158.53	98	156.12	21	2.47	2.15	2.47	3.3
SRISAILAM	243.84	270.7	1,392	249.33	57	253.59	124	0	0	0	0
SUPA	495	564	3,159	526.57	692	530.4	1,561	0.11	7.69	0.11	7.51
KAKKI	908.3	981.45	916	937.46	106	962.68	415	0.31	2.93	0.31	2.71
LINGANAMAKKI	522.73	554.5	4,557	534.07	605	538.38	1,050	0	15	0	12.62
TOTAL	-	-	15,608	-	2,633	-	5,219	4.61	39	4.61	41.84

8(A). Short-Term Open Access Details:

State	Off- Peak Hours (03:00)												
	T-GNA Bilateral (MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX HPDAM (MW)	IEX RTM (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXIL HPDAM (MW)	PXI RTM (MW)	HPX GDAM (MW)	HPX DAM (MW)	HPX HPDAM (MW)	HPX RTM (MW)
AP	-12.09	-2.9	-346.6	0	105.96	0	0	0	0	0	0	0	0
KARNATAKA	-229.03	-75.15	-62.54	0	-64.1	0	0	0	0	0	0	0	0
KERALA	0	0	279.27	0	95.19	0	0	0	0	0	0	0	0
PONDICHER ..	9.66	0	-26.9	0	-18	0	0	0	0	0	0	0	0
TAMILNADU	2,101.6	8.69	-19.5	0	1,075.2	0	0	0	0	0	0	0	0
TELANGANA	-159.16	0.87	965.99	0	922.63	0	0	0	0	0	0	0	0
TOTAL	1,710.98	-68.49	789.72	0	2,116.88	0	0	0	0	0	0	0	0

State	Peak Hours (20:00)												
	T-GNA Bilateral (MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX HPDAM (MW)	IEX RTM (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXIL HPDAM (MW)	PXI RTM (MW)	HPX GDAM (MW)	HPX DAM (MW)	HPX HPDAM (MW)	HPX RTM (MW)
AP	-11.73	-6.2	-47.3	0	-36.26	0	0	0	0	0	0	0	0
KARNATAKA	-315.34	-128.57	-55.8	0	-131.99	0	0	0	-100	0	0	0	0
KERALA	0	0	165.41	0	546.87	0	0	0	0	0	0	0	0
PONDICHER ..	2.22	3.97	10.5	0	-23	0	0	0	0	0	0	0	0
TAMILNADU	3,702.4	1.99	268.71	0	-9.4	0	0	0	0	0	0	0	0
TELANGANA	-42.25	0.1	131.03	0	1,582.9	0	0	0	0	0	0	0	0
TOTAL	3,335.3	-128.71	472.55	0	1,929.12	0	0	0	-100	0	0	0	0

State	Day Energy (MU)						
	ISGS+GNA Schedule	T-GNA Bilateral	GDAM Schedule	DAM Schedule	HPDAM Schedule	RTM Schedule	Total (MU)
ANDHRA PRADESH	56.75	0.59	0.8	2.24	0	8.99	69.37
KARNATAKA	104.3	-5.41	-1.63	0.04	0	-0.93	96.36
KERALA	53.01	1.28	0.61	9.61	0	7.93	72.44
PONDICHERRY	11.38	0.51	0.03	-0.29	0	-0.48	11.15
TAMILNADU	193.2	36.9	1.8	-3.25	0	6.14	234.78
TELANGANA	80.21	-0.58	0.56	9	0	25.7	114.89
TOTAL	498.85	33.29	2.17	17.35	0	47.35	598.99

8(B). Short-Term Open Access Details

State	ISGS+GNA Schedule		T-GNA Bilateral (MW)		IEX GDAM (MW)		PXIL GDAM(MW)		HPX GDAM(MW)		IEX DAM (MW)		PXIL DAM(MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
ANDHRA PRADESH	3,199.81	1,572.73	77.08	-20.68	166.81	-6.8	0	0	0	0	401.89	-346.6	0	0
KARNATAKA	5,617.56	3,419.95	-61.75	-515.34	2.17	-481.25	0	0	0	0	61.22	-83.13	0	0
KERALA	2,476.16	1,501.11	380.46	0	80.85	0	0	0	0	0	798.63	-10.5	0	0
PONDICHERRY	542.23	405.18	42.79	0	15.79	0	0	0	0	0	16.72	-63.9	0	0
TAMILNADU	8,845.29	7,714.39	4,040.94	-59	243.12	0	0	0	0	0	1032.38	-1392.27	0	0
TELANGANA	5,006.24	2,214.33	43.11	-166.64	63.6	-1.3	0	0	0	0	1344.9	-43.9	0	0

State	HPX DAM(MW)		IEX HPDAM (MW)		PXIL HPDAM(MW)		HPX HPDAM(MW)		IEX RTM (MW)		PXIL RTM(MW)		HPX RTM(MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
ANDHRA PRADESH	0	0	0	0	0	0	0	0	1,859.72	-551.78	0	0	0	0
KARNATAKA	0	0	0	0	0	0	0	0	556.34	-282.55	0	-600	0	0
KERALA	0	0	0	0	0	0	0	0	879.79	-1.4	0	0	0	0
PONDICHER ..	0	0	0	0	0	0	0	0	5.8	-63	0	0	0	0
TAMILNADU	0	0	0	0	0	0	0	0	1,803.06	-961.92	102.63	0	0	0
TELANGANA	0	0	0	0	0	0	0	0	2,334.22	321.32	0	0	0	0

9. Synchronisation of new generating units :

SL.NO	Station Name	Owner	Inst. Capacity (MW)	Date	Time

10. Synchronisation of new 220 / 400 / 765 KV Transmission elements and energising of bus /substation :

11.Significant events (If any):

At 06:37Hrs Bus bar protection operated at 220kV Sabarigiri S/S while switching off the Unit#5, as the circuit breaker of generator failed to open. Consequently, all connected elements [220 kV lines - 6 Nos, 220/66 kV Transformer and generating units (Unit 1,3,4,5 & 6)] at Sabarigiri S/S tripped, resulting in complete power supply failure at the station. 130 MW generation Loss reported. All tripped elements restored except 220kV PathanamthittaSabarigiri line and Sabarigiri Unit-5 .

12.Constraints and instances of congestion in the transmission system

1) 400KV-KALPAKKA-KHAMMAM_PG-1 & 400KV-KALPAKKA-ASUPAKA-1 Lines Under S/D for replacement of badly damaged rusted towers from Loc No.1 to 11 in 400KV Kalapaka Khammam along with stringing of conductor at 400kv SS Kalapaka. S/D availed on 05-05-2026 ,Expected to be restored on 26-06-2026.

2) 400KV Kaiga-Guttur 1&2 tripped on 14.05.2026 at 17:39Hrs due to the tower collapse in multiple locations.
3) 400KV-GAZUWAKA-JEYPORE-1,2 under shutdown for NH-130CD Diversion works (Between 130-133/150-153/179-180) availed on 15-05-2026 at 09:36 Hrs. Expected to restore by 05.06.2026 18:00 Hrs.
4) 400KV-PAVAGADA_PG-TUMKUR-1&2 availed S/D on 17.05.2026 at 10:17Hrs for Conductor Release, Existing tower dismantle, New Tower erection, and stringing of the conductor for the work of Shifting/Heightening/Modification by providing 01 No. of 400KV DD+18 type tower, Expected to be restored on 05-06-2026.
5) 220KV-GADAG_PSS-Vena_GadagPS-1 and 220KV-GADAG_PSS-Green Infra_GadagPS-1 tripped on 17-05-2026 at 16:14 Hrs due to the tower collapse Loc. No.32-36. Generation affected 237MW(I.C)
6) At 18:13 hrs of 23-05-2026, 400KV-GADAG_PSS-KOPPAL D/C tripped on Y-B fault due to tower collapse. total 15 number of tower Collapsed (Tower location number 52-66).
7) 400KV-NAGAPATTNAM_PS-TRICHY-1&2 tripped on 31.05.2026 at 17:05Hrs due to the tower collapse at loc. 437(DA), 438(DA), 439(DB) towers are collapsed and 435(DA),436(DA),440(DA), 441(DA) towers are found cross arm/earth peak damaged.
8) 400/220kV SOMANAHALLI ICT-1 tripped at 20:07 hours of 31-05-2026 due to REF, Differential & body protections.

13. Weather Condition:

Kerala: Rains reported in Kochi and Kozhikode areas.
Tamilnadu: Light Rains reported in Coimbatore area.
Karnataka: Light rains reported in Bangalore, Hassan, Mysore and Udupi areas.

14. RE/Load Curtailment details

State	Load Curtailment (Shortage)			RE Curtailment				Reason
	Energy	Maximum	At the time of maximum demand	Wind		Solar		
	MU	MW	MW	Max MW	Energy(MU)	Max MW	Energy(MU)	
ANDHRA PRADESH	0	0	0	0	0	0	0	
KARNATAKA	0	0	0	0	0	0	0	
KERALA	0.37	245	0	0	0	0	0	
TAMILNADU	0	0	0	0	0	0	0	
PONDICHERRY	0	0	0	0	0	0	0	
TELANGANA	0	0	0	0	0	0	0	

15.Instances of persistant/significant non-complaint with grid code

State	Frequency and Deviation				Voltage				ICT loading			
	Alert	Emergency	Extreme Emergency	Non Compliance	Alert	Emergency	Extreme Emergency	Non Compliance	Alert	Emergency	Extreme Emergency	Non Compliance
ANDHRA PRADESH	0	2	0	0	30	10	0	0	0	0	0	0
KARNATAKA	0	0	0	0	24	6	0	0	0	0	0	0
KERALA	0	0	0	0	2	0	0	0	0	0	0	0
TAMILNADU	1	2	0	1	14	4	0	0	0	0	0	0
PONDICHERRY	0	0	0	0	0	0	0	0	0	0	0	0
TELANGANA	0	0	0	0	44	36	0	0	0	0	0	0

REMARKS:

Shift In Charge