ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
GRID CONTROLLER OF INDIA LIMITED
क्षेत्रीय लोड प्रेषण केन्द्र
SOUTHERN REGIONAL LOAD DESPATCH CENTER

Date of Reporting: 04-Jun-2026

Power Supply Position Report For

03-Jun-2026

1. Regional Availability/Demand:

Evening Peak (20:00) MW				Off-Peak (03:00) MW				Day Energy (Net MU)	
Demand Met	Shortage	Requirement	Freq (Hz)	Demand Met	Shortage	Requirement	Freq (Hz)	Demand Met	Shortage #
54799	0	54799	50.06	47962	0	47962	50.05	1279.12	0

2(A) State's Load Deails (At State Periphery) in MUs:

State	State's Control Area Generation (Net MU)						Net SCH	Drawal	UI	Availability	Demand Met	Shortage #
	THERMAL	HYDRO	GAS/DIESEL /NAPTHA	WIND	SOLAR	OTHERS	(Net Mu)	(Net Mu)	(Net Mu)	(Net Mu)	(Net Mu)	(Net Mu)
Andhra Pradesh	143.34	5.56	0	15.72	18.53	2.09	65.73	65.95	0.22	250.97	251.19	0
Karnataka	96.3	28.18	0	18.01	26.33	9.25	97.24	96.37	-0.87	275.31	274.44	0
Kerala	0	16.54	0	0.53	1.02	0.3	72.03	72.79	0.76	90.42	91.18	0
Puducherry	0	0	0.36	0	0.06	0	11.39	11.3	-0.09	11.81	11.72	0
Tamil Nadu	83.26	7.47	3.3	62.17	55.5	7.36	190.21	186.84	-3.37	409.27	405.9	0
Telangana	99.77	2.07	0	0.68	21.49	2.99	118.87	117.69	-1.18	245.87	244.69	0
Total	422.67	59.82	3.66	97.11	122.93	21.99	555.47	550.94	-4.53	1283.65	1279.12	0

2(B) State's Demand Met in MWs and day energy forecast and deviation particulars

State	Evening Peak (20:00) MW			Off-Peak (03:00) MW			Average Demand	Day Energy (Net MU)	
	Demand Met	Shortage	Requirement	Demand Met	Shortage	Requirement	(MW)	Forecast (LGBR)	Deviation [Forecast - Consumption]
Andhra Pradesh	10451	0	10451	9424	0	9424	10490	250	1.19
Karnataka	11316	0	11316	9166	0	9166	11319	285.24	-10.8
Kerala	4605	0	4605	3494	0	3494	3896	90.04	1.14
Puducherry	526	0	526	439	0	439	478	11.5	0.22
Tamil Nadu	18365	0	18365	16377	0	16377	17403	430	-24.1
Telangana	9536	0	9536	9062	0	9062	9874	235	9.69
Total	54799	0	54799	47962	0	47962	53460	1301.78	-22.66

2(C) State's Demand Met in MWs (maximum demand met and Maximum requirement of the day details)

State	Maximum Demand, corresponding shortage and requirement details for the day				Maximum requirement, corresponding shortage and demand details for the day				ACE			
	Maximum Demand Met	Time	Shortage at maximum demand	Requirement at the max demand met	Demand Met at maximum requiremnet	Time	Shortage at maximum Requirement	Maximum Requirement	Maximum ACE(MW)	Time	Minimum ACE(MW)	Time
Andhra Pradesh	12951	15:16	0	12951	12951	15:16	0	12951	1321.01	16:20	-947.47	17:01
Karnataka	13394	10:00	0	13394	13394	10:00	0	13394	972.67	13:41	-537.05	18:01
Kerala	4728	19:30	0	4728	4728	19:30	0	4728	318.98	10:55	-356.83	14:29
Puducherry	562	22:15	0	562	562	22:15	0	562	40.51	23:46	-41.5	00:17
Tamil Nadu	19208	22:30	0	19208	19208	22:30	0	19208	2063.46	09:01	-1197.77	00:01
Telangana	12392	15:15	0	12392	12392	15:15	0	12392	776.67	01:27	-857.84	17:53
Region	60444	15:15	0	60444	60444	15:15	0	60444	4063.1	10:00	-2600.92	15:24

3(A) State Entities Generation:

ANDHRA PRADESH

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
HINDUJA POWER CORPORATION LTD (2*520)	1040	1009	1007	1025	22:43	552	08:29	21.6	20.42	851
KRISHNAPATTANAM (3*800)	2400	1948	1955	2071	23:48	1336	10:13	39.92	37.71	1571
RAYALASEEMA TPP (5*210 + 600)	1650	1441	1395	1496	01:58	899	06:12	28.64	25.76	1073
SEIL P2 Unit-2 (1*660)	660	621	630	632	13:35	342	11:36	15.08	14.28	595
VIJAYAWADA TPS (6*210 + 500 + 800)	2560	2110	2109	2227	20:25	1436	12:40	48.81	45.17	1882
Total Thermal	8310	7129	7096	-	-	-	-	154.05	143.34	5972

DONKARAYI (1*25)	25	0	0	0	00:00	0	06:00	0	0	0
HAMPI & T.B.DAM (8 * 9)	57	0	0	0	00:00	0	06:00	0	0	0
LOWER SILERU (4*115)	460	308	13	406	00:55	13	10:37	3.94	3.93	164
MACHKUND (3 * 17 + 3 * 23)	84	0	0	0	00:00	0	06:00	0	0	0
NAGARJUNASAGAR TAILPOND (2*25)	50	1	1	1	00:00	1	06:00	0.03	0.03	1
NSR RT.CANAL.P.H (3*30)	90	0	0	0	00:00	0	06:00	0	0	0
SRISAILAM RBPH (7*110)	770	0	0	0	00:00	0	06:00	0	0	0
UPPER SILERU (4*60)	240	56	0	166	01:15	0	06:07	1.61	1.6	67
OTHER HYDEL	124	0	0	0	00:00	0	06:00	0	0	0
Total Hydro	1900	365	14	-	-	-	-	5.58	5.56	232
GAUTAMI CCPP (2*145 + 174)	464	0	0	0	00:00	0	06:00	0	0	0
GMR (BARG) (1 * 237)	237	0	0	0	00:00	0	06:00	0	0	0
JEGURUPADU (GAS) (2*45.8 + 49.9 + 75.5)	217	0	0	0	00:00	0	06:00	0	0	0
Jegrupadu Ext. (1 * 220)	220	0	0	0	00:00	0	06:00	0	0	0
KONASEEMA CCPP (145 + 140 + 165)	450	0	0	0	00:00	0	06:00	0	0	0
LANCO (GAS) (2*115 + 121)	351	0	0	0	00:00	0	06:00	0	0	0
RELIANCE ENERGY LTD. (GAS) (140 + 80)	220	0	0	0	00:00	0	06:00	0	0	0
SPECTRUM (GAS) (46.8 + 2*46.1 + 68.8)	208	0	0	0	00:00	0	06:00	0	0	0
VEMAGIRI POWER GENERATION LTD.(GAS) (233 + 137)	370	0	0	0	00:00	0	06:00	0	0	0
VIJJESWARAM GTS (2*33 + 34 + 112.5 + 59.5)	272	0	0	0	00:00	0	06:00	0	0	0
OTHER GAS/NAPTHA/DIESEL	27	0	0	0	00:00	0	06:00	0	0	0
Total Gas	3036	0	0	-	-	-	-	0	0	0
WIND	4102	468	1182	2066	00:22	185	15:07	15.72	15.72	655
SOLAR	3965	1	0	2532	12:16	16	06:01	18.53	18.53	772
OTHERS	619	117	124	156	14:02	115	16:02	2.09	2.09	87
Total ANDHRA PRADESH	21932	8080	8416	-	-	-	-	195.97	185.24	7718

TELANGANA

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
BHADRADRI TPS (4*270)	1080	854	857	900	01:51	518	09:27	19.7	17.93	747
KAKATIYA ST1&ST2 (500 + 600)	1100	1034	1032	1054	08:25	558	11:18	23.7	22.37	932
KOTHAGUDEM TPS (2*250 + 500 + 800)	1800	1054	1276	1493	07:41	902	09:05	30.34	28.24	1177
RAMAGUNDAM-B (1*62.5)	63	0	0	0	00:00	0	06:00	0	0	0
SINGARENI TPS (2*600)	1200	986	581	1087	23:45	311	10:05	16.06	14.74	614
YADADRI (4*800)	3200	723	778	914	00:00	632	17:40	17.89	16.49	687
Total Thermal	8443	4651	4524	-	-	-	-	107.69	99.77	4157
L JURALA (6*40)	240	0	0	0	00:00	0	06:00	0	0	0
NAGARJUNA SAGAR (110 + 7*100.8)	816	0	0	626	00:03	0	06:00	2.09	2.07	86
NAGARJUNA SAGAR (Pump) (110 + 7*100.8)	816	108	0	434	06:52	107	16:13	3.3	3.3	138
NIZAMSAGAR (2*5)	10	0	0	0	00:00	0	06:00	0	0	0
NSR LT.CANAL.P.H (2*30)	60	0	0	0	00:00	0	06:00	0	0	0
POCHAMPAD (4*9)	36	0	0	0	00:00	0	06:00	0	0	0
PULICHINTALA (4*30)	120	0	0	0	00:00	0	06:00	0	0	0
SINGUR (2*7.5)	15	0	0	0	00:00	0	06:00	0	0	0
SRISAILAM LBPH (6*150)	900	0	0	0	00:00	0	06:00	0	0	0
SRISAILAM LBPH(Pump) (6*150)	900	0	0	0	00:00	0	06:00	0	0	0
U JURALA (6*39)	234	0	0	0	00:00	0	06:00	0	0	0
OTHER HYDEL	51	0	0	0	00:00	0	06:00	0	0	0
Total Hydro	2482	0	0	-	-	-	-	2.09	2.07	86
WIND	128	2	41	84	04:34	1	15:47	0.68	0.68	28
SOLAR	3848	0	0	2606	11:50	31	06:00	21.49	21.49	895
OTHERS	252	124	124	124	00:00	124	06:00	2.99	2.99	125
Total TELANGANA	15153	4777	4689	-	-	-	-	134.94	127	5291

KARNATAKA

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak	Min Generation (06:00 to 18:00)	Day Energy	Avg

	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
Bellary TPS (2*500 + 700)	1700	1444	1491	1556	02:17	1118	13:56	35.09	33.04	1377
JINDAL (2*130 + 4*300)	1460	948	1001	1071	04:32	699	12:05	22.74	20.85	869
Jindal (Excl. Captive Consumption) (2 * 130 + 4 * 300)	1460	0	2	222	04:57	0	07:32	1.23	1.23	51
Raichur TPS (7*210 + 250)	1720	998	950	1063	09:13	849	12:00	25.76	22.87	953
UPCL (2*600)	1200	1105	1109	1129	05:58	581	16:24	24.14	22.66	944
YERAMARAS TPS (2*800)	1600	957	638	1002	19:28	410	12:06	18.17	16.5	688
Total Thermal	7680	4504	4190	-	-	-	-	104.39	96.3	4013
Almatty (15 + 5*55)	290	0	0	0	00:00	0	06:00	0	0	0
Bhadra (2*12.1 + 7 + 2 + 6)	39	0	0	0	00:00	0	06:00	0	0	0
Ghataprabha (2*16)	32	0	0	0	00:00	0	06:00	0	0	0
JOG (MGHES) (4*21.6 + 4*13.2)	139	48	62	62	02:29	48	06:09	1.26	1.24	52
LINGANAMAKKI.P.H. (2*27.5)	55	8	0	8	08:07	0	06:00	0.19	0.18	8
Kadra (3*50)	150	141	0	145	06:45	0	07:05	0.73	0.71	30
Kodasalli (3*40)	120	111	28	113	06:07	0	07:16	0.91	0.89	37
MANI DAM.P.H. (2*4.5)	9	1	1	1	00:44	1	13:42	0.04	0.04	2
Munirabad (3*9 + 10)	37	0	0	0	00:00	0	06:00	0	0	0
NAGJHERI (135 + 5*150)	885	423	269	444	06:02	98	13:24	7.78	7.68	320
SHARAVATHI (10*103.5)	1035	849	445	859	20:25	264	11:58	12.82	12.69	529
Sharavati Tail Race (4*60)	240	199	0	207	06:14	0	07:21	1.41	1.39	58
SIVANSAMUDRAM (6*3 + 4*6)	42	0	0	0	00:00	0	06:00	0.25	0.24	10
Supa (2*50)	100	30	30	30	13:18	29	13:41	0.73	0.72	30
U JURALA (6*39)	234	0	0	0	00:00	0	06:00	0	0	0
Varahi UGPH (4*115)	460	395	50	400	21:03	44	09:43	2.46	2.42	101
OTHER HYDEL	143	0	0	0	00:00	0	06:00	0	0	0
Total Hydro	4010	2205	885	-	-	-	-	28.58	28.2	1177
OTHER GAS/NAPTHA/DIESEL	126	0	0	0	00:00	0	06:00	0	0	0
Total Gas	126	0	0	-	-	-	-	0	0	0
WIND	5676	681	649	1346	00:00	469	08:27	18.01	18.01	750
SOLAR	7171	3	204	3871	13:23	6	06:00	26.33	26.33	1097
OTHERS	1832	99	100	127	14:07	54	06:12	9.25	9.25	385
Total KARNATAKA	26495	7492	6028	-	-	-	-	186.56	178.09	7422

KERALA

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
Idamalayar (2*37.5)	75	51	0	51	22:41	0	06:00	0.34	0.34	14
Iddukki (6*130)	780	604	650	756	20:50	29	07:31	7.45	7.42	309
Kakkad (2*25)	50	24	35	36	20:55	0	12:08	0.49	0.49	20
KALLADA (2*7.5)	15	4	7	8	07:09	5	16:41	0.11	0.11	5
Kuttiyadi (3*25)	75	102	0	196	21:18	0	06:00	1	0.99	41
Lower Periyar (3*60)	180	0	0	170	21:44	0	06:00	0.46	0.46	19
Neriamangalam (3*17.5 + 25)	78	72	0	73	23:10	0	06:00	0.57	0.57	24
PALLIVASAL (3*5 + 3*7.5)	38	0	0	0	00:00	0	06:00	0	0	0
PALLIVASAL EXTENSION SCHEME (2*30)	60	58	18	60	00:07	18	06:01	0.9	0.9	38
Panniar (2*16.2)	32	0	0	0	00:00	0	06:00	0.28	0.28	12
PORINGALKUTHU (4*9)	36	16	0	50	00:08	0	06:00	0.24	0.24	10
Sengulam (4*12.8)	51	51	0	51	20:51	0	06:00	0.53	0.53	22
Sholayar (3*18)	54	30	0	53	00:01	0	06:00	0.33	0.33	14
Sabarigiri (4*55 + 2*60)	340	172	226	229	06:21	27	14:50	2.77	2.77	115
THOTTIYAR HEP (2*20)	40	0	0	30	00:01	0	06:00	0.1	0.1	4
OTHER HYDEL	230	82	56	237	00:54	0	06:51	1.02	1.01	42
Total Hydro	2134	1266	992	-	-	-	-	16.59	16.54	689
BRAHMAPURAM DGPP (DIESEL) (3*21.32)	64	0	0	0	00:00	0	06:00	0	0	0
BSES (NAPTHA) (3*40.5 + 35.5)	157	0	0	0	00:00	0	06:00	0	0	0
KOZHIKODE DPP (DIESEL) (6*16)	96	0	0	0	00:00	0	06:00	0	0	0
MPS STEEL CASTINGS (1 * 10)	10	0	0	0	00:00	0	06:00	0	0	0

RGCCPP KAYAMKULAM (KSEB) - NTPC (2*116.6 + 126.38)	360	0	0	0	00:00	0	06:00	0	0	0
OTHER GAS/NAPTHA/DIESEL	22	0	0	0	00:00	0	06:00	0	0	0
Total Gas	709	0	0	-	-	-	-	0	0	0
WIND	70	17	3	23	20:11	0	06:29	0.53	0.53	22
SOLAR	1988	0	1	208	13:03	0	06:07	1.02	1.02	43
OTHERS	20	18	4	220	13:03	2	06:13	0.3	0.3	13
Total KERALA	4921	1301	1000	-	-	-	-	18.44	18.39	767

TAMIL NADU

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
Mettur TPS (4*210 + 600)	1440	801	1276	1309	05:46	775	16:45	27.76	25.47	1061
NORTH CHENNAI TPS STG-III (1*800)	800	0	566	603	00:49	426	15:14	9.75	9.14	381
NORTH CHENNAI TPS STG-II (2*600)	1200	596	703	716	01:32	595	08:17	16.59	15.2	633
North Chennai TPS (3*210)	630	402	478	497	02:01	384	09:42	11.49	10.32	430
UDANGUDI(Infirm - 660MW)	0	0	0	0	00:00	0	06:00	0	0	0
OPG PGPL (2*77 + 80 + 180)	414	269	300	304	00:44	261	17:14	7.42	6.76	282
SEPC (1*525)	525	0	0	0	00:00	0	06:00	0	0	0
ST - CMS (1*250)	250	157	214	268	15:39	143	17:47	5.05	4.63	193
Tuticorin (5*210)	1050	466	574	578	03:04	428	15:24	12.93	11.74	489
Total Thermal	6309	2691	4111	-	-	-	-	90.99	83.26	3469
Kadamparai (4*100)	400	99	0	100	22:14	0	06:00	0.62	0.61	25
Kadamparai (Pump) (4*100)	400	0	1	110	08:46	0	07:43	0.85	0.85	35
Kodayar I (1*60)	60	0	0	0	00:00	0	06:00	0	0	0
Kodayar II (1*40)	40	22	0	22	11:46	0	06:00	0.29	0.28	12
Kundah I (3*20)	60	51	28	52	01:34	2	10:00	0.68	0.67	28
Kundah II (5*35)	175	142	106	174	04:56	12	10:08	1.8	1.78	74
Kundah III (3*60)	180	100	11	132	00:02	3	07:45	1.03	1.02	43
Kundah IV (2*50)	100	0	0	95	22:50	0	06:00	0.29	0.29	12
Kundah V (2*20)	40	0	0	0	00:00	0	06:00	0.19	0.19	8
Kundah VI (1*30)	30	0	0	0	00:00	0	06:00	0	0	0
Mettur Dam (4*12.5)	50	0	0	0	08:40	0	06:00	0.21	0.21	9
Mettur Tunnel (4*50)	200	0	0	0	00:00	0	06:00	0	0	0
Moyar (3*12)	36	4	28	28	01:03	2	08:29	0.43	0.43	18
PAPANASAM (4*8)	32	4	4	4	00:00	4	06:00	0.1	0.1	4
Periyar (4*35)	140	0	0	0	00:00	0	06:00	0	0	0
Pykara (3*6.65 + 11 + 2*14)	59	8	7	11	00:16	7	09:52	0.17	0.17	7
PYKARA ULTIMATE (3*50)	150	50	0	151	00:38	0	06:00	0.78	0.77	32
Sarkarpathy (1*30)	30	12	18	18	14:47	12	16:29	0.39	0.39	16
Servalar (1*20)	20	0	0	0	00:00	0	06:00	0.02	0.01	0
Sholayar I (2*42)	84	0	0	0	00:00	0	06:00	0	0	0
Sholayar II (1*25)	25	0	0	0	00:00	0	06:00	0	0	0
Suruliyar (1*35)	35	0	0	21	01:39	0	06:00	0.04	0.04	2
OTHER HYDEL	1826	114	56	326	00:33	0	06:57	0.52	0.52	22
Total Hydro	3772	606	258	-	-	-	-	7.56	7.48	312
BASIN BRIDGE (NAPTHA) (4*30)	120	0	0	0	00:00	0	06:00	0	0	0
KOVIL KALAPPAL (GAS) (70 + 37.88)	108	0	0	0	00:00	0	06:00	0	0	0
KUTTALAM (GAS) (64 + 37)	101	70	70	70	00:00	70	06:00	1.84	1.71	71
MADURAI POWER CL (DIESEL) (1 * 106)	106	0	0	0	00:00	0	06:00	0	0	0
P P NALLUR (NAPTHA) (1 * 330.5)	331	0	0	0	00:00	0	06:00	0	0	0
SAMALPATTY (DIESEL) (7 * 15.1)	106	0	0	0	00:00	0	06:00	0	0	0
VALATTUR(STG1&STG2) (2*60 + 35 + 32)	187	28	35	68	11:13	34	06:23	1.71	1.59	66
OTHER GAS/NAPTHA/DIESEL	362	0	0	0	00:00	0	06:00	0	0	0
Total Gas	1421	98	105	-	-	-	-	3.55	3.3	137
WIND	9495	2458	900	4382	11:55	1481	06:38	62.17	62.17	2590
SOLAR	12065	0	0	7084	13:07	25	06:00	55.5	55.5	2313
OTHERS	2029	670	650	671	11:53	650	06:00	7.36	7.36	307

Total TAMIL NADU	35091	6523	6024	-	-	-	-	227.13	219.07	9128

PUDUCHERRY

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
KARAIKAL POWER PLANT (GAS) (1 * 22.9 + 1 * 9.6)	33	15	15	15	00:00	15	06:00	0.38	0.36	15
Total Gas	33	15	15	-	-	-	-	0.38	0.36	15
SOLAR	20	0	0	10	11:57	0	06:00	0.06	0.06	3
Total PUDUCHERRY	53	15	15	-	-	-	-	0.44	0.42	18

3(B) Regional Entities Generation:

ISGS

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
KUDGI (3*800)	2400	1340	1474	2333	22:34	834	07:47	33.31	30.92	1288
Neyveli TS I Expn (2*210)	420	290	158	322	21:47	239	10:33	6.78	6.05	252
Neyveli TS II (7*210)	1470	719	764	810	00:28	597	14:15	19.06	15.53	647
Neyveli TS II Expn (2*250)	500	0	0	0	00:00	0	06:00	0	0	0
NNTPS (2*500)	1000	360	395	429	06:32	272	11:19	9	7.02	293
NTPC-TELANGANA STPP (2*800)	1600	1468	1477	1533	01:41	795	08:27	32.39	30.27	1261
Ramagundam (3*200 + 4*500)	2600	2330	2355	2480	00:21	1331	08:51	48.11	45.64	1902
Simhadri Stage I (2*500)	1000	730	902	946	00:59	484	08:01	19.05	17.81	742
Simhadri Stage II (2*500)	1000	923	921	968	00:39	510	13:49	20.23	18.95	790
TALCHER ST2 (4*500)	2000	1797	1815	1886	05:50	985	10:08	42.62	40.2	1675
Total Thermal	13990	9957	10261	-	-	-	-	230.55	212.39	8850
KAIGA STG1 (2*220)	440	205	199	209	05:01	194	09:29	4.99	4.48	187
KAIGA STG2 (2*220)	440	447	448	450	02:40	441	11:34	11.32	10.38	433
KUDANKULAM (2*1000)	2000	1992	1997	2019	00:01	1978	16:31	49.06	46.05	1919
MAPS (2*220)	440	208	211	214	02:51	195	17:37	5.04	4.09	170
Total Nuclear	3320	2852	2855	-	-	-	-	70.41	65	2709
Total ISGS	17310	12809	13116	-	-	-	-	300.96	277.39	11559

JOINT VENTURE

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
NTPL (2*500)	1000	717	477	966	21:39	246	07:14	14.66	13.79	575
Vallur TPS (3*500)	1500	1314	1332	1395	02:36	730	08:44	29.54	27.46	1144
Total Thermal	2500	2031	1809	-	-	-	-	44.2	41.25	1719
Total JOINT VENTURE	2500	2031	1809	-	-	-	-	44.2	41.25	1719

IPP UNDER OPEN ACCESS

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
COASTAL ENERGEN (2*600)	1200	1139	1145	1162	02:33	0	16:20	24.62	22.91	955
IL&FS (2*600)	1200	783	569	999	23:47	314	09:23	13.78	12.78	533
JINDAL POWER LIMITED (Simhapuri Unit) (4*150)	600	532	510	545	22:47	272	10:13	11.45	10.27	428
MEENAKSHI ENERGY LTD STAGE1 (2*150)	300	82	91	94	05:00	72	08:07	2.25	2.02	84
MEENAKSHI ENERGY LTD STAGE2 (2*350)	700	243	245	273	14:56	212	11:06	6.32	5.74	239
SEIL (2*660)	1320	1245	1263	1278	00:55	579	13:17	28.5	27	1125
SEIL-PROJECT2 (1*660)	660	624	622	632	00:55	298	10:04	13.61	12.87	536
Total Thermal	5980	4648	4445	-	-	-	-	100.53	93.59	3900
Greenko (6 * 240 + 2 * 120)	1680	1183	402	1227	22:31	0	07:31	10.48	10.34	431
GREENKO(Pump) (6 * 240 + 2 * 120)	1680	0	0	1705	09:59	0	06:00	12.89	12.92	538
Total Hydro	1680	1183	402	-	-	-	-	10.48	10.34	431
LKPPL ST2 (233 + 133)	366	98	1	265	23:29	1	06:00	1.12	1.07	45
LKPPL ST3 (2*233 + 2*133)	732	0	0	0	00:00	0	06:00	0	0	0

Total Gas	1098	98	1	-	-	-	-	1.12	1.07	45
Total IPP UNDER OPEN ACCESS	8758	5929	4848	-	-	-	-	112.13	105	4376

RENEWABLE WIND

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
GADAG_GreenInfra_W	55	0	0	0	00:00	0	06:00	0	0	0
GADAG_RSPPL_W	202	9	19	227	14:03	1	15:20	1.29	1.29	54
GADAG_Serentica3_W	52	5	12	115	00:00	0	12:13	0.68	0.68	28
GADAG_VENA_W	133	0	0	0	00:00	0	06:00	0	0	0
GREEN INFRA	250	166	36	211	18:34	3	07:31	1.85	1.85	77
Hiriyur_Ostro	300	44	14	112	15:03	19	13:07	1.19	1.19	50
HIRIYUR_ZREPL_W	66	31	9	56	23:56	3	14:03	0.56	0.56	23
JSW RENEW ENERGY TWO LTD	300	269	40	278	11:20	38	06:00	4.39	4.39	183
KARUR_JSWRENEW_W	162	151	0	159	13:11	18	06:00	2.2	2.2	92
Karur_JSWRETwo_W	150	105	0	132	21:35	10	06:00	1.79	1.79	75
KARUR_TPVARDHAMAN_W	50	148	2	187	21:50	0	06:16	2.35	2.35	98
KOPPAL_AyanaSix_W	300	6	21	159	23:07	0	14:57	1.12	1.12	47
KOPPAL_Kleio_W	101	10	5	42	18:20	5	12:37	0.35	0.35	15
Koppal_RenewOjas_W	322	8	25	162	14:28	3	15:50	1.17	1.17	49
Koppal_RenewRoshni_W	286	31	11	175	13:56	2	06:18	0.86	0.86	36
KOPPAL_SRI1PL_W	79	25	83	159	00:03	0	12:23	1.25	1.25	52
Kurnool_AMGreeen_W	304	279	189	290	19:00	0	09:58	2.08	2.08	87
MYTRA	250	153	15	211	15:56	21	06:00	2.96	2.96	123
ORANGE	200	127	25	181	15:13	0	06:48	2.08	2.08	87
PGLR_SAUPL_W	53	34	0	47	13:36	1	10:09	0.45	0.45	19
PGLR_SREPL	300	187	1	289	12:20	15	07:22	3.19	3.19	133
TuticorinJSWRenewW	540	469	242	484	15:11	288	06:02	9.52	9.52	397
VIVID SOLAIRE (BEETAM)	220	164	19	220	16:24	10	06:10	2.9	2.9	121
Total SR_Wind	4675	2421	768	-	-	-	-	44.23	44.23	1846
Total RENEWABLE WIND	4675	2421	768	-	-	-	-	44.23	44.23	1846

RENEWABLE SOLAR

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
ANP_AdaniAPSeven	250	0	0	222	12:03	2	06:00	1.06	1.06	44
ANP_ATHENA BIWADI	50	0	0	43	13:00	0	06:00	0.24	0.24	10
ANP_ATHENA HISAR	50	0	0	52	11:29	0	06:00	0.28	0.28	12
ANP_ATHENA KARNAL	50	0	0	44	13:51	0	06:00	0.26	0.26	11
ANP_AYANA	250	0	0	264	10:34	3	06:00	1.64	1.64	68
ANP_AZURE	50	0	0	45	12:47	0	06:04	0.2	0.2	8
ANP_IGS1	50	0	0	49	12:35	0	06:00	0.28	0.28	12
ANP_IGS2	50	0	0	53	11:42	1	06:04	0.28	0.28	12
ANP_NTPC	250	0	0	179	12:41	0	06:04	0.91	0.91	38
ANP_TATA	100	0	0	92	12:00	0	06:00	0.47	0.47	20
SPRING ANG ITRA	250	0	0	255	12:32	2	06:00	1.28	1.28	53
Total NP_KUNTA	1400	0	0	-	-	-	-	6.9	6.9	288
PVG_ADYAH	300	0	0	277	11:16	0	06:00	1.9	1.9	79
PVG_AMPLUS PAVAGADA	50	0	0	51	12:21	0	06:00	0.34	0.34	14
PVG_AMPLUS TUMKUR	50	0	0	52	11:15	0	06:00	0.34	0.34	14
PVG_AVAADA SOLAR	150	0	0	150	11:18	0	06:00	1.02	1.02	43
PVG_AVAADA SOLARISE	150	0	0	152	12:38	0	06:00	0.93	0.93	39
PVG_AZURE POWER EARTH	100	0	0	100	12:16	0	06:00	0.7	0.7	29
PVG_FORTUM FIN SURYA	100	0	0	95	13:19	0	06:00	0.57	0.57	24
PVG_IRCON_S	225	0	0	392	13:06	1	06:00	2.97	2.97	124
PVG_KREDL	50	0	0	46	12:35	1	06:00	0.31	0.31	13
PVG_PARAMPUJYA	150	0	0	127	11:48	1	06:00	0.86	0.86	36

PVG_RENEW TN2	50	0	0	50	11:08	0	06:00	0.32	0.32	13
PVG_SBG ENERGY	200	0	0	172	13:13	0	06:00	1.11	1.11	46
PVG_SPRING SOLAR INDIA	250	0	0	251	13:26	0	06:00	1.67	1.67	70
PVG_TATA RENEWABLES	400	0	0	364	11:22	0	06:00	2.43	2.43	101
PVG_YARROW	50	0	0	46	11:12	1	06:00	0.29	0.29	12
Total PAVAGADA	2275	0	0	-	-	-	-	15.76	15.76	657
GADAG_Serentica3_S	69	0	0	153	10:00	0	06:00	0.4	0.4	17
GADAG_VENA_S	31	0	0	0	00:00	0	06:00	0	0	0
GRT	150	0	0	151	12:31	0	06:00	1.1	1.1	46
HIRIYUR_ZREPL_S	94	0	0	82	14:23	0	06:00	0.4	0.4	17
KOPPAL_Kleio_S	105	0	0	113	12:26	0	06:07	0.41	0.41	17
KOPPAL_RenewOjas_S	81	0	0	73	15:04	0	06:00	0.29	0.29	12
KOPPAL_SRI1PL_S	188	0	0	194	13:20	0	06:02	0.86	0.86	36
KOPPAL_TPSAURYA_S	131	0	0	243	12:25	0	06:03	1.01	1.01	42
Kurnool3_SAEL1_S	300	0	0	303	11:42	2	06:01	2.46	2.46	103
Kurnool3_SAEL2_S	300	0	0	301	09:22	0	06:00	2.36	2.36	98
Kurnool_AMGreen_S	599	0	0	554	11:52	7	06:00	3.39	3.39	141
Kurnool_Greenko_S	300	0	0	467	12:15	7	06:00	2.68	2.68	112
NTPC ETTAYAPURAM SOLAR PLANT	230	0	0	234	12:31	0	06:00	1.82	1.82	76
RAMANGUNDAM (SOLAR)	100	0	0	96	11:48	0	17:55	0.69	0.69	29
SIMHADRI (SOLAR)	25	0	0	24	10:47	0	17:59	0.17	0.17	7
Total OTHER	2703	0	0	-	-	-	-	18.04	18.04	753
Total RENEWABLE SOLAR	6378	0	0	-	-	-	-	40.7	40.7	1698

RENEWABLE BESS

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
KOPPAL_RenewOjas_BESS (Discharge)	75	64	0	68	05:33	0	07:36	0.18	0.18	8
KOPPAL_RenewOjas_BESS (Charge)	75	0	1	65	12:31	0	06:00	0.14	0.14	6
Total SR_BESS	75	64	0	-	-	-	-	0.18	0.18	8
Total RENEWABLE BESS	75	64	0	-	-	-	-	0.18	0.18	8

Total ISGS IPP Thermal	22470	16636	16515	-	-	-	-	375.28	347.23	14469
Total State Thermal	30742	18975	19921	-	-	-	-	457.12	422.67	17611
Total ISGS IPP Hydro	1680	1183	402	-	-	-	-	10.48	10.34	431
Total State Hydro	14298	4442	2149	-	-	-	-	60.4	59.85	2496
Total Gas/Naptha/Diesel	6423	211	121	-	-	-	-	5.05	4.73	197
Total Nuclear	3320	2852	2855	-	-	-	-	70.41	65	2709
Total Wind	24146	6047	3543	-	-	-	-	141.34	141.34	5891
Total Solar	35435	4	205	-	-	-	-	163.63	163.63	6821
Total Others	4752	1028	1002	-	-	-	-	21.99	21.99	917
Total BESS	75	64	0	-	-	-	-	0.18	0.18	8

4(A) INTER-REGIONAL EXCHANGES (Import=(+ve) /Export =(-ve))

SL.No.	Element	20:00	03:00	Maximum Interchange (MW)		Import in MU	Export in MU	NET
		MW	MW	Import	Export			
Import/Export between SOUTH REGION and EAST REGION								
1	220KV-UPPER_SILERU-BALIMELA	0	0	0.0	-	0	0	0
2	400KV-GAZUWAKA-JEYPORE	0	0	0.0	-	0	0	0
3	765KV-SRIKAKULAM-ANGUL	2163	1743	2458.0	-	43.14	0	43.14
4	HVDC500KV-TALCHER-KOLAR_DC	1847	1857	1881.0	-	40.03	0	40.03
Sub-Total EAST REGION		4010	3600	-	-	83.17	0	83.17
Import/Export between SOUTH REGION and WEST REGION								
1	220KV-AMBEWADI-PONDA	0	0	0.0	-	0	0	0
2	220KV-AMBEWADI-XELDEM	100	83	-	109.0	0	2.08	-2.08
3	220KV-CHIKKODI-MUDASANGI	0	0	0.0	-	0	0	0
4	220KV-CHIKKODI-TALANGADE	0	0	0.0	-	0	0	0

5	220KV-LOWER_SILERU-BARSUR	0	0	0.0	-	0	0	0
6	400KV-BHADRAVTAHI-RAMAGUNDAM	309	298	328.0	-	1.12	0	1.12
7	400KV-KUDGI_PG-KHOLAPUR_PG	929	1086	-	1832.0	0	28.83	-28.83
8	765KV-NIZAMABAD-WARDHA	1334	681	2046.0	-	24.37	0	24.37
9	765KV-RAICHUR_PG-SHOLAPUR	167	531	-	1393.0	0	8.09	-8.09
10	765KV-WARANGAL(NEW)-WARORA	1510	926	2164.0	-	27.76	0	27.76
11	HVDC800KV-RAIGARH HVDC-PUGALUR HVDC	563	563	1441.0	-	11.88	0	11.88
Sub-Total WEST REGION		4912	4168	-	-	65.13	39	26.13
TOTAL IR EXCHANGE		8922	7768	-	-	148.3	39	109.3

4(B) Inter Regional Schedule & Actual Exchange (Import=(+ve) /Export =(-ve)) in MU

Link	ISGS+URS+GNA	TGNA	GDAM	DAM	HPDAM	RTM	Total IR Schedule	Total IR Actual	Net UI
East-South	27.24	-8.46	0	0	0	-1.09	-22.84	42.97	65.81
West-South	63.44	12.06	1.09	26.83	0	-0.11	98.69	26.13	-72.56
Total	90.68	3.6	1.09	26.83	0	-1.2	75.85	69.1	-6.75

5. Frequency Profile

RANGE(Hz)	< 48.8	< 49	< 49.2	< 49.5	< 49.7	< 49.9	>= 49.9 - <= 50.05	> 50	> 50.05
%	0	0	0	0.417	4.641	10.313	70.313	52.535	19.375

Max Freq		Min Freq		Avg Freq	Freq Variation Index	Standard Deviation	Freq in 15 mnt blk	
Freq (HZ)	Time	Freq (HZ)	Time				Max (Hz)	Min (Hz)
50.279	18:02:30	49.451	00:36:00	49.985	0.117	0.108	50.16	49.51

6(A). Voltage Profile: 765 kV

Station	Max		Min		Voltage (in %)			
	Voltage	Time	Voltage	Time	< 720	< 750	> 780	> 800
KURNOOL - 765KV	799	23:57	775	06:35	0	0	89.58	0
NIZAMABAD - 765KV	799	23:58	774	15:11	0	0	90.14	0
RAICHUR_PG - 765KV	793	23:57	767	15:24	0	0	53.26	0
SRIKAKULAM - 765KV	794	10:00	766	14:42	0	0	75.07	0

6(B). Voltage Profile: 400 kV

Station	Max		Min		Voltage (in %)			
	Voltage	Time	Voltage	Time	< 380	< 390	> 420	> 430
GHANAPUR - 400KV	420	23:58	405	15:24	0	0	0.9	0
GOOTY - 400KV	424	02:52	402	11:24	0	0	11.32	0
HIRIYUR - 400KV	427	03:00	404	11:29	0	0	30.56	0
KAIGA - 400KV	425	20:37	397	09:23	0	0	16.81	0
KOLAR_AC - 400KV	424	03:07	394	09:11	0	0	10.9	0
KUDANKULAM - 400KV	419	00:13	396	09:54	0	0	0	0
SHANKARAPALLY - 400KV	422	23:58	410	15:13	0	0	4.93	0
SOMANAHALLI - 400KV	426	03:03	396	11:35	0	0	18.47	0
SRIPERUMBADUR - 400KV	415	00:16	403	10:55	0	0	0	0
TRICHY - 400KV	416	00:13	395	09:54	0	0	0	0
TRIVANDRUM - 400KV	420	20:02	389	09:53	0	0.28	0	0
VIJAYAWADA - 400KV	418	18:05	403	15:23	0	0	0	0

6(C). Voltage Profile: 220 kV

Station	Max		Min		Voltage (in %)			
	Voltage	Time	Voltage	Time	< 198	< 210	> 235	> 245
GHANAPUR - 220KV	229	23:58	220	15:51	0	0	0	0
GOOTY - 220KV	233	03:14	222	11:25	0	0	0	0
HIRIYUR - 220KV	232	02:05	229	00:03	0	0	0	0
KAIGA - 220KV	237	16:41	221	09:28	0	0	1.81	0
KOLAR_AC - 220KV	233	03:03	228	00:03	0	0	0	0
SOMANAHALLI - 220KV	239	03:03	220	11:28	0	0	22.29	0

SRIPERUMBADUR - 220KV	229	03:46	213	14:25	0	0	0	0
TRICHY - 220KV	235	00:14	208	09:54	0	1.94	0	0
TRIVANDRUM - 220KV	232	03:00	229	15:08	0	0	0	0
VIJAYAWADA - 220KV	240	06:10	218	15:11	0	0	3.26	0

7. Major Reservoir Particulars

RESERVOIR	DESIGNED			PRESENT		LAST YEAR		LAST DAY		MONTH	
	MDDL (m)	FRL (m)	Energy (MU)	Level (m)	Energy (MU)	Level (m)	Energy (MU)	Inflow (MU)	Usage (MU)	Prog Inflow (MU)	Prog Usage (MU)
IDUKKI	694.94	732.43	2148	706.06	452	714.63	906	3.76	9.22	3.76	16.64
JALAPUT	818.39	838.4	534	825.31	128	831.77	281	0.26	0	0.77	0
KAKKI	908.3	981.45	916	937.16	104	962.93	414	0.63	2.71	0.94	5.48
LINGANAMAKKI	522.73	554.5	4557	533.87	588	538.34	1044	0	12.62	0	25.31
N.SAGAR	149.3	179.9	1398	158.47	96	156.06	19	6.25	3.3	8.72	5.37
NILAGIRIS	0	0	1504	0	484	0	714	1.23	6.48	2.44	11.8
SRISAILAM	243.84	270.7	1392	249.39	58	253.75	127	0	0	0	0
SUPA	495	564	3159	526.47	688	530.25	852	0.19	7.51	0.31	15.9
Total	-	-	15608	-	2598	-	4357	12.32	41.84	16.94	80.5

8(A). Short-Term Open Access Details

State	Off- Peak Hours (03:00)												
	TGNA	IEX GDAM	IEX DAM	IEX HPDAM	IEX RTM	PXIL GDAM	PXIL DAM	PXIL HPDAM	PXIL RTM	HPX GDAM	HPX DAM	HPX HPDAM	HPX RTM
Andhra Pradesh	-7.77	-2.7	-438.1	0	-434.3	0	0	0	0	0	0	0	0
Karnataka	-521.83	-64.9	43.44	0	-41.4	0	0	0	0	0	0	0	0
Kerala	0	0	-10.2	0	29.67	0	0	0	0	0	0	0	0
Puducherry	49.07	0	-32	0	-45	0	0	0	0	0	0	0	0
Tamil Nadu	2833.02	0	-38.7	0	363.83	0	0	0	0	0	0	0	0
Telangana	-35.63	0	887.13	0	406.2	0	0	0	0	0	0	0	0
Total	2316.86	-67.6	411.57	0	279	0	0	0	0	0	0	0	0

State	Peak Hours (20:00)												
	TGNA	IEX GDAM	IEX DAM	IEX HPDAM	IEX RTM	PXIL GDAM	PXIL DAM	PXIL HPDAM	PXIL RTM	HPX GDAM	HPX DAM	HPX HPDAM	HPX RTM
Andhra Pradesh	-21.28	-2.1	-46.84	0	303.04	0	0	0	0	0	0	0	0
Karnataka	-839.19	-89.84	-48.12	0	11.73	0	0	0	0	0	0	0	0
Kerala	0	0	147.1	0	590.39	0	0	0	0	0	0	0	0
Puducherry	50.23	0	0	0	-32	0	0	0	0	0	0	0	0
Tamil Nadu	3862.92	1.05	584.36	0	-13.9	0	0	0	0	0	0	0	0
Telangana	-33.51	0	628.08	0	1265.06	0	0	0	0	0	0	0	0
Total	3019.17	-90.89	1264.58	0	2124.32	0	0	0	0	0	0	0	0

State	Day Energy (MU)						
	ISGS+GNA	TGNA	GDAM	DAM	HPDAM	RTM	Total
Andhra Pradesh	56.55	0.48	0.47	4.43	0	3.79	65.72
Karnataka	108.42	-8.73	-1.03	0.18	0	-1.61	97.23
Kerala	56.26	1.27	0.58	9.5	0	4.42	72.03
Puducherry	10.94	1.62	0	-0.43	0	-0.74	11.39
Tamil Nadu	185.76	40.06	1.98	-2.57	0	-35.03	190.2
Telangana	82.01	0.14	0.9	9.41	0	26.41	118.87
Total	499.94	34.84	2.9	20.52	0	-2.76	555.44

8(B). Short-Term Open Access Details

State	ISGS+GNA		TGNA		IEX GDAM		PXI GDAM		HPX GDAM		IEX DAM		PXI DAM	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
Andhra Pradesh	3167.28	1566.85	70.3	-28.25	151.86	-11.08	0	0	0	0	711.33	-628.82	0	0
Karnataka	6008.35	3691.7	-62.73	-839.19	72.03	-100.13	0	0	0	0	80.25	-86.77	0	0
Kerala	2681.79	1729.63	374.38	0	70.32	0	0	0	0	0	784.83	-10.2	0	0
Puducherry	535.68	374.34	91.09	48.3	0	0	0	0	0	0	0	-53	0	0
Tamil Nadu	8383.44	6972.56	3896.49	-57	286.87	0	0	0	0	0	1242.17	-1874.84	0	0

Telangana	4874.68	2653.16	50.03	-38.55	112.38	-1.3	0	0	0	0	1135.18	-7	0	0

State	HPX DAM		IEX HPDAM		PXI HPDAM		HPX HPDAM		IEX RTM		PXI RTM		HPX RTM	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
Andhra Pradesh	0	0	0	0	0	0	0	0	1342.02	-1120.39	0	0	0	0
Karnataka	0	0	0	0	0	0	0	0	16.99	-250.61	0	-400	0	0
Kerala	0	0	0	0	0	0	0	0	800.98	-2.6	0	0	0	0
Puducherry	0	0	0	0	0	0	0	0	0	-115	0	0	0	0
Tamil Nadu	0	0	0	0	0	0	0	0	829.13	-4741.28	285.38	0	0	0
Telangana	0	0	0	0	0	0	0	0	2190.27	198.88	0	0	0	0

9. Synchronisation of new generating units:

SL.NO	Station Name	Owner	Inst. Capacity (MW)	Date	Time

10. Synchronisation of new 220 / 400 / 765 KV Transmission elements and energising of bus /substation:

11. Significant events (If any):

1. 400 kV Bus 2 Bus Bar protection operated at 400kV Alamathy substation at 18:00 hrs on 03.06.2026
2. At 18:34 Hrs on 03.06.2026, 765kV NCPS7_TN station dead due to the tripping of 765kV NCPS7_TN-Ariyalur-2 on Y-N fault. Resulting a Generation loss 490 MW. 765kV NCPS7_TN-Ariyalur-2 charged at 20:14Hrs

12. Constraints and instances of congestion in the transmission system

1) 400KV-KALPAKKA-KHAMMAM_PG-1 & 400KV-KALPAKKA-ASUPAKA-1 Lines Under S/D for replacement of badly damaged rusted towers from Loc No.1 to 11 in 400KV Kalapaka – Khammam along with stringing of conductor at 400kv SS Kalapaka. S/D availed on 05-05-2026 ,Expected to be restored on 26-06-2026.
2) 400KV Kaiga-Guttur 1&2 tripped on 14.05.2026 at 17:39Hrs due to the tower collapse in multiple locations.
3) 400KV-GAZUWAKA-JEYPORE-1,2 under shutdown for NH-130CD Diversion works (Between 130-133/150-153/179-180) availed on 15-05-2026 at 09:36 Hrs. Expected to restore by 05.06.2026 18:00 Hrs.
4) 400KV-PAVAGADA_PG-TUMKUR-1&2 availed S/D on 17.05.2026 at 10:17Hrs for Conductor Release, Existing tower dismantle, New Tower erection, and stringing of the conductor for the work of Shifting/Heightening/Modification by providing 01 No. of 400KV DD+18 type tower, Expected to be restored on 05-06-2026.
5) 220KV-GADAG_PSS-Vena_GadagPS-1 and 220KV-GADAG_PSS-Green Infra_GadagPS-1 tripped on 17-05-2026 at 16:14 Hrs due to the tower collapse Loc. No.32-36. Generation affected 237MW(I.C)
6) At 18:13 hrs of 23-05-2026, 400KV-GADAG_PSS-KOPPAL D/C tripped on Y-B fault due to tower collapse. total 15 number of tower Collapsed (Tower location number 52-66).
7) 400KV-NAGAPATTNAM_PS-TRICHY-1&2 tripped on 31.05.2026 at 17:05Hrs due to the tower collapse at loc. 437(DA), 438(DA), 439(DB) towers are collapsed and 435(DA),436(DA),440(DA), 441(DA) towers are found cross arm/earth peak damaged.
8) 400/220kV SOMANAHALLI ICT-1 tripped at 20:07 hours of 31-05-2026 due to REF, Differential & body protections.
9) 400KV/220KV VIJAYAWADA-ICT-2 tripped on 25.05.2026 due to the failure of 220kV B-ph bushing. Expected charging on 15.06.2026

13. Weather Condition

Karnataka: Rains reported in Mangalore, Bangalore and Chikmangaluru areas;
Tamilnadu: Rains reported in Coimbatore area.

14. RE/Load Curtailment details

State	Load Curtailment (Shortage)			RE Curtailment				
	Energy (MU)	Max (MW)	At the time of maximum demand	Wind Max (MW)	Wind Energy (MU)	Solar Max (MW)	Solar Energy (MU)	Reason
Andhra Pradesh	0	0	0	0	0	0	0	0
Karnataka	0	0	0	0	0	0	0	0
Kerala	0	0	0	0	0	0	0	0
Puducherry	0	0	0	0	0	0	0	0
Tamil Nadu	0	0	0	0	0	0	0	0
Telangana	0	0	0	0	0	0	0	0

15.Instances of persistant/significant non-complaint with grid code

State	Frequency and Deviation				Voltage				ICT loading			
	Alert	Emergency	Extreme Emergency	Non Compliance	Alert	Emergency	Extreme Emergency	Non Compliance	Alert	Emergency	Extreme Emergency	Non Compliance
Andhra Pradesh	0	1	0	1	0	0	0	0	6	12	0	0
Karnataka	0	0	0	0	0	0	0	0	0	4	0	0
Kerala	0	0	0	0	0	0	0	0	0	0	0	0
Puducherry	0	0	0	0	0	0	0	0	0	0	0	0
Tamil Nadu	1	2	0	2	13	0	0	0	3	14	1	0
Telangana	0	0	0	0	0	0	0	0	0	0	0	0