ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
GRID CONTROLLER OF INDIA LIMITED
क्षेत्रीय लोड प्रेषण केन्द्र
SOUTHERN REGIONAL LOAD DESPATCH CENTER

Date of Reporting: 05-Jun-2026

Power Supply Position Report For

04-Jun-2026

1. Regional Availability/Demand:

Evening Peak (20:00) MW				Off-Peak (03:00) MW				Day Energy (Net MU)	
Demand Met	Shortage	Requirement	Freq (Hz)	Demand Met	Shortage	Requirement	Freq (Hz)	Demand Met	Shortage #
54699	0	54699	50.21	47779	0	47779	49.99	1279.33	0

2(A) State's Load Deails (At State Periphery) in MUs:

State	State's Control Area Generation (Net MU)						Net SCH	Drawal	UI	Availability	Demand Met	Shortage #
	THERMAL	HYDRO	GAS/DIESEL /NAPTHA	WIND	SOLAR	OTHERS	(Net Mu)	(Net Mu)	(Net Mu)	(Net Mu)	(Net Mu)	(Net Mu)
Andhra Pradesh	137.95	3.58	0	25.76	18.94	1.98	70.34	69.54	-0.8	258.55	257.75	0
Karnataka	84.23	19.76	0	30.76	34.84	8.93	93.46	90.63	-2.83	271.98	269.15	0
Kerala	0	9.94	0	0.55	0.67	0.27	78.19	77.7	-0.49	89.62	89.13	0
Puducherry	0	0	0.35	0	0.06	0	11.47	11.25	-0.22	11.88	11.66	0
Tamil Nadu	78.96	7.81	3.41	65.54	52.6	7.33	199.06	197.43	-1.63	414.71	413.08	0
Telangana	98.6	1.86	0	0.97	20.51	3.36	113.41	113.26	-0.15	238.71	238.56	0
Total	399.74	42.95	3.76	123.58	127.62	21.87	565.93	559.81	-6.12	1285.45	1279.33	0

2(B) State's Demand Met in MWs and day energy forecast and deviation particulars

State	Evening Peak (20:00) MW			Off-Peak (03:00) MW			Average Demand	Day Energy (Net MU)	
	Demand Met	Shortage	Requirement	Demand Met	Shortage	Requirement	(MW)	Forecast (LGBR)	Deviation [Forecast - Consumption]
Andhra Pradesh	10673	0	10673	10054	0	10054	10784	257	0.75
Karnataka	11277	0	11277	8516	0	8516	11113	270.65	-1.5
Kerala	4470	0	4470	3265	0	3265	3823	92.53	-3.4
Puducherry	533	0	533	443	0	443	476	11.8	-0.14
Tamil Nadu	18430	0	18430	16599	0	16599	17569	428	-14.92
Telangana	9316	0	9316	8902	0	8902	10054	235	3.56
Total	54699	0	54699	47779	0	47779	53819	1294.98	-15.65

2(C) State's Demand Met in MWs (maximum demand met and Maximum requirement of the day details)

State	Maximum Demand, corresponding shortage and requirement details for the day				Maximum requirement, corresponding shortage and demand details for the day				ACE			
	Maximum Demand Met	Time	Shortage at maximum demand	Requirement at the max demand met	Demand Met at maximum requiremnet	Time	Shortage at maximum Requirement	Maximum Requirement	Maximum ACE(MW)	Time	Minimum ACE(MW)	Time
Andhra Pradesh	13212	14:54	0	13212	13212	14:54	0	13212	965.5	08:02	-662.01	12:56
Karnataka	12543	10:00	0	12543	12543	10:00	0	12543	1217.51	00:04	-868.76	02:08
Kerala	4605	19:18	0	4605	4605	19:18	0	4605	1222.53	18:33	-325.68	11:26
Puducherry	545	21:45	0	545	545	21:45	0	545	81.24	09:46	-50.41	07:28
Tamil Nadu	19353	22:00	0	19353	19353	22:00	0	19353	2089.91	08:00	-751.6	00:01
Telangana	11536	12:44	0	11536	11536	12:44	0	11536	427.49	01:28	-568.56	09:29
Region	60039	15:27	0	60039	60039	15:27	0	60039	4187.86	07:58	-2905.96	17:56

3(A) State Entities Generation:

ANDHRA PRADESH

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
HINDUJA POWER CORPORATION LTD (2*520)	1040	1005	1010	1021	18:34	554	12:57	21.92	20.48	853
KRISHNAPATTANAM (3*800)	2400	1482	1544	2052	00:04	1284	13:02	38.78	36.33	1514
RAYALASEEMA TPP (5*210 + 600)	1650	613	1189	1471	00:03	601	16:47	24.01	21.7	904
SEIL P2 Unit-2 (1*660)	660	627	628	631	12:10	340	08:46	14.9	14.07	586
VIJAYAWADA TPS (6*210 + 500 + 800)	2560	2109	2216	2259	06:06	1504	09:09	49.08	45.37	1890
Total Thermal	8310	5836	6587	-	-	-	-	148.69	137.95	5747

DONKARAYI (1*25)	25	0	0	0	00:00	0	06:00	0	0	0
HAMPI & T.B.DAM (8 * 9)	57	0	0	0	00:00	0	06:00	0	0	0
LOWER SILERU (4*115)	460	97	13	315	12:29	13	14:35	2.48	2.46	103
MACHKUND (3 * 17 + 3 * 23)	84	0	0	0	00:00	0	06:00	0	0	0
NAGARJUNASAGAR TAILPOND (2*25)	50	0	0	0	00:00	0	06:00	0	0	0
NSR RT.CANAL.P.H (3*30)	90	0	0	0	00:00	0	06:00	0	0	0
SRISAILAM RBPH (7*110)	770	0	0	0	00:00	0	06:00	0	0	0
UPPER SILERU (4*60)	240	0	0	160	00:03	0	08:19	1.12	1.12	47
OTHER HYDEL	124	0	0	0	00:00	0	06:00	0	0	0
Total Hydro	1900	97	13	-	-	-	-	3.6	3.58	150
GAUTAMI CCPP (2*145 + 174)	464	0	0	0	00:00	0	06:00	0	0	0
GMR (BARG) (1 * 237)	237	0	0	0	00:00	0	06:00	0	0	0
JEGURUPADU (GAS) (2*45.8 + 49.9 + 75.5)	217	0	0	0	00:00	0	06:00	0	0	0
Jegrupadu Ext. (1 * 220)	220	0	0	0	00:00	0	06:00	0	0	0
KONASEEMA CCPP (145 + 140 + 165)	450	0	0	0	00:00	0	06:00	0	0	0
LANCO (GAS) (2*115 + 121)	351	0	0	0	00:00	0	06:00	0	0	0
RELIANCE ENERGY LTD. (GAS) (140 + 80)	220	0	0	0	00:00	0	06:00	0	0	0
SPECTRUM (GAS) (46.8 + 2*46.1 + 68.8)	208	0	0	0	00:00	0	06:00	0	0	0
VEMAGIRI POWER GENERATION LTD.(GAS) (233 + 137)	370	0	0	0	00:00	0	06:00	0	0	0
VIJJESWARAM GTS (2*33 + 34 + 112.5 + 59.5)	272	0	0	0	00:00	0	06:00	0	0	0
OTHER GAS/NAPTHA/DIESEL	27	0	0	0	00:00	0	06:00	0	0	0
Total Gas	3036	0	0	-	-	-	-	0	0	0
WIND	4102	1857	1112	1972	21:32	569	16:28	25.76	25.76	1073
SOLAR	3965	1	2	2443	10:38	36	06:00	18.94	18.94	789
OTHERS	619	118	124	189	14:11	114	06:13	1.98	1.98	83
Total ANDHRA PRADESH	21932	7909	7838	-	-	-	-	198.97	188.21	7842

TELANGANA

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
BHADRADRI TPS (4*270)	1080	812	805	844	00:01	513	13:31	18.95	17.06	711
KAKATIYA ST1&ST2 (500 + 600)	1100	1035	1038	1060	07:13	551	11:24	23.31	21.97	915
KOTHAGUDEM TPS (2*250 + 500 + 800)	1800	1318	1191	1386	23:40	910	15:10	29.31	27.26	1136
RAMAGUNDAM-B (1*62.5)	63	0	0	0	00:00	0	06:00	0	0	0
SINGARENI TPS (2*600)	1200	1090	1101	1111	00:46	310	09:58	20.6	19.2	800
YADADRI (4*800)	3200	615	386	711	15:51	597	13:05	15.05	13.11	546
Total Thermal	8443	4870	4521	-	-	-	-	107.22	98.6	4108
L JURALA (6*40)	240	0	0	0	00:00	0	06:00	0	0	0
NAGARJUNA SAGAR (110 + 7*100.8)	816	0	158	575	23:59	0	06:00	1.87	1.86	78
NAGARJUNA SAGAR (Pump) (110 + 7*100.8)	816	0	0	433	06:54	107	17:12	2.96	2.96	123
NIZAMSAGAR (2*5)	10	0	0	0	00:00	0	06:00	0	0	0
NSR LT.CANAL.P.H (2*30)	60	0	0	0	00:00	0	06:00	0	0	0
POCHAMPAD (4*9)	36	0	0	0	00:00	0	06:00	0	0	0
PULICHINTALA (4*30)	120	0	0	0	00:00	0	06:00	0	0	0
SINGUR (2*7.5)	15	0	0	0	00:00	0	06:00	0	0	0
SRISAILAM LBPH (6*150)	900	0	0	0	00:00	0	06:00	0	0	0
SRISAILAM LBPH(Pump) (6*150)	900	0	0	0	00:00	0	06:00	0	0	0
U JURALA (6*39)	234	0	0	0	00:00	0	06:00	0	0	0
OTHER HYDEL	51	0	0	0	00:00	0	06:00	0	0	0
Total Hydro	2482	0	158	-	-	-	-	1.87	1.86	78
WIND	128	34	61	96	05:53	13	14:27	0.97	0.97	40
SOLAR	3848	0	0	2537	11:52	14	06:00	20.51	20.51	855
OTHERS	252	140	140	140	00:00	140	06:00	3.36	3.36	140
Total TELANGANA	15153	5044	4880	-	-	-	-	133.93	125.3	5221

KARNATAKA

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak	Min Generation (06:00 to 18:00)	Day Energy	Avg

	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
Bellary TPS (2*500 + 700)	1700	1381	1094	1466	17:55	866	15:36	30.6	28.64	1193
JINDAL (2*130 + 4*300)	1460	752	898	1005	07:29	610	17:01	20.94	19.1	796
Jindal (Excl. Captive Consumption) (2 * 130 + 4 * 300)	1460	103	62	246	16:23	0	06:02	1.61	1.61	67
Raichur TPS (7*210 + 250)	1720	983	888	1041	04:51	855	15:15	25.18	22.61	942
UPCL (2*600)	1200	1102	603	1120	18:26	577	14:26	22.56	21.17	882
YERAMARAS TPS (2*800)	1600	0	855	1056	06:43	0	13:37	11.54	10.2	425
Total Thermal	7680	3569	3502	-	-	-	-	91.49	84.23	3509
Almatty (15 + 5*55)	290	0	0	0	00:00	0	06:00	0	0	0
Bhadra (2*12.1 + 7 + 2 + 6)	39	0	0	0	00:00	0	06:00	0	0	0
Ghataprabha (2*16)	32	0	0	0	00:00	0	06:00	0	0	0
JOG (MGHES) (4*21.6 + 4*13.2)	139	48	48	48	18:19	39	10:59	1.14	1.13	47
LINGANAMAKKI.P.H. (2*27.5)	55	8	8	8	18:11	7	14:18	0.19	0.18	8
Kadra (3*50)	150	141	0	144	23:21	0	06:00	0.66	0.64	27
Kodasalli (3*40)	120	111	0	111	19:49	0	06:00	0.78	0.76	32
MANI DAM.P.H. (2*4.5)	9	1	1	1	01:32	0	11:17	0.03	0.03	1
Munirabad (3*9 + 10)	37	0	0	0	00:00	0	06:00	0	0	0
NAGJHERI (135 + 5*150)	885	395	0	588	21:40	0	09:44	3.66	3.6	150
SHARAVATHI (10*103.5)	1035	466	468	854	19:04	247	12:17	11.03	10.95	456
Sharavati Tail Race (4*60)	240	108	0	161	19:15	0	06:00	0.47	0.46	19
SIVANSAMUDRAM (6*3 + 4*6)	42	1	0	6	15:50	0	06:00	0.04	0.03	1
Supa (2*50)	100	30	0	30	00:00	30	06:00	0.58	0.57	24
U JURALA (6*39)	234	0	0	0	00:00	0	06:00	0	0	0
Varahi UGPH (4*115)	460	45	57	254	02:18	34	10:27	1.45	1.42	59
OTHER HYDEL	143	0	0	0	00:00	0	06:00	0	0	0
Total Hydro	4010	1354	582	-	-	-	-	20.03	19.77	824
OTHER GAS/NAPTHA/DIESEL	126	0	0	0	00:00	0	06:00	0	0	0
Total Gas	126	0	0	-	-	-	-	0	0	0
WIND	5676	2021	1163	2118	19:48	771	07:35	30.76	30.76	1282
SOLAR	7171	0	3	4563	11:29	0	14:35	34.84	34.84	1452
OTHERS	1832	109	102	123	16:05	35	09:32	8.93	8.93	372
Total KARNATAKA	26495	7053	5352	-	-	-	-	186.05	178.53	7439

KERALA

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
Idamalayar (2*37.5)	75	0	0	51	00:28	0	06:00	0.09	0.08	3
Iddukki (6*130)	780	58	281	417	00:00	28	16:48	2.38	2.36	98
Kakkad (2*25)	50	18	34	36	22:14	0	09:21	0.43	0.43	18
KALLADA (2*7.5)	15	5	6	7	18:17	1	10:19	0.11	0.11	5
Kuttiyadi (3*25)	75	71	0	190	00:20	0	06:00	0.61	0.6	25
Lower Periyar (3*60)	180	0	0	171	22:34	0	06:00	0.65	0.65	27
Neriamangalam (3*17.5 + 25)	78	68	0	73	17:16	0	06:00	0.68	0.68	28
PALLIVASAL (3*5 + 3*7.5)	38	0	0	0	00:00	0	06:00	0	0	0
PALLIVASAL EXTENSION SCHEME (2*30)	60	35	18	60	00:01	23	14:08	1.11	1.11	46
Panniar (2*16.2)	32	0	0	0	00:00	0	06:00	0.22	0.22	9
PORINGALKUTHU (4*9)	36	0	26	50	00:02	0	06:00	0.15	0.15	6
Sengulam (4*12.8)	51	19	13	51	00:49	19	14:50	0.76	0.76	32
Sholayar (3*18)	54	10	0	53	01:30	0	06:00	0.16	0.16	7
Sabarigiri (4*55 + 2*60)	340	44	142	168	23:22	0	07:21	1.17	1.17	49
THOTTIYAR HEP (2*20)	40	0	0	30	00:40	0	06:00	0.3	0.3	13
OTHER HYDEL	230	27	54	234	01:23	0	06:00	1.15	1.15	48
Total Hydro	2134	355	574	-	-	-	-	9.97	9.93	414
BRAHMAPURAM DGPP (DIESEL) (3*21.32)	64	0	0	0	00:00	0	06:00	0	0	0
BSES (NAPTHA) (3*40.5 + 35.5)	157	0	0	0	00:00	0	06:00	0	0	0
KOZHIKODE DPP (DIESEL) (6*16)	96	0	0	0	00:00	0	06:00	0	0	0
MPS STEEL CASTINGS (1 * 10)	10	0	0	0	00:00	0	06:00	0	0	0

RGCCPP KAYAMKULAM (KSEB) - NTPC (2*116.6 + 126.38)	360	0	0	0	00:00	0	06:00	0	0	0
OTHER GAS/NAPTHA/DIESEL	22	0	0	0	00:00	0	06:00	0	0	0
Total Gas	709	0	0	-	-	-	-	0	0	0
WIND	70	11	3	22	17:18	2	07:58	0.55	0.55	23
SOLAR	1988	0	1	113	14:03	0	06:02	0.67	0.67	28
OTHERS	20	11	4	127	14:03	3	06:04	0.27	0.27	11
Total KERALA	4921	377	582	-	-	-	-	11.46	11.42	476

TAMIL NADU

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
Mettur TPS (4*210 + 600)	1440	798	1209	1280	07:39	768	11:51	27.67	25.39	1058
NORTH CHENNAI TPS STG-III (1*800)	800	454	29	539	22:03	10	10:42	5.51	4.77	199
NORTH CHENNAI TPS STG-II (2*600)	1200	611	619	733	23:39	593	15:32	16.37	15.03	626
North Chennai TPS (3*210)	630	407	479	501	22:37	386	15:32	11.79	10.64	443
UDANGUDI(Infirm - 660MW)	0	0	0	0	00:00	0	06:00	0	0	0
OPG PGPL (2*77 + 80 + 180)	414	268	271	303	22:39	195	11:04	6.89	6.26	261
SEPC (1*525)	525	0	0	0	00:00	0	06:00	0	0	0
ST - CMS (1*250)	250	208	214	243	20:23	86	14:48	5.34	4.9	204
Tuticorin (5*210)	1050	436	568	579	23:31	429	09:26	13.16	11.97	499
Total Thermal	6309	3182	3389	-	-	-	-	86.73	78.96	3290
Kadamparai (4*100)	400	0	98	99	07:02	0	07:30	0.75	0.74	31
Kadamparai (Pump) (4*100)	400	110	0	111	19:55	0	06:00	0.3	0.3	13
Kodayar I (1*60)	60	0	0	0	00:00	0	06:00	0	0	0
Kodayar II (1*40)	40	40	0	40	05:29	22	11:17	0.74	0.73	30
Kundah I (3*20)	60	2	6	53	09:43	1	08:01	0.62	0.61	25
Kundah II (5*35)	175	34	39	174	21:11	17	13:18	1.61	1.59	66
Kundah III (3*60)	180	10	4	127	09:29	5	07:06	0.86	0.85	35
Kundah IV (2*50)	100	0	0	93	00:04	0	06:00	0.2	0.2	8
Kundah V (2*20)	40	0	0	20	14:48	0	06:00	0.12	0.12	5
Kundah VI (1*30)	30	0	0	0	00:00	0	06:00	0	0	0
Mettur Dam (4*12.5)	50	0	0	0	07:57	0	06:00	0.21	0.2	8
Mettur Tunnel (4*50)	200	1	1	37	11:44	0	11:32	0.01	0.01	0
Moyar (3*12)	36	28	28	28	15:26	4	13:18	0.54	0.54	23
PAPANASAM (4*8)	32	4	4	30	14:48	4	06:00	0.1	0.1	4
Periyar (4*35)	140	23	0	23	22:19	0	06:00	0.27	0.27	11
Pykara (3*6.65 + 11 + 2*14)	59	6	11	11	00:00	7	07:20	0.16	0.16	7
PYKARA ULTIMATE (3*50)	150	0	62	152	05:39	0	07:59	1.06	1.05	44
Sarkarpathy (1*30)	30	12	12	13	06:09	12	11:31	0.3	0.3	13
Servalar (1*20)	20	10	0	10	18:05	0	06:00	0.02	0.02	1
Sholayar I (2*42)	84	0	0	0	00:00	0	06:00	0	0	0
Sholayar II (1*25)	25	0	0	0	00:00	0	06:00	0	0	0
Suruliyar (1*35)	35	0	0	0	00:00	0	06:00	0	0	0
OTHER HYDEL	1826	98	9	222	00:00	0	17:26	0.35	0.35	15
Total Hydro	3772	268	274	-	-	-	-	7.92	7.84	326
BASIN BRIDGE (NAPTHA) (4*30)	120	0	0	0	00:00	0	06:00	0	0	0
KOVIL KALAPPAL (GAS) (70 + 37.88)	108	0	0	0	00:00	0	06:00	0	0	0
KUTTALAM (GAS) (64 + 37)	101	85	70	85	23:27	70	06:00	1.97	1.83	76
MADURAI POWER CL (DIESEL) (1 * 106)	106	0	0	0	00:00	0	06:00	0	0	0
P P NALLUR (NAPTHA) (1 * 330.5)	331	0	0	0	00:00	0	06:00	0	0	0
SAMALPATTY (DIESEL) (7 * 15.1)	106	0	0	0	00:00	0	06:00	0	0	0
VALATTUR(STG1&STG2) (2*60 + 35 + 32)	187	30	32	65	10:04	29	06:15	1.7	1.58	66
OTHER GAS/NAPTHA/DIESEL	362	0	0	0	00:00	0	06:00	0	0	0
Total Gas	1421	115	102	-	-	-	-	3.67	3.41	142
WIND	9495	3335	1666	4276	14:15	1322	06:14	65.54	65.54	2731
SOLAR	12065	0	0	7285	11:31	44	06:00	52.6	52.6	2192
OTHERS	2029	687	670	687	19:15	654	14:48	7.33	7.33	305

Total TAMIL NADU	35091	7587	6101	-	-	-	-	223.79	215.68	8986

PUDUCHERRY

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
KARAIKAL POWER PLANT (GAS) (1 * 22.9 + 1 * 9.6)	33	15	15	15	00:00	15	06:00	0.38	0.35	15
Total Gas	33	15	15	-	-	-	-	0.38	0.35	15
SOLAR	20	0	0	10	11:27	0	06:00	0.06	0.06	3
Total PUDUCHERRY	53	15	15	-	-	-	-	0.44	0.41	18

3(B) Regional Entities Generation:

ISGS

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
KUDGI (3*800)	2400	1478	1480	2302	05:45	1226	08:12	38.16	35.52	1480
Neyveli TS I Expn (2*210)	420	266	317	320	01:06	204	13:19	6.78	6.05	252
Neyveli TS II (7*210)	1470	668	728	756	04:51	543	13:14	17.86	14.56	607
Neyveli TS II Expn (2*250)	500	0	0	0	00:00	0	06:00	0	0	0
NNTPS (2*500)	1000	228	372	393	00:11	219	16:35	7.14	5.33	222
NTPC-TELANGANA STPP (2*800)	1600	1306	1514	1528	03:07	764	08:06	30.22	28.16	1173
Ramagundam (3*200 + 4*500)	2600	1801	2458	2472	03:47	1066	15:16	40.44	37.51	1563
Simhadri Stage I (2*500)	1000	838	921	942	03:09	491	15:20	18.86	17.49	729
Simhadri Stage II (2*500)	1000	874	961	971	05:59	501	10:06	19.01	18.06	753
TALCHER ST2 (4*500)	2000	1778	1853	1886	21:26	983	12:09	41.9	39.5	1646
Total Thermal	13990	9237	10604	-	-	-	-	220.37	202.18	8425
KAIGA STG1 (2*220)	440	202	202	209	20:06	194	09:54	4.99	4.49	187
KAIGA STG2 (2*220)	440	449	447	452	09:57	441	11:29	11.32	10.36	432
KUDANKULAM (2*1000)	2000	1994	2000	2014	20:17	1980	17:18	49.1	46.27	1928
MAPS (2*220)	440	210	209	214	14:38	192	11:08	5.04	4.09	170
Total Nuclear	3320	2855	2858	-	-	-	-	70.45	65.21	2717
Total ISGS	17310	12092	13462	-	-	-	-	290.82	267.39	11142

JOINT VENTURE

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
NTPL (2*500)	1000	302	932	965	05:42	487	07:47	15.41	14.52	605
Vallur TPS (3*500)	1500	1239	1340	1372	01:36	732	10:32	27.8	25.78	1074
Total Thermal	2500	1541	2272	-	-	-	-	43.21	40.3	1679
Total JOINT VENTURE	2500	1541	2272	-	-	-	-	43.21	40.3	1679

IPP UNDER OPEN ACCESS

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
COASTAL ENERGEN (2*600)	1200	956	1111	1181	23:04	618	11:34	22.7	21.1	879
IL&FS (2*600)	1200	987	991	1000	18:27	582	09:46	21.31	19.85	827
JINDAL POWER LIMITED (Simhapuri Unit) (4*150)	600	370	542	547	03:53	259	10:43	10.35	9.25	385
MEENAKSHI ENERGY LTD STAGE1 (2*150)	300	92	92	94	20:56	63	11:00	2.24	1.98	83
MEENAKSHI ENERGY LTD STAGE2 (2*350)	700	240	240	258	21:46	215	08:49	6.21	5.63	235
SEIL (2*660)	1320	1237	1260	1275	07:19	612	11:08	28.02	26.48	1103
SEIL-PROJECT2 (1*660)	660	625	622	634	16:40	294	10:17	13.73	12.94	539
Total Thermal	5980	4507	4858	-	-	-	-	104.56	97.23	4051
Greenko (6 * 240 + 2 * 120)	1680	1043	509	1233	23:47	0	07:31	10.19	10.14	423
GREENKO(Pump) (6 * 240 + 2 * 120)	1680	0	0	1696	10:36	0	06:00	12.63	12.65	527
Total Hydro	1680	1043	509	-	-	-	-	10.19	10.14	423
LKPPL ST2 (233 + 133)	366	150	2	267	22:37	1	16:20	1.83	1.77	74
LKPPL ST3 (2*233 + 2*133)	732	0	0	0	00:00	0	06:00	0	0	0

Total Gas	1098	150	2	-	-	-	-	1.83	1.77	74
Total IPP UNDER OPEN ACCESS	8758	5700	5369	-	-	-	-	116.58	109.14	4548

RENEWABLE WIND

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
GADAG_GreenInfra_W	55	0	0	0	00:00	0	06:00	0	0	0
GADAG_RSPPL_W	202	237	135	262	19:37	52	07:18	3.21	3.21	134
GADAG_Serentica3_W	52	171	65	175	20:04	8	07:31	1.69	1.69	70
GADAG_VENA_W	133	0	0	0	00:00	0	06:00	0	0	0
GREEN INFRA	250	134	20	175	19:23	8	07:05	1.88	1.88	78
Hiriyur_Ostro	300	209	83	263	17:07	34	11:39	3.02	3.02	126
HIRIYUR_ZREPL_W	66	88	55	111	16:21	19	15:41	1.35	1.35	56
JSW RENEW ENERGY TWO LTD	300	217	79	276	19:25	56	06:17	4.54	4.54	189
KARUR_JSWRENEW_W	162	151	91	153	00:19	37	08:49	3.01	3.01	125
Karur_JSWRETwo_W	150	125	57	136	20:42	40	08:49	2.45	2.45	102
KARUR_TPVARDHAMAN_W	50	180	114	187	20:06	85	11:20	3.35	3.35	140
KOPPAL_AyanaSix_W	300	208	105	237	19:38	34	07:19	2.28	2.28	95
KOPPAL_Kleio_W	101	53	27	66	17:31	8	07:12	0.64	0.64	27
Koppal_RenewOjas_W	322	200	130	212	20:13	12	07:37	2.48	2.48	103
Koppal_RenewRoshni_W	286	218	96	231	19:18	35	12:30	2.51	2.51	105
KOPPAL_SRI1PL_W	79	122	93	149	21:18	23	14:05	2.17	2.17	90
Kurnool_AMGreeen_W	304	64	114	252	23:40	54	16:11	2.74	2.74	114
MYTRA	250	166	63	215	14:38	38	06:00	2.98	2.98	124
ORANGE	200	103	13	188	15:36	0	06:52	1.79	1.79	75
PGLR_SAUPL_W	53	43	8	47	19:00	2	06:00	0.7	0.7	29
PGLR_SREPL	300	288	90	312	22:43	35	06:01	4.69	4.69	195
TuticorinJSWRenewW	540	432	327	485	16:41	190	09:00	9.91	9.91	413
VIVID SOLAIRE (BEETAM)	220	163	37	220	14:30	24	06:00	2.68	2.68	112
Total SR_Wind	4675	3572	1802	-	-	-	-	60.07	60.07	2502
Total RENEWABLE WIND	4675	3572	1802	-	-	-	-	60.07	60.07	2502

RENEWABLE SOLAR

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
ANP_AdaniAPSeven	250	0	0	255	12:06	5	06:00	1.78	1.78	74
ANP_ATHENA BIWADI	50	0	0	43	12:52	0	06:00	0.27	0.27	11
ANP_ATHENA HISAR	50	0	0	52	12:52	1	06:00	0.28	0.28	12
ANP_ATHENA KARNAL	50	0	0	48	12:45	1	06:00	0.27	0.27	11
ANP_AYANA	250	0	0	262	12:07	5	06:00	1.75	1.75	73
ANP_AZURE	50	0	0	44	13:27	0	06:00	0.27	0.27	11
ANP_IGS1	50	0	0	49	12:46	1	06:00	0.27	0.27	11
ANP_IGS2	50	0	0	52	12:27	1	06:00	0.34	0.34	14
ANP_NTPC	250	0	0	174	12:20	0	06:00	1.09	1.09	45
ANP_TATA	100	0	0	92	12:59	1	06:00	0.53	0.53	22
SPRING ANG ITRA	250	0	0	263	13:00	4	06:00	1.82	1.82	76
Total NP_KUNTA	1400	0	0	-	-	-	-	8.67	8.67	360
PVG_ADYAH	300	0	0	272	12:34	0	06:00	1.78	1.78	74
PVG_AMPLUS PAVAGADA	50	0	0	52	11:45	1	06:00	0.35	0.35	15
PVG_AMPLUS TUMKUR	50	0	0	53	14:12	1	06:00	0.35	0.35	15
PVG_AVAADA SOLAR	150	0	0	150	12:38	0	06:00	0.99	0.99	41
PVG_AVAADA SOLARISE	150	0	0	155	12:42	1	06:00	0.97	0.97	40
PVG_AZURE POWER EARTH	100	0	0	99	12:59	0	06:00	0.67	0.67	28
PVG_FORTUM FIN SURYA	100	0	0	97	12:12	0	06:00	0.61	0.61	25
PVG_IRCON_S	225	0	0	402	12:41	2	06:00	3.03	3.03	126
PVG_KREDL	50	0	0	46	13:29	1	06:00	0.31	0.31	13
PVG_PARAMPUJYA	150	0	0	127	13:04	1	06:00	0.93	0.93	39

PVG_RENEW TN2	50	0	0	51	12:35	0	06:00	0.37	0.37	15
PVG_SBG ENERGY	200	0	0	185	12:06	0	06:00	1.27	1.27	53
PVG_SPRING SOLAR INDIA	250	0	0	249	12:40	0	06:00	1.67	1.67	70
PVG_TATA RENEWABLES	400	0	0	366	12:52	1	06:00	2.51	2.51	105
PVG_YARROW	50	0	0	48	12:43	1	06:00	0.29	0.29	12
Total PAVAGADA	2275	0	0	-	-	-	-	16.1	16.1	671
GADAG_Serentica3_S	69	0	0	153	14:34	0	06:00	0.8	0.8	33
GADAG_VENA_S	31	0	0	0	00:00	0	06:00	0	0	0
GRT	150	0	0	151	13:18	0	06:00	0.98	0.98	41
HIRIYUR_ZREPL_S	94	0	0	86	12:59	0	06:00	0.63	0.63	26
KOPPAL_Kleio_S	105	0	0	113	12:21	0	06:00	0.61	0.61	25
KOPPAL_RenewOjas_S	81	0	0	86	12:30	0	06:00	0.54	0.54	23
KOPPAL_SRI1PL_S	188	0	0	192	12:53	0	06:00	1.42	1.42	59
KOPPAL_TPSAURYA_S	131	0	0	243	12:35	0	06:00	1.79	1.79	75
Kurnool3_SAEL1_S	300	0	0	304	14:26	8	06:00	2.38	2.38	99
Kurnool3_SAEL2_S	300	0	0	300	09:48	7	06:00	2.22	2.22	93
Kurnool_AMGreen_S	599	0	0	548	13:34	10	06:00	3.93	3.93	164
Kurnool_Greenko_S	300	0	0	476	12:10	8	06:00	3.31	3.31	138
NTPC ETTAYAPURAM SOLAR PLANT	230	0	0	241	11:52	0	06:00	1.62	1.62	68
RAMANGUNDAM (SOLAR)	100	0	0	98	10:38	0	17:54	0.58	0.58	24
SIMHADRI (SOLAR)	25	0	0	24	11:55	0	17:58	0.18	0.18	8
Total OTHER	2703	0	0	-	-	-	-	20.99	20.99	876
Total RENEWABLE SOLAR	6378	0	0	-	-	-	-	45.76	45.76	1907

RENEWABLE BESS

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
KOPPAL_RenewOjas_BESS (Discharge)	75	0	0	64	07:32	0	07:37	0.12	0.12	5
KOPPAL_RenewOjas_BESS (Charge)	75	0	1	65	09:26	0	06:00	0.15	0.15	6
Total SR_BESS	75	0	0	-	-	-	-	0.12	0.12	5
Total RENEWABLE BESS	75	0	0	-	-	-	-	0.12	0.12	5

Total ISGS IPP Thermal	22470	15285	17734	-	-	-	-	368.14	339.71	14155
Total State Thermal	30742	17457	17999	-	-	-	-	434.13	399.74	16654
Total ISGS IPP Hydro	1680	1043	509	-	-	-	-	10.19	10.14	423
Total State Hydro	14298	2074	1601	-	-	-	-	43.39	42.98	1792
Total Gas/Naptha/Diesel	6423	280	119	-	-	-	-	5.88	5.53	231
Total Nuclear	3320	2855	2858	-	-	-	-	70.45	65.21	2717
Total Wind	24146	10830	5807	-	-	-	-	183.65	183.65	7651
Total Solar	35435	1	6	-	-	-	-	173.38	173.38	7226
Total Others	4752	1065	1040	-	-	-	-	21.87	21.87	911
Total BESS	75	0	0	-	-	-	-	0.12	0.12	5

4(A) INTER-REGIONAL EXCHANGES (Import=(+ve) /Export =(-ve))

SL.No.	Element	20:00	03:00	Maximum Interchange (MW)		Import in MU	Export in MU	NET
		MW	MW	Import	Export			
Import/Export between SOUTH REGION and EAST REGION								
1	220KV-UPPER_SILERU-BALIMELA	0	0	0.0	-	0	0	0
2	400KV-GAZUWAKA-JEYPORE	0	0	0.0	-	0	0	0
3	765KV-SRIKAKULAM-ANGUL	2212	1493	2591.0	-	39.89	0	39.89
4	HVDC500KV-TALCHER-KOLAR_DC	1846	1856	1856.0	-	42.54	0	42.54
Sub-Total EAST REGION		4058	3349	-	-	82.43	0	82.43
Import/Export between SOUTH REGION and WEST REGION								
1	220KV-AMBEWADI-PONDA	0	0	0.0	-	0	0	0
2	220KV-AMBEWADI-XELDEM	97	87	-	105.0	0	2.05	-2.05
3	220KV-CHIKKODI-MUDASANGI	0	0	0.0	-	0	0	0
4	220KV-CHIKKODI-TALANGADE	0	0	0.0	-	0	0	0

5	220KV-LOWER_SILERU-BARSUR	0	0	0.0	-	0	0	0
6	400KV-BHADRAVTAHI-RAMAGUNDAM	511	309	-	926.0	0	11.35	-11.35
7	400KV-KUDGI_PG-KHOLAPUR_PG	1234	1417	-	2131.0	0	35.07	-35.07
8	765KV-NIZAMABAD-WARDHA	1660	397	2407.0	-	25.6	0	25.6
9	765KV-RAICHUR_PG-SHOLAPUR	576	877	-	1626.0	0	8.78	-8.78
10	765KV-WARANGAL(NEW)-WARORA	1908	608	2537.0	-	28.4	0	28.4
11	HVDC800KV-RAIGARH HVDC-PUGALUR HVDC	561	1442	1448.0	-	22.31	0	22.31
Sub-Total WEST REGION		6547	5137	-	-	76.31	57.25	19.06
TOTAL IR EXCHANGE		10605	8486	-	-	158.74	57.25	101.49

4(B) Inter Regional Schedule & Actual Exchange (Import=(+ve) /Export =(-ve)) in MU

Link	ISGS+URS+GNA	TGNA	GDAM	DAM	HPDAM	RTM	Total IR Schedule	Total IR Actual	Net UI
East-South	25.61	-16.61	0	0	0	-0.43	-31.74	42.93	74.67
West-South	62.16	4.58	1.09	13.47	0	23.77	96.7	19.06	-77.64
Total	87.77	-12.03	1.09	13.47	0	23.34	64.96	61.99	-2.97

5. Frequency Profile

RANGE(Hz)	< 48.8	< 49	< 49.2	< 49.5	< 49.7	< 49.9	>= 49.9 - <= 50.05	> 50	> 50.05
%	0	0	0	0	0	4.19	71.528	50.683	24.282

Max Freq		Min Freq		Avg Freq	Freq Variation Index	Standard Deviation	Freq in 15 mnt blk	
Freq (HZ)	Time	Freq (HZ)	Time				Max (Hz)	Min (Hz)
50.251	07:59:40	49.841	11:32:30	50.005	0.045	0.067	50.18	49.9

6(A). Voltage Profile: 765 kV

Station	Max		Min		Voltage (in %)			
	Voltage	Time	Voltage	Time	< 720	< 750	> 780	> 800
KURNOOL - 765KV	804	04:01	778	15:41	0	0	90.97	15.14
NIZAMABAD - 765KV	802	02:28	779	15:29	0	0	97.78	6.18
RAICHUR_PG - 765KV	795	02:26	767	11:55	0	0	60.07	0
SRIKAKULAM - 765KV	795	04:02	770	15:46	0	0	70.9	0

6(B). Voltage Profile: 400 kV

Station	Max		Min		Voltage (in %)			
	Voltage	Time	Voltage	Time	< 380	< 390	> 420	> 430
GHANAPUR - 400KV	424	02:13	408	14:58	0	0	25.56	0
GOOTY - 400KV	422	02:29	399	12:10	0	0	11.94	0
HIRIYUR - 400KV	426	02:12	401	10:20	0	0	22.29	0
KAIGA - 400KV	431	18:05	395	09:55	0	0	17.01	0.28
KOLAR_AC - 400KV	421	03:26	393	09:06	0	0	1.53	0
KUDANKULAM - 400KV	418	00:00	401	10:20	0	0	0	0
SHANKARAPALLY - 400KV	425	02:13	412	15:44	0	0	36.18	0
SOMANAHALLI - 400KV	423	03:25	394	10:19	0	0	18.47	0
SRIPERUMBADUR - 400KV	418	02:24	403	12:00	0	0	0	0
TRICHY - 400KV	414	00:00	397	12:23	0	0	0	0
TRIVANDRUM - 400KV	420	03:24	399	11:12	0	0	0	0
VIJAYAWADA - 400KV	419	08:00	405	14:50	0	0	0	0

6(C). Voltage Profile: 220 kV

Station	Max		Min		Voltage (in %)			
	Voltage	Time	Voltage	Time	< 198	< 210	> 235	> 245
GHANAPUR - 220KV	231	02:13	220	15:19	0	0	0	0
GOOTY - 220KV	233	02:26	222	10:48	0	0	0	0
HIRIYUR - 220KV	238	15:40	216	10:27	0	0	0.21	0
KAIGA - 220KV	240	18:02	220	09:56	0	0	4.44	0
KOLAR_AC - 220KV	230	00:01	212	09:52	0	0	0	0
SOMANAHALLI - 220KV	238	03:00	218	10:53	0	0	21.88	0

SRIPERUMBADUR - 220KV	229	05:00	211	16:44	0	0	0	0
TRICHY - 220KV	230	20:32	214	11:12	0	0	0	0
TRIVANDRUM - 220KV	232	03:24	229	21:14	0	0	0	0
VIJAYAWADA - 220KV	236	01:57	219	14:54	0	0	0.42	0

7. Major Reservoir Particulars

RESERVOIR	DESIGNED			PRESENT		LAST YEAR		LAST DAY		MONTH	
	MDDL (m)	FRL (m)	Energy (MU)	Level (m)	Energy (MU)	Level (m)	Energy (MU)	Inflow (MU)	Usage (MU)	Prog Inflow (MU)	Prog Usage (MU)
IDUKKI	694.94	732.43	2148	706.03	451	714.56	901	6.04	7.42	6.04	18.99
JALAPUT	818.39	838.4	534	825.28	127	831.71	279	0	0	0.77	0
KAKKI	908.3	981.45	916	937.34	107	963.08	413	5.5	2.77	5.81	6.64
LINGANAMAKKI	522.73	554.5	4557	533.67	571	538.29	1039	0	12.69	0	36.25
N.SAGAR	149.3	179.9	1398	158.4	94	156	17	0.08	2.07	8.8	7.23
NILAGIRIS	0	0	1504	0	480	0	711	1.63	5.32	4.07	16.91
SRISAILAM	243.84	270.7	1392	249.45	59	254.17	136	0	0	0	0
SUPA	495	564	3159	526.39	685	530.1	845	0.01	8.39	0.32	20.07
Total	-	-	15608	-	2574	-	4341	13.26	38.66	25.81	106.09

8(A). Short-Term Open Access Details

State	Off- Peak Hours (03:00)												
	TGNA	IEX GDAM	IEX DAM	IEX HPDAM	IEX RTM	PXIL GDAM	PXIL DAM	PXIL HPDAM	PXIL RTM	HPX GDAM	HPX DAM	HPX HPDAM	HPX RTM
Andhra Pradesh	-33.23	-1.4	-334.2	0	0.8	0	0	0	0	0	0	0	0
Karnataka	-530.83	-49.84	10.92	0	-31.19	0	0	0	0	0	0	0	0
Kerala	0	0	305.89	0	-1.1	0	0	0	0	0	0	0	0
Puducherry	56.99	0	-95	0	-102	0	0	0	0	0	0	0	0
Tamil Nadu	2131.93	0	-24.7	0	258.61	0	0	0	0	0	0	0	0
Telangana	-167.49	0.19	446.39	0	680.86	0	0	0	0	0	0	0	0
Total	1457.37	-51.05	309.3	0	805.98	0	0	0	0	0	0	0	0

State	Peak Hours (20:00)												
	TGNA	IEX GDAM	IEX DAM	IEX HPDAM	IEX RTM	PXIL GDAM	PXIL DAM	PXIL HPDAM	PXIL RTM	HPX GDAM	HPX DAM	HPX HPDAM	HPX RTM
Andhra Pradesh	-24.29	-0.9	-30.89	0	403.19	0	0	0	0	0	0	0	0
Karnataka	-705.74	-59.08	-0.93	0	46.65	0	0	0	0	0	0	0	0
Kerala	0	0	104.64	0	776.25	0	0	0	0	0	0	0	0
Puducherry	55.97	0	0	0	-34	0	0	0	0	0	0	0	0
Tamil Nadu	3382.69	0	310.83	0	419.75	0	0	0	0	0	0	0	0
Telangana	-39.16	0.19	748.49	0	192.6	0	0	0	0	0	0	0	0
Total	2669.47	-59.79	1132.14	0	1804.44	0	0	0	0	0	0	0	0

State	Day Energy (MU)						
	ISGS+GNA	TGNA	GDAM	DAM	HPDAM	RTM	Total
Andhra Pradesh	59.28	0.37	0.63	0.93	0	9.12	70.33
Karnataka	103.37	-8.5	-1.21	0.54	0	-0.74	93.46
Kerala	57.67	1.14	0.55	10.34	0	8.5	78.2
Puducherry	12.38	1.69	0	-1.4	0	-1.2	11.47
Tamil Nadu	186.22	37.59	1.84	-4.93	0	-21.66	199.06
Telangana	81	-0.34	0.62	5.99	0	26.15	113.42
Total	499.92	31.95	2.43	11.47	0	20.17	565.94

8(B). Short-Term Open Access Details

State	ISGS+GNA		TGNA		IEX GDAM		PXI GDAM		HPX GDAM		IEX DAM		PXI DAM	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
Andhra Pradesh	3337.86	1676.96	79.38	-34.11	149.74	-11.91	0	0	0	0	385.79	-538	0	0
Karnataka	5983.49	3215.9	-75.93	-707.17	58.65	-350.75	0	0	0	0	80.28	-23.95	0	0
Kerala	3239.95	1890.77	357.91	0	72.64	0	0	0	0	0	803.67	-10.17	0	0
Puducherry	585.41	414.71	91.09	51	0	0	0	0	0	0	0	-128	0	0
Tamil Nadu	8752.57	6534.83	3603.26	-60.7	250.07	0	0	0	0	0	970.32	-1869.41	0	0

Telangana	4599.71	2325.54	48.52	-167.97	77.32	-1.95	0	0	0	0	1007.83	-42.9	0	0

State	HPX DAM		IEX HPDAM		PXI HPDAM		HPX HPDAM		IEX RTM		PXI RTM		HPX RTM	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
Andhra Pradesh	0	0	0	0	0	0	0	0	1239.47	-240.4	0	0	0	0
Karnataka	0	0	0	0	0	0	0	0	635.27	-1033.69	0	0	0	0
Kerala	0	0	0	0	0	0	0	0	1579.27	-1.1	0	0	0	0
Puducherry	0	0	0	0	0	0	0	0	0	-132	0	0	0	0
Tamil Nadu	0	0	0	0	0	0	0	0	957	-3921.7	0	0	0	0
Telangana	0	0	0	0	0	0	0	0	2669.26	181.59	0	0	0	0

9. Synchronisation of new generating units:

SL.NO	Station Name	Owner	Inst. Capacity (MW)	Date	Time

10. Synchronisation of new 220 / 400 / 765 KV Transmission elements and energising of bus /substation:

11. Significant events (If any):

Nil

12. Constraints and instances of congestion in the transmission system

1) 400KV-KALPAKKA-KHAMMAM_PG-1 & 400KV-KALPAKKA-ASUPAKA-1 Lines Under S/D for replacement of badly damaged rusted towers from Loc No.1 to 11 in 400KV Kalapaka – Khammam along with stringing of conductor at 400kv SS Kalapaka. S/D availed on 05-05-2026 ,Expected to be restored on 26-06-2026.
2) 400KV Kaiga-Guttur 1&2 tripped on 14.05.2026 at 17:39Hrs due to the tower collapse in multiple locations.
3) 400KV-GAZUWAKA-JEYPORE-1,2 under shutdown for NH-130CD Diversion works (Between 130-133/150-153/179-180) availed on 15-05-2026 at 09:36 Hrs. Expected to restore by 05.06.2026 18:00 Hrs.
4) 400KV-PAVAGADA_PG-TUMKUR-1&2 availed S/D on 17.05.2026 at 10:17Hrs for Conductor Release, Existing tower dismantle, New Tower erection, and stringing of the conductor for the work of Shifting/Heightening/Modification by providing 01 No. of 400KV DD+18 type tower, Expected to be restored on 05-06-2026.
5) 220KV-GADAG_PSS-Vena_GadagPS-1 and 220KV-GADAG_PSS-Green Infra_GadagPS-1 tripped on 17-05-2026 at 16:14 Hrs due to the tower collapse Loc. No.32-36. Generation affected 237MW(I.C)
6) At 18:13 hrs of 23-05-2026, 400KV-GADAG_PSS-KOPPAL D/C tripped on Y-B fault due to tower collapse. total 15 number of tower Collapsed (Tower location number 52-66).
7) 400KV-NAGAPATTNAM_PS-TRICHY-1&2 tripped on 31.05.2026 at 17:05Hrs due to the tower collapse at loc. 437(DA), 438(DA), 439(DB) towers are collapsed and 435(DA),436(DA),440(DA), 441(DA) towers are found cross arm/earth peak damaged.
8) 400/220kV SOMANAHALLI ICT-1 tripped at 20:07 hours of 31-05-2026 due to REF, Differential & body protections.
9) 400KV/220KV VIJAYAWADA-ICT-2 tripped on 25.05.2026 due to the failure of 220kV B-ph bushing. Expected charging on 15.06.2026

13. Weather Condition

Kerala:Moderate rains reported in the state.
Telengana:Mderate rains reported in Hydrabad and Northern part of the states.
Tamilnadu:Moderate rains reported in Madurai district

14. RE/Load Curtailment details

State	Load Curtailment (Shortage)			RE Curtailment				
	Energy (MU)	Max (MW)	At the time of maximum demand	Wind Max (MW)	Wind Energy (MU)	Solar Max (MW)	Solar Energy (MU)	Reason
Andhra Pradesh	0	0	0	0	0	0	0	0
Karnataka	0	0	0	0	0	0	0	0
Kerala	0	0	0	0	0	0	0	0
Puducherry	0	0	0	0	0	0	0	0
Tamil Nadu	0	0	0	0	0	0	0	0
Telangana	0	0	0	0	0	0	0	0

15.Instances of persistant/significant non-complaint with grid code

State	Frequency and Deviation				Voltage				ICT loading			
	Alert	Emergency	Extreme Emergency	Non Compliance	Alert	Emergency	Extreme Emergency	Non Compliance	Alert	Emergency	Extreme Emergency	Non Compliance
Andhra Pradesh	0	1	0	0	3	0	0	0	8	0	0	0
Karnataka	0	2	0	2	1	0	0	0	11	7	0	0
Kerala	0	0	0	0	0	0	0	0	2	0	0	0
Puducherry	0	0	0	0	0	0	0	0	0	0	0	0
Tamil Nadu	0	2	0	5	0	0	0	0	0	16	0	0
Telangana	0	0	0	0	23	1	0	0	0	0	0	0