ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
GRID CONTROLLER OF INDIA LIMITED
क्षेत्रीय लोड प्रेषण केन्द्र
SOUTHERN REGIONAL LOAD DESPATCH CENTER

Date of Reporting: 06-Jun-2026

Power Supply Position Report For

05-Jun-2026

1. Regional Availability/Demand:

Evening Peak (20:00) MW				Off-Peak (03:00) MW				Day Energy (Net MU)	
Demand Met	Shortage	Requirement	Freq (Hz)	Demand Met	Shortage	Requirement	Freq (Hz)	Demand Met	Shortage #
54090	0	54090	50.04	47590	0	47590	50.02	1278.77	0

2(A) State's Load Deails (At State Periphery) in MUs:

State	State's Control Area Generation (Net MU)						Net SCH	Drawal	UI	Availability	Demand Met	Shortage #
	THERMAL	HYDRO	GAS/DIESEL /NAPTHA	WIND	SOLAR	OTHERS	(Net Mu)	(Net Mu)	(Net Mu)	(Net Mu)	(Net Mu)	(Net Mu)
Andhra Pradesh	131.49	5.62	0	34.46	18.21	2.14	71.74	71.18	-0.56	263.66	263.1	0
Karnataka	78.87	21.87	0	33.18	28.98	7.16	106.31	104.67	-1.64	276.37	274.73	0
Kerala	0	13.85	0	0.49	0.52	0.28	73.41	72.79	-0.62	88.55	87.93	0
Puducherry	0	0	0.36	0	0.07	0	11.58	11.37	-0.21	12.01	11.8	0
Tamil Nadu	73.66	6.72	3.39	71.29	53.4	4.71	192.71	190.46	-2.25	405.88	403.63	0
Telangana	102.01	2.86	0	0.97	20.48	2.98	109.72	108.28	-1.44	239.02	237.58	0
Total	386.03	50.92	3.75	140.39	121.66	17.27	565.47	558.75	-6.72	1285.49	1278.77	0

2(B) State's Demand Met in MWs and day energy forecast and deviation particulars

State	Evening Peak (20:00) MW			Off-Peak (03:00) MW			Average Demand	Day Energy (Net MU)	
	Demand Met	Shortage	Requirement	Demand Met	Shortage	Requirement	(MW)	Forecast (LGBR)	Deviation [Forecast - Consumption]
Andhra Pradesh	10564	0	10564	10125	0	10125	10926	257	6.1
Karnataka	10770	0	10770	9025	0	9025	11406	272.3	2.43
Kerala	4395	0	4395	3120	0	3120	3740	89	-1.07
Puducherry	528	0	528	466	0	466	482	11.3	0.5
Tamil Nadu	18336	0	18336	16140	0	16140	17105	421	-17.37
Telangana	9497	0	9497	8714	0	8714	10053	230	7.58
Total	54090	0	54090	47590	0	47590	53712	1280.6	-1.83

2(C) State's Demand Met in MWs (maximum demand met and Maximum requirement of the day details)

State	Maximum Demand, corresponding shortage and requirement details for the day				Maximum requirement, corresponding shortage and demand details for the day				ACE			
	Maximum Demand Met	Time	Shortage at maximum demand	Requirement at the max demand met	Demand Met at maximum requiremnet	Time	Shortage at maximum Requirement	Maximum Requirement	Maximum ACE(MW)	Time	Minimum ACE(MW)	Time
Andhra Pradesh	13539	14:54	0	13539	13539	14:54	0	13539	844.82	18:05	-749.24	22:31
Karnataka	13904	10:00	0	13904	13904	10:00	0	13904	1000.16	14:21	-866.51	09:11
Kerala	4566	19:16	0	4566	4566	19:16	0	4566	370.75	14:18	-290.49	09:20
Puducherry	570	22:30	0	570	570	22:30	0	570	56.69	15:28	-19.47	18:50
Tamil Nadu	19381	22:00	0	19381	19381	22:00	0	19381	1657.5	09:00	-1336.86	23:02
Telangana	11585	12:50	0	11585	11585	12:50	0	11585	546.66	14:03	-379.06	21:16
Region	58424	14:30	0	58424	58424	14:30	0	58424	3973.69	14:18	-3225.94	10:59

3(A) State Entities Generation:

ANDHRA PRADESH

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
HINDUJA POWER CORPORATION LTD (2*520)	1040	1012	1012	1035	19:14	554	08:39	21.73	20.49	854
KRISHNAPATTANAM (3*800)	2400	1904	1520	2020	20:40	1324	07:41	39.22	36.84	1535
RAYALASEEMA TPP (5*210 + 600)	1650	874	637	922	20:29	603	16:16	17.97	15.93	664
SEIL P2 Unit-2 (1*660)	660	629	623	633	14:37	338	09:44	15.2	14.39	600
VIJAYAWADA TPS (6*210 + 500 + 800)	2560	2181	2138	2227	20:18	1441	10:15	47.56	43.84	1827
Total Thermal	8310	6600	5930	-	-	-	-	141.68	131.49	5480

DONKARAYI (1*25)	25	0	0	0	00:00	0	06:00	0	0	0
HAMPI & T.B.DAM (8 * 9)	57	0	0	0	00:00	0	06:00	0	0	0
LOWER SILERU (4*115)	460	277	302	410	22:13	13	08:48	4.18	4.16	173
MACHKUND (3 * 17 + 3 * 23)	84	0	0	0	00:00	0	06:00	0	0	0
NAGARJUNASAGAR TAILPOND (2*25)	50	0	0	0	00:00	0	06:00	0	0	0
NSR RT.CANAL.P.H (3*30)	90	0	0	0	00:00	0	06:00	0	0	0
SRISAILAM RBPH (7*110)	770	0	0	0	00:00	0	06:00	0	0	0
UPPER SILERU (4*60)	240	111	40	167	10:57	0	06:19	1.46	1.46	61
OTHER HYDEL	124	0	0	0	00:00	0	06:00	0	0	0
Total Hydro	1900	388	342	-	-	-	-	5.64	5.62	234
GAUTAMI CCPP (2*145 + 174)	464	0	0	0	00:00	0	06:00	0	0	0
GMR (BARG) (1 * 237)	237	0	0	0	00:00	0	06:00	0	0	0
JEGURUPADU (GAS) (2*45.8 + 49.9 + 75.5)	217	0	0	0	00:00	0	06:00	0	0	0
Jegrupadu Ext. (1 * 220)	220	0	0	0	00:00	0	06:00	0	0	0
KONASEEMA CCPP (145 + 140 + 165)	450	0	0	0	00:00	0	06:00	0	0	0
LANCO (GAS) (2*115 + 121)	351	0	0	0	00:00	0	06:00	0	0	0
RELIANCE ENERGY LTD. (GAS) (140 + 80)	220	0	0	0	00:00	0	06:00	0	0	0
SPECTRUM (GAS) (46.8 + 2*46.1 + 68.8)	208	0	0	0	00:00	0	06:00	0	0	0
VEMAGIRI POWER GENERATION LTD.(GAS) (233 + 137)	370	0	0	0	00:00	0	06:00	0	0	0
VIJJESWARAM GTS (2*33 + 34 + 112.5 + 59.5)	272	0	0	0	00:00	0	06:00	0	0	0
OTHER GAS/NAPTHA/DIESEL	27	0	0	0	00:00	0	06:00	0	0	0
Total Gas	3036	0	0	-	-	-	-	0	0	0
WIND	4102	1895	1521	2180	19:13	663	07:17	34.46	34.46	1436
SOLAR	3965	2	1	2398	11:47	13	06:00	18.21	18.21	759
OTHERS	619	116	119	151	10:00	106	15:33	2.14	2.14	89
Total ANDHRA PRADESH	21932	9001	7913	-	-	-	-	202.13	191.92	7998

TELANGANA

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
BHADRADRI TPS (4*270)	1080	878	791	892	23:19	513	14:20	18.94	17.05	710
KAKATIYA ST1&ST2 (500 + 600)	1100	1027	1038	1060	01:41	550	13:35	22.52	21.2	883
KOTHAGUDEM TPS (2*250 + 500 + 800)	1800	1362	1277	1467	06:22	910	13:19	29.08	27	1125
RAMAGUNDAM-B (1*62.5)	63	0	0	0	00:00	0	06:00	0	0	0
SINGARENI TPS (2*600)	1200	1040	1074	1106	07:41	574	10:47	23.54	22.12	922
YADADRI (4*800)	3200	673	559	744	21:06	557	06:22	16.41	14.64	610
Total Thermal	8443	4980	4739	-	-	-	-	110.49	102.01	4250
L JURALA (6*40)	240	0	0	0	00:00	0	06:00	0	0	0
NAGARJUNA SAGAR (110 + 7*100.8)	816	79	0	624	00:04	0	06:00	2.88	2.86	119
NAGARJUNA SAGAR (Pump) (110 + 7*100.8)	816	0	0	433	07:39	106	17:21	3.42	3.42	143
NIZAMSAGAR (2*5)	10	0	0	0	00:00	0	06:00	0	0	0
NSR LT.CANAL.P.H (2*30)	60	0	0	0	00:00	0	06:00	0	0	0
POCHAMPAD (4*9)	36	0	0	0	00:00	0	06:00	0	0	0
PULICHINTALA (4*30)	120	0	0	0	00:00	0	06:00	0	0	0
SINGUR (2*7.5)	15	0	0	0	00:00	0	06:00	0	0	0
SRISAILAM LBPH (6*150)	900	0	0	0	00:00	0	06:00	0	0	0
SRISAILAM LBPH(Pump) (6*150)	900	0	0	0	00:00	0	06:00	0	0	0
U JURALA (6*39)	234	0	0	0	00:00	0	06:00	0	0	0
OTHER HYDEL	51	0	0	0	00:00	0	06:00	0	0	0
Total Hydro	2482	79	0	-	-	-	-	2.88	2.86	119
WIND	128	12	104	107	03:15	0	17:04	0.97	0.97	40
SOLAR	3848	0	0	2500	11:26	38	06:00	20.48	20.48	853
OTHERS	252	124	124	124	00:00	124	06:00	2.98	2.98	124
Total TELANGANA	15153	5195	4967	-	-	-	-	137.8	129.3	5386

KARNATAKA

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg

	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
Bellary TPS (2*500 + 700)	1700	1391	1419	1457	22:38	892	14:39	33.12	31.12	1297
JINDAL (2*130 + 4*300)	1460	819	953	1106	03:24	685	12:57	21.66	19.74	823
Jindal (Excl. Captive Consumption) (2 * 130 + 4 * 300)	1460	173	91	296	17:05	0	07:26	2.48	2.48	103
Raichur TPS (7*210 + 250)	1720	1008	1003	1048	22:36	859	14:16	26.31	23.57	982
UPCL (2*600)	1200	1110	1111	1138	23:12	590	16:21	23.12	21.7	904
YERAMARAS TPS (2*800)	1600	0	0	0	00:00	0	06:00	0	0	0
Total Thermal	7680	3682	3624	-	-	-	-	85.03	78.87	3286
Almatty (15 + 5*55)	290	0	0	0	00:00	0	06:00	0	0	0
Bhadra (2*12.1 + 7 + 2 + 6)	39	0	0	0	00:00	0	06:00	0	0	0
Ghataprabha (2*16)	32	0	0	0	00:00	0	06:00	0	0	0
JOG (MGHES) (4*21.6 + 4*13.2)	139	48	48	49	04:03	48	06:35	1.17	1.15	48
LINGANAMAKKI.P.H. (2*27.5)	55	8	8	8	20:01	8	12:07	0.2	0.18	8
Kadra (3*50)	150	0	0	144	06:24	0	08:01	0.27	0.26	11
Kodasalli (3*40)	120	38	0	111	06:21	0	08:07	0.5	0.49	20
MANI DAM.P.H. (2*4.5)	9	1	1	1	07:33	1	06:43	0.04	0.04	2
Munirabad (3*9 + 10)	37	0	0	0	00:00	0	06:00	0	0	0
NAGJHERI (135 + 5*150)	885	197	0	590	06:56	0	10:52	4.34	4.27	178
SHARAVATHI (10*103.5)	1035	549	373	852	06:13	242	13:46	10.62	10.58	441
Sharavati Tail Race (4*60)	240	153	0	210	06:24	0	13:36	1.84	1.81	75
SIVANSAMUDRAM (6*3 + 4*6)	42	1	1	1	00:00	1	06:00	0.04	0.04	2
Supa (2*50)	100	30	30	30	17:11	0	10:08	0.68	0.67	28
U JURALA (6*39)	234	0	0	0	00:00	0	06:00	0	0	0
Varahi UGPH (4*115)	460	55	57	404	22:37	45	07:42	2.43	2.39	100
OTHER HYDEL	143	0	0	0	00:00	0	06:00	0	0	0
Total Hydro	4010	1080	518	-	-	-	-	22.13	21.88	913
OTHER GAS/NAPTHA/DIESEL	126	0	0	0	00:00	0	06:00	0	0	0
Total Gas	126	0	0	-	-	-	-	0	0	0
WIND	5676	2294	1269	2382	19:52	761	07:05	33.18	33.18	1383
SOLAR	7171	0	0	3651	14:04	0	06:00	28.98	28.98	1208
OTHERS	1832	93	98	120	22:46	63	11:28	7.16	7.16	298
Total KARNATAKA	26495	7149	5509	-	-	-	-	176.48	170.07	7088

KERALA

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
Idamalayar (2*37.5)	75	42	0	51	20:18	0	06:00	0.21	0.21	9
Iddukki (6*130)	780	399	64	756	20:22	29	17:03	4.63	4.6	192
Kakkad (2*25)	50	35	36	37	19:41	0	10:06	0.51	0.51	21
KALLADA (2*7.5)	15	4	6	7	22:44	5	11:46	0.12	0.12	5
Kuttiyadi (3*25)	75	188	0	196	20:35	0	06:00	0.82	0.82	34
Lower Periyar (3*60)	180	45	91	167	00:05	0	09:10	1.38	1.37	57
Neriamangalam (3*17.5 + 25)	78	70	70	71	01:23	0	09:28	1.01	1.01	42
PALLIVASAL (3*5 + 3*7.5)	38	0	0	0	00:00	0	06:00	0	0	0
PALLIVASAL EXTENSION SCHEME (2*30)	60	58	18	60	00:07	17	06:42	0.71	0.71	30
Panniar (2*16.2)	32	0	0	0	00:00	0	06:00	0.19	0.19	8
PORINGALKUTHU (4*9)	36	0	0	50	21:50	0	06:00	0.16	0.16	7
Sengulam (4*12.8)	51	44	13	51	21:56	6	14:02	0.43	0.43	18
Sholayar (3*18)	54	30	0	53	20:19	0	06:00	0.22	0.22	9
Sabarigiri (4*55 + 2*60)	340	126	30	185	22:44	21	09:04	1.54	1.53	64
THOTTIYAR HEP (2*20)	40	0	0	30	23:30	0	06:00	0.48	0.48	20
OTHER HYDEL	230	126	61	275	23:14	0	06:49	1.51	1.51	63
Total Hydro	2134	1167	389	-	-	-	-	13.92	13.87	579
BRAHMAPURAM DGPP (DIESEL) (3*21.32)	64	0	0	0	00:00	0	06:00	0	0	0
BSES (NAPTHA) (3*40.5 + 35.5)	157	0	0	0	00:00	0	06:00	0	0	0
KOZHIKODE DPP (DIESEL) (6*16)	96	0	0	0	00:00	0	06:00	0	0	0
MPS STEEL CASTINGS (1 * 10)	10	0	0	0	00:00	0	06:00	0	0	0

RGCCPP KAYAMKULAM (KSEB) - NTPC (2*116.6 + 126.38)	360	0	0	0	00:00	0	06:00	0	0	0
OTHER GAS/NAPTHA/DIESEL	22	0	0	0	00:00	0	06:00	0	0	0
Total Gas	709	0	0	-	-	-	-	0	0	0
WIND	70	6	9	24	13:09	4	06:55	0.49	0.49	20
SOLAR	1988	1	0	102	14:07	0	06:00	0.52	0.52	22
OTHERS	20	6	10	121	14:07	6	06:09	0.28	0.28	12
Total KERALA	4921	1180	408	-	-	-	-	15.21	15.16	633

TAMIL NADU

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
Mettur TPS (4*210 + 600)	1440	812	802	1090	21:04	462	11:19	26.54	24.31	1013
NORTH CHENNAI TPS STG-III (1*800)	800	0	0	0	00:00	0	06:00	0	0	0
NORTH CHENNAI TPS STG-II (2*600)	1200	610	651	720	01:44	600	11:33	16.8	15.45	644
North Chennai TPS (3*210)	630	408	402	505	02:03	343	17:54	11.13	10.64	443
UDANGUDI(Infirm - 660MW)	0	0	0	0	00:00	0	06:00	0	0	0
OPG PGPL (2*77 + 80 + 180)	414	274	271	300	20:50	263	13:19	7.28	6.69	279
SEPC (1*525)	525	0	0	0	00:00	0	06:00	0	0	0
ST - CMS (1*250)	250	213	213	341	08:01	144	13:06	5.56	5.1	213
Tuticorin (5*210)	1050	569	569	582	23:07	0	11:16	12.69	11.47	478
Total Thermal	6309	2886	2908	-	-	-	-	80	73.66	3070
Kadamparai (4*100)	400	98	0	101	19:41	0	06:00	0.44	0.44	18
Kadamparai (Pump) (4*100)	400	0	108	110	04:30	0	07:28	1.36	1.36	57
Kodayar I (1*60)	60	0	0	0	00:00	0	06:00	0	0	0
Kodayar II (1*40)	40	22	40	40	00:00	22	14:12	0.77	0.76	32
Kundah I (3*20)	60	38	19	53	00:26	1	09:04	0.53	0.52	22
Kundah II (5*35)	175	86	13	176	19:05	19	17:43	1.31	1.29	54
Kundah III (3*60)	180	7	8	142	23:35	7	06:43	0.94	0.93	39
Kundah IV (2*50)	100	0	0	92	22:09	0	06:00	0.21	0.2	8
Kundah V (2*20)	40	0	0	20	08:01	0	06:00	0.03	0.03	1
Kundah VI (1*30)	30	0	0	0	00:00	0	06:00	0	0	0
Mettur Dam (4*12.5)	50	0	0	0	00:00	0	06:00	0.21	0.21	9
Mettur Tunnel (4*50)	200	0	0	0	00:00	0	06:00	0	0	0
Moyar (3*12)	36	28	4	28	19:09	0	11:16	0.18	0.17	7
PAPANASAM (4*8)	32	6	4	30	08:01	4	06:00	0.13	0.12	5
Periyar (4*35)	140	24	23	25	14:07	23	10:51	0.57	0.56	23
Pykara (3*6.65 + 11 + 2*14)	59	0	0	0	00:00	0	06:00	0	0	0
PYKARA ULTIMATE (3*50)	150	40	21	152	21:36	0	06:00	0.76	0.75	31
Sarkarpathy (1*30)	30	12	12	13	13:30	12	13:58	0.3	0.3	13
Servalar (1*20)	20	0	0	14	16:15	0	06:00	0.04	0.04	2
Sholayar I (2*42)	84	0	0	0	00:00	0	06:00	0	0	0
Sholayar II (1*25)	25	0	0	0	00:00	0	06:00	0	0	0
Suruliyar (1*35)	35	0	0	21	23:15	0	06:00	0.05	0.05	2
OTHER HYDEL	1826	14	98	295	22:38	3	11:03	0.35	0.34	14
Total Hydro	3772	375	242	-	-	-	-	6.82	6.71	280
BASIN BRIDGE (NAPTHA) (4*30)	120	0	0	0	00:00	0	06:00	0	0	0
KOVIL KALAPPAL (GAS) (70 + 37.88)	108	0	0	0	00:00	0	06:00	0	0	0
KUTTALAM (GAS) (64 + 37)	101	84	85	86	06:32	76	16:01	1.96	1.82	76
MADURAI POWER CL (DIESEL) (1 * 106)	106	0	0	0	00:00	0	06:00	0	0	0
P P NALLUR (NAPTHA) (1 * 330.5)	331	0	0	0	00:00	0	06:00	0	0	0
SAMALPATTY (DIESEL) (7 * 15.1)	106	0	0	0	00:00	0	06:00	0	0	0
VALATTUR(STG1&STG2) (2*60 + 35 + 32)	187	10	32	65	12:28	19	17:52	1.69	1.58	66
OTHER GAS/NAPTHA/DIESEL	362	0	0	0	00:00	0	06:00	0	0	0
Total Gas	1421	94	117	-	-	-	-	3.65	3.4	142
WIND	9495	2673	2213	4083	14:57	2386	06:00	71.29	71.29	2970
SOLAR	12065	0	0	7356	12:09	114	06:00	53.4	53.4	2225
OTHERS	2029	587	687	687	00:04	550	11:16	4.71	4.71	196

Total TAMIL NADU	35091	6615	6167	-	-	-	-	219.87	213.17	8883

PUDUCHERRY

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
KARAIKAL POWER PLANT (GAS) (1 * 22.9 + 1 * 9.6)	33	15	15	15	00:00	15	06:00	0.38	0.36	15
Total Gas	33	15	15	-	-	-	-	0.38	0.36	15
SOLAR	20	0	0	10	12:10	0	06:00	0.07	0.07	3
Total PUDUCHERRY	53	15	15	-	-	-	-	0.45	0.43	18

3(B) Regional Entities Generation:

ISGS

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
KUDGI (3*800)	2400	1900	1276	2323	22:28	1233	08:03	36.56	34	1417
Neyveli TS I Expn (2*210)	420	252	305	321	01:05	238	09:41	7.28	6.51	271
Neyveli TS II (7*210)	1470	600	687	715	01:14	443	11:32	15.57	12.48	520
Neyveli TS II Expn (2*250)	500	0	0	0	00:00	0	06:00	0	0	0
NNTPS (2*500)	1000	665	224	677	19:38	231	06:30	11.73	9.55	398
NTPC-TELANGANA STPP (2*800)	1600	1387	1487	1537	01:40	805	13:26	30.57	28.38	1183
Ramagundam (3*200 + 4*500)	2600	1931	1196	1987	22:35	1060	12:30	34.78	32.18	1341
Simhadri Stage I (2*500)	1000	898	927	942	22:44	495	07:33	19.21	17.82	743
Simhadri Stage II (2*500)	1000	891	933	967	02:20	505	12:13	19.28	18.32	763
TALCHER ST2 (4*500)	2000	1817	1868	1892	21:20	1014	08:27	40.92	38.52	1605
Total Thermal	13990	10341	8903	-	-	-	-	215.9	197.76	8241
KAIGA STG1 (2*220)	440	198	200	208	01:22	195	12:16	4.99	4.47	186
KAIGA STG2 (2*220)	440	445	445	450	18:06	438	12:49	11.32	10.37	432
KUDANKULAM (2*1000)	2000	2002	2001	2017	19:46	1981	14:46	49.08	46.33	1930
MAPS (2*220)	440	207	210	215	22:48	188	09:20	5.07	4.1	171
Total Nuclear	3320	2852	2856	-	-	-	-	70.46	65.27	2719
Total ISGS	17310	13193	11759	-	-	-	-	286.36	263.03	10960

JOINT VENTURE

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
NTPL (2*500)	1000	448	291	487	23:37	256	13:06	8.22	7.28	303
Vallur TPS (3*500)	1500	1352	1316	1402	18:17	725	12:28	28.38	26.35	1098
Total Thermal	2500	1800	1607	-	-	-	-	36.6	33.63	1401
Total JOINT VENTURE	2500	1800	1607	-	-	-	-	36.6	33.63	1401

IPP UNDER OPEN ACCESS

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
COASTAL ENERGEN (2*600)	1200	1006	1093	1198	03:55	672	15:59	21.59	20.02	834
IL&FS (2*600)	1200	994	994	1007	18:11	586	14:53	21.19	19.86	828
JINDAL POWER LIMITED (Simhapuri Unit) (4*150)	600	540	311	546	19:40	242	13:40	8.98	8	333
MEENAKSHI ENERGY LTD STAGE1 (2*150)	300	92	91	94	07:33	62	09:16	2.14	1.91	80
MEENAKSHI ENERGY LTD STAGE2 (2*350)	700	243	239	259	17:52	209	09:55	6.2	5.63	235
SEIL (2*660)	1320	1260	1184	1275	01:33	603	10:21	26.73	25.28	1053
SEIL-PROJECT2 (1*660)	660	619	623	630	21:13	303	14:38	13.54	12.77	532
Total Thermal	5980	4754	4535	-	-	-	-	100.37	93.47	3895
Greenko (6 * 240 + 2 * 120)	1680	1194	364	1238	00:08	0	07:06	10.1	10.03	418
GREENKO(Pump) (6 * 240 + 2 * 120)	1680	0	0	1705	09:04	0	06:00	11.74	11.77	490
Total Hydro	1680	1194	364	-	-	-	-	10.1	10.03	418
LKPPL ST2 (233 + 133)	366	14	47	237	22:58	1	07:03	1.26	1.2	50
LKPPL ST3 (2*233 + 2*133)	732	0	0	0	00:00	0	06:00	0	0	0

Total Gas	1098	14	47	-	-	-	-	1.26	1.2	50
Total IPP UNDER OPEN ACCESS	8758	5962	4946	-	-	-	-	111.73	104.7	4363

RENEWABLE WIND

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
GADAG_GreenInfra_W	55	0	0	0	00:00	0	06:00	0	0	0
GADAG_RSPPL_W	202	247	108	274	18:15	9	06:00	2.88	2.88	120
GADAG_Serentica3_W	52	141	41	172	18:54	0	08:02	1.6	1.6	67
GADAG_VENA_W	133	0	0	0	00:00	0	06:00	0	0	0
GREEN INFRA	250	230	101	237	10:54	71	07:02	4.22	4.22	176
Hiriyur_Ostro	300	175	146	263	17:09	58	07:05	3.09	3.09	129
HIRIYUR_ZREPL_W	66	74	8	103	17:05	19	07:21	1.41	1.41	59
JSW RENEW ENERGY TWO LTD	300	203	254	282	06:39	53	12:57	5.43	5.43	226
KARUR_JSWRENEW_W	162	130	119	156	10:04	103	11:15	3.01	3.01	125
Karur_JSWRETwo_W	150	122	86	134	17:31	58	11:34	2.4	2.4	100
KARUR_TPVARDHAMAN_W	50	178	162	189	05:40	99	10:53	3.83	3.83	160
KOPPAL_AyanaSix_W	300	180	101	266	16:58	20	06:13	2.47	2.47	103
KOPPAL_Kleio_W	101	47	34	68	17:02	13	07:23	0.8	0.8	33
Koppal_RenewOjas_W	322	164	62	232	17:14	29	06:01	2.58	2.58	108
Koppal_RenewRoshni_W	286	229	97	249	15:47	12	06:06	2.68	2.68	112
KOPPAL_SRI1PL_W	79	153	118	167	01:49	23	13:01	2.59	2.59	108
Kurnool_AMGreeen_W	304	198	111	290	21:43	61	06:52	3.32	3.32	138
MYTRA	250	175	171	213	14:02	125	11:50	4.23	4.23	176
ORANGE	200	180	78	188	18:25	68	06:15	3.31	3.31	138
PGLR_SAUPL_W	53	46	8	48	13:34	3	06:00	0.71	0.71	30
PGLR_SREPL	300	289	153	310	14:34	131	06:26	5.53	5.53	230
TuticorinJSWRenewW	540	409	450	490	06:41	243	12:27	10.15	10.15	423
VIVID SOLAIRE (BEETAM)	220	220	158	221	17:14	133	06:13	4.26	4.26	178
Total SR_Wind	4675	3790	2566	-	-	-	-	70.5	70.5	2939
Total RENEWABLE WIND	4675	3790	2566	-	-	-	-	70.5	70.5	2939

RENEWABLE SOLAR

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
ANP_AdaniAPSeven	250	0	0	242	14:43	2	06:00	1.46	1.46	61
ANP_ATHENA BIWADI	50	0	0	42	13:15	1	06:00	0.27	0.27	11
ANP_ATHENA HISAR	50	0	0	52	12:32	0	06:00	0.29	0.29	12
ANP_ATHENA KARNAL	50	0	0	48	11:59	0	06:00	0.27	0.27	11
ANP_AYANA	250	0	0	249	14:14	3	06:00	1.59	1.59	66
ANP_AZURE	50	0	0	47	12:47	0	06:00	0.28	0.28	12
ANP_IGS1	50	0	0	49	12:49	0	06:00	0.28	0.28	12
ANP_IGS2	50	0	0	53	12:14	0	06:00	0.34	0.34	14
ANP_NTPC	250	0	0	150	14:19	0	06:03	0.95	0.95	40
ANP_TATA	100	0	0	85	14:06	0	06:00	0.44	0.44	18
SPRING ANG ITRA	250	0	0	258	14:20	0	06:00	1.6	1.6	67
Total NP_KUNTA	1400	0	0	-	-	-	-	7.77	7.77	324
PVG_ADYAH	300	0	0	250	14:31	6	06:00	1.35	1.35	56
PVG_AMPLUS PAVAGADA	50	0	0	52	14:05	1	06:00	0.3	0.3	13
PVG_AMPLUS TUMKUR	50	0	0	52	12:36	1	06:00	0.31	0.31	13
PVG_AVAADA SOLAR	150	0	0	149	14:18	1	06:00	0.75	0.75	31
PVG_AVAADA SOLARISE	150	0	0	139	14:32	1	06:00	0.75	0.75	31
PVG_AZURE POWER EARTH	100	0	0	100	12:43	0	06:00	0.53	0.53	22
PVG_FORTUM FIN SURYA	100	0	0	88	12:46	1	06:00	0.48	0.48	20
PVG_IRCON_S	225	0	0	393	14:26	2	06:00	2.17	2.17	90
PVG_KREDL	50	0	0	46	12:47	1	06:00	0.26	0.26	11
PVG_PARAMPUJYA	150	0	0	126	14:30	1	06:00	0.72	0.72	30

PVG_RENEW TN2	50	0	0	51	10:46	0	06:00	0.31	0.31	13
PVG_SBG ENERGY	200	0	0	191	14:12	0	06:00	1.05	1.05	44
PVG_SPRING SOLAR INDIA	250	0	0	237	14:25	1	06:00	1.25	1.25	52
PVG_TATA RENEWABLES	400	0	0	336	14:28	1	06:00	1.85	1.85	77
PVG_YARROW	50	0	0	48	13:40	1	06:00	0.26	0.26	11
Total PAVAGADA	2275	0	0	-	-	-	-	12.34	12.34	514
GADAG_Serentica3_S	69	0	0	151	14:49	0	06:00	0.98	0.98	41
GADAG_VENA_S	31	0	0	0	00:00	0	06:00	0	0	0
GRT	150	0	0	129	14:23	0	06:00	0.88	0.88	37
HIRIYUR_ZREPL_S	94	0	0	85	14:36	1	06:00	0.51	0.51	21
KOPPAL_Kleio_S	105	0	0	93	14:24	0	06:07	0.39	0.39	16
KOPPAL_RenewOjas_S	81	0	0	81	11:38	0	06:00	0.4	0.4	17
KOPPAL_SRI1PL_S	188	0	0	194	15:14	0	06:05	1.13	1.13	47
KOPPAL_TPSAURYA_S	131	0	0	229	15:07	0	06:04	1.3	1.3	54
Kurnool3_SAEL1_S	300	0	0	307	10:14	0	06:00	2.08	2.08	87
Kurnool3_SAEL2_S	300	0	0	301	10:22	3	06:00	2.11	2.11	88
Kurnool_AMGreen_S	599	0	0	528	14:19	4	06:00	3.6	3.6	150
Kurnool_Greenko_S	300	0	0	476	11:53	4	06:00	3.18	3.18	133
NTPC ETTAYAPURAM SOLAR PLANT	230	0	0	231	14:13	0	06:00	1.53	1.53	64
RAMANGUNDAM (SOLAR)	100	0	0	96	11:25	2	06:00	0.64	0.64	27
SIMHADRI (SOLAR)	25	0	0	25	12:05	1	17:59	0.18	0.18	8
Total OTHER	2703	0	0	-	-	-	-	18.91	18.91	790
Total RENEWABLE SOLAR	6378	0	0	-	-	-	-	39.02	39.02	1628

RENEWABLE BESS

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
KOPPAL_RenewOjas_BESS (Discharge)	75	0	0	60	23:47	0	07:37	0.09	0.09	4
KOPPAL_RenewOjas_BESS (Charge)	75	1	5	73	02:00	0	06:00	0.16	0.16	7
Total SR_BESS	75	0	0	-	-	-	-	0.09	0.09	4
Total RENEWABLE BESS	75	0	0	-	-	-	-	0.09	0.09	4

Total ISGS IPP Thermal	22470	16895	15045	-	-	-	-	352.87	324.86	13537
Total State Thermal	30742	18148	17201	-	-	-	-	417.2	386.03	16086
Total ISGS IPP Hydro	1680	1194	364	-	-	-	-	10.1	10.03	418
Total State Hydro	14298	3089	1491	-	-	-	-	51.39	50.94	2125
Total Gas/Naptha/Diesel	6423	123	179	-	-	-	-	5.29	4.96	207
Total Nuclear	3320	2852	2856	-	-	-	-	70.46	65.27	2719
Total Wind	24146	10670	7682	-	-	-	-	210.89	210.89	8788
Total Solar	35435	3	1	-	-	-	-	160.68	160.68	6698
Total Others	4752	926	1038	-	-	-	-	17.27	17.27	719
Total BESS	75	0	0	-	-	-	-	0.09	0.09	4

4(A) INTER-REGIONAL EXCHANGES (Import=(+ve) /Export =(-ve))

SL.No.	Element	20:00	03:00	Maximum Interchange (MW)		Import in MU	Export in MU	NET
		MW	MW	Import	Export			
Import/Export between SOUTH REGION and EAST REGION								
1	220KV-UPPER_SILERU-BALIMELA	0	0	0.0	-	0	0	0
2	400KV-GAZUWAKA-JEYPORE	0	0	0.0	-	0	0	0
3	765KV-SRIKAKULAM-ANGUL	1754	1826	2520.0	-	41.84	0	41.84
4	HVDC500KV-TALCHER-KOLAR_DC	1845	1849	1855.0	-	41.79	0	41.79
Sub-Total EAST REGION		3599	3675	-	-	83.63	0	83.63
Import/Export between SOUTH REGION and WEST REGION								
1	220KV-AMBEWADI-PONDA	0	0	0.0	-	0	0	0
2	220KV-AMBEWADI-XELDEM	95	82	-	98.0	0	2.13	-2.13
3	220KV-CHIKKODI-MUDASANGI	0	0	0.0	-	0	0	0
4	220KV-CHIKKODI-TALANGADE	0	0	0.0	-	0	0	0

5	220KV-LOWER_SILERU-BARSUR	0	0	0.0	-	0	0	0
6	400KV-BHADRAVTAHI-RAMAGUNDAM	512	513	-	530.0	0	12.3	-12.3
7	400KV-KUDGI_PG-KHOLAPUR_PG	1696	1098	-	1950.0	0	31.46	-31.46
8	765KV-NIZAMABAD-WARDHA	934	1123	2128.0	-	29.86	0	29.86
9	765KV-RAICHUR_PG-SHOLAPUR	503	177	-	957.0	0	2.95	-2.95
10	765KV-WARANGAL(NEW)-WARORA	1135	1287	2308.0	-	33.69	0	33.69
11	HVDC800KV-RAIGARH HVDC-PUGALUR HVDC	561	566	572.0	-	13.74	0	13.74
Sub-Total WEST REGION		5436	4846	-	-	77.29	48.84	28.45
TOTAL IR EXCHANGE		9035	8521	-	-	160.92	48.84	112.08

4(B) Inter Regional Schedule & Actual Exchange (Import=(+ve) /Export =(-ve)) in MU

Link	ISGS+URS+GNA	TGNA	GDAM	DAM	HPDAM	RTM	Total IR Schedule	Total IR Actual	Net UI
East-South	21.41	-8.78	0	0	0	0	-25.29	45.11	70.4
West-South	53.37	6.61	1.96	-0.73	0	41.62	97.88	28.45	-69.43
Total	74.78	-2.17	1.96	-0.73	0	41.62	72.59	73.56	0.97

5. Frequency Profile

RANGE(Hz)	< 48.8	< 49	< 49.2	< 49.5	< 49.7	< 49.9	>= 49.9 - <= 50.05	> 50	> 50.05
%	0	0	0	0	0	4.988	86.713	40.37	8.299

Max Freq		Min Freq		Avg Freq	Freq Variation Index	Standard Deviation	Freq in 15 mnt blk	
Freq (HZ)	Time	Freq (HZ)	Time				Max (Hz)	Min (Hz)
50.182	09:03:30	49.826	07:04:20	49.986	0.025	0.05	50.09	49.89

6(A). Voltage Profile: 765 kV

Station	Max		Min		Voltage (in %)			
	Voltage	Time	Voltage	Time	< 720	< 750	> 780	> 800
KURNOOL - 765KV	799	03:01	776	14:26	0	0	89.03	0
NIZAMABAD - 765KV	798	01:58	778	06:47	0	0	96.6	0
RAICHUR_PG - 765KV	795	03:55	767	14:24	0	0	57.85	0
SRIKAKULAM - 765KV	794	08:00	773	15:39	0	0	84.03	0

6(B). Voltage Profile: 400 kV

Station	Max		Min		Voltage (in %)			
	Voltage	Time	Voltage	Time	< 380	< 390	> 420	> 430
GHANAPUR - 400KV	422	04:00	408	11:43	0	0	15.35	0
GOOTY - 400KV	423	03:45	401	10:06	0	0	11.11	0
HIRIYUR - 400KV	426	03:01	403	09:48	0	0	28.19	0
KAIGA - 400KV	425	18:36	396	09:58	0	0	15.69	0
KOLAR_AC - 400KV	422	03:01	393	08:45	0	0	5.69	0
KUDANKULAM - 400KV	418	23:40	399	11:29	0	0	0	0
SHANKARAPALLY - 400KV	420	03:02	412	16:42	0	0	19.51	0
SOMANAHALLI - 400KV	424	03:02	394	10:05	0	0	15.69	0
SRIPERUMBADUR - 400KV	417	02:53	401	09:06	0	0	0	0
TRICHY - 400KV	412	23:39	394	10:01	0	0	0	0
TRIVANDRUM - 400KV	419	23:39	392	09:07	0	0	0	0
VIJAYAWADA - 400KV	419	18:03	405	14:45	0	0	0	0

6(C). Voltage Profile: 220 kV

Station	Max		Min		Voltage (in %)			
	Voltage	Time	Voltage	Time	< 198	< 210	> 235	> 245
GHANAPUR - 220KV	230	04:01	220	12:31	0	0	0	0
GOOTY - 220KV	232	03:01	222	09:47	0	0	0	0
HIRIYUR - 220KV	245	02:36	217	12:31	0	0	1.04	0.07
KAIGA - 220KV	236	18:31	221	06:24	0	0	1.81	0
KOLAR_AC - 220KV	231	03:02	211	09:48	0	0	0	0
SOMANAHALLI - 220KV	238	03:02	218	10:06	0	0	19.65	0

SRIPERUMBADUR - 220KV	228	03:45	212	14:24	0	0	0	0
TRICHY - 220KV	231	11:16	208	10:03	0	3.4	0	0
TRIVANDRUM - 220KV	232	03:31	229	20:47	0	0	0	0
VIJAYAWADA - 220KV	237	17:57	219	14:54	0	0	0.56	0

7. Major Reservoir Particulars

RESERVOIR	DESIGNED			PRESENT		LAST YEAR		LAST DAY		MONTH	
	MDDL (m)	FRL (m)	Energy (MU)	Level (m)	Energy (MU)	Level (m)	Energy (MU)	Inflow (MU)	Usage (MU)	Prog Inflow (MU)	Prog Usage (MU)
IDUKKI	694.94	732.43	2148	706.18	458	-	-	9.2	2.36	9.2	23.6
JALAPUT	818.39	838.4	534	825.32	128	831.65	277.0	0.77	0	1.54	0
KAKKI	908.3	981.45	916	938.6	118	-	-	11.9	1.17	12.21	8.17
LINGANAMAKKI	522.73	554.5	4557	533.55	560	538.23	1031.0	0	10.95	0	46.83
N.SAGAR	149.3	179.9	1398	158.34	92	155.94	15.0	5.88	1.86	14.68	10.09
NILAGIRIS	0	0	1504	0	477	0.0	708.0	1.74	5.11	5.8	20.81
SRISAILAM	243.84	270.7	1392	249.51	60	254.51	143.0	0	0	0	0
SUPA	495	564	3159	526.28	681	530.02	841.0	0	4.17	0.32	25.01
Total	-	-	15608	-	2574	-	3015	29.49	25.62	43.75	134.51

8(A). Short-Term Open Access Details

State	Off- Peak Hours (03:00)												
	TGNA	IEX GDAM	IEX DAM	IEX HPDAM	IEX RTM	PXIL GDAM	PXIL DAM	PXIL HPDAM	PXIL RTM	HPX GDAM	HPX DAM	HPX HPDAM	HPX RTM
Andhra Pradesh	-44.86	-3.5	-321.3	0	555.78	0	0	0	0	0	0	0	0
Karnataka	-399.83	-46.38	34.63	0	23.72	0	0	0	0	0	0	0	0
Kerala	0	0	-10.2	0	288.37	0	0	0	0	0	0	0	0
Puducherry	49.59	0	-89	0	-33	0	0	0	0	0	0	0	0
Tamil Nadu	2441.57	0	-19.7	0	145.55	0	0	0	0	0	0	0	0
Telangana	-32.1	0.1	137.44	0	1084.03	0	0	0	0	0	0	0	0
Total	2014.37	-49.78	-268.13	0	2064.45	0	0	0	0	0	0	0	0

State	Peak Hours (20:00)												
	TGNA	IEX GDAM	IEX DAM	IEX HPDAM	IEX RTM	PXIL GDAM	PXIL DAM	PXIL HPDAM	PXIL RTM	HPX GDAM	HPX DAM	HPX HPDAM	HPX RTM
Andhra Pradesh	-29.68	-3.4	-19.65	0	-833.2	0	0	0	0	0	0	0	0
Karnataka	-431.22	-49.77	8.42	0	-3.51	0	0	0	0	0	0	0	0
Kerala	0	0	35.79	0	421.96	0	0	0	0	0	0	0	0
Puducherry	49.88	0	0	0	-20	0	0	0	0	0	0	0	0
Tamil Nadu	4051.53	0	-11	0	199.93	0	0	0	0	0	0	0	0
Telangana	-38.19	0.1	272.55	0	984.28	0	0	0	0	0	0	0	0
Total	3602.32	-53.07	286.11	0	749.46	0	0	0	0	0	0	0	0

State	Day Energy (MU)						
	ISGS+GNA	TGNA	GDAM	DAM	HPDAM	RTM	Total
Andhra Pradesh	56.94	0.19	0.61	0.47	0	13.53	71.74
Karnataka	107	-7.02	-0.81	0.87	0	6.28	106.32
Kerala	55.88	1.26	0.6	8.06	0	7.61	73.41
Puducherry	11.8	1.61	0	-1.34	0	-0.5	11.57
Tamil Nadu	182.3	47.61	1.88	-16.79	0	-22.28	192.72
Telangana	72.48	0.13	0.61	5.96	0	30.54	109.72
Total	486.4	43.78	2.89	-2.77	0	35.18	565.48

8(B). Short-Term Open Access Details

State	ISGS+GNA		TGNA		IEX GDAM		PXI GDAM		HPX GDAM		IEX DAM		PXI DAM	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
Andhra Pradesh	3128.66	1725.14	71.82	-52.71	153.9	-13.99	0	0	0	0	394.76	-904.21	0	0
Karnataka	5494.86	3973.4	-93.26	-447.93	22.46	-290.91	0	0	0	0	100.82	-8.75	0	0
Kerala	2574.12	1749.85	361.65	0	71.28	0	0	0	0	0	796.71	-10.2	0	0
Puducherry	544.94	416.59	89.25	49.3	0	0	0	0	0	0	0	-126	0	0
Tamil Nadu	8393.21	6765.48	4163.97	250.6	249.88	0	0	0	0	0	422.84	-3862.08	0	0

Telangana	3523.74	1889.89	60.07	-38.19	67.95	-0.8	0	0	0	0	1709.79	-6.9	0	0

State	HPX DAM		IEX HPDAM		PXI HPDAM		HPX HPDAM		IEX RTM		PXI RTM		HPX RTM	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
Andhra Pradesh	0	0	0	0	0	0	0	0	2033.55	-833.2	0	0	0	0
Karnataka	0	0	0	0	0	0	0	0	954.08	-117.96	0	0	0	0
Kerala	0	0	0	0	0	0	0	0	1219.4	-1.4	0	0	0	0
Puducherry	0	0	0	0	0	0	0	0	27.05	-113	0	0	0	0
Tamil Nadu	0	0	0	0	0	0	0	0	338.51	-3475.79	0	0	0	0
Telangana	0	0	0	0	0	0	0	0	2307.54	214.62	0	0	0	0

9. Synchronisation of new generating units:

SL.NO	Station Name	Owner	Inst. Capacity (MW)	Date	Time

10. Synchronisation of new 220 / 400 / 765 KV Transmission elements and energising of bus /substation:

11. Significant events (If any):

Nil

12. Constraints and instances of congestion in the transmission system

1) 400KV-KALPAKKA-KHAMMAM_PG-1 & 400KV-KALPAKKA-ASUPAKA-1 Lines Under S/D for replacement of badly damaged rusted towers from Loc No.1 to 11 in 400KV Kalapaka – Khammam along with stringing of conductor at 400kv SS Kalapaka. S/D availed on 05-05-2026 ,Expected to be restored on 26-06-2026.
2) 400KV Kaiga-Guttur 1&2 tripped on 14.05.2026 at 17:39Hrs due to the tower collapse in multiple locations.
3) 400KV-GAZUWAKA-JEYPORE-1,2 under shutdown for NH-130CD Diversion works (Between 130-133/150-153/179-180) availed on 15-05-2026 at 09:36 Hrs. Expected to restore by 16.06.2026 18:00 Hrs.
4) 400KV-PAVAGADA_PG-TUMKUR-1&2 availed S/D on 17.05.2026 at 10:17Hrs for Conductor Release, Existing tower dismantle, New Tower erection, and stringing of the conductor for the work of Shifting/Heightening/Modification by providing 01 No. of 400KV DD+18 type tower, Expected to be restored on 06-06-2026.
5) 220KV-GADAG_PSS-Vena_GadagPS-1 and 220KV-GADAG_PSS-Green Infra_GadagPS-1 tripped on 17-05-2026 at 16:14 Hrs due to the tower collapse Loc. No.32-36. Generation affected 237MW(I.C)
6) At 18:13 hrs of 23-05-2026, 400KV-GADAG_PSS-KOPPAL D/C tripped on Y-B fault due to tower collapse. total 15 number of tower Collapsed (Tower location number 52-66).
7) 400KV-NAGAPATTNAM_PS-TRICHY-1&2 tripped on 31.05.2026 at 17:05Hrs due to the tower collapse at loc. 437(DA), 438(DA), 439(DB) towers are collapsed and 435(DA),436(DA),440(DA), 441(DA) towers are found cross arm/earth peak damaged.
8) 400/220kV SOMANAHALLI ICT-1 tripped at 20:07 hours of 31-05-2026 due to REF, Differential & body protections.
9) 400KV/220KV VIJAYAWADA-ICT-2 tripped on 25.05.2026 due to the failure of 220kV B-ph bushing. Expected charging on 15.06.2026
10) 400KV/220KV MADAKKATHARA-ICT-2 Shutdown availed on 05.06.2026 08:33 Hrs for Annual maintenance works and Shutdown returned on 05.06.2026 16:51 Hrs. On account of this S3 Import reduced by 300 MW.

13. Weather Condition

Andhra Pradesh : Light rains reported in Krishna and Guntur districts.
Telengana: Moderate rains reported in Nalgunda,Yadadri,Mehaboobnagar,Khammam.Badradri,Warangal area.
Kerala : Light rains reported through out the state.
Tamilnadu : Moderate rains reported in Gumudupundi and Manali area.
Karnataka: Moderate rains reported in Mangalore,Uduppi and Karwar area.

14. RE/Load Curtailment details

State	Load Curtailment (Shortage)			RE Curtailment				
	Energy (MU)	Max (MW)	At the time of maximum demand	Wind Max (MW)	Wind Energy (MU)	Solar Max (MW)	Solar Energy (MU)	Reason
Andhra Pradesh	0	0	0	0	0	0	0	0
Karnataka	0	0	0	0	0	0	0	0
Kerala	0	0	0	0	0	0	0	0
Puducherry	0	0	0	0	0	0	0	0
Tamil Nadu	0	0	0	0	0	0	0	0
Telangana	0	0	0	0	0	0	0	0

15.Instances of persistant/significant non-complaint with grid code

State	Frequency and Deviation				Voltage				ICT loading			
	Alert	Emergency	Extreme Emergency	Non Compliance	Alert	Emergency	Extreme Emergency	Non Compliance	Alert	Emergency	Extreme Emergency	Non Compliance
Andhra Pradesh	0	1	0	1	4	0	0	0	7	8	0	0
Karnataka	0	0	0	0	0	0	0	0	6	3	0	0
Kerala	0	0	0	0	0	0	0	0	0	0	0	0
Puducherry	0	0	0	0	0	0	0	0	0	0	0	0
Tamil Nadu	0	2	0	1	1	0	0	0	3	13	2	0
Telangana	0	0	0	0	15	0	0	0	0	0	0	0