



MINIT Ignífugos

minitargentina@gmail.com www.minitfireretardant.com

COPIA FIEL DE CERTIFICADOS

Producto MINIT PARA MADERAS

Presentación válida únicamente con el Certificado / Factura de Compra



INDEX (imprima los certificados de acuerdo al material y uso que necesita)

Página 2: MADERAS SIN PERMEABILIDAD PREVIAMENTE SELLADAS CON LACAS PINTURAS O BARNIZ ANTES DEL IGNIFUGADO

- IRAM 11910-3 NBR 9442/86 ASTM 162 (METODO PANEL RADIANTE EN MADERA, RE4 CLASE C, MEDIANA PROPAGACION DEL FUEGO)

Página 4: MADERAS / PAPEL / CARTÓN SUPERFICIES PERMEABLES

- ASTM 162 Equivalente (Homologado) a IRAM 11910-3 NBR 9442/86 y con estándares europeos: CSE RF 3/77; BS 476 part 6 and part 7 (METODO PANEL RADIANTE EN MADERA, CARTÓN Y PAPEL) Resultado: Determinación de la propagación superficial de llama "I" 39.8 (IRAM RE 3, Clase ABNT "B"). Baja Propagación. Govmark/SGS (<https://www.sgs.com/en/service-groups/fire-testing>) Convenio de reciprocidad INTI / SGS, 23/08/2001

Página 7: ENSAYOS DE EMANACIÓN y DENSIDAD DE HUMO Y GASES / HOMOLOGACIÓN de De Densidad de Humo NORMA IRAM 11914

Marco de Reconocimiento Internacional (Reciprocidad)

El sistema de aceptación de ensayos extranjeros en Argentina se basa en acuerdos internacionales de reciprocidad que eliminan la necesidad de repetir pruebas locales. Recientemente, el marco normativo se ha simplificado mediante el **Decreto 892/2025**.

El Gobierno argentino estableció el reconocimiento automático de certificaciones y ensayos internacionales para agilizar el comercio:

- Se consideran válidos los ensayos realizados en países con altos estándares de vigilancia técnica (países de "alta vigilancia") detallados en la normativa.
- Los productos que posean certificaciones de laboratorios acreditados por entidades avaladas por acuerdos de reciprocidad no requieren nuevos ensayos locales.

Principales Organismos de Acreditación y Cooperación Regional e Internacional

Organismo	Alcance	Rol Principal
ILAC	Global	Cooperación para laboratorios de ensayo y calibración.
IAF	Global	Reconocimiento de organismos de certificación de productos y sistemas.
IAAC	Regional (Américas)	Cooperación Interamericana de Acreditación.
OCDE	Global	Acuerdos de "Aceptación Mutua de Datos" (MAD) para seguridad ambiental y sanitaria.
A2LA	Regional (Américas)	Asociación para la Acreditación de Laboratorios. Bajo la norma ISO/IEC 17025. Garantiza la competencia técnica y la confianza global.
ANAB / ANSI	Regional (Américas)	Junta de Acreditación. Organismo de acreditación de normas, laboratorios y organismos de inspección y certificación (ISO/IEC 17025, 17020, 17021, 17034).



MINIT Ignífugos

minitargentina@gmail.com www.minitfireretardant.com

COPIA FIEL DE CERTIFICADOS

Producto MINIT PARA MADERAS

Presentación válida únicamente con el Certificado / Factura de Compra



MADERAS SIN PERMEABILIDAD REVIAMENTE SELLADAS CON LACAS PINTURAS O BARNIZ

IRAM 11910-3 NBR 9442/86 ASTM 162 (METODO PANEL RADIANTE EN MADERA, RE4 CLASE C, MEDIANA PROPAGACION DEL FUEGO)

INTI Construcciones

INFORME DE ENSAYO

Solicitante: MINOTTI PABLO DAVID

O.T.: 101/20905

Pág.: 1 de 2

Fecha: 12/08/2011

Informe: Único.

Dirección: Cochrane 2322
(1419) – Cdad. Autónoma de Buenos Aires

1. OBJETIVO

Clasificación de acuerdo al Índice de Propagación de Llama.

2. MATERIAL

Una (1) muestra de placa de madera maciza, identificada por el solicitante como:
"Madera con retardante ignífugo marca MINIT de Pablo Minotti"



3. MÉTODO EMPLEADO

El ensayo de Propagación Superficial de Llama se realizó de acuerdo a la Norma IRAM 11910-3: "Materiales de Construcción, Reacción al fuego, Determinación del índice de propagación de llama – método del panel radiante" (coincide con los métodos de ensayo de la Norma NBR 9442/1986 y ASTM E162).

La muestra fue recibida el día 15/06/11 y ensayada el día 10/08/11.

4. RESULTADOS OBTENIDOS

Determinación de la Propagación superficial de llama

F(promedio):	6,18
Q(promedio):	15,63
I(promedio):	95,89

Este informe no podrá ser reproducido parcialmente sin la autorización escrita del Laboratorio. Los resultados consignados se refieren exclusivamente a los elementos recibidos, el INTI y su Centro de Investigación y Desarrollo en Construcciones declinan toda responsabilidad por el uso indebido o incorrecto que se hiciere de este informe.

Instituto Nacional de Tecnología Industrial
Centro de Investigación y Desarrollo
en Construcciones

Avenida General Paz 3445
81650KNA San Martín, Buenos Aires, Argentina
Teléfono (54 11) 4724 6200
e-mail: construcciones@inti.gov.ar



MINIT Ignifugos

minitargentina@gmail.com www.minitfireretardant.com

COPIA FIEL DE CERTIFICADOS

Producto MINIT PARA MADERAS

Presentación válida únicamente con el Certificado / Factura de Compra



validacion

INTI Construcciones

Solicitante: MINOTTI PABLO DAVID

O.T.: 101/20905
Pág.: 2 de 2
Fecha: 12/08/2011
Informe: Único.

Dirección: Cochrane 2322
(1419) – Cdad. Autónoma de Buenos Aires

De acuerdo al **Índice de Propagación de Llamas (I)** hallado y teniendo en cuenta la Tabla de Clasificación de la Norma IRAM 11910-1 del año 1994, que se detalla como referencias, el material **"Madera con retardante ignífugo marca MINIT de Pablo Minotti"** se clasifica como:

"Clase RE 4: Material de Mediana propagación de llama"

(A esta clase pertenecen los materiales con un índice entre 76 y 150)
Coincide con la Clase C de la Norma brasileña NBR 9442/1986

Referencias para el ensayo de determinación de la propagación superficial de llama

Clase	Clase ABNT	Denominación	Norma IRAM	Criterio de clasificación
RE 1	-	Incombustible	11910-2	Anexo A de la norma
RE 2	A	Muy baja propagación de llama	11910-1	Índice: 0 a 25
RE 3	B	Baja propagación de llama	11910-1	Índice: 26 a 75
RE 4	C	Mediana propagación de llama	11910-1	Índice: 76 a 150
RE 5	D	Elevada propagación de llama	11910-1	Índice: 151 a 400
RE 6	E	Muy elevada propagación de llama	11910-1	Índice mayor a 400

Definiciones:


Un factor derivado de la rapidez de propagación del frente de llama (F) y otro relativo al calor liberado por el material ensayado (Q) son combinados para proveer el índice de propagación superficial de llama (I).

I: Índice de propagación superficial de llama.

F: Factor de propagación de llama.

Q: Factor de evolución de calor.


Arq. BASILIO MASAROV
COORDINADOR
U.T. TECNOLOGÍA EN INCENDIOS
INTI-CONSTRUCCIONES


Ing. VICENTE L. VOLANTINO
DIRECCIÓN
INTI-CONSTRUCCIONES

Nota:

De acuerdo a reglamentaciones internacionales, estos ensayos deben considerarse para medir y describir el comportamiento del material bajo condiciones controladas, pero no se puede estimar cuál será el comportamiento del mismo si se modifican total o parcialmente las condiciones de ensayo.



MINIT Ignifugos

minitargentina@gmail.com www.minitfireretardant.com

COPIA FIEL DE CERTIFICADOS

Producto MINIT PARA MADERAS

Presentación válida únicamente con el Certificado / Factura de Compra



validacion

ASTM 162 Equivalente (Homologado) a IRAM 11910-3 NBR 9442/86 y con estándares europeos: CSE RF 3/77; BS 476 part 6 and part 7
(METODO PANEL RADIANTE EN MADERA, CARTÓN Y PAPEL)

Resultado: Determinación de la propagación superficial de llama "I" 39.8 (IRAM RE 3, Clase ABNT "B"). Baja Propagación.

Govmark/SGS (<https://www.sgs.com/en/service-groups/fire-testing>) Convenio de reciprocidad INTI / SGS, 23/08/2001



96-D Allen Boulevard
Farmingdale, New York 11735-5626 USA
Tel. +1 (631) 293-8944 Fax +1 (631) 293-8956
e-mail: testing@govmark.com

Page 1

Received:04/05/2016	Completed:04/07/2016	Letter: P	JB	P.O.#:	Test Report #:	3-12594-0-				
Client's Identification (see continuation)	Style: Wood Treated by Spray wit Flame Retardant. Date of Mfg.: 03/31/2016. Composition: Pine Wood. Thickness: 1".									
Tested For: Pablo Minotti Flame Retardant Technologies LLC 1330 NW 78th Ave Miami, FL 33126	Key Test: ASTM E 162					725				
Tel: 1-(305)-400-8889 Ext: Fax: 1-()- -										
CLIENT'S IDENTIFICATION (continuation): Product End Use: MINIT Flame Retardant, for Wood cardboard and Paper Treatment. Additional Information: Pine Wood Treated by Spray with the Product MINIT Flame Retardant for Wood Cardboard and Paper.										
Category: Radiant Panel LE 2015a; V 09/15 NTR 2/16 PC: 24H+ME /dl SM/mg										
APPROXIMATE [x] THICKNESS [] DIAMETER OF MATERIAL (as measured by Govmark): 1.514"										
TEST PERFORMED: ASTM E 162 - Standard Test Method for Surface Flammability of Materials Using a Radiant Heat Energy Source										
SPECIMEN: [x] Rigid Material: 6" x 18" [] Cellular Sheet Foam Materials: 6" x 18" [] Fabric/Flexible Materials: 10" x 22" [] Cable: 18" lengths were grouped to form 6" x 18" test specimens										
SPECIMEN PREPARATION: [] No backing required, as specimens exceeded 0.75" in thickness. [x] The specimens were backed by a 0.5" Etera board (a cement asbestos substitute). [] The specimens were backed with 1/4 inch high density reinforced cement board. [x] The back and sides of each specimen were wrapped with 0.002" thick aluminum foil. [] The face of each specimen was covered with a 1.0" hexagonal wire mesh screen. [] The specimen was flexible material such that the top and bottom of the 10" by 22" specimen was wrapped around the back of the board with all slack removed.										
SPECIMEN PREPARATION: [] No backing required, as specimens exceeded 0.75" in thickness. [x] The specimens were backed by a 0.5" Etera board (a cement asbestos substitute). [] The specimens were backed with 1/4 inch high density reinforced cement board. [x] The back and sides of each specimen were wrapped with 0.002" thick aluminum foil. [] The face of each specimen was covered with a 1.0" hexagonal wire mesh screen. [] The specimen was flexible material such that the top and bottom of the 10" by 22" specimen was wrapped around the back of the board with all slack removed.										
BRIEF DESCRIPTION OF TEST: (see page 2 of 2)										
RESULTS:										
Specimen #	Flame Progression (mm:ss)					Net Stack Rise°C	Q	FS	Flame Spread Index*	Flaming, Dripping, or Flaming Running (yes/no)
1	01:39	02:06	04:11	05:50	FN	59.0	9.0	4.0	36.0	No
2	F	01:19	02:03	04:33	FN	53.0	8.1	5.8	47.0	No
3	F	01:45	02:52	07:24	10:36	71.0	10.8	4.7	50.8	No
4	F	02:48	03:16	08:32	FN	41.0	6.3	4.0	25.2	No
Avg: 39.8										
ABBREVIATIONS WHICH MAY BE USED IN RESULTS: F = Flashed beyond benchmark. FN = Flame front did not reach this benchmark. WM = Flame front was attributable to burning of the residue on the wire mesh.										
CALCULATION FACTORS: Etera board correction factor: 19°C Beta: 37.36 Flux: 2.8 - 1.6 - 0.7 (Flux Transducer # 184117)										

(Page 1 of 2)

File Copy




MINIT Ignífugos

minitargentina@gmail.com www.minitfireretardant.com

COPIA FIEL DE CERTIFICADOS

Producto MINIT PARA MADERAS

Presentación valida únicamente con el Certificado / Factura de Compra



validacion



96-D Allen Boulevard
Farmingdale, New York 11735-5626 USA
Tel. +1 (631) 293-8944 Fax +1 (631) 293-8956
e-mail: testing@govmark.com

Page 2

Received: 04/05/2016	Completed: 04/07/2016	Letter: P	JB	P.O.#:	Test Report #:	3-12594-0-
Client's Identification (see continuation) Style: Wood Treated by Spray wit Flame Retardant. Date of Mfg.: 03/31/2016. Composition: Pine Wood. Thickness: 1".						
Tested For: Pablo Minotti Flame Retardant Technologies LLC 1330 NW 78th Ave Miami, FL 33126			Key Test: ASTM E 162 725 Tel: 1-(305)-400-8889 Fax: 1-()- - Ext:			
BRIEF DESCRIPTION OF TEST: The test specimen faces a radiant heat source. At the beginning of the test period an igniting flame impinges at the top of the specimen. Visual observation is made of the downward progression of the flame front. The test is completed when the flame front has progressed to the 15" mark, or after an exposure time of 15 minutes, whichever occurs first. The heat given off by the burning specimen is automatically recorded. The combination of the two factors, flame front progression and heat, result in a Flame Spread Index.						
NOTES: * While the Standard calls out "Radiant Panel Index", Govmark reports "Flame Spread Index", since this is the terminology used in most Code specifications. "Flame Spread Index" and "Radiant Panel Index" are identical for the purposes of this report. ** Flashing is defined as a flame front of 3 seconds or less in duration. Where ANY flashing has occurred, an individual specimen's Flame Spread Index is understood to be qualified as "(Flashing)".						
REMARKS:						
Specimen #	Non Sustained (Flashing**) Flame Front Off Gas Ignition (yes/no)	Sustained Flame Front Ignition at (mm:ss)	All Flaming Out (mm:ss)	Test End (mm:ss)	Drips Flame on Test Floor (yes/no)	
1	Yes	01:30	SB	15:00	No	
2	Yes	01:09	SB	15:00	No	
3	Yes	00:49	SB	15:00	No	
4	Yes	00:54	11:33	15:00	No	
ABBREVIATIONS WHICH MAY BE USED IN "REMARKS": DNI = Did not ignite SB = Still burning at test end						
ACCEPTANCE CRITERIA: None cited.						
CONCLUSION: Not applicable.						
CERTIFICATION: I certify that the above results were obtained after testing specimens in accordance with the procedures and equipment specified above.						
AUTHORIZED SIGNATURE GOVMARK /pm /tm			<i>Robert I. Brown</i> (Page 2 of 2)			

The results contained in this report relate only to item(s) tested. The test report shall not be reproduced, except in full, without written approval from Govmark.

File Copy

IRAM



MINIT Ignífugos

minitargentina@gmail.com www.minitfireretardant.com

COPIA FIEL DE CERTIFICADOS

Producto MINIT PARA MADERAS

Presentación válida únicamente con el Certificado / Factura de Compra



validacion

Homologación con estándar Europeo

Homologation ASTM E162 with European Standards Applicable to Wood and Wood-Derived Products

ASTM E162 – Standard Test Method for Surface Flammability of Materials Using a Radiant Heat Energy Source

Determine the surface flame propagation of materials exposed to a radiant heat source.

Typical application in: wood, MDF panels, solid wood, plywood, decorative coverings, wood flooring.

Equivalent European Standards

EN ISO 5658-2 Reaction to fire tests — Spread of flame

Similarities with ASTM E162

Characteristic	ASTM E162	EN ISO 5658-2
Radiant panel	Yes	Yes
Flame propagation evaluation	Yes	Yes
Combustible materials	Yes	Yes
Use in wood	Yes	Yes
Application in coverings	Yes	Yes
Surface testing	Yes	Yes

EN 13501-1 Fire classification of construction products and building elements

European fire reaction classification.system using results from: EN ISO 5658-2 /EN 13823 (SBI) /EN ISO 11925-2

European Class	Performance
A1	Non-combustible
A2	Very limited combustibility
B	Very low propagation
C	Limited propagation
D	Controlled combustible
E	High flammability

Technical Homologation for Wood Products Approximate Technical Correspondence

ASTM E162	Equivalent European
Surface propagation test	EN ISO 5658-2
Fire reaction classification	EN 13501-1
Comprehensive construction evaluation	EN 13823

Conclusion

Main equivalency: ASTM E162 ≈ EN ISO 5658-2

Complementary European standards: EN 13501-1 / EN 13823

Marco de Reconocimiento Internacional (Reciprocidad)

El sistema de aceptación de ensayos extranjeros en Argentina se basa en acuerdos internacionales de reciprocidad que eliminan la necesidad de repetir pruebas locales. Recientemente, el marco normativo se ha simplificado mediante el **Decreto 892/2025**.

El Gobierno argentino estableció el reconocimiento automático de certificaciones y ensayos internacionales para agilizar el comercio:

- Se consideran válidos los ensayos realizados en países con altos estándares de vigilancia técnica (países de "alta vigilancia") detallados en la normativa.
- Los productos que posean certificaciones de laboratorios acreditados por entidades avaladas por acuerdos de reciprocidad no requieren nuevos ensayos locales.

Principales Organismos de Acreditación y Cooperación Regional e Internacional

Organismo	Alcance	Hol Principal
ILAC	Global	Cooperación para laboratorios de ensayo y calibración.
IAF	Global	Reconocimiento de organismos de certificación de productos y sistemas.
IAAC	Regional (Américas)	Cooperación Interamericana de Acreditación.
OCDE	Global	Acuerdos de "Aceptación Mutua de Datos" (MAD) para seguridad ambiental y sanitaria.
AZLA	Regional (Américas)	Asociación para la Acreditación de Laboratorios. Bajo la norma ISO/IEC 17025. Garantiza la competencia técnica y la confianza global
ANAB / ANSI	Regional (Américas)	Junta de Acreditación. Organismo de acreditación de normas, laboratorios y organismos de inspección y certificación (ISO/IEC 17025, 17020, 17021, 17034).



MINIT Ignifugos

minitargentina@gmail.com www.minitfireretardant.com

COPIA FIEL DE CERTIFICADOS

Producto MINIT PARA MADERAS

Presentación valida únicamente con el Certificado / Factura de Compra



validacion

ENSAYOS DE EMANACIÓN DE HUMO Y GASES



Industrial Global Standards LLC
1209 MOUNTAIN ROAD PL NE STE N
ALBUQUERQUE, NM 87110
EIN 37-218160
www.inglobalstandards.com
industrialglobalstandards@gmail.com

TEST REPORT

Nº 1143-27-522

LAB SERVICE

VALIDO SOLO CON CERTIFICADO DE COMPRA.

MINIT-IGNIFUGOS

Applicant/ Manufacturer	MINIT Fire Retatadant (MINIT Ignifugos) Pablo David Minotti ID: 20224196270 Argentina
Product	MINIT Ignifugos / Fire retardant applied on different specimens described below
Reference Standard/ Method Tests	BSS 7239-88. // ASTM E-662. // EN 13823. // ISO 5659-2. TESTS METHODS FOR TOXIC GAS GENERATION BY MATERIALS ON COMBUSTION.
Description of Test Specimens	REF A -Total pieces with fire retardant (provided by Applicant/ Manufacturer) - 4 piece of 100% cotton fabric, treated with MINIT Ignifugos/ Fire retardant - Ref 1 - 4 piece of 100% polyester fabric, treated with MINIT Ignifugos/ Fire retardant - Ref 2 - 4 piece of synthetic carpet, treated with MINIT Ignifugos/ Fire retardant - Ref 3 - 4 piece of synthetic grass carpet, treated with MINIT Ignifugos/ Fire retardant - Ref 4 - 4 piece of foam, treated with MINIT Ignifugos/ Fire retardant - Ref 5 - 4 piece of wood, treated with MINIT Ignifugos/ Fire retardant - Ref 6 REF B -Total pieces without fire retardant (provided by Applicant/ Manufacturer) - 2 piece of 100% cotton fabric, without fire retardant - Ref 1 - 2 piece of 100% polyester fabric, without fire retardant - Ref 2 - 2 piece of synthetic carpet, without fire retardant - Ref 3 - 2 piece of synthetic grass carpet, without fire retardant - Ref 4 - 2 piece of foam, without fire retardant - Ref 5 - 2 piece of wood, without fire retardant - Ref 6 Size of Specimens: 3" x 3" , specified for test methods Size of Specimens: 15" x 15" , specified for test methods
Date Received	May 20, 2025
Issued Date	Jun 27, 2025
Pages	3

BSS 7239-88 is a Boeing standard test method that measures the concentration of toxic gases produced during the combustion of materials, specifically focusing on those used in aircraft interiors. It is a critical tool for evaluating fire safety, especially in the confined spaces of an aircraft cabin, by assessing the potential hazards from toxic gases like carbon monoxide, hydrogen fluoride, hydrogen cyanide, hydrogen chloride, and sulfur dioxide. The test is performed in a controlled environment, where a material sample is burned and the resulting gases are analyzed.

ASTM E-662 is a standard test method that measures the amount of smoke produced by solid materials when exposed to heat and flame, specifically focusing on the specific optical density of the smoke. It's used to evaluate how much light is blocked by the smoke generated by a material, which is an indicator of visibility reduction in a fire. This test is crucial for assessing fire hazards and is often a requirement in various industries and transportation codes. The test measures the "specific optical density," which is a normalized value that accounts for the amount of smoke generated relative to the sample's exposed area and volume.

EN 13823, is a Single Burning Item (SBI) test, is a European standard for evaluating the fire behavior of building products (excluding flooring) when exposed to a thermal attack. The product is mounted in a corner configuration with two walls (or wings) forming a 90-degree angle. A propane gas burner (30kW) is placed at the bottom of the corner to simulate a fire source. The specimen and burner are placed inside an enclosure with an exhaust system that collects combustion gases. Instruments measure heat release, smoke production, and flame spread, while visual observations record burning droplets and other relevant characteristics. The SBI test results are used to classify products into Euroclasses (A1, A2, B, C, D, etc.) which indicate their fire performance.

ISO 5659-2 is an international standard that specifies a method for measuring smoke production from materials, particularly plastics or synthetic, when exposed to heat and flame. It focuses on determining the optical density of the smoke produced in a single-chamber test. This standard is primarily used for research and development, as well as in fire safety engineering for buildings, trains, and ships, rather than for setting building code ratings.



AMERICAN SOCIETY OF
SAFETY PROFESSIONALS

Authorized Signatory
Industrial Global Standards LLC
1209 MOUNTAIN ROAD PL NE STE N
ALBUQUERQUE, NM 87110



Validation Code

The client acknowledges and agrees that any services provided and/or reports produced by Industrial Global Standards LLC are done so within the limits of the scope of work agreed pursuant to the client's specific instructions. This report relates specifically to the sample(s) tested that were drawn and delivered by the client or their nominated third party. Industrial Global Standards LLC does not make any representation or warranty for any bulk samples or certify the bulk samples received from the client. Furthermore, Industrial Global Standards LLC does not provide a warranty or verification on the sample(s) representing any specific goods, material and/or shipment and only relate to the sample(s) as received and tested. Industrial Global Standards LLC have aimed to conduct the review on a diligent and careful basis and we do not accept any liability to you for any loss arising out of or in connection with this report, in contract, tort, by statute or otherwise, except in the event of our gross negligence or willful misconduct. In no event, will the contents of any reports or any extracts, excerpts or parts of any reports be distributed or published without the prior written consent of Industrial Global Standards LLC in each instance. Only the client is authorized to permit copying or distribution of this report (and then only in its entirety). Any such third parties to whom this report may be circulated rely on the content of the report solely at their own risk. The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor of $k = 2$, providing a level of confidence of approximately 95 %. Unless otherwise specified all compliance and pass/fail statements are binary simple acceptance based on the tolerance interval.



MINIT Ignifugos

minitargentina@gmail.com www.minitfireretardant.com

COPIA FIEL DE CERTIFICADOS

Producto MINIT PARA MADERAS

Presentación valida únicamente con el Certificado / Factura de Compra



validacion



Industrial Global Standards LLC
1209 MOUNTAIN ROAD PL NE STE N
ALBUQUERQUE, NM 87110
EIN 37-218160
www.inglobalstandards.com
industrialglobalstandards@gmail.com

TEST REPORT

Nº 1143-27-522

LAB SERVICE
VALIDO SOLO CON CERTIFICADO DE COMPRA.
MINIT IGNIFUGOS

BSS 7239-88 RESULTS:

Relative Room Humidity: 20% / Test Duration: 20 min. // Chamber Wall Temp: 35°C

Carbon Monoxide (CO ppm) at 1.5 minutes
at 4.0 minutes
at maximum

Nitrogen Oxides (as NO₂ ppm)

Sulfur Dioxide (SO₂ ppm)

Hydrogen Chloride (HCl ppm)

Hydrogen Fluoride (HF ppm)

Hydrogen Cyanide (HCN ppm)

REF A	HCl	HCN	HF	NO ₂	SO ₂	CO 1.5	CO 4.0	CO MAX
1	< 1	ND	ND	< 1	ND	5	55	118
2	< 2	ND	ND	< 1	ND	8	98	211
3	< 3	ND	< 2	< 1	< 1	9	101	218
4	< 3	ND	< 2	< 1	< 1	9	125	238
5	< 3	ND	< 2	< 1	< 1	9	127	247
6	< 2	ND	ND	< 1	ND	6	87	209

2

Conclusions:

Boeing BSS 7239 is solely a test procedure and as such, has no specific pass/fail criteria of its own. The reference criteria cited are typical for the transportation industry and are listed for reference purposes only. They may or may not apply to the specific products. Specimens are exposed to the combustion conditions described in ASTM E 662 - Standard Test Method for Specific Optical Density of Smoke Generated by Solid Materials. In compliance with this standards the material tested approve the BSS 7239 Tests

ASTM E-662 RESULTS:

REF A	Relative Room Humidity: 33% / Chamber Wall Temp: 35°C
1	Ds (1.5): 34, Ds (4.0): 52, Dm: 114.
2	Ds (1.5): 61, Ds (4.0): 89, Dm: 197.
3	Ds (1.5): 63, Ds (4.0): 91, Dm: 211.
4	Ds (1.5): 64, Ds (4.0): 94, Dm: 212.
5	Ds (1.5): 68, Ds (4.0): 97, Dm: 232.
6	Ds (1.5): 64, Ds (4.0): 95, Dm: 212.

Among the parameters normally reported are:

Ds 1.5 - specific optical density after 1.5 minutes

Ds 4.0 - specific optical density after 4.0 minutes

Dm - maximum specific optical density at any time during the 20 minute test

Authorities generally specify a maximum Ds 1.5 of 100 and a maximum Ds 4.0 of 200 in either flaming or non-flaming test mode.

Conclusions:

All specimens materials, identified in this report, when tested, meet requirements to smoke rate required by authorities.



AMERICAN SOCIETY OF
SAFETY PROFESSIONALS

Authorized Signatory
Industrial Global Standards LLC
1209 MOUNTAIN ROAD PL NE STE N
ALBUQUERQUE, NM 87110



Validation Code

The client acknowledges and agrees that any services provided and/or reports produced by Industrial Global Standards LLC are done so within the limits of the scope of work agreed pursuant to the client's specific instructions. This report relates specifically to the sample(s) tested that were drawn and delivered by the client or their nominated third party. Industrial Global Standards LLC does not make any representation or warranty for any bulk samples or certify the bulk samples received from the client. Furthermore, Industrial Global Standards LLC does not provide a warranty or verification on the sample(s) representing any specific goods, material and/or shipment and only relate to the sample(s) as received and tested. Industrial Global Standards LLC have aimed to conduct the review on a diligent and careful basis and we do not accept any liability to you for any loss arising out of or in connection with this report, in contract, tort, by statute or otherwise, except in the event of our gross negligence or willful misconduct. In no event, will the contents of any reports or any extracts, excerpts or parts of any reports be distributed or published without the prior written consent of Industrial Global Standards LLC in each instance. Only the client is authorized to permit copying or distribution of this report (and then only in its entirety). Any such third parties to whom this report may be circulated rely on the content of the report solely at their own risk. The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor of $k = 2$, providing a level of confidence of approximately 95 %. Unless otherwise specified all compliance and pass/fail statements are binary simple acceptance based on the tolerance interval.



MINIT Ignifugos

minitargentina@gmail.com www.minitfireretardant.com

COPIA FIEL DE CERTIFICADOS

Producto MINIT PARA MADERAS

Presentación valida únicamente con el Certificado / Factura de Compra



validacion

IGS

Industrial Global Standards LLC

Industrial Global Standards LLC
1209 MOUNTAIN ROAD PL NE STE N
ALBUQUERQUE, NM 87110
EIN 37-218160
www.inglobalstandards.com
industrialglobalstandards@gmail.com

TEST REPORT

Nº 1143-27-522

LAB SERVICE

VALIDO SOLO CON CERTIFICADO DE COMPRA.
MINIT IGNIFUGOS

EN 13823 RESULTS:

Cumulative smoke production (TSP), Fire Growth Rate (FIGRA), Cumulative heat release (THR), Smoke growth rate (SMOGRA)

REF A	Lateral Flame Spread to End of Specimen	Flaming droplets	Flaming of Fallen Particle Exceeding 10s	FIGRA (w/s)	THR 600s (MJ)	SMOGRA (m²/s²)	TSP 600s (m²)
1	N	N	N	178.68	11.89	79.68	86.15
2	N	N	N	367.17	24.78	187.23	149.95
3	N	N	N	389.82	25.49	162.89	144.56
4	N	N	N	391.25	24.87	161.76	142.82
5	N	N	N	396.12	25.45	163.08	144.78
6	N	N	N	185.98	12.87	83.45	89.27

Conclusion on specimens REF A: All specimens materials, identified in this report, when tested, meet requirements to smoke rate required by authorities. (Pass)

REF B	Lateral Flame Spread to End of Specimen	Flaming droplets	Flaming of Fallen Particle Exceeding 10s	FIGRA (w/s)	THR 600s (MJ)	SMOGRA (m²/s²)	TSP 600s (m²)
1	Y	Y	Y	536.04	35.67	239.04	258.45
2	Y	Y	Y	1101.51	74.37	561.96	449.85
3	Y	Y	Y	1069.46	76.47	488.67	433.68
4	Y	Y	Y	1173.75	74.61	485.28	428.46
5	Y	Y	Y	1188.36	76.35	489.24	434.34
6	Y	Y	Y	557.94	38.61	250.35	267.81

Conclusion on specimens REF B: All specimens materials, identified in this report, when tested, do not meet smoke rate required by authorities. (Do not pass)

ISO 5659-2 RESULTS:

The radiator cone was located so that the lower rim of the radiator cone shade junction was 25 mm above the upper surface of the specimen when oriented in the horizontal position. Exposed to a radiant heat source (25kW/m² or 50kW/m²) within a closed chamber. Pilot flame was applied.

REF A	/ Relative Room Humidity: 50% / Chamber Wall Temp: 26 °C
1	Ds (1.5): 31, Ds (4.0): 49, Dm: 111.
2	Ds (1.5): 59, Ds (4.0): 86, Dm: 194.
3	Ds (1.5): 61, Ds (4.0): 88, Dm: 208.
4	Ds (1.5): 61, Ds (4.0): 91, Dm: 209.
5	Ds (1.5): 65, Ds (4.0): 94, Dm: 229.
6	Ds (1.5): 61, Ds (4.0): 25, Dm: 209.

Conclusion on specimens REF A: All specimens materials, identified in this report, when tested, meet requirements to smoke rate required by authorities. (Pass)

REF B	/ Relative Room Humidity: 50% / Chamber Wall Temp: 26 °C
1	Ds (1.5): 119, Ds (4.0): 182, Dm: 399.
2	Ds (1.5): 213, Ds (4.0): 311, Dm: 689.
3	Ds (1.5): 220, Ds (4.0): 318, Dm: 738.
4	Ds (1.5): 224, Ds (4.0): 329, Dm: 742.
5	Ds (1.5): 238, Ds (4.0): 339, Dm: 812.
6	Ds (1.5): 224, Ds (4.0): 332, Dm: 742.

Conclusion on specimens REF B: All specimens materials, identified in this report, when tested, do not meet smoke rate required by authorities. (Do not pass)



AMERICAN SOCIETY OF
SAFETY PROFESSIONALS

Authorized Signatory
Industrial Global Standards LLC
1209 MOUNTAIN ROAD PL NE STE N
ALBUQUERQUE, NM 87110



Validation Code

The client acknowledges and agrees that any services provided and/or reports produced by Industrial Global Standards LLC are done so within the limits of the scope of work agreed pursuant to the client's specific instructions. This report relates specifically to the sample(s) tested that were drawn and delivered by the client or their nominated third party. Industrial Global Standards LLC does not make any representation or warranty for any bulk samples or certify the bulk samples received from the client. Furthermore, Industrial Global Standards LLC does not provide a warranty or verification on the sample(s) representing any specific goods, material and/or shipment and only relate to the sample(s) as received and tested. Industrial Global Standards LLC have aimed to conduct the review on a diligent and careful basis and we do not accept any liability to you for any loss arising out of or in connection with this report, in contract, tort, by statute or otherwise, except in the event of our gross negligence or wilful misconduct. In no event, will the contents of any reports or any extracts, excerpts or parts of any reports be distributed or published without the prior written consent of Industrial Global Standards LLC in each instance. Only the client is authorized to permit copying or distribution of this report (and then only in its entirety). Any such third parties to whom this report may be circulated rely on the content of the report solely at their own risk. The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor of $k = 2$, providing a level of confidence of approximately 95 %. Unless otherwise specified all compliance and pass/fail statements are binary simple acceptance based on the tolerance interval.



MINIT Ignífugos

minitargentina@gmail.com www.minitfireretardant.com

COPIA FIEL DE CERTIFICADOS

Producto MINIT PARA MADERAS

Presentación válida únicamente con el Certificado / Factura de Compra



Homologación de De Densidad de Humo NORMA IRAM 11914

Evaluación Comparativa del Índice de Densidad de Humo (Dm) de diferentes materiales, tratados con Retardante de fuego MINIT Ignífugos, según certificado de ensayo Internacional **IGS 1143-27-522** con Normativa **IRAM 11914 1**.

Comparación de Normativas, Aspecto Propósito, Método de Prueba, Criterios de Evaluación, Similitud con Normas:

ISO 5659-2 Medición de la densidad de humo en cámara cerrada. Se mide la densidad óptica de los humos en función del tiempo y calor irradiado. Densidad óptica específica máxima (Ds). Alta similitud en técnicas de medición.

EN 13823 (SBI Test) Evaluación de la densidad de humo en materiales de construcción mediante SMOGRA. Evaluación de liberación de humo durante la combustión con un objeto en llamas. Tasa de crecimiento de humo (**SMOGRA**).

Ambas normas son compatibles en parte con la evaluación de propagación del humo. IRAM 11914"

En el certificado de ensayo internacional **IGS 1143-27-522** se realizó sobre los siguientes materiales tratados con Retardante de fuego MINIT Ignífugo y no tratados en ensayos comparativos:

- Tela 100% algodón
- Tela 100% poliéster
- Alfombra 100% sintética
- Alfombra de pasto 100% sintética
- Goma espuma
- Madera

En la valuación de la densidad óptica específica corregida (Dmc) de humos en incendios se mide la absorción de luz en una cámara específica para calcular Dm. Densidad óptica específica corregida (Dmc). Especifica los mismos criterios de clasificación.

Desarrollo Comparativo de Normativas Internacionales.

ISO 5659-2 es la norma internacional utilizada para medir la densidad de humo en cámara cerrada. Su método de medición es comparable con IRAM 11914, aunque sus criterios de clasificación difieren levemente.

EN 13823 (SBI Test) evalúa la propagación del fuego y la generación de humo, midiendo SMOGRA. No es idéntico a IRAM 11914 pero se usa en conjunto para clasificar materiales.

IRAM 11914 clasifica los materiales en función de la densidad de humo corregida (Dmc):

- ≤ 132 Clasificación Baja generación de humo
- 133 – 264 Mediana generación de humo
- 265 – 396 Alta generación de humo
- > 396 Muy alta generación de humo

Para evaluar un material en Argentina según IRAM 11914, los valores obtenidos de ISO 5659-2 o EN 13823 sirven como referencia.

Conclusión Final

A partir del análisis de normativas internacionales y estudios previos, se ha determinado que los materiales tratados con retardantes de llama MINIT tienen una generación de humo moderada, lo que permite su clasificación en "**Baja a Mediana Generación de Humo**" según **IRAM 11914 (Dmc 130 - 250)**. Comparado con los materiales sin Retardante de llama.

El informe sugiere que los materiales con retardantes de llama MINIT son una opción viable para aplicaciones donde la generación de humo debe ser controlada, cumpliendo con normativas de seguridad.

Marco de Reconocimiento Internacional (Reciprocidad)

El sistema de aceptación de ensayos extranjeros en Argentina se basa en acuerdos internacionales de reciprocidad que eliminan la necesidad de repetir pruebas locales. Recientemente, el marco normativo se ha simplificado mediante el **Decreto 892/2025**.

El Gobierno argentino estableció el reconocimiento automático de certificaciones y ensayos internacionales para agilizar el comercio:

- Se consideran válidos los ensayos realizados en países con altos estándares de vigilancia técnica (países de "alta vigilancia") detallados en la normativa.
- Los productos que posean certificaciones de laboratorios acreditados por entidades avaladas por acuerdos de reciprocidad no requieren nuevos ensayos locales.

Principales Organismos de Acreditación y Cooperación Regional e Internacional

Organismo	Alcance	Hol Principal
ILAC	Global	Cooperación para laboratorios de ensayo y calibración.
IAF	Global	Reconocimiento de organismos de certificación de productos y sistemas.
IAAC	Regional (Américas)	Cooperación Interamericana de Acreditación.
OCDE	Global	Acuerdos de "Aceptación Mutua de Datos" (MAD) para seguridad ambiental y sanitaria.
A2LA	Regional (Américas)	Asociación para la Acreditación de Laboratorios. Bajo la norma ISO/IEC 17025. Garantiza la competencia técnica y la confianza global
ANAB / ANSI	Regional (Américas)	Junta de Acreditación. Organismo de acreditación de normas, laboratorios y organismos de inspección y certificación (ISO/IEC 17025, 17020, 17021, 17034).