

## Our Ref. CEA/WE/CM/UMA/SL/B59/4411/09

Licence No. B 03129(R<sub>12</sub>)

## NATIONAL ENVIRONMENTAL ACT NO. 47 OF 1980 ENVIRONMENTAL PROTECTION LICENCE ISSUED UNDER SECTION 23B

M/s Pannipitiya Medical Services (Pvt) Ltd of No.334/4, Hokandara Road, Pannipitiya situated within the area of authority of the Urban Council of Maharagama is hereby authorized to discharge/deposit effluents/waste and /or emit noise/ vibrations/ air emissions which may arise as a result of the operation of the said industry/process, in accordance with the standards and criteria prescribed by the National Environmental (Protection and Quality) Regulations No. 1 of 2008, published in the gazette No 1534/18 dated 01.02.2008 amended by gazette No.2264/17 dated 27.01.2022 and the National Environmental (Noise Control) Regulation No. 01 of 1996, published in the gazette No. 924/12 dated 23.05.1996.

This licence shall be in force from 19.11.2022 to 18.11.2023 unless it is earlier cancelled or suspended.

This licence is subject to the general terms and conditions stated overleaf and to the additional terms and conditions stated below.

## Noise Control

1. Noise level at the boundary of the Nursing Home during the operation should be maintained at or below 50dB (A) during day (between 0600 hrs and 1800 hrs) and at or below 45dB(A) during night. (1800 hrs and 0600 hrs).

## Water Pollution Control

- 2. 2.1 All waste water generated from the operation of the Nursing Home should be treated upto tolerance limits for discharge of industrial waste water into inland surface waters prior to discharge. (Vide annexure I).
  - 2.2 Treated waste water should be used for gardening.
  - Outlet tube/ sampling manhole of the wastewater treatment plant shall always be safe & accessible enabling to collect samples of treated wastewater for analysis at all times to inspecting officers.

02.11.2022

Chairman / Director General / Authorize Officer Central Environmental Authority

H.S. Premachandra
Director - Western Province
Central Environmental Authority