

BOARD OF INVESTMENT OF SRI LANKA

P.O. Box 1768, World Trade Centre – West Tower, Echelon Square, Colombo 1, Sri Lanka

Date : 17/08/2022
Our Ref : EC/18/LE/715
Your Ref:

Manager – Finance & Operations
Nawaloka Medicare (Pvt) Ltd
No. 169, Colombo Road
Negombo

Dear Sir

RENEWAL OF ENVIRONMENTAL PROTECTION LICENCE (EPL)


We refer to your EPL renewal application submitted to the BOI in respect of your hospital at No. 169, Colombo Road, Negombo.

The Environmental Protection Licence bearing No CEA B 133822/2022 issued for the period from 18 January 2022 to 17 January 2023 under the National Environmental Act is sent herewith.

Please note you will be required to submit

- i. an application for renewal of the EPL three(03) months prior to the expiry date stated above.
- ii. test reports as per conditions stipulated in the EPL.

Yours faithfully



(Ms) A S Beling

Director (Environment Management)

BOARD OF INVESTMENT OF SRI LANKA

cc: Chairman
Urban Council
Katunayake-Seeduwa

Director
Gampaha District Office/CEA



NATIONAL ENVIRONMENT ACT NO.47 OF 1980
ENVIRONMENTAL PROTECTION LICENCE ISSUED UNDER SECTION 23B

M/s Nawaloka Medicare (Pvt) Ltd

Of No. 169, Colombo Road, Negombo.

situated within the area of authority of the Urban Council of Katunayake-Seeduwa is/are hereby authorized to discharge/deposit effluents/waste and/or emit noise/vibrations/air emissions which may arise as a result of the operation of the said industry/process, in accordance with the gazette notification No. 2264/17 dated 27.01.2022 made under the Provision of National Environmental Act.

This Licence shall be in force from **18 January 2022 to 17 January 2023** unless it is earlier cancelled or suspended.

This Licence is subject to the General Terms and Conditions stated overleaf and to the additional Terms and Conditions stated below.

- (1) (a) Domestic wastewater & sewage generated shall be treated and disposed of after ensuring conformity to the "Tolerance Limits for discharge of wastewater or effluent into Inland Surface Waters".
- (b) An analytical report of treated wastewater shall be obtained from a CEA recognized laboratory and submitted to BOI/CEA on regular basis, at the end of every three month period and following parameters shall be included in the analytical report.

No	Parameter	Tolerance Limit
I	pH at ambient temperature	6.0 - 8.5
II	Chemical Oxygen Demand (COD)	250 mg/l, max
III	Biochemical Oxygen Demand (BOD ₅) (BOD ₅ in five days at 20° C or BOD ₃ in three days at 27° C)	30 mg/l, max
IV	Total Suspended Solids (TSS)	50 mg/l, max
V	Oils and Greases	10 mg/l, max
VI	Fecal Coliform	150 MPN/100 ml,max
VII	Ammoniacal Nitrogen (as N)	50 mg/l, max
VIII	Dissolved Phosphates (as P)	5 mg/l, max

- (c) Treated wastewater shall be reused as much as possible for non-portable use and balance portion shall be used for irrigation purposes.

This Licence is issued in consultation with and the concurrence of the **Central Environmental Authority** obtained by the BOI.

17 August 2022

.....
Director (Environment Management)