



No. CEA B 41983

NATIONAL ENVIRONMENTAL ACT NO. 47 OF 1980
ENVIRONMENTAL PROTECTION LICENCE ISSUED UNDER SECTION 23B

M/s. Holy Cross Health Centre (Hospital), No: 769, Beach Road, Jaffna situated within the area of authority of the Municipal Council, Jaffna is hereby authorized to discharge/deposit effluents/waste and /or emit noise/vibrations/air emissions which may arise as a result of the operation of the said industry/process, in accordance with the standards and criteria prescribed by the National Environmental (Protection and Quality) Regulations No. 1 of 2008, published in the gazette No 1534/18 dated 01.02.2008 amended by gazette No. 2264/17 dated 27.01.2022 and the National Environmental (Noise Control) Regulation No. 01 of 1996, published in the gazette No. 924/12 dated 23.05.1996.

This licence shall be in force from **18.02.2022** to **17.02.2023** unless it is earlier cancelled or suspended.

This licence is subject to the general terms and conditions stated overleaf and to the additional terms and conditions stated below.

Noise Control

1. Noise level at the boundary of the hospital during the operation should be maintained at or below 63dB (A) during day (between 0600 hrs and 1800 hrs) and at or below 50dB (A) during night time (1800 hrs and 0600 hrs).

Water Pollution Control

2. 2.1 All waste water generated from the operation of the Holy Cross Health Centre (Hospital) should be treated up to tolerance limits for industrial and domestic effluents discharged into marine coastal areas prior to discharge.
- 2.2 An waste water analytical report shall be obtained from any one of the laboratories registered under the Central Environmental Authority in the annexed list (Annexure II) and such reports should be submitted to the Central Environmental Authority once in every six (06) months commencing from the date of this licence and one report shall be obtained from the Central Environmental Authority.
- 2.3 Outlet tube/sampling manhole of the wastewater treatment plant shall be set up to provide free & safe access to collect sample of treated wastewater.

Air Pollution Control

3. Adequate control mechanism should be adopted to control air emissions arising from hospital activities.

Solid Waste Management

4. 4.1 Solid waste such as polythene, plastic, paper shall not be disposed of into any water body or at a site where it is likely to enter a water body.
- 4.2 Clinical waste/Infectious waste generated from the hospital should be separated from the normal garbage.
- 4.3 All the solid waste other than clinical waste generated shall be collected into a central place within the premises and shall be removed and disposed at regular intervals in an environmentally safe and nuisance free manner in consultation with the relevant local authority.
- 4.4 All the infectious solid waste shall be transported and disposed at regular intervals after disinfection in an environmentally safe and nuisance free manner with consultation with **Sanicare Services (Pvt.) Ltd.** as per the agreement submitted by Holy Cross Health Centre (Hospital).
- 4.5 According to the Part II of Gazette Extraordinary No.1534/18 dated 01.02.2008 shall obtain separate Licence for the management of waste under the scheduled VIII, No.28 of Part II waste from specific sources.

28.03.2022

Chairman/Director General/Authorize Officer
Central Environmental Authority

T. Suboharan
Director (Act.)
Central Environmental Authority
Northern Provincial Office
Kilinochchi.