

CERTIFICATE FOR STRUCTURAL SAFETY

HMCD HERATH

CHARTED ENGINEER

Membership No. 6485

25/35A, Chocolate Factory Road, Heerassagala, Kandy

This certificate is issued on the request of Dr. D.M.P. Dissanayake, No:875/1, William Gopallawa Mawatha, Kandy for the purpose of submission to Private Health Services Regulatory Council under the Ministry of Health, Nutrition, Indigenous Medicine.

Observation and Certification on Building/s or Structure: Private Building at No:875/1, William Gopallawa Mawatha, Kandy

Element	Observation	Certification/Comments
Foundation		
Settlement and cracks in columns, walls. Joint at plinth	Limited access No any defects observed	Recommended for use of proposed intended purpose
Super Structure		
Frame Structure Columns, beams, and slabs	No any defects observed	Recommended for use of proposed intended purpose
Wall/Cladding	Dampness and fungi attacks observed	Non- structural defects and recommended to carry out remedial measures
Roof /downpipes	No any defects observed	Recommended for use of proposed intended purpose
Floor/Expansion Joints	No any defects observed	Recommended for use of proposed intended purpose
Roofing System	No any defects Observed	Recommended for use of proposed intended purpose
Others	No any defects Observed	Overall structural stability of the building is in satisfactory level and recommended for the use of intended purpose

Note: This certificate is issued base on the inspection carried out on July 18, 2021.

It is hereby certified that structural safety of the subject building is in a satisfactory level for prevailing and future usage/operation for the five-year period effective from October 01, 2021 subject to conditions stipulated in the below.

1. Establishing proper maintenance system for the building
2. Carrying out remedial measures for defects observed
3. Carrying out structural inspection after two years under new loading condition

Prepared by and Certified by


Eng. H M C D Herath

BSc.Eng., M Eng., CEng., MIE(SL)

Date: 2021.09.15

