



කොළඹ මහා නගර සභාව / கொழும்பு மாநகர சபை / Colombo Municipal Council



ගිනි නිවිම් සේවා දෙපාර්තමේන්තුව  
தீயணைக்கும் சேவை திணைக்களம்  
FIRE SERVICE DEPARTMENT

ටී. ඩී. ජයා මාවත, කොළඹ 10. / தி. பி. ஜயா மாவத்தை, கொழும்பு 10. / T.B. Jayah Mawatha, Colombo 10.

දුරකථන / தொலைபேசி / Telephone : 011-2686087      ෆැක්ස් / பெக்ஸ் / Fax : 011-2692222

ගිනි අපරිම      110  
அவசர தொலைபேசி      2422222-3  
Emergency Numbers      4222222

වෙබ් අඩවිය      }  
செய்      } www.cmc.lk  
Web      }

විද්‍යුත් තැපෑල      }  
ஈ-மேயில்      } cmcfireservice@sltnet.lk  
E-mail      }

06<sup>th</sup> December 2022

Managing Director

Phillip Hospital

No. 255"

Galle Road

Kalutara

**FIRE COVER ADEQUACY CERTIFICATE 2022-2023**

Dear Sri,

I hereby certify that below mentioned results obtained after the fire safety inspection on 04<sup>th</sup> December 2022 and all available fire protection equipment, warning systems and warning signs etc. **are in order to the required standards.**

|                                |   |
|--------------------------------|---|
| Nature of Business             | - Hospital                                      |
| Hazard Group                   | - OH – Group 01                                 |
| Purpose of Inspection          | - For Pre disaster & Post disaster preparedness |
| Inspected on                   | - 04 <sup>th</sup> December 2022                |
| Next Inspection due            | - On or before 03 <sup>rd</sup> December 2022   |
| Testing & Inspection Procedure | - According to the accepted standards           |
| Responsible Bodies             | - Managing Director                             |
| Inspected Areas                | - Entire hospital Premises                      |
| Building Structure elements    | - Sufficient and in order                       |
| Emergency Notification System  | - Can be accepted – Tested with prior notices   |
| Gangways and pathways          | - In order                                      |
| Exit Signs                     | - In order                                      |
| Ventilation and illumination   | - In order                                      |
| Communication facility         | - Sufficient and in order                       |
| Emergency lights etc.          | can be satisfied                                |
| Floor evacuation plan          | Displayed properly                              |
| Available ext widths           | Sufficient to escape & directional exit to AP   |
| Fire Hose Reel Hose            | Sufficient and in order                         |
| First aid fire extinguisher    | Sufficient and in order                         |

### Comments

- 01 Good housekeeping practice are very essential to maintain in all areas
- 02 Emergency assembly points should be kept without any hindrance at all times

### RECOMMENDATION


Can be satisfied with the available fire safety set up and with the theoretical and practical knowledge given by fire brigade personnel, workers are in position to take their initial actions with the available firefighting resources. Situation beyond medium nearest fire brigade units at request can be summoned.

Therefore no objection of issuing this fire cover adequacy certificate.

I will take this opportunity to thank you for inviting me to conduct this fire safety audit and really appreciate your concern about safety matters.

*(The certificate is valid only for one year from the date of issue)*

Thanking you  
Your Faithfully.



.....  
H. H. MADUSIRI  
Assistant Chief Fire Officer  
Fire Service Department  
Colombo 10.

H. H. MADUSIRI  
G. I. Fire E (UK)  
Assistant Chief Fire Officer  
Fire Service Department  
Colombo 10.