

MOTOR INSPECTION REPORT

Document Ref: IR-560 | Electric Motor M-204 (drives Pump P-204)

Inspection Date	03 Jul 2024
Asset	Electric Motor M-204 (drives P-204)
Inspector	R. Krishnan

Motor M-204 insulation resistance and winding temperature within normal limits. Motor DE and NDE bearing vibration nominal (below 3.0 mm/s). No action required on the motor. Note: the driven pump P-204 has a separate elevated-vibration finding recorded under IR-556.