

STANDARD MAINTENANCE PROCEDURE

Document Ref: M-118 | Rotating Equipment Condition Monitoring

Procedure ID	M-118
Title	Condition Monitoring & Bearing Management, Rotating Equipment
Applies To	Centrifugal pumps, motors, fans (rotating assets)
Governing Regulation	OISD-132 (Inspection of Rotating Equipment)
Revision	Rev 4

Clause 4.3 - Elevated Vibration Response

Where a bearing is flagged with elevated vibration (ISO 10816-3 Zone C) during inspection, the bearing shall be scheduled for replacement within 14 days of the inspection date. Interim lubrication may be applied but does not substitute for replacement. Deferral beyond 14 days requires documented risk assessment and area manager approval, not supervisor sign-off alone.

Clause 4.4 - Zone D Alarm Response

Any asset crossing the Zone D alarm threshold (7.1 mm/s RMS for this class) requires an immediate corrective work order and consideration for controlled shutdown. Online alarms shall not be left without a raised work order.

Regulatory Basis

This procedure implements the inspection and integrity requirements of OISD-132. Non-compliance with bearing replacement timelines constitutes a procedural deviation reportable under the plant integrity management system.