

PUMP OPERATING MANUAL (EXTRACT)

Asset: Centrifugal Pump P-210 | Cooling Water Service

Bearing Lubrication

P-210 uses grease-lubricated deep-groove ball bearings. Recommended relubrication interval is 2000 operating hours with ISO VG 68 grade grease. Over-lubrication can cause elevated bearing temperature. Normal DE bearing vibration for this unit is below 2.8 mm/s RMS.

Routine Checks

Weekly: check seal leakage, bearing temperature, and suction pressure. Monthly: vibration spot reading. P-210 is not on continuous online monitoring.