

VIBRATION MONITORING TREND LOG

Document Ref: VS-204 | Online Condition Monitoring

Asset	Pump P-204 - DE Bearing
Sensor Tag	VT-204-DE (accelerometer, mm/s RMS)
Monitoring Mode	Continuous online (post IR-556 escalation)
Alarm Threshold	7.1 mm/s RMS (ISO 10816-3 Zone D)

Trend Data (weekly RMS)

Date	DE Bearing (mm/s RMS)	Status
01 Jul 2024	4.6	Zone C - Elevated
08 Jul 2024	4.9	Zone C - Elevated
12 Jul 2024	5.8	Zone C - Rising
17 Jul 2024	7.4	Zone D - ALARM
19 Jul 2024	9.1	Zone D - CRITICAL

DE bearing vibration crossed the 7.1 mm/s Zone D alarm threshold on 17 Jul 2024, five days before failure. Amplitude continued rising to 9.1 mm/s. Alarm was logged by the online system. No corrective work order was raised in response to the Zone D alarm.