



## OPERATIONS AND MAINTENANCE

### DAPITAN CTS

District 1, Mindanao Operations and Maintenance

### DAPITAN CTS DAILY OPERATION LOG SHEET

Date: April 03, 2025

Day : Thursday

Time	CSE Oil Pressure Line 1 (Bar)				CSE Oil Pressure Line 2 (Bar)				Weather Condition
	Critical Low Pressure Alarm	Low Pressure Alarm	Actual Operating Pressure	High Pressure Alarm	Critical Low Pressure Alarm	Low Pressure Alarm	Actual Operating Pressure	High Pressure Alarm	
0200H	1.50	2.00	3.55	6.00	1.50	2.00	2.55	6.00	A
0500H	1.50	2.00	3.50	6.00	1.50	2.50	2.50	6.00	A
0700H	1.50	2.00	3.55	6.00	1.50	2.00	2.55	6.00	A
1100H	1.50	2.00	3.60	6.00	1.50	2.00	2.60	6.00	A
1400H	1.50	2.00	3.70	6.00	1.50	2.00	2.65	6.00	A
1700H	1.50	2.00	3.65	6.00	1.50	2.00	2.60	6.00	A
1900H	1.50	2.00	3.60	6.00	1.50	2.00	2.60	6.00	A
2300H	1.50	2.00	3.55	6.00	1.50	2.00	2.55	6.00	A
Max. reading			3.70				2.65		
Min. reading			3.50				2.50		
Surge Counter Reading	8				4				

Reported by:

**JOVEMAR R PIDOR**  
SSEOD

Approved by:

**JAY LHORD S. TUMAPON**  
Principal Engineer

Legend:

**A** - Fair/Sunny

**B** - Cloudy

**C** - Rainy

**D** - Stormy

**CSE Oil Pressure Line 1 & 2 Characteristic Graph**

