

Proyecto_final

Totally Integrated Automation Portal																																																																																																																																						
<div>Table of contents</div> <div>Proyecto_final</div> <table><tr><td>PLC_1 [CPU 1516-3 PN/DP]</td><td>4 - 1</td></tr><tr><td>Software units</td><td>5 - 1</td></tr><tr><td>Program blocks</td><td></td></tr><tr><td> Main [OB1]</td><td>6 - 1</td></tr><tr><td> PLC1_Ban [DB2]</td><td>7 - 1</td></tr><tr><td>System blocks</td><td></td></tr><tr><td>Program resources</td><td></td></tr><tr><td> IEC_Timer_0_DB [DB1]</td><td>8 - 1</td></tr><tr><td>Technology objects</td><td>9 - 1</td></tr><tr><td>PLC tags</td><td></td></tr><tr><td> Default tag table [61]</td><td></td></tr><tr><td> PLC tags</td><td>10 - 1</td></tr><tr><td> User constants</td><td>11 - 1</td></tr><tr><td>PLC data types</td><td></td></tr><tr><td> System data types</td><td>12 - 1</td></tr><tr><td>Watch and force tables</td><td></td></tr><tr><td> Force table</td><td>13 - 1</td></tr><tr><td>Traces</td><td>14 - 1</td></tr><tr><td>Measurements</td><td>15 - 1</td></tr><tr><td> Combined measurements</td><td>16 - 1</td></tr><tr><td>OPC UA communication</td><td></td></tr><tr><td> Server interfaces</td><td>17 - 1</td></tr><tr><td> Client interfaces</td><td>18 - 1</td></tr><tr><td>PLC supervisions & alarms</td><td></td></tr><tr><td> PLC supervisions</td><td>19 - 1</td></tr><tr><td> PLC alarms</td><td>20 - 1</td></tr><tr><td> System alarms</td><td>21 - 1</td></tr><tr><td>PLC alarm text lists</td><td>22 - 1</td></tr><tr><td>Local modules</td><td></td></tr><tr><td> PLC_1 [CPU 1516-3 PN/DP]</td><td>23 - 1</td></tr><tr><td> AI 8xU/I/RTD/TC ST_1</td><td>24 - 1</td></tr><tr><td> AQ 4xU/I ST_1</td><td>25 - 1</td></tr><tr><td> DI 32x24VDC HF_1</td><td>26 - 1</td></tr><tr><td> DQ 32x24VDC/0.5A HF_1</td><td>27 - 1</td></tr><tr><td>PLC_2 [CPU 1215C DC/DC/DC]</td><td>28 - 1</td></tr><tr><td>Program blocks</td><td></td></tr><tr><td> Main [OB1]</td><td>29 - 1</td></tr><tr><td> PLC2_Rev [DB5]</td><td>30 - 1</td></tr><tr><td>System blocks</td><td></td></tr><tr><td>Program resources</td><td></td></tr><tr><td> IEC_Timer_0_DB [DB1]</td><td>31 - 1</td></tr><tr><td> IEC_Timer_0_DB_2 [DB3]</td><td>32 - 1</td></tr><tr><td> IEC_Counter_0_DB [DB2]</td><td>33 - 1</td></tr><tr><td> IEC_Timer_0_DB_1 [DB4]</td><td>34 - 1</td></tr><tr><td> IEC_Timer_0_DB_3 [DB6]</td><td>35 - 1</td></tr><tr><td> IEC_Timer_0_DB_4 [DB7]</td><td>36 - 1</td></tr><tr><td> IEC_Timer_0_DB_5 [DB8]</td><td>37 - 1</td></tr><tr><td>Web server</td><td></td></tr><tr><td> DB 333 [DB333]</td><td>38 - 1</td></tr><tr><td>Technology objects</td><td>39 - 1</td></tr><tr><td>PLC tags</td><td></td></tr><tr><td> Default tag table [54]</td><td></td></tr><tr><td> PLC tags</td><td>40 - 1</td></tr><tr><td> User constants</td><td>41 - 1</td></tr><tr><td>PLC data types</td><td></td></tr><tr><td> System data types</td><td>42 - 1</td></tr><tr><td>Watch and force tables</td><td></td></tr><tr><td> Force table</td><td>43 - 1</td></tr><tr><td>Traces</td><td>44 - 1</td></tr><tr><td>Measurements</td><td>45 - 1</td></tr><tr><td> Combined measurements</td><td>46 - 1</td></tr><tr><td>PLC alarm text lists</td><td>47 - 1</td></tr><tr><td>Local modules</td><td></td></tr><tr><td> PLC_2 [CPU 1215C DC/DC/DC]</td><td>48 - 1</td></tr><tr><td>PLC_3 [CPU 1215C DC/DC/DC]</td><td>49 - 1</td></tr><tr><td>Program blocks</td><td></td></tr></table>			PLC_1 [CPU 1516-3 PN/DP]	4 - 1	Software units	5 - 1	Program blocks		Main [OB1]	6 - 1	PLC1_Ban [DB2]	7 - 1	System blocks		Program resources		IEC_Timer_0_DB [DB1]	8 - 1	Technology objects	9 - 1	PLC tags		Default tag table [61]		PLC tags	10 - 1	User constants	11 - 1	PLC data types		System data types	12 - 1	Watch and force tables		Force table	13 - 1	Traces	14 - 1	Measurements	15 - 1	Combined measurements	16 - 1	OPC UA communication		Server interfaces	17 - 1	Client interfaces	18 - 1	PLC supervisions & alarms		PLC supervisions	19 - 1	PLC alarms	20 - 1	System alarms	21 - 1	PLC alarm text lists	22 - 1	Local modules		PLC_1 [CPU 1516-3 PN/DP]	23 - 1	AI 8xU/I/RTD/TC ST_1	24 - 1	AQ 4xU/I ST_1	25 - 1	DI 32x24VDC HF_1	26 - 1	DQ 32x24VDC/0.5A HF_1	27 - 1	PLC_2 [CPU 1215C DC/DC/DC]	28 - 1	Program blocks		Main [OB1]	29 - 1	PLC2_Rev [DB5]	30 - 1	System blocks		Program resources		IEC_Timer_0_DB [DB1]	31 - 1	IEC_Timer_0_DB_2 [DB3]	32 - 1	IEC_Counter_0_DB [DB2]	33 - 1	IEC_Timer_0_DB_1 [DB4]	34 - 1	IEC_Timer_0_DB_3 [DB6]	35 - 1	IEC_Timer_0_DB_4 [DB7]	36 - 1	IEC_Timer_0_DB_5 [DB8]	37 - 1	Web server		DB 333 [DB333]	38 - 1	Technology objects	39 - 1	PLC tags		Default tag table [54]		PLC tags	40 - 1	User constants	41 - 1	PLC data types		System data types	42 - 1	Watch and force tables		Force table	43 - 1	Traces	44 - 1	Measurements	45 - 1	Combined measurements	46 - 1	PLC alarm text lists	47 - 1	Local modules		PLC_2 [CPU 1215C DC/DC/DC]	48 - 1	PLC_3 [CPU 1215C DC/DC/DC]	49 - 1	Program blocks	
PLC_1 [CPU 1516-3 PN/DP]	4 - 1																																																																																																																																					
Software units	5 - 1																																																																																																																																					
Program blocks																																																																																																																																						
Main [OB1]	6 - 1																																																																																																																																					
PLC1_Ban [DB2]	7 - 1																																																																																																																																					
System blocks																																																																																																																																						
Program resources																																																																																																																																						
IEC_Timer_0_DB [DB1]	8 - 1																																																																																																																																					
Technology objects	9 - 1																																																																																																																																					
PLC tags																																																																																																																																						
Default tag table [61]																																																																																																																																						
PLC tags	10 - 1																																																																																																																																					
User constants	11 - 1																																																																																																																																					
PLC data types																																																																																																																																						
System data types	12 - 1																																																																																																																																					
Watch and force tables																																																																																																																																						
Force table	13 - 1																																																																																																																																					
Traces	14 - 1																																																																																																																																					
Measurements	15 - 1																																																																																																																																					
Combined measurements	16 - 1																																																																																																																																					
OPC UA communication																																																																																																																																						
Server interfaces	17 - 1																																																																																																																																					
Client interfaces	18 - 1																																																																																																																																					
PLC supervisions & alarms																																																																																																																																						
PLC supervisions	19 - 1																																																																																																																																					
PLC alarms	20 - 1																																																																																																																																					
System alarms	21 - 1																																																																																																																																					
PLC alarm text lists	22 - 1																																																																																																																																					
Local modules																																																																																																																																						
PLC_1 [CPU 1516-3 PN/DP]	23 - 1																																																																																																																																					
AI 8xU/I/RTD/TC ST_1	24 - 1																																																																																																																																					
AQ 4xU/I ST_1	25 - 1																																																																																																																																					
DI 32x24VDC HF_1	26 - 1																																																																																																																																					
DQ 32x24VDC/0.5A HF_1	27 - 1																																																																																																																																					
PLC_2 [CPU 1215C DC/DC/DC]	28 - 1																																																																																																																																					
Program blocks																																																																																																																																						
Main [OB1]	29 - 1																																																																																																																																					
PLC2_Rev [DB5]	30 - 1																																																																																																																																					
System blocks																																																																																																																																						
Program resources																																																																																																																																						
IEC_Timer_0_DB [DB1]	31 - 1																																																																																																																																					
IEC_Timer_0_DB_2 [DB3]	32 - 1																																																																																																																																					
IEC_Counter_0_DB [DB2]	33 - 1																																																																																																																																					
IEC_Timer_0_DB_1 [DB4]	34 - 1																																																																																																																																					
IEC_Timer_0_DB_3 [DB6]	35 - 1																																																																																																																																					
IEC_Timer_0_DB_4 [DB7]	36 - 1																																																																																																																																					
IEC_Timer_0_DB_5 [DB8]	37 - 1																																																																																																																																					
Web server																																																																																																																																						
DB 333 [DB333]	38 - 1																																																																																																																																					
Technology objects	39 - 1																																																																																																																																					
PLC tags																																																																																																																																						
Default tag table [54]																																																																																																																																						
PLC tags	40 - 1																																																																																																																																					
User constants	41 - 1																																																																																																																																					
PLC data types																																																																																																																																						
System data types	42 - 1																																																																																																																																					
Watch and force tables																																																																																																																																						
Force table	43 - 1																																																																																																																																					
Traces	44 - 1																																																																																																																																					
Measurements	45 - 1																																																																																																																																					
Combined measurements	46 - 1																																																																																																																																					
PLC alarm text lists	47 - 1																																																																																																																																					
Local modules																																																																																																																																						
PLC_2 [CPU 1215C DC/DC/DC]	48 - 1																																																																																																																																					
PLC_3 [CPU 1215C DC/DC/DC]	49 - 1																																																																																																																																					
Program blocks																																																																																																																																						

Totally Integrated Automation Portal		
Main [OB1]		50 - 1
PLC3_emp [DB3]		51 - 1
System blocks		
Program resources		
IEC_Timer_0_DB [DB1]		52 - 1
IEC_Counter_0_DB [DB2]		53 - 1
IEC_Timer_0_DB_1 [DB4]		54 - 1
IEC_Counter_0_DB_1 [DB5]		55 - 1
IEC_Timer_0_DB_2 [DB6]		56 - 1
Technology objects		57 - 1
PLC tags		
Default tag table [46]		
PLC tags		58 - 1
User constants		59 - 1
PLC data types		
System data types		60 - 1
Watch and force tables		
Force table		61 - 1
Traces		62 - 1
Measurements		63 - 1
Combined measurements		64 - 1
PLC alarm text lists		65 - 1
Local modules		
PLC_3 [CPU 1215C DC/DC/DC]		66 - 1
HMI_1 [KTP400 Basic PN]		67 - 1
Runtime settings		68 - 1
Screens		
Banda transportadora		69 - 1
Screen management		
Templates		
Template_1		70 - 1
Global screen		71 - 1
HMI tags		
Default tag table [3]		72 - 1
Connections		73 - 1
HMI alarms		
Discrete alarms		74 - 1
Analog alarms		75 - 1
Alarm groups		76 - 1
Alarm classes		77 - 1
System events		78 - 1
Recipes		79 - 1
Historical data		
Datalogs		80 - 1
AlarmLogs		81 - 1
Scheduled tasks		82 - 1
Text and graphic lists		
Text lists		83 - 1
Graphic lists		84 - 1
User administration		
User		85 - 1
Groups		86 - 1
Authorizations		87 - 1
HMI_2 [KTP400 Basic PN]		88 - 1
Runtime settings		89 - 1
Screens		
Revolvedora		90 - 1
Screen management		
Templates		
Template_1		91 - 1
Global screen		92 - 1
HMI tags		
Default tag table [5]		93 - 1
Connections		94 - 1
HMI alarms		
Discrete alarms		95 - 1
Analog alarms		96 - 1
Alarm groups		97 - 1
Alarm classes		98 - 1
System events		99 - 1

Totally Integrated Automation Portal																																																																																																										
<table><tr><td>Recipes</td><td>100 - 1</td></tr><tr><td>Historical data</td><td></td></tr><tr><td> Datalogs</td><td>101 - 1</td></tr><tr><td> AlarmLogs</td><td>102 - 1</td></tr><tr><td> Scheduled tasks</td><td>103 - 1</td></tr><tr><td>Text and graphic lists</td><td></td></tr><tr><td> Text lists</td><td>104 - 1</td></tr><tr><td> Graphic lists</td><td>105 - 1</td></tr><tr><td>User administration</td><td></td></tr><tr><td> User</td><td>106 - 1</td></tr><tr><td> Groups</td><td>107 - 1</td></tr><tr><td> Authorizations</td><td>108 - 1</td></tr><tr><td>HMI_3 [KTP400 Basic PN]</td><td>109 - 1</td></tr><tr><td> Runtime settings</td><td>110 - 1</td></tr><tr><td>Screens</td><td></td></tr><tr><td> Empacadora</td><td>111 - 1</td></tr><tr><td>Screen management</td><td></td></tr><tr><td> Templates</td><td></td></tr><tr><td> Template_1</td><td>112 - 1</td></tr><tr><td> Global screen</td><td>113 - 1</td></tr><tr><td>HMI tags</td><td></td></tr><tr><td> Default tag table [5]</td><td>114 - 1</td></tr><tr><td>Connections</td><td>115 - 1</td></tr><tr><td>HMI alarms</td><td></td></tr><tr><td> Discrete alarms</td><td>116 - 1</td></tr><tr><td> Analog alarms</td><td>117 - 1</td></tr><tr><td> Alarm groups</td><td>118 - 1</td></tr><tr><td> Alarm classes</td><td>119 - 1</td></tr><tr><td> System events</td><td>120 - 1</td></tr><tr><td>Recipes</td><td>121 - 1</td></tr><tr><td>Historical data</td><td></td></tr><tr><td> Datalogs</td><td>122 - 1</td></tr><tr><td> AlarmLogs</td><td>123 - 1</td></tr><tr><td> Scheduled tasks</td><td>124 - 1</td></tr><tr><td>Text and graphic lists</td><td></td></tr><tr><td> Text lists</td><td>125 - 1</td></tr><tr><td> Graphic lists</td><td>126 - 1</td></tr><tr><td>User administration</td><td></td></tr><tr><td> User</td><td>127 - 1</td></tr><tr><td> Groups</td><td>128 - 1</td></tr><tr><td> Authorizations</td><td>129 - 1</td></tr><tr><td>Ungrouped devices</td><td>130 - 1</td></tr><tr><td>Security settings</td><td>131 - 1</td></tr><tr><td>Common data</td><td></td></tr><tr><td> Alarm classes</td><td>132 - 1</td></tr><tr><td> Logs</td><td>133 - 1</td></tr><tr><td> Styles</td><td>134 - 1</td></tr><tr><td>Languages & resources</td><td></td></tr><tr><td> Project languages</td><td>135 - 1</td></tr><tr><td>Project texts</td><td></td></tr><tr><td> Project texts</td><td>136 - 1</td></tr><tr><td>Project graphics</td><td>137 - 1</td></tr></table>			Recipes	100 - 1	Historical data		Datalogs	101 - 1	AlarmLogs	102 - 1	Scheduled tasks	103 - 1	Text and graphic lists		Text lists	104 - 1	Graphic lists	105 - 1	User administration		User	106 - 1	Groups	107 - 1	Authorizations	108 - 1	HMI_3 [KTP400 Basic PN]	109 - 1	Runtime settings	110 - 1	Screens		Empacadora	111 - 1	Screen management		Templates		Template_1	112 - 1	Global screen	113 - 1	HMI tags		Default tag table [5]	114 - 1	Connections	115 - 1	HMI alarms		Discrete alarms	116 - 1	Analog alarms	117 - 1	Alarm groups	118 - 1	Alarm classes	119 - 1	System events	120 - 1	Recipes	121 - 1	Historical data		Datalogs	122 - 1	AlarmLogs	123 - 1	Scheduled tasks	124 - 1	Text and graphic lists		Text lists	125 - 1	Graphic lists	126 - 1	User administration		User	127 - 1	Groups	128 - 1	Authorizations	129 - 1	Ungrouped devices	130 - 1	Security settings	131 - 1	Common data		Alarm classes	132 - 1	Logs	133 - 1	Styles	134 - 1	Languages & resources		Project languages	135 - 1	Project texts		Project texts	136 - 1	Project graphics	137 - 1
Recipes	100 - 1																																																																																																									
Historical data																																																																																																										
Datalogs	101 - 1																																																																																																									
AlarmLogs	102 - 1																																																																																																									
Scheduled tasks	103 - 1																																																																																																									
Text and graphic lists																																																																																																										
Text lists	104 - 1																																																																																																									
Graphic lists	105 - 1																																																																																																									
User administration																																																																																																										
User	106 - 1																																																																																																									
Groups	107 - 1																																																																																																									
Authorizations	108 - 1																																																																																																									
HMI_3 [KTP400 Basic PN]	109 - 1																																																																																																									
Runtime settings	110 - 1																																																																																																									
Screens																																																																																																										
Empacadora	111 - 1																																																																																																									
Screen management																																																																																																										
Templates																																																																																																										
Template_1	112 - 1																																																																																																									
Global screen	113 - 1																																																																																																									
HMI tags																																																																																																										
Default tag table [5]	114 - 1																																																																																																									
Connections	115 - 1																																																																																																									
HMI alarms																																																																																																										
Discrete alarms	116 - 1																																																																																																									
Analog alarms	117 - 1																																																																																																									
Alarm groups	118 - 1																																																																																																									
Alarm classes	119 - 1																																																																																																									
System events	120 - 1																																																																																																									
Recipes	121 - 1																																																																																																									
Historical data																																																																																																										
Datalogs	122 - 1																																																																																																									
AlarmLogs	123 - 1																																																																																																									
Scheduled tasks	124 - 1																																																																																																									
Text and graphic lists																																																																																																										
Text lists	125 - 1																																																																																																									
Graphic lists	126 - 1																																																																																																									
User administration																																																																																																										
User	127 - 1																																																																																																									
Groups	128 - 1																																																																																																									
Authorizations	129 - 1																																																																																																									
Ungrouped devices	130 - 1																																																																																																									
Security settings	131 - 1																																																																																																									
Common data																																																																																																										
Alarm classes	132 - 1																																																																																																									
Logs	133 - 1																																																																																																									
Styles	134 - 1																																																																																																									
Languages & resources																																																																																																										
Project languages	135 - 1																																																																																																									
Project texts																																																																																																										
Project texts	136 - 1																																																																																																									
Project graphics	137 - 1																																																																																																									

Totally Integrated Automation Portal												
<div>Proyecto_final</div>												
Project												
Name:	Proyecto_final	Creation time:	5/1/2025 7:23:43 PM	Last change	5/13/2025 2:47:41 AM	Author: 192072						
Last modified by:	192072	Version:										
Comment:												
Operating system												
Name				Description								
Operating system				Microsoft Windows 11 Education								
Version of the operating system				6.3.9600.0								
Operating system service pack												
Version of the Internet Explorer				11.1882.26100.0								
Computer name				J102M9								
User name				IBERO\192072								
Installation path of the TIA Portal				C:\Program Files\Siemens\Automation\Portal V15_1								
Components												
Name			Version		Release							
TIA Portal Multiuser Server V15.1 - TIA Portal Multiuser Server Single SetupPackage V15.1 (MUSERVERV15_1)			V15.1		V15.01.00.00_28.01.00.01							
TIA Administrator - AWB Licensing Module V1.0 + SP1 (TIAADMIN)			V1.0 + SP1		V01.00.01.00_01.22.00.03							
TIA Administrator - AWB Software Management V1.0 + SP1 (TIAADMIN)			V1.0 + SP1		V01.00.01.00_01.22.00.03							
TIA Administrator - TIA UMC Agent Configurator Module V1.0 + SP1 (TIAADMIN)			V1.0 + SP1		V01.00.01.00_01.22.00.03							
TIA Administrator - TIA Administrator V1.0 SP1 (TIAADMIN)			V1.0 + SP1		V01.00.01.00_01.22.00.03							
Siemens Totally Integrated Automation Portal V15.1 - HM All Editions Single SetupPackage V15.1 (TIAP15_1)			V15.1		V15.01.00.00_28.01.00.01							
Siemens Totally Integrated Automation Portal V15.1 - HM NoBasic Single SetupPackage V15.1 (TIAP15_1)			V15.1		V15.01.00.00_28.01.00.01							
Siemens Totally Integrated Automation Portal V15.1 - Hardware Support Base Package 0 V15.1 (TIAP15_1)			V15.1		V15.01.00.00_11.01.00.07							
Siemens Totally Integrated Automation Portal V15.1 - Multiuser Client Single SetupPackage V15.1 (TIAP15_1)			V15.1		V15.01.00.00_28.01.00.01							
Siemens Totally Integrated Automation Portal V15.1 - STEP 7 Single SetupPackage V15.1 (TIAP15_1)			V15.1		V15.01.00.00_28.01.00.01							
Siemens Totally Integrated Automation Portal V15.1 - Hardware Support Base Package 02 V15.1 (TIAP15_1)			V15.1		V15.01.00.00_11.01.00.07							
Siemens Totally Integrated Automation Portal V15.1 - Hardware Support Base Package 03 V15.1 (TIAP15_1)			V15.1		V15.01.00.00_11.01.00.07							
Siemens Totally Integrated Automation Portal V15.1 - Hardware Support Base Package 04 V15.1 (TIAP15_1)			V15.1		V15.01.00.00_11.01.00.07							
Siemens Totally Integrated Automation Portal V15.1 - Support Base Package TO-01 V15.1 (TIAP15_1)			V15.1		V15.01.00.00_11.01.00.07							
Siemens Totally Integrated Automation Portal V15.1 - Support Base Package TO-02 V15.1 (TIAP15_1)			V15.1		V15.01.00.00_11.01.00.07							
Siemens Totally Integrated Automation Portal V15.1 - Hardware Support Base Package WCF-01 V15.1 (TIAP15_1)			V15.1		V15.01.00.00_11.01.00.07							
Siemens Totally Integrated Automation Portal V15.1 - TIACOMP CHECK Single SetupPackage V15.1 (TIAP15_1)			V15.1		V15.01.00.00_28.01.00.01							
Siemens Totally Integrated Automation Portal V15.1 - Simatic Single SetupPackage V15.1 (TIAP15_1)			V15.1		V15.01.00.00_28.01.00.01							
Siemens Totally Integrated Automation Portal V15.1 - WinCC Single SetupPackage V15.1 (TIAP15_1)			V15.1		V15.01.00.00_28.01.00.01							
Siemens Totally Integrated Automation Portal V15.1 - Openness SetupPackage V15.1 (TIAP15_1)			V15.1		V15.01.00.00_28.01.00.01							
Siemens Totally Integrated Automation Portal V15.1 - WinCC Transfer Current All Single SetupPackage V15.1 (TIAP15_1)			V15.1		V15.01.00.00_28.01.00.01							
Siemens Totally Integrated Automation Portal V15.1 - WinCC Transfer Current CAP Single SetupPackage V15.1 (TIAP15_1)			V15.1		V15.01.00.00_28.01.00.01							
Siemens Totally Integrated Automation Portal V15.1 - WinCC Transfer Mandatory Single SetupPackage V15.1 (TIAP15_1)			V15.1		V15.01.00.00_28.01.00.01							
User Management Component - UserManagementComponentx64 01.9 + SP1 (UMC64)			V01.9 + SP1 + Upd3		V01.09.01.03_01.01.00.11							
WinCC Runtime Advanced V15.1 - HMIRTM Tagging Package 01 Single SetupPackage V15.1 (HMIRTM_V11)			V15.1		V15.01.00.00_28.01.00.01							
Siemens Totally Integrated Automation Portal V15.1 - Simatic Single SetupPackage 32 Bit V15.1 (TIAP15_1)			V15.1		V15.01.00.00_28.01.00.01							
Siemens Totally Integrated Automation Portal V15.1 - WinCC Single SetupPackage 32 Bit V15.1 (TIAP15_1)			V15.1		V15.01.00.00_28.01.00.01							
SIMATIC HMI License Manager Panel Plugin (x64)			15.1.0.0		V15.01.00.00_28.01.00.01							
Automation Access Control Component x64			05.01		K05.01.01.12_00.00.00.04							
SIMATIC WinCC Runtime Advanced Driver (x64)			15.1.0.0		V15.01.00.00_28.01.00.01							
SIMATIC NCM FWL 64			5.6.0.3		K5.6.0.3_1.1.0.2							
NCM GPRS 64			01.02.00.00		V1.2.0.0_2.1.0.1							
SIMATIC PLCSIM 64			15.01.00		15.01.00.00_17.00.02.01							
SIMATIC Device Drivers			9.2		09.02.01.00_01.11.00.01							
Automation Access Control Component			05.01		K05.01.01.12_00.00.00.04							
Automation Software Updater			02.04.0000		V02.04.00.00_01.12.00.05							
SIEMENS OPC			3.9		03.09.08.00_01.07.00.01							
SIMATIC HMI ProSave			15.1.0.0		V15.01.00.00_28.01.00.01							
SIMATIC HMI Symbol Library			15.1.0.0		V15.01.00.00_28.01.00.01							
SIMATIC HMI Touch Input			15.1.0.0		V15.01.00.00_28.01.00.01							
SIMATIC Device Drivers WoW			29.2		29.02.01.00_01.11.00.01							
SIMATIC Event Database			5.6		05.06.01.00_02.01.00.01							
SeCon			2.5		V02.05.01.01_01.01.00.02							
WinCC Runtime Advanced Simulator			15.1.0.0		V15.01.00.00_28.01.00.01							

Totally Integrated Automation Portal																													
<div>Products</div> <table><tr><th>Name</th><th>Version</th><th>Release</th></tr><tr><td>TIA Portal Multiuser Server</td><td>V15.1</td><td>V15.01.00.00_28.01.00.01</td></tr><tr><td>TIA Administrator</td><td>V1.0</td><td>V01.00.00.00_01.00.00.01</td></tr><tr><td>SIMATIC STEP 7 Professional - WinCC Advanced</td><td>V15.1</td><td>V15.01.00.00_28.01.00.01</td></tr><tr><td>User Management Component x64</td><td>V1.9 SP1</td><td>V01.20.00.00_01.01.00.01</td></tr><tr><td>SIMATIC WinCC Runtime Advanced Simulation</td><td>V15.1</td><td>V15.01.00.00_28.01.00.01</td></tr><tr><td>Automation License Manager</td><td>V6.2 + SP2</td><td>06.02.02.00_00.00.00.37</td></tr><tr><td>S7-PLCSIM</td><td>V5.4 + SP8</td><td>V05.04.08.01_01.24.00.01</td></tr><tr><td>SIMATIC ProSave</td><td>V15.1</td><td>V15.01.00.00_28.01.00.01</td></tr></table>			Name	Version	Release	TIA Portal Multiuser Server	V15.1	V15.01.00.00_28.01.00.01	TIA Administrator	V1.0	V01.00.00.00_01.00.00.01	SIMATIC STEP 7 Professional - WinCC Advanced	V15.1	V15.01.00.00_28.01.00.01	User Management Component x64	V1.9 SP1	V01.20.00.00_01.01.00.01	SIMATIC WinCC Runtime Advanced Simulation	V15.1	V15.01.00.00_28.01.00.01	Automation License Manager	V6.2 + SP2	06.02.02.00_00.00.00.37	S7-PLCSIM	V5.4 + SP8	V05.04.08.01_01.24.00.01	SIMATIC ProSave	V15.1	V15.01.00.00_28.01.00.01
Name	Version	Release																											
TIA Portal Multiuser Server	V15.1	V15.01.00.00_28.01.00.01																											
TIA Administrator	V1.0	V01.00.00.00_01.00.00.01																											
SIMATIC STEP 7 Professional - WinCC Advanced	V15.1	V15.01.00.00_28.01.00.01																											
User Management Component x64	V1.9 SP1	V01.20.00.00_01.01.00.01																											
SIMATIC WinCC Runtime Advanced Simulation	V15.1	V15.01.00.00_28.01.00.01																											
Automation License Manager	V6.2 + SP2	06.02.02.00_00.00.00.37																											
S7-PLCSIM	V5.4 + SP8	V05.04.08.01_01.24.00.01																											
SIMATIC ProSave	V15.1	V15.01.00.00_28.01.00.01																											

Totally Integrated Automation Portal		
--------------------------------------	--	--

Proyecto_final

PLC_1 [CPU 1516-3 PN/DP]

PLC_1

General\Project information

Name	PLC_1	Author	192072	Comment	
Rack	0	Slot	1		

General\Catalog information

Short designation	CPU 1516-3 PN/DP	Description	CPU with display; work memory 1 MB code and 5 MB data; 10 ns bit instruction time; 4-stage protection concept, technology functions: motion control, closed-loop control, counting & measuring; tracing; 1st interface: PROFINET IO controller, supports RT/IRT, performance upgrade PROFINET V2.3, 2 ports, I-device, MRP, MRPD, transport protocol TCP/IP, secure Open User Communication, S7 communication, Web server, DNS client, OPC UA: server DA, client DA, methods, companion specifications; constant bus cycle time, routing; 2nd interface: PROFINET IO controller, supports RT, I-device, transport protocol TCP/IP, secure Open User Communication, S7 communication, Web server, DNS client, OPC UA: server DA, client DA, methods, companion specifications; routing; 3rd interface: PROFIBUS DP master, S7 communication, constant bus cycle time, routing; Runtime options, firmware V2.6	Article number	6ES7 516-3AN01-0AB0
Firmware version	V2.6				

General\Identification & Maintenance

Plant designation		Location identifier		Installation date	2025-05-01 19:24:19.220
Additional information					

General\Checksums

Text lists	FA 70 E8 75 1D 5A 8E 29	Software	BE FD 42 44 47 21 06 98		
------------	-------------------------	----------	-------------------------	--	--

PROFINET interface [X1]\General

Name	PROFINET interface_1	Author	192072	Comment	
------	----------------------	--------	--------	---------	--

PROFINET interface [X1]\Ethernet addresses\Interface networked with

Subnet:	PN/IE_2				
---------	---------	--	--	--	--

PROFINET interface [X1]\Ethernet addresses\IP protocol

IP configuration	Set IP address in the project	IP address:	192.168.0.1	Subnet mask:	255.255.255.0
Use router	False				

PROFINET interface [X1]\Ethernet addresses\PROFINET

PROFINET device name is set directly at the device	False	Generate PROFINET device name automatically	True	PROFINET device name:	plc_1.profinet interface_1
Converted name:	plcxb1.profinetxainterfacexb1036c	Device number:	0		

PROFINET interface [X1]\Time synchronization\NTP mode

Note	Time synchronization for all PROFINET interfaces take place within the settings for time synchronization of the PROFINET interface [X1].	Enable time synchronization via NTP server	False		IP addresses
Server 1	0.0.0.0	Server 2	0.0.0.0	Server 3	0.0.0.0
Server 4	0.0.0.0	Update interval	10s		

PROFINET interface [X1]\Operating mode

IO controller	True	IO system		Device number	0
IO device	False				

PROFINET interface [X1]\Advanced options\Interface options

Call the user program if communication errors occur	False	Support device replacement without exchangeable medium	True	Permit overwriting of device names of all assigned IO devices	False
Limit data infeed into the network	True	Use IEC V2.2 LLDP mode	False	Keep-Alive connection monitoring:	30s

PROFINET interface [X1]\Advanced options\Media redundancy

MRP domain	mrpdomain-1	Media redundancy role:	Not device in the ring		
------------	-------------	------------------------	------------------------	--	--

PROFINET interface [X1]\Advanced options\Real time settings\IO communication

Send clock:	1.000ms				
-------------	---------	--	--	--	--

PROFINET interface [X1]\Advanced options\Real time settings\Synchronization

Sync domain:	Sync-Domain_1	Synchronization role:	Unsynchronized	RT class:	RT,IRT
--------------	---------------	-----------------------	----------------	-----------	--------

PROFINET interface [X1]\Advanced options\Real time settings\Real time options



Calculated bandwidth for cyclic IO data:	0.000ms	Calculated bandwidth for cyclic IO data:	0.000%		
--	---------	--	--------	--	--

PROFINET interface [X1]\Advanced options\Port [X1 P1 R]\General

Name	Port_1	Author	192072	Comment	
------	--------	--------	--------	---------	--

PROFINET interface [X1]\Advanced options\Port [X1 P1 R]\Port interconnection\Local port:

Local port:	PLC_1\PROFINET interface_1 [X1]\Port_1 [X1 P1 R]	Medium:	Copper	Cable name:	---
-------------	--	---------	--------	-------------	-----

Totally Integrated Automation Portal							
							
PROFINET interface [X1]\Advanced options\Port [X1 P1 R]\Port interconnection\Partner port:							
	Monitoring of partner port is executed		Alternative partners	False	Partner port:	HMI_1.IE_CP_1\PROFINET Interface_1 [X1]\Port_1 [X1 P1]	
Medium:	Copper		Cable length:				
PROFINET interface [X1]\Advanced options\Port [X1 P1 R]\Port options\Activate							
Activate this port for use	True						
PROFINET interface [X1]\Advanced options\Port [X1 P1 R]\Port options\Connection							
Transmission rate / duplex:	Automatic		Monitor	False	Enable autonegotiation	True	
PROFINET interface [X1]\Advanced options\Port [X1 P1 R]\Port options\Boundaries							
End of detection of accessible devices	False		End of topology discovery	False	End of the sync domain	False	
PROFINET interface [X1]\Advanced options\Port [X1 P2 R]\General							
Name	Port_2		Author	192072	Comment		
PROFINET interface [X1]\Advanced options\Port [X1 P2 R]\Port interconnection\Local port:							
Local port:	PLC_1\PROFINET interface_1 [X1]\Port_2 [X1 P2 R]		Medium:	Copper	Cable name:	---	
							
PROFINET interface [X1]\Advanced options\Port [X1 P2 R]\Port interconnection\Partner port:							
	Monitoring of partner port is not possible		Alternative partners	False	Partner port:	Switch_1\SCALANCE interface_1 [X1]\Port_1 [X1 P1]	
Medium:	Copper		Cable length:				
PROFINET interface [X1]\Advanced options\Port [X1 P2 R]\Port options\Activate							
Activate this port for use	True						
PROFINET interface [X1]\Advanced options\Port [X1 P2 R]\Port options\Connection							
Transmission rate / duplex:	Automatic		Monitor	False	Enable autonegotiation	True	
PROFINET interface [X1]\Advanced options\Port [X1 P2 R]\Port options\Boundaries							
End of detection of accessible devices	False		End of topology discovery	False	End of the sync domain	False	
PROFINET interface [X1]\Web server access							
Note	The Web server must also be activated in the properties of the PLC.		Enable Web server using this interface	False			
PROFINET interface [X2]\General							
Name	PROFINET interface_2		Author	192072	Comment		
PROFINET interface [X2]\Ethernet addresses\Interface networked with							
Subnet:	Not connected						
PROFINET interface [X2]\Ethernet addresses\IP protocol							
IP configuration	Set IP address in the project		IP address:	192.168.1.1	Subnet mask:	255.255.255.0	
Use router	False						
PROFINET interface [X2]\Ethernet addresses\PROFINET							
PROFINET device name is set directly at the device	False		Generate PROFINET device name automatically	True	PROFINET device name:	plc_1.profinet interface_2	
Converted name:	plcxb1.profinetxainterfacexb2022c		Device number:	0			
PROFINET interface [X2]\Time synchronization\NTP mode							
Note	Time synchronization for all PROFINET interfaces take place within the settings for time synchronization of the PROFINET interface [X1].		Enable time synchronization via NTP server	False	IP addresses		
Server 1	0.0.0.0		Server 2	0.0.0.0	Server 3	0.0.0.0	
Server 4	0.0.0.0		Update interval	10s			
PROFINET interface [X2]\Operating mode							
IO controller	True		IO system		Device number	0	
IO device	False						
PROFINET interface [X2]\Advanced options\Interface options							
Call the user program if communication errors occur	False		Support device replacement without exchangeable medium	True	Permit overwriting of device names of all assigned IO devices	False	
Limit data infeed into the network	False		Use IEC V2.2 LLDP mode	False	Keep-Alive connection monitoring:	30s	
PROFINET interface [X2]\Advanced options\Real time settings\IO communication							
Send clock:	1.000ms						
PROFINET interface [X2]\Advanced options\Real time settings\Real time options							
Calculated bandwidth for cyclic IO data:	0.000ms		Calculated bandwidth for cyclic IO data:	0.000%			
PROFINET interface [X2]\Advanced options\Port [X2 P1]\General							
Name	Port_1		Author	192072	Comment		

Totally Integrated Automation Portal						
PROFINET interface [X2]\Advanced options\Port [X2 P1]\Port interconnection\Local port:						
Local port:	PLC_1\PROFINET interface_2 [X2]\Port_1 [X2 P1]		Medium:	Copper	Cable name:	---
						
PROFINET interface [X2]\Advanced options\Port [X2 P1]\Port interconnection\Partner port:						
	Monitoring of partner port is not possible		Alternative partners	False	Partner port:	Any partner
PROFINET interface [X2]\Advanced options\Port [X2 P1]\Port options\Activate						
Activate this port for use	True					
PROFINET interface [X2]\Advanced options\Port [X2 P1]\Port options\Connection						
Transmission rate / duplex:	Automatic		Monitor	False	Enable autonegotiation	True
PROFINET interface [X2]\Advanced options\Port [X2 P1]\Port options\Boundaries						
End of detection of accessible devices	False		End of topology discovery	False	End of the sync domain	False
PROFINET interface [X2]\Web server access						
Note	The Web server must also be activated in the properties of the PLC.		Enable Web server using this interface	False		
DP interface [X3]\General						
Name	DP interface_1		Author	192072	Comment	
DP interface [X3]\PROFIBUS address\Interface networked with						
Subnet:	Not networked					
DP interface [X3]\PROFIBUS address\Parameters						
Address:	2		Highest address:		Transmission speed:	
DP interface [X3]\Operating mode\						
Operating mode	DP master		DP master system:	Not created		
DP interface [X3]\Time synchronization\SIMATIC mode						
Synchronization type	None		Time interval	None		
DP interface [X3]\SYNC/FREEZE\						
Group	SYNC		FREEZE		Comment	
1	True		True			
2	True		True			
3	True		True			
4	True		True			
5	True		True			
6	True		True			
7	True		True			
8	True		True			
Startup						
Startup after POWER ON	Warm restart - Operating mode before POWER OFF		Comparison preset to actual configuration	Startup CPU even if mismatch	Configuration time	60000ms
Cycle						
Maximum cycle time	150ms				Enable minimum cycle time for cyclic OBs	True
Minimum cycle time	1ms					
Communication load						
Cycle load due to communication	50%					
System and clock memory\System memory bits						
Enable the use of system memory byte	False		Address of system memory byte (MBx)	1	First cycle	
Diagnostic status changed			Always 1 (high)		Always 0 (low)	
System and clock memory\Clock memory bits						
Enable the use of clock memory byte	False		Address of clock memory byte (MBx)	0	10 Hz clock	
5 Hz clock			2.5 Hz clock		2 Hz clock	
1.25 Hz clock			1 Hz clock		0.625 Hz clock	
0.5 Hz clock						
SIMATIC Memory Card\Diagnostics						
Aging of the SIMATIC memory card	False		Threshold value	80%		
System diagnostics\General						
Activate system diagnostics for this device	True		Report network faults as maintenance instead of fault	False		
PLC alarms\General						
Central alarm management in the PLC	True					
Web server\General						
Activate web server on this module	False		Permit access only with HTTPS	True		
Web server\Automatic update						
Enable automatic update	True		Update interval	0s		
Web server\User management						
User name				User rights		
Everybody						

Totally Integrated Automation Portal						
Web server\						
User-defined web pages						
Application name		HTML source path	Default HTML page	Files with dynamic content	Web DB number	Fragment DB number
			index.htm	.htm;.html	333	334
Web server\						
Overview of interfaces						
Device		Interface			Enabled web server access	
PLC_1		PROFINET interface_1			False	
PLC_1		PROFINET interface_2			False	
DNS configuration						
No DNS server address is configured.						
Display\General\						
Display standby mode						
Time to standby mode	30 minutes					
Display\General\						
Energy saving mode						
Time to energy saving mode	15 minutes					
Display\General\						
Display language						
Default language on display	English					
Display\						
Automatic update						
Time to update	5 seconds					
Display\Password\						
Display protection						
Enable write access	True	Enable display protection	False			
Display\User-defined logo\						
User logo activated	True	Adapt logo	True	Resolution	240x260	
Company logo	---					
User interface languages						
Assign project language			User interface languages			
English (United States)			German			
English (United States)			English			
English (United States)			French			
English (United States)			Spanish			
English (United States)			Italian			
English (United States)			Japanese			
English (United States)			Chinese (simplified)			
English (United States)			Korean			
English (United States)			Russian			
English (United States)			Turkish			
English (United States)			Portuguese (Brazil)			
Time of day\						
Local time						
Time zone	(UTC) Dublin, Edinburgh, Lisbon, London					
Time of day\						
Daylight saving time						
Activate daylight saving time	True	Difference between standard and daylight saving time	60mins			
Time of day\						
Daylight saving time\Start of daylight saving time						
Selection of the week	Last	Selection of the weekday	Sunday	of	March	
at	01:00 a.m.					
Time of day\						
Daylight saving time\Start of standard time						
Selection of the week	Last	Selection of the weekday	Sunday	of	October	
at	02:00 a.m.					
Protection						
Level of protection	Full access (no protection)					
Protection\						
Connection mechanisms						
Permit access with PUT/GET communication from remote partner	True					
Protection\						
Security event						
Summarize security events in case of high message volume	True	Length of an interval	20	Unit	seconds	
OPC UA\						
Accessibility of the server						
Activate OPC UA server	False					
OPC UA\						
Accessibility of the client						
Activate OPC UA client	False					

Totally Integrated Automation Portal

System power supply\General

General

Connection to supply voltage L+

System power supply\Power segment overview

Module	Slot	Supply/consumption
PLC_1	1	12.00W
AI 8xU/I/RTD/TC ST_1	2	-0.70W
AQ 4xU/I ST_1	3	-0.60W
DI 32x24VDC HF_1	4	-1.10W
DQ 32x24VDC/0.5A HF_1	5	-1.10W
	Summary	8.50W

Configuration control\Configuration control for central configuration

Allow reconfiguration of device via the user program

False

Connection resources\

	Station resources - Reserved - Maximum	Station resources - Reserved - Configured	Station resources - Dynamic - Configured	Module resources - PLC_1 [CPU 1516-3 PN/DP] - Configured
Maximum number of resources:		10	118	128
	Maximum	Configured	Configured	Configured
PG communication:	4	-	-	-
HMI communication:	4	1	0	1
S7 communication:	0	-	0	0
Open user communication:	0	-	0	0
Web communication:	2	-	-	-
Other communication:	-	-	0	0
Total resources used:		1	0	1
Available resources:		9	118	127

Overview of addresses\Overview of addresses\Overview of addresses

Inputs	True	Outputs	True	Address gaps	False						
Slot	True										
Type	Addr. from	Addr. to	Module	PIP	OB	Device name	Device number	Size	Master / IO system	Rack	Slot
I	0	15	AI 8xU/I/RTD/TC ST_1	Automatic update	-	PLC_1 [CPU 1516-3 PN/DP]	-	16 Bytes	-	0	2
O	0	7	AQ 4xU/I ST_1	Automatic update	-	PLC_1 [CPU 1516-3 PN/DP]	-	8 Bytes	-	0	3
I	16	19	DI 32x24VDC HF_1	Automatic update	-	PLC_1 [CPU 1516-3 PN/DP]	-	4 Bytes	-	0	4
O	8	11	DQ 32x24VDC/0.5A HF_1	Automatic update	-	PLC_1 [CPU 1516-3 PN/DP]	-	4 Bytes	-	0	5

Runtime licenses\OPC UA\Runtime licenses

Type of required license

None

Type of purchased license

No license

Runtime licenses\ProDiag\Supervisions

Number of used supervisions

0

Runtime licenses\ProDiag\Runtime licenses

Number of required licenses

None (<= 25 supervisions)

Used ProDiag licenses

No license

Runtime licenses\Energy Suite\Energy objects

Number of configured energy objects

0

Runtime licenses\Energy Suite\Runtime licenses

Total number of licensed energy objects

0

Runtime licenses\Energy Suite\Runtime licenses\Number of purchased licenses

License type '5 energy objects'

No license

License type '10 energy objects'

No license

Totally Integrated Automation Portal		
<div>Proyecto_final / PLC_1 [CPU 1516-3 PN/DP]</div> <div>Software units</div> <div>This folder is empty.</div>		

Proyecto_final / PLC_1 [CPU 1516-3 PN/DP] / Program blocks

Main [OB1]

Main Properties

General


Name	Main	Number	1	Type	OB	Language	LAD
Numbering	Automatic						

Information


Title	Control de banda transportadora	Author		Comment		Family	
Version	0.1	User-defined ID					

Name	Data type	Default value	Comment
▼ Input			
Initial_Call	Bool		Initial call of this OB
Remanence	Bool		=True, if remanent data are available
Temp			
Constant			

Network 1: Control motor



Network 2: Botones físicos



Totally Integrated Automation Portal

Proyecto_final / PLC_1 [CPU 1516-3 PN/DP] / Program blocks

PLC1_Ban [DB2]

PLC1_Ban Properties

General

Name	PLC1_Ban	Number	2	Type	DB	Language	DB
Numbering	Automatic						

Information

Title		Author		Comment		Family	
Version	0.1	User-defined ID					

Name	Data type	Offset	Start value	Retain	Accessi-ble from HMI/OPC UA	Writ-able from HMI/OPC UA	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Static										
Ban_estado	Bool	0.0	false	False	True	True	True	False		
Ban_dirección	UInt	2.0	0	False	True	True	True	False		

Totally Integrated Automation Portal

Proyecto_final / PLC_1 [CPU 1516-3 PN/DP] / Program blocks / System blocks / Program resources

IEC_Timer_0_DB [DB1]

IEC_Timer_0_DB Properties

General

Name	IEC_Timer_0_DB	Number	1	Type	DB	Language	DB
Numbering	Automatic						

Information

Title		Author	Simatic	Comment		Family	IEC
Version	1.0	User-defined ID	IEC_TMR				










Name	Data type	Start value	Retain	Accessible from HMI/OPC UA	Writ-able from HMI/OPC UA	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Static									
PT	Time	T#0ms	False	True	True	True	False		
ET	Time	T#0ms	False	True	False	True	False		
IN	Bool	false	False	True	True	True	False		
Q	Bool	false	False	True	False	True	False		

Totally Integrated Automation Portal		
<div>Proyecto_final / PLC_1 [CPU 1516-3 PN/DP]</div> <div>Technology objects</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal

Proyecto_final / PLC_1 [CPU 1516-3 PN/DP] / PLC tags / Default tag table [61]

PLC tags

PLC tags									
	Name	Data type	Address	Retain	Accessi-ble from HMI/OPC UA	Writable from HMI/OPC UA	Visible in HMI engi-neering	Supervision	Comment
	Encendido	Bool	%M8.0	False	True	True	True		
	PE	Bool	%I17.3	False	True	True	True		
	Tag_1	Bool	%Q9.3	False	True	True	True		
	Tag_2	Bool	%Q9.4	False	True	True	True		
	LED_estado	Bool	%Q9.5	False	True	True	True		
	LED_PE	Bool	%Q9.6	False	True	True	True		
	Tag_3	Bool	%I17.4	False	True	True	True		
	Tag_4	Bool	%I17.5	False	True	True	True		
	Tag_5	Bool	%I17.6	False	True	True	True		

User constants

User constants			
Name	Data type	Value	Comment

Totally Integrated Automation Portal		
<div>Proyecto_final / PLC_1 [CPU 1516-3 PN/DP] / PLC data types</div> <div>System data types</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal							
<div>Proyecto_final / PLC_1 [CPU 1516-3 PN/DP] / Watch and force tables</div> <div>Force table</div> <table><thead><tr><th>Name</th><th>Address</th><th>Display format</th><th>Force value</th><th>Comment</th></tr></thead><tbody></tbody></table>			Name	Address	Display format	Force value	Comment
Name	Address	Display format	Force value	Comment			

Totally Integrated Automation Portal			
<div>Proyecto_final / PLC_1 [CPU 1516-3 PN/DP]</div> <div>Traces</div> <table><thead><tr><th>Name</th></tr></thead><tbody></tbody></table>			Name
Name			

Totally Integrated Automation Portal		
<div>Proyecto_final / PLC_1 [CPU 1516-3 PN/DP] / Traces</div> <div>Measurements</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / PLC_1 [CPU 1516-3 PN/DP] / Traces</div> <div>Combined measurements</div> <div><div>Name</div></div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / PLC_1 [CPU 1516-3 PN/DP] / OPC UA communication</div> <div>Server interfaces</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / PLC_1 [CPU 1516-3 PN/DP] / OPC UA communication</div> <div>Client interfaces</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / PLC_1 [CPU 1516-3 PN/DP] / PLC supervisions & alarms</div> <div>PLC supervisions</div> <div>This folder is empty.</div>		


Totally Integrated Automation Portal		
<div>Proyecto_final / PLC_1 [CPU 1516-3 PN/DP] / PLC supervisions & alarms</div> <div>PLC alarms</div> <div><div>PLC alarms</div><div>No entries</div></div>		

Totally Integrated Automation Portal																																																																																																																																																																																																																																																																																																		
<div>Proyecto_final / PLC_1 [CPU 1516-3 PN/DP] / PLC supervisions & alarms</div> <div>System alarms</div> <table><tr><th colspan="4">System alarms</th></tr><tr><td>Name</td><td> SDIAG_ALCAT_SUBMODUL_MSG_0002</td><td>Type</td><td>PLC alarm</td></tr><tr><td>ID</td><td>1</td><td>Location</td><td>PLC_1</td></tr><tr><td>Alarm text</td><td>Error: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@</td><td>Info text</td><td>Short name: @6W%t#260K@ Order number: @6W%t#265K@</td></tr><tr><td>Alarm class</td><td>No Acknowledgement</td><td>Acknowledgment</td><td>False</td></tr><tr><td>Information only</td><td>True</td><td>Priority</td><td>0</td></tr><tr><td>Report</td><td>False</td><td>Created by</td><td>System diagnostics</td></tr><tr><td>Date created</td><td>5/1/2025 2:11 PM</td><td>Last change</td><td>5/1/2025 2:11 PM</td></tr><tr><td>Group ID</td><td>0</td><td>Additional text 1</td><td>PLC_1</td></tr><tr><td>Additional text 2</td><td></td><td>Additional text 3</td><td></td></tr><tr><td>Additional text 4</td><td></td><td>Additional text 5</td><td></td></tr><tr><td>Additional text 6</td><td></td><td>Additional text 7</td><td></td></tr><tr><td>Additional text 8</td><td></td><td>Additional text 9</td><td></td></tr><tr><td>Name</td><td> SDIAG_ALCAT_MODUL_MSG_0003</td><td>Type</td><td>PLC alarm</td></tr><tr><td>ID</td><td>2</td><td>Location</td><td>PLC_1</td></tr><tr><td>Alarm text</td><td>Error: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@ @6W%t#262K@ @6W%t#263K@</td><td>Info text</td><td>Short name: @6W%t#260K@ Order number: @6W%t#265K@</td></tr><tr><td>Alarm class</td><td>No Acknowledgement</td><td>Acknowledgment</td><td>False</td></tr><tr><td>Information only</td><td>True</td><td>Priority</td><td>0</td></tr><tr><td>Report</td><td>False</td><td>Created by</td><td>System diagnostics</td></tr><tr><td>Date created</td><td>5/1/2025 2:11 PM</td><td>Last change</td><td>5/1/2025 2:11 PM</td></tr><tr><td>Group ID</td><td>0</td><td>Additional text 1</td><td>PLC_1</td></tr><tr><td>Additional text 2</td><td></td><td>Additional text 3</td><td></td></tr><tr><td>Additional text 4</td><td></td><td>Additional text 5</td><td></td></tr><tr><td>Additional text 6</td><td></td><td>Additional text 7</td><td></td></tr><tr><td>Additional text 8</td><td></td><td>Additional text 9</td><td></td></tr><tr><td>Name</td><td> SDIAG_ALCAT_RACK_MSG_0004</td><td>Type</td><td>PLC alarm</td></tr><tr><td>ID</td><td>3</td><td>Location</td><td>PLC_1</td></tr><tr><td>Alarm text</td><td>Error: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ @6W%t#262K@ @6W%t#263K@</td><td>Info text</td><td>Short name: @6W%t#260K@ Order number: @6W%t#265K@</td></tr><tr><td>Alarm class</td><td>No Acknowledgement</td><td>Acknowledgment</td><td>False</td></tr><tr><td>Information only</td><td>True</td><td>Priority</td><td>0</td></tr><tr><td>Report</td><td>False</td><td>Created by</td><td>System diagnostics</td></tr><tr><td>Date created</td><td>5/1/2025 2:11 PM</td><td>Last change</td><td>5/1/2025 2:11 PM</td></tr><tr><td>Group ID</td><td>0</td><td>Additional text 1</td><td>PLC_1</td></tr><tr><td>Additional text 2</td><td></td><td>Additional text 3</td><td></td></tr><tr><td>Additional text 4</td><td></td><td>Additional text 5</td><td></td></tr><tr><td>Additional text 6</td><td></td><td>Additional text 7</td><td></td></tr><tr><td>Additional text 8</td><td></td><td>Additional text 9</td><td></td></tr><tr><td>Name</td><td> SDIAG_ALCAT_DEVICE_MSG_0005</td><td>Type</td><td>PLC alarm</td></tr><tr><td>ID</td><td>4</td><td>Location</td><td>PLC_1</td></tr><tr><td>Alarm text</td><td>Error: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@</td><td>Info text</td><td>Short name: @6W%t#260K@ Order number: @6W%t#265K@</td></tr><tr><td>Alarm class</td><td>No Acknowledgement</td><td>Acknowledgment</td><td>False</td></tr><tr><td>Information only</td><td>True</td><td>Priority</td><td>0</td></tr><tr><td>Report</td><td>False</td><td>Created by</td><td>System diagnostics</td></tr><tr><td>Date created</td><td>5/1/2025 2:11 PM</td><td>Last change</td><td>5/1/2025 2:11 PM</td></tr><tr><td>Group ID</td><td>0</td><td>Additional text 1</td><td>PLC_1</td></tr><tr><td>Additional text 2</td><td></td><td>Additional text 3</td><td></td></tr><tr><td>Additional text 4</td><td></td><td>Additional text 5</td><td></td></tr><tr><td>Additional text 6</td><td></td><td>Additional text 7</td><td></td></tr><tr><td>Additional text 8</td><td></td><td>Additional text 9</td><td></td></tr><tr><td>Name</td><td> SDIAG_ALCAT_IOSYSTEM_MSG_0006</td><td>Type</td><td>PLC alarm</td></tr><tr><td>ID</td><td>5</td><td>Location</td><td>PLC_1</td></tr><tr><td>Alarm text</td><td>Error: @1W%t#7W@ @5W%t#7W@ @6W%t#276K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@</td><td>Info text</td><td>Short name: @6W%t#260K@ Order number: @6W%t#265K@</td></tr><tr><td>Alarm class</td><td>No Acknowledgement</td><td>Acknowledgment</td><td>False</td></tr><tr><td>Information only</td><td>True</td><td>Priority</td><td>0</td></tr><tr><td>Report</td><td>False</td><td>Created by</td><td>System diagnostics</td></tr><tr><td>Date created</td><td>5/1/2025 2:11 PM</td><td>Last change</td><td>5/1/2025 2:11 PM</td></tr><tr><td>Group ID</td><td>0</td><td>Additional text 1</td><td>PLC_1</td></tr><tr><td>Additional text 2</td><td></td><td>Additional text 3</td><td></td></tr><tr><td>Additional text 4</td><td></td><td>Additional text 5</td><td></td></tr><tr><td>Additional text 6</td><td></td><td>Additional text 7</td><td></td></tr><tr><td>Additional text 8</td><td></td><td>Additional text 9</td><td></td></tr><tr><td>Name</td><td> SDIAG_ALCAT_CPU_OST_MSG_000D</td><td>Type</td><td>PLC alarm</td></tr><tr><td>ID</td><td>6</td><td>Location</td><td>PLC_1</td></tr><tr><td>Alarm text</td><td>CPU status message: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@</td><td>Info text</td><td>Short name: @6W%t#260K@ Order number: @6W%t#265K@</td></tr><tr><td>Alarm class</td><td>No Acknowledgement</td><td>Acknowledgment</td><td>False</td></tr><tr><td>Information only</td><td>True</td><td>Priority</td><td>0</td></tr><tr><td>Report</td><td>False</td><td>Created by</td><td>System diagnostics</td></tr><tr><td>Date created</td><td>5/1/2025 2:11 PM</td><td>Last change</td><td>5/1/2025 2:11 PM</td></tr><tr><td>Group ID</td><td>0</td><td>Additional text 1</td><td>PLC_1</td></tr><tr><td>Additional text 2</td><td></td><td>Additional text 3</td><td></td></tr><tr><td>Additional text 4</td><td></td><td>Additional text 5</td><td></td></tr><tr><td>Additional text 6</td><td></td><td>Additional text 7</td><td></td></tr></table>	System alarms				Name	 SDIAG_ALCAT_SUBMODUL_MSG_0002	Type	PLC alarm	ID	1	Location	PLC_1	Alarm text	Error: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@	Alarm class	No Acknowledgement	Acknowledgment	False	Information only	True	Priority	0	Report	False	Created by	System diagnostics	Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM	Group ID	0	Additional text 1	PLC_1	Additional text 2		Additional text 3		Additional text 4		Additional text 5		Additional text 6		Additional text 7		Additional text 8		Additional text 9		Name	 SDIAG_ALCAT_MODUL_MSG_0003	Type	PLC alarm	ID	2	Location	PLC_1	Alarm text	Error: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@	Alarm class	No Acknowledgement	Acknowledgment	False	Information only	True	Priority	0	Report	False	Created by	System diagnostics	Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM	Group ID	0	Additional text 1	PLC_1	Additional text 2		Additional text 3		Additional text 4		Additional text 5		Additional text 6		Additional text 7		Additional text 8		Additional text 9		Name	 SDIAG_ALCAT_RACK_MSG_0004	Type	PLC alarm	ID	3	Location	PLC_1	Alarm text	Error: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@	Alarm class	No Acknowledgement	Acknowledgment	False	Information only	True	Priority	0	Report	False	Created by	System diagnostics	Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM	Group ID	0	Additional text 1	PLC_1	Additional text 2		Additional text 3		Additional text 4		Additional text 5		Additional text 6		Additional text 7		Additional text 8		Additional text 9		Name	 SDIAG_ALCAT_DEVICE_MSG_0005	Type	PLC alarm	ID	4	Location	PLC_1	Alarm text	Error: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@	Alarm class	No Acknowledgement	Acknowledgment	False	Information only	True	Priority	0	Report	False	Created by	System diagnostics	Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM	Group ID	0	Additional text 1	PLC_1	Additional text 2		Additional text 3		Additional text 4		Additional text 5		Additional text 6		Additional text 7		Additional text 8		Additional text 9		Name	 SDIAG_ALCAT_IOSYSTEM_MSG_0006	Type	PLC alarm	ID	5	Location	PLC_1	Alarm text	Error: @1W%t#7W@ @5W%t#7W@ @6W%t#276K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@	Alarm class	No Acknowledgement	Acknowledgment	False	Information only	True	Priority	0	Report	False	Created by	System diagnostics	Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM	Group ID	0	Additional text 1	PLC_1	Additional text 2		Additional text 3		Additional text 4		Additional text 5		Additional text 6		Additional text 7		Additional text 8		Additional text 9		Name	 SDIAG_ALCAT_CPU_OST_MSG_000D	Type	PLC alarm	ID	6	Location	PLC_1	Alarm text	CPU status message: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@	Alarm class	No Acknowledgement	Acknowledgment	False	Information only	True	Priority	0	Report	False	Created by	System diagnostics	Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM	Group ID	0	Additional text 1	PLC_1	Additional text 2		Additional text 3		Additional text 4		Additional text 5		Additional text 6		Additional text 7			
System alarms																																																																																																																																																																																																																																																																																																		
Name	 SDIAG_ALCAT_SUBMODUL_MSG_0002	Type	PLC alarm																																																																																																																																																																																																																																																																																															
ID	1	Location	PLC_1																																																																																																																																																																																																																																																																																															
Alarm text	Error: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@																																																																																																																																																																																																																																																																																															
Alarm class	No Acknowledgement	Acknowledgment	False																																																																																																																																																																																																																																																																																															
Information only	True	Priority	0																																																																																																																																																																																																																																																																																															
Report	False	Created by	System diagnostics																																																																																																																																																																																																																																																																																															
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM																																																																																																																																																																																																																																																																																															
Group ID	0	Additional text 1	PLC_1																																																																																																																																																																																																																																																																																															
Additional text 2		Additional text 3																																																																																																																																																																																																																																																																																																
Additional text 4		Additional text 5																																																																																																																																																																																																																																																																																																
Additional text 6		Additional text 7																																																																																																																																																																																																																																																																																																
Additional text 8		Additional text 9																																																																																																																																																																																																																																																																																																
Name	 SDIAG_ALCAT_MODUL_MSG_0003	Type	PLC alarm																																																																																																																																																																																																																																																																																															
ID	2	Location	PLC_1																																																																																																																																																																																																																																																																																															
Alarm text	Error: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@																																																																																																																																																																																																																																																																																															
Alarm class	No Acknowledgement	Acknowledgment	False																																																																																																																																																																																																																																																																																															
Information only	True	Priority	0																																																																																																																																																																																																																																																																																															
Report	False	Created by	System diagnostics																																																																																																																																																																																																																																																																																															
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM																																																																																																																																																																																																																																																																																															
Group ID	0	Additional text 1	PLC_1																																																																																																																																																																																																																																																																																															
Additional text 2		Additional text 3																																																																																																																																																																																																																																																																																																
Additional text 4		Additional text 5																																																																																																																																																																																																																																																																																																
Additional text 6		Additional text 7																																																																																																																																																																																																																																																																																																
Additional text 8		Additional text 9																																																																																																																																																																																																																																																																																																
Name	 SDIAG_ALCAT_RACK_MSG_0004	Type	PLC alarm																																																																																																																																																																																																																																																																																															
ID	3	Location	PLC_1																																																																																																																																																																																																																																																																																															
Alarm text	Error: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@																																																																																																																																																																																																																																																																																															
Alarm class	No Acknowledgement	Acknowledgment	False																																																																																																																																																																																																																																																																																															
Information only	True	Priority	0																																																																																																																																																																																																																																																																																															
Report	False	Created by	System diagnostics																																																																																																																																																																																																																																																																																															
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM																																																																																																																																																																																																																																																																																															
Group ID	0	Additional text 1	PLC_1																																																																																																																																																																																																																																																																																															
Additional text 2		Additional text 3																																																																																																																																																																																																																																																																																																
Additional text 4		Additional text 5																																																																																																																																																																																																																																																																																																
Additional text 6		Additional text 7																																																																																																																																																																																																																																																																																																
Additional text 8		Additional text 9																																																																																																																																																																																																																																																																																																
Name	 SDIAG_ALCAT_DEVICE_MSG_0005	Type	PLC alarm																																																																																																																																																																																																																																																																																															
ID	4	Location	PLC_1																																																																																																																																																																																																																																																																																															
Alarm text	Error: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@																																																																																																																																																																																																																																																																																															
Alarm class	No Acknowledgement	Acknowledgment	False																																																																																																																																																																																																																																																																																															
Information only	True	Priority	0																																																																																																																																																																																																																																																																																															
Report	False	Created by	System diagnostics																																																																																																																																																																																																																																																																																															
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM																																																																																																																																																																																																																																																																																															
Group ID	0	Additional text 1	PLC_1																																																																																																																																																																																																																																																																																															
Additional text 2		Additional text 3																																																																																																																																																																																																																																																																																																
Additional text 4		Additional text 5																																																																																																																																																																																																																																																																																																
Additional text 6		Additional text 7																																																																																																																																																																																																																																																																																																
Additional text 8		Additional text 9																																																																																																																																																																																																																																																																																																
Name	 SDIAG_ALCAT_IOSYSTEM_MSG_0006	Type	PLC alarm																																																																																																																																																																																																																																																																																															
ID	5	Location	PLC_1																																																																																																																																																																																																																																																																																															
Alarm text	Error: @1W%t#7W@ @5W%t#7W@ @6W%t#276K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@																																																																																																																																																																																																																																																																																															
Alarm class	No Acknowledgement	Acknowledgment	False																																																																																																																																																																																																																																																																																															
Information only	True	Priority	0																																																																																																																																																																																																																																																																																															
Report	False	Created by	System diagnostics																																																																																																																																																																																																																																																																																															
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM																																																																																																																																																																																																																																																																																															
Group ID	0	Additional text 1	PLC_1																																																																																																																																																																																																																																																																																															
Additional text 2		Additional text 3																																																																																																																																																																																																																																																																																																
Additional text 4		Additional text 5																																																																																																																																																																																																																																																																																																
Additional text 6		Additional text 7																																																																																																																																																																																																																																																																																																
Additional text 8		Additional text 9																																																																																																																																																																																																																																																																																																
Name	 SDIAG_ALCAT_CPU_OST_MSG_000D	Type	PLC alarm																																																																																																																																																																																																																																																																																															
ID	6	Location	PLC_1																																																																																																																																																																																																																																																																																															
Alarm text	CPU status message: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@																																																																																																																																																																																																																																																																																															
Alarm class	No Acknowledgement	Acknowledgment	False																																																																																																																																																																																																																																																																																															
Information only	True	Priority	0																																																																																																																																																																																																																																																																																															
Report	False	Created by	System diagnostics																																																																																																																																																																																																																																																																																															
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM																																																																																																																																																																																																																																																																																															
Group ID	0	Additional text 1	PLC_1																																																																																																																																																																																																																																																																																															
Additional text 2		Additional text 3																																																																																																																																																																																																																																																																																																
Additional text 4		Additional text 5																																																																																																																																																																																																																																																																																																
Additional text 6		Additional text 7																																																																																																																																																																																																																																																																																																

Totally Integrated Automation Portal																																																																																																																																																																																																																																																																																																						
<table><tr><td>Additional text 8</td><td></td><td>Additional text 9</td><td></td></tr><tr><td>Name</td><td> SDIAG_ALCAT_CPU_INFO_MSG_000F</td><td>Type</td><td>PLC alarm</td></tr><tr><td>ID</td><td>7</td><td>Location</td><td>PLC_1</td></tr><tr><td>Alarm text</td><td>CPU info: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@</td><td>Info text</td><td>Short name: @6W%t#260K@ Order number: @6W%t#265K@</td></tr><tr><td>Alarm class</td><td>No Acknowledgement</td><td>Acknowledgment</td><td>False</td></tr><tr><td>Information only</td><td>True</td><td>Priority</td><td>0</td></tr><tr><td>Report</td><td>False</td><td>Created by</td><td>System diagnostics</td></tr><tr><td>Date created</td><td>5/1/2025 2:11 PM</td><td>Last change</td><td>5/1/2025 2:11 PM</td></tr><tr><td>Group ID</td><td>0</td><td>Additional text 1</td><td>PLC_1</td></tr><tr><td>Additional text 2</td><td></td><td>Additional text 3</td><td></td></tr><tr><td>Additional text 4</td><td></td><td>Additional text 5</td><td></td></tr><tr><td>Additional text 6</td><td></td><td>Additional text 7</td><td></td></tr><tr><td>Additional text 8</td><td></td><td>Additional text 9</td><td></td></tr><tr><td>Name</td><td> SDIAG_ALCAT_CPU_ERR_MSG_0010</td><td>Type</td><td>PLC alarm</td></tr><tr><td>ID</td><td>8</td><td>Location</td><td>PLC_1</td></tr><tr><td>Alarm text</td><td>CPU error: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@</td><td>Info text</td><td>Short name: @6W%t#260K@ Order number: @6W%t#265K@</td></tr><tr><td>Alarm class</td><td>No Acknowledgement</td><td>Acknowledgment</td><td>False</td></tr><tr><td>Information only</td><td>True</td><td>Priority</td><td>0</td></tr><tr><td>Report</td><td>False</td><td>Created by</td><td>System diagnostics</td></tr><tr><td>Date created</td><td>5/1/2025 2:11 PM</td><td>Last change</td><td>5/1/2025 2:11 PM</td></tr><tr><td>Group ID</td><td>0</td><td>Additional text 1</td><td>PLC_1</td></tr><tr><td>Additional text 2</td><td></td><td>Additional text 3</td><td></td></tr><tr><td>Additional text 4</td><td></td><td>Additional text 5</td><td></td></tr><tr><td>Additional text 6</td><td></td><td>Additional text 7</td><td></td></tr><tr><td>Additional text 8</td><td></td><td>Additional text 9</td><td></td></tr><tr><td>Name</td><td> SDIAG_ALCAT_CPU_MD_MSG_0011</td><td>Type</td><td>PLC alarm</td></tr><tr><td>ID</td><td>9</td><td>Location</td><td>PLC_1</td></tr><tr><td>Alarm text</td><td>CPU maintenance demanded: @1W%t#7W@ @6W%t#257K@ / @5W%t#7W@ @6W%t#258K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@</td><td>Info text</td><td>Short name: @6W%t#260K@ Order number: @6W%t#265K@</td></tr><tr><td>Alarm class</td><td>No Acknowledgement</td><td>Acknowledgment</td><td>False</td></tr><tr><td>Information only</td><td>True</td><td>Priority</td><td>0</td></tr><tr><td>Report</td><td>False</td><td>Created by</td><td>System diagnostics</td></tr><tr><td>Date created</td><td>5/1/2025 2:11 PM</td><td>Last change</td><td>5/1/2025 2:11 PM</td></tr><tr><td>Group ID</td><td>0</td><td>Additional text 1</td><td>PLC_1</td></tr><tr><td>Additional text 2</td><td></td><td>Additional text 3</td><td></td></tr><tr><td>Additional text 4</td><td></td><td>Additional text 5</td><td></td></tr><tr><td>Additional text 6</td><td></td><td>Additional text 7</td><td></td></tr><tr><td>Additional text 8</td><td></td><td>Additional text 9</td><td></td></tr><tr><td>Name</td><td> SDIAG_ALCAT_CPU_MR_MSG1_0012</td><td>Type</td><td>PLC alarm</td></tr><tr><td>ID</td><td>10</td><td>Location</td><td>PLC_1</td></tr><tr><td>Alarm text</td><td>CPU maintenance required: @1W%t#7W@ @6W%t#257K@ / @5W%t#7W@ @6W%t#258K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@</td><td>Info text</td><td>Short name: @6W%t#260K@ Order number: @6W%t#265K@</td></tr><tr><td>Alarm class</td><td>No Acknowledgement</td><td>Acknowledgment</td><td>False</td></tr><tr><td>Information only</td><td>True</td><td>Priority</td><td>0</td></tr><tr><td>Report</td><td>False</td><td>Created by</td><td>System diagnostics</td></tr><tr><td>Date created</td><td>5/1/2025 2:11 PM</td><td>Last change</td><td>5/1/2025 2:11 PM</td></tr><tr><td>Group ID</td><td>0</td><td>Additional text 1</td><td>PLC_1</td></tr><tr><td>Additional text 2</td><td></td><td>Additional text 3</td><td></td></tr><tr><td>Additional text 4</td><td></td><td>Additional text 5</td><td></td></tr><tr><td>Additional text 6</td><td></td><td>Additional text 7</td><td></td></tr><tr><td>Additional text 8</td><td></td><td>Additional text 9</td><td></td></tr><tr><td>Name</td><td> SDIAG_ALCAT_CPU_TMPERR_MSG_0013</td><td>Type</td><td>PLC alarm</td></tr><tr><td>ID</td><td>11</td><td>Location</td><td>PLC_1</td></tr><tr><td>Alarm text</td><td>Temporary CPU error: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@</td><td>Info text</td><td>Short name: @6W%t#260K@ Order number: @6W%t#265K@</td></tr><tr><td>Alarm class</td><td>No Acknowledgement</td><td>Acknowledgment</td><td>False</td></tr><tr><td>Information only</td><td>True</td><td>Priority</td><td>0</td></tr><tr><td>Report</td><td>False</td><td>Created by</td><td>System diagnostics</td></tr><tr><td>Date created</td><td>5/1/2025 2:11 PM</td><td>Last change</td><td>5/1/2025 2:11 PM</td></tr><tr><td>Group ID</td><td>0</td><td>Additional text 1</td><td>PLC_1</td></tr><tr><td>Additional text 2</td><td></td><td>Additional text 3</td><td></td></tr><tr><td>Additional text 4</td><td></td><td>Additional text 5</td><td></td></tr><tr><td>Additional text 6</td><td></td><td>Additional text 7</td><td></td></tr><tr><td>Additional text 8</td><td></td><td>Additional text 9</td><td></td></tr><tr><td>Name</td><td> SDIAG_ALCAT_CH_ERR_MSG_0015</td><td>Type</td><td>PLC alarm</td></tr><tr><td>ID</td><td>12</td><td>Location</td><td>PLC_1</td></tr><tr><td>Alarm text</td><td>Error: @1W%t#7W@ on @8W%t#280K@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@</td><td>Info text</td><td>Short name: @6W%t#260K@ Order number: @6W%t#265K@</td></tr><tr><td>Alarm class</td><td>No Acknowledgement</td><td>Acknowledgment</td><td>False</td></tr><tr><td>Information only</td><td>True</td><td>Priority</td><td>0</td></tr><tr><td>Report</td><td>False</td><td>Created by</td><td>System diagnostics</td></tr><tr><td>Date created</td><td>5/1/2025 2:11 PM</td><td>Last change</td><td>5/1/2025 2:11 PM</td></tr><tr><td>Group ID</td><td>0</td><td>Additional text 1</td><td>PLC_1</td></tr><tr><td>Additional text 2</td><td></td><td>Additional text 3</td><td></td></tr><tr><td>Additional text 4</td><td></td><td>Additional text 5</td><td></td></tr><tr><td>Additional text 6</td><td></td><td>Additional text 7</td><td></td></tr><tr><td>Additional text 8</td><td></td><td>Additional text 9</td><td></td></tr></table>	Additional text 8		Additional text 9		Name	 SDIAG_ALCAT_CPU_INFO_MSG_000F	Type	PLC alarm	ID	7	Location	PLC_1	Alarm text	CPU info: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@	Alarm class	No Acknowledgement	Acknowledgment	False	Information only	True	Priority	0	Report	False	Created by	System diagnostics	Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM	Group ID	0	Additional text 1	PLC_1	Additional text 2		Additional text 3		Additional text 4		Additional text 5		Additional text 6		Additional text 7		Additional text 8		Additional text 9		Name	 SDIAG_ALCAT_CPU_ERR_MSG_0010	Type	PLC alarm	ID	8	Location	PLC_1	Alarm text	CPU error: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@	Alarm class	No Acknowledgement	Acknowledgment	False	Information only	True	Priority	0	Report	False	Created by	System diagnostics	Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM	Group ID	0	Additional text 1	PLC_1	Additional text 2		Additional text 3		Additional text 4		Additional text 5		Additional text 6		Additional text 7		Additional text 8		Additional text 9		Name	 SDIAG_ALCAT_CPU_MD_MSG_0011	Type	PLC alarm	ID	9	Location	PLC_1	Alarm text	CPU maintenance demanded: @1W%t#7W@ @6W%t#257K@ / @5W%t#7W@ @6W%t#258K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@	Alarm class	No Acknowledgement	Acknowledgment	False	Information only	True	Priority	0	Report	False	Created by	System diagnostics	Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM	Group ID	0	Additional text 1	PLC_1	Additional text 2		Additional text 3		Additional text 4		Additional text 5		Additional text 6		Additional text 7		Additional text 8		Additional text 9		Name	 SDIAG_ALCAT_CPU_MR_MSG1_0012	Type	PLC alarm	ID	10	Location	PLC_1	Alarm text	CPU maintenance required: @1W%t#7W@ @6W%t#257K@ / @5W%t#7W@ @6W%t#258K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@	Alarm class	No Acknowledgement	Acknowledgment	False	Information only	True	Priority	0	Report	False	Created by	System diagnostics	Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM	Group ID	0	Additional text 1	PLC_1	Additional text 2		Additional text 3		Additional text 4		Additional text 5		Additional text 6		Additional text 7		Additional text 8		Additional text 9		Name	 SDIAG_ALCAT_CPU_TMPERR_MSG_0013	Type	PLC alarm	ID	11	Location	PLC_1	Alarm text	Temporary CPU error: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@	Alarm class	No Acknowledgement	Acknowledgment	False	Information only	True	Priority	0	Report	False	Created by	System diagnostics	Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM	Group ID	0	Additional text 1	PLC_1	Additional text 2		Additional text 3		Additional text 4		Additional text 5		Additional text 6		Additional text 7		Additional text 8		Additional text 9		Name	 SDIAG_ALCAT_CH_ERR_MSG_0015	Type	PLC alarm	ID	12	Location	PLC_1	Alarm text	Error: @1W%t#7W@ on @8W%t#280K@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@	Alarm class	No Acknowledgement	Acknowledgment	False	Information only	True	Priority	0	Report	False	Created by	System diagnostics	Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM	Group ID	0	Additional text 1	PLC_1	Additional text 2		Additional text 3		Additional text 4		Additional text 5		Additional text 6		Additional text 7		Additional text 8		Additional text 9			
Additional text 8		Additional text 9																																																																																																																																																																																																																																																																																																				
Name	 SDIAG_ALCAT_CPU_INFO_MSG_000F	Type	PLC alarm																																																																																																																																																																																																																																																																																																			
ID	7	Location	PLC_1																																																																																																																																																																																																																																																																																																			
Alarm text	CPU info: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@																																																																																																																																																																																																																																																																																																			
Alarm class	No Acknowledgement	Acknowledgment	False																																																																																																																																																																																																																																																																																																			
Information only	True	Priority	0																																																																																																																																																																																																																																																																																																			
Report	False	Created by	System diagnostics																																																																																																																																																																																																																																																																																																			
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM																																																																																																																																																																																																																																																																																																			
Group ID	0	Additional text 1	PLC_1																																																																																																																																																																																																																																																																																																			
Additional text 2		Additional text 3																																																																																																																																																																																																																																																																																																				
Additional text 4		Additional text 5																																																																																																																																																																																																																																																																																																				
Additional text 6		Additional text 7																																																																																																																																																																																																																																																																																																				
Additional text 8		Additional text 9																																																																																																																																																																																																																																																																																																				
Name	 SDIAG_ALCAT_CPU_ERR_MSG_0010	Type	PLC alarm																																																																																																																																																																																																																																																																																																			
ID	8	Location	PLC_1																																																																																																																																																																																																																																																																																																			
Alarm text	CPU error: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@																																																																																																																																																																																																																																																																																																			
Alarm class	No Acknowledgement	Acknowledgment	False																																																																																																																																																																																																																																																																																																			
Information only	True	Priority	0																																																																																																																																																																																																																																																																																																			
Report	False	Created by	System diagnostics																																																																																																																																																																																																																																																																																																			
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM																																																																																																																																																																																																																																																																																																			
Group ID	0	Additional text 1	PLC_1																																																																																																																																																																																																																																																																																																			
Additional text 2		Additional text 3																																																																																																																																																																																																																																																																																																				
Additional text 4		Additional text 5																																																																																																																																																																																																																																																																																																				
Additional text 6		Additional text 7																																																																																																																																																																																																																																																																																																				
Additional text 8		Additional text 9																																																																																																																																																																																																																																																																																																				
Name	 SDIAG_ALCAT_CPU_MD_MSG_0011	Type	PLC alarm																																																																																																																																																																																																																																																																																																			
ID	9	Location	PLC_1																																																																																																																																																																																																																																																																																																			
Alarm text	CPU maintenance demanded: @1W%t#7W@ @6W%t#257K@ / @5W%t#7W@ @6W%t#258K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@																																																																																																																																																																																																																																																																																																			
Alarm class	No Acknowledgement	Acknowledgment	False																																																																																																																																																																																																																																																																																																			
Information only	True	Priority	0																																																																																																																																																																																																																																																																																																			
Report	False	Created by	System diagnostics																																																																																																																																																																																																																																																																																																			
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM																																																																																																																																																																																																																																																																																																			
Group ID	0	Additional text 1	PLC_1																																																																																																																																																																																																																																																																																																			
Additional text 2		Additional text 3																																																																																																																																																																																																																																																																																																				
Additional text 4		Additional text 5																																																																																																																																																																																																																																																																																																				
Additional text 6		Additional text 7																																																																																																																																																																																																																																																																																																				
Additional text 8		Additional text 9																																																																																																																																																																																																																																																																																																				
Name	 SDIAG_ALCAT_CPU_MR_MSG1_0012	Type	PLC alarm																																																																																																																																																																																																																																																																																																			
ID	10	Location	PLC_1																																																																																																																																																																																																																																																																																																			
Alarm text	CPU maintenance required: @1W%t#7W@ @6W%t#257K@ / @5W%t#7W@ @6W%t#258K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@																																																																																																																																																																																																																																																																																																			
Alarm class	No Acknowledgement	Acknowledgment	False																																																																																																																																																																																																																																																																																																			
Information only	True	Priority	0																																																																																																																																																																																																																																																																																																			
Report	False	Created by	System diagnostics																																																																																																																																																																																																																																																																																																			
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM																																																																																																																																																																																																																																																																																																			
Group ID	0	Additional text 1	PLC_1																																																																																																																																																																																																																																																																																																			
Additional text 2		Additional text 3																																																																																																																																																																																																																																																																																																				
Additional text 4		Additional text 5																																																																																																																																																																																																																																																																																																				
Additional text 6		Additional text 7																																																																																																																																																																																																																																																																																																				
Additional text 8		Additional text 9																																																																																																																																																																																																																																																																																																				
Name	 SDIAG_ALCAT_CPU_TMPERR_MSG_0013	Type	PLC alarm																																																																																																																																																																																																																																																																																																			
ID	11	Location	PLC_1																																																																																																																																																																																																																																																																																																			
Alarm text	Temporary CPU error: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@																																																																																																																																																																																																																																																																																																			
Alarm class	No Acknowledgement	Acknowledgment	False																																																																																																																																																																																																																																																																																																			
Information only	True	Priority	0																																																																																																																																																																																																																																																																																																			
Report	False	Created by	System diagnostics																																																																																																																																																																																																																																																																																																			
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM																																																																																																																																																																																																																																																																																																			
Group ID	0	Additional text 1	PLC_1																																																																																																																																																																																																																																																																																																			
Additional text 2		Additional text 3																																																																																																																																																																																																																																																																																																				
Additional text 4		Additional text 5																																																																																																																																																																																																																																																																																																				
Additional text 6		Additional text 7																																																																																																																																																																																																																																																																																																				
Additional text 8		Additional text 9																																																																																																																																																																																																																																																																																																				
Name	 SDIAG_ALCAT_CH_ERR_MSG_0015	Type	PLC alarm																																																																																																																																																																																																																																																																																																			
ID	12	Location	PLC_1																																																																																																																																																																																																																																																																																																			
Alarm text	Error: @1W%t#7W@ on @8W%t#280K@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@																																																																																																																																																																																																																																																																																																			
Alarm class	No Acknowledgement	Acknowledgment	False																																																																																																																																																																																																																																																																																																			
Information only	True	Priority	0																																																																																																																																																																																																																																																																																																			
Report	False	Created by	System diagnostics																																																																																																																																																																																																																																																																																																			
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM																																																																																																																																																																																																																																																																																																			
Group ID	0	Additional text 1	PLC_1																																																																																																																																																																																																																																																																																																			
Additional text 2		Additional text 3																																																																																																																																																																																																																																																																																																				
Additional text 4		Additional text 5																																																																																																																																																																																																																																																																																																				
Additional text 6		Additional text 7																																																																																																																																																																																																																																																																																																				
Additional text 8		Additional text 9																																																																																																																																																																																																																																																																																																				

Totally Integrated Automation Portal			
Name	 SDIAG_ALCAT_ECH_ERR_MSG_0016	Type	PLC alarm
ID	13	Location	PLC_1
Alarm text	Error: @1W%t#7W@ - @5W%t#7W@ on @8W%t#280K@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	True	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_CH_MD_MSG_0018	Type	PLC alarm
ID	14	Location	PLC_1
Alarm text	Maintenance demanded:@1W%t#7W@ on @8W%t#280K@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	True	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_ECH_MD_MSG_0019	Type	PLC alarm
ID	15	Location	PLC_1
Alarm text	Maintenance demanded:@1W%t#7W@ - @5W%t#7W@ on @8W%t#280K@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	True	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_CH_MR_MSG_001B	Type	PLC alarm
ID	16	Location	PLC_1
Alarm text	Maintenance required:@1W%t#7W@ on @8W%t#280K@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	True	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_ECH_MR_MSG_001C	Type	PLC alarm
ID	17	Location	PLC_1
Alarm text	Maintenance required:@1W%t#7W@ - @5W%t#7W@ on @8W%t#280K@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	True	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_SUB_ERR_MSG_001E	Type	PLC alarm
ID	18	Location	PLC_1
Alarm text	Error: @1W%t#7W@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	True	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	




Totally Integrated Automation Portal			
Name	 SDIAG_ALCAT_ESUB_ERR_MSG_001F	Type	PLC alarm
ID	19	Location	PLC_1
Alarm text	Error: @1W%t#7W@ - @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	True	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_SUB_MD_MSG_0021	Type	PLC alarm
ID	20	Location	PLC_1
Alarm text	Maintenance demanded: @1W%t#7W@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	True	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_ESUB_MD_MSG_0022	Type	PLC alarm
ID	21	Location	PLC_1
Alarm text	Maintenance demanded: @1W%t#7W@ - @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	True	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_SUB_MR_MSG_0024	Type	PLC alarm
ID	22	Location	PLC_1
Alarm text	Maintenance required: @1W%t#7W@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	True	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_ESUB_MR_MSG_0025	Type	PLC alarm
ID	23	Location	PLC_1
Alarm text	Maintenance required: @1W%t#7W@ - @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	True	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_CONFIG_INFO_0028	Type	PLC alarm
ID	24	Location	PLC_1
Alarm text	Info: @1W%t#7W@ - @5W%t#7W@ @6W%t#257K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	True	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_CONFIG_REPORT_0029	Type	PLC alarm
ID	25	Location	PLC_1

Totally Integrated Automation Portal			
Alarm text	Info: @1W%t#7W@ - @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	True	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_SECU_EV_MSG_005E	Type	PLC alarm
ID	26	Location	PLC_1
Alarm text	Security event: @1W%t#7W@ @5W%t#7W@ @6W%t#258K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	True	Priority	0
Report	False	Created by	Security
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_SECU_EV_INFO_005F	Type	PLC alarm
ID	27	Location	PLC_1
Alarm text	Security information: @1W%t#7W@ @5W%t#7W@ @6W%t#258K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	True	Priority	0
Report	False	Created by	Security
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_USER_MSG_0080	Type	PLC alarm
ID	28	Location	PLC_1
Alarm text	User message: @1W%t#2W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	True	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_PLC_MSG_00FF	Type	PLC alarm
ID	29	Location	PLC_1
Alarm text	PLC notification: @1W%t#7W@ @5W%t#7W@ @6W%t#256K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	True	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_SUBMODUL_MSG_0102	Type	PLC alarm
ID	30	Location	PLC_1
Alarm text	Error: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	False	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_MODUL_MSG_0103	Type	PLC alarm
ID	31	Location	PLC_1
Alarm text	Error: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	False	Priority	0

Totally Integrated Automation Portal			
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_RACK_MSG_0104	Type	PLC alarm
ID	32	Location	PLC_1
Alarm text	Error: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	False	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_DEVICE_MSG_0105	Type	PLC alarm
ID	33	Location	PLC_1
Alarm text	Error: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	False	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_IOSYSTEM_MSG_0106	Type	PLC alarm
ID	34	Location	PLC_1
Alarm text	Error: @1W%t#7W@ @5W%t#7W@ @6W%t#276K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	False	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_CPU_OST_MSG_010D	Type	PLC alarm
ID	35	Location	PLC_1
Alarm text	CPU status message: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	False	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_CPU_ERR_MSG_0110	Type	PLC alarm
ID	36	Location	PLC_1
Alarm text	CPU error: @1W%t#7W@ @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	False	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_CPU_MD_MSG_0111	Type	PLC alarm
ID	37	Location	PLC_1
Alarm text	CPU maintenance demanded: @1W%t#7W@ @6W%t#257K@ / @5W%t#7W@ @6W%t#258K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	False	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	

Totally Integrated Automation Portal			
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_CPU_MR_MSG1_0112	Type	PLC alarm
ID	38	Location	PLC_1
Alarm text	CPU maintenance required: @1W%t#7W@ @6W%t#257K@ / @5W%t#7W@ @6W%t#258K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	False	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_CH_ERR_MSG_0115	Type	PLC alarm
ID	39	Location	PLC_1
Alarm text	Error: @1W%t#7W@ on @8W%t#280K@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	False	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_ECH_ERR_MSG_0116	Type	PLC alarm
ID	40	Location	PLC_1
Alarm text	Error: @1W%t#7W@ - @5W%t#7W@ on @8W%t#280K@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	False	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_CH_MD_MSG_0118	Type	PLC alarm
ID	41	Location	PLC_1
Alarm text	Maintenance demanded:@1W%t#7W@ on @8W%t#280K@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	False	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_ECH_MD_MSG_0119	Type	PLC alarm
ID	42	Location	PLC_1
Alarm text	Maintenance demanded:@1W%t#7W@ - @5W%t#7W@ on @8W%t#280K@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	False	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_CH_MR_MSG_011B	Type	PLC alarm
ID	43	Location	PLC_1
Alarm text	Maintenance required:@1W%t#7W@ on @8W%t#280K@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	False	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	

Totally Integrated Automation Portal			
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_ECH_MR_MSG_011C	Type	PLC alarm
ID	44	Location	PLC_1
Alarm text	Maintenance required: @1W%t#7W@ - @5W%t#7W@ on @8W%t#280K@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	False	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_SUB_ERR_MSG_011E	Type	PLC alarm
ID	45	Location	PLC_1
Alarm text	Error: @1W%t#7W@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	False	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_ESUB_ERR_MSG_011F	Type	PLC alarm
ID	46	Location	PLC_1
Alarm text	Error: @1W%t#7W@ - @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	False	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_SUB_MD_MSG_0121	Type	PLC alarm
ID	47	Location	PLC_1
Alarm text	Maintenance demanded: @1W%t#7W@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	False	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_ESUB_MD_MSG_0122	Type	PLC alarm
ID	48	Location	PLC_1
Alarm text	Maintenance demanded: @1W%t#7W@ - @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	False	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_SUB_MR_MSG_0124	Type	PLC alarm
ID	49	Location	PLC_1
Alarm text	Maintenance required: @1W%t#7W@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	False	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	

Totally Integrated Automation Portal			
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_ESUB_MR_MSG_0125	Type	PLC alarm
ID	50	Location	PLC_1
Alarm text	Maintenance required: @1W%t#7W@ - @5W%t#7W@ @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	False	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_CONFIG_INFO_0128	Type	PLC alarm
ID	51	Location	PLC_1
Alarm text	Info: @1W%t#7W@ - @5W%t#7W@ @6W%t#257K@ @6W%t#262K@ @6W%t#263K@ @8W%t#7W@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	False	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	
Name	 SDIAG_ALCAT_PLC_MSG_01FF	Type	PLC alarm
ID	52	Location	PLC_1
Alarm text	PLC notification: @1W%t#7W@ @5W%t#7W@ @6W%t#256K@ @6W%t#262K@ @6W%t#263K@	Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@
Alarm class	No Acknowledgement	Acknowledgment	False
Information only	False	Priority	0
Report	False	Created by	System diagnostics
Date created	5/1/2025 2:11 PM	Last change	5/1/2025 2:11 PM
Group ID	0	Additional text 1	PLC_1
Additional text 2		Additional text 3	
Additional text 4		Additional text 5	
Additional text 6		Additional text 7	
Additional text 8		Additional text 9	

Totally Integrated Automation Portal		
<div>Proyecto_final / PLC_1 [CPU 1516-3 PN/DP]</div> <div>PLC alarm text lists</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
--------------------------------------	--	--

Proyecto_final / PLC_1 [CPU 1516-3 PN/DP] / Local modules

PLC_1 [CPU 1516-3 PN/DP]

PLC_1

General\Project information

Name	PLC_1	Author	192072	Comment	
Rack	0	Slot	1		

General\Catalog information

Short designation	CPU 1516-3 PN/DP	Description	CPU with display; work memory 1 MB code and 5 MB data; 10 ns bit instruction time; 4-stage protection concept, technology functions: motion control, closed-loop control, counting & measuring; tracing; 1st interface: PROFINET IO controller, supports RT/IRT, performance upgrade PROFINET V2.3, 2 ports, I-device, MRP, MRPD, transport protocol TCP/IP, secure Open User Communication, S7 communication, Web server, DNS client, OPC UA: server DA, client DA, methods, companion specifications; constant bus cycle time, routing; 2nd interface: PROFINET IO controller, supports RT, I-device, transport protocol TCP/IP, secure Open User Communication, S7 communication, Web server, DNS client, OPC UA: server DA, client DA, methods, companion specifications; routing; 3rd interface: PROFIBUS DP master, S7 communication, constant bus cycle time, routing; Runtime options, firmware V2.6	Article number	6ES7 516-3AN01-0AB0
Firmware version	V2.6				

General\Identification & Maintenance

Plant designation		Location identifier		Installation date	2025-05-01 19:24:19.220
Additional information					

General\Checksums

Text lists	FA 70 E8 75 1D 5A 8E 29	Software	BE FD 42 44 47 21 06 98		
------------	-------------------------	----------	-------------------------	--	--

PROFINET interface [X1]\General

Name	PROFINET interface_1	Author	192072	Comment	
------	----------------------	--------	--------	---------	--

PROFINET interface [X1]\Ethernet addresses\Interface networked with

Subnet:	PN/IE_2				
---------	---------	--	--	--	--

PROFINET interface [X1]\Ethernet addresses\IP protocol

IP configuration	Set IP address in the project	IP address:	192.168.0.1	Subnet mask:	255.255.255.0
Use router	False				

PROFINET interface [X1]\Ethernet addresses\PROFINET

PROFINET device name is set directly at the device	False	Generate PROFINET device name automatically	True	PROFINET device name:	plc_1.profinet interface_1
Converted name:	plcxb1.profinetxainterfacexb1036c	Device number:	0		

PROFINET interface [X1]\Time synchronization\NTP mode

Note	Time synchronization for all PROFINET interfaces take place within the settings for time synchronization of the PROFINET interface [X1].	Enable time synchronization via NTP server	False		IP addresses
Server 1	0.0.0.0	Server 2	0.0.0.0	Server 3	0.0.0.0
Server 4	0.0.0.0	Update interval	10s		

PROFINET interface [X1]\Operating mode

IO controller	True	IO system		Device number	0
IO device	False				

PROFINET interface [X1]\Advanced options\Interface options

Call the user program if communication errors occur	False	Support device replacement without exchangeable medium	True	Permit overwriting of device names of all assigned IO devices	False
Limit data infeed into the network	True	Use IEC V2.2 LLDP mode	False	Keep-Alive connection monitoring:	30s

PROFINET interface [X1]\Advanced options\Media redundancy

MRP domain	mrpdomain-1	Media redundancy role:	Not device in the ring		
------------	-------------	------------------------	------------------------	--	--

PROFINET interface [X1]\Advanced options\Real time settings\IO communication

Send clock:	1.000ms				
-------------	---------	--	--	--	--

PROFINET interface [X1]\Advanced options\Real time settings\Synchronization

Sync domain:	Sync-Domain_1	Synchronization role:	Unsynchronized	RT class:	RT,IRT
--------------	---------------	-----------------------	----------------	-----------	--------

PROFINET interface [X1]\Advanced options\Real time settings\Real time options



Calculated bandwidth for cyclic IO data:	0.000ms	Calculated bandwidth for cyclic IO data:	0.000%		
--	---------	--	--------	--	--

PROFINET interface [X1]\Advanced options\Port [X1 P1 R]\General


Name	Port_1	Author	192072	Comment	
------	--------	--------	--------	---------	--

PROFINET interface [X1]\Advanced options\Port [X1 P1 R]\Port interconnection\Local port:

Local port:	PLC_1\PROFINET interface_1 [X1]\Port_1 [X1 P1 R]	Medium:	Copper	Cable name:	---
-------------	--	---------	--------	-------------	-----

Totally Integrated Automation Portal						
						
PROFINET interface [X1]\Advanced options\Port [X1 P1 R]\Port interconnection\Partner port:						
	Monitoring of partner port is executed		Alternative partners	False	Partner port:	HMI_1.IE_CP_1\PROFINET Interface_1 [X1]\Port_1 [X1 P1]
Medium:	Copper		Cable length:			
PROFINET interface [X1]\Advanced options\Port [X1 P1 R]\Port options\Activate						
Activate this port for use	True					
PROFINET interface [X1]\Advanced options\Port [X1 P1 R]\Port options\Connection						
Transmission rate / duplex:	Automatic		Monitor	False	Enable autonegotiation	True
PROFINET interface [X1]\Advanced options\Port [X1 P1 R]\Port options\Boundaries						
End of detection of accessible devices	False		End of topology discovery	False	End of the sync domain	False
PROFINET interface [X1]\Advanced options\Port [X1 P2 R]\General						
Name	Port_2		Author	192072	Comment	
PROFINET interface [X1]\Advanced options\Port [X1 P2 R]\Port interconnection\Local port:						
Local port:	PLC_1\PROFINET interface_1 [X1]\Port_2 [X1 P2 R]		Medium:	Copper	Cable name:	---
						
PROFINET interface [X1]\Advanced options\Port [X1 P2 R]\Port interconnection\Partner port:						
	Monitoring of partner port is not possible		Alternative partners	False	Partner port:	Switch_1\SCALANCE interface_1 [X1]\Port_1 [X1 P1]
Medium:	Copper		Cable length:			
PROFINET interface [X1]\Advanced options\Port [X1 P2 R]\Port options\Activate						
Activate this port for use	True					
PROFINET interface [X1]\Advanced options\Port [X1 P2 R]\Port options\Connection						
Transmission rate / duplex:	Automatic		Monitor	False	Enable autonegotiation	True
PROFINET interface [X1]\Advanced options\Port [X1 P2 R]\Port options\Boundaries						
End of detection of accessible devices	False		End of topology discovery	False	End of the sync domain	False
PROFINET interface [X1]\Web server access						
Note	The Web server must also be activated in the properties of the PLC.		Enable Web server using this interface	False		
PROFINET interface [X2]\General						
Name	PROFINET interface_2		Author	192072	Comment	
PROFINET interface [X2]\Ethernet addresses\Interface networked with						
Subnet:	Not connected					
PROFINET interface [X2]\Ethernet addresses\IP protocol						
IP configuration	Set IP address in the project		IP address:	192.168.1.1	Subnet mask:	255.255.255.0
Use router	False					
PROFINET interface [X2]\Ethernet addresses\PROFINET						
PROFINET device name is set directly at the device	False		Generate PROFINET device name automatically	True	PROFINET device name:	plc_1.profinet interface_2
Converted name:	plcxb1.profinetxainterfacexb2022c		Device number:	0		
PROFINET interface [X2]\Time synchronization\NTP mode						
Note	Time synchronization for all PROFINET interfaces take place within the settings for time synchronization of the PROFINET interface [X1].		Enable time synchronization via NTP server	False	IP addresses	
Server 1	0.0.0.0		Server 2	0.0.0.0	Server 3	0.0.0.0
Server 4	0.0.0.0		Update interval	10s		
PROFINET interface [X2]\Operating mode						
IO controller	True		IO system		Device number	0
IO device	False					
PROFINET interface [X2]\Advanced options\Interface options						
Call the user program if communication errors occur	False		Support device replacement without exchangeable medium	True	Permit overwriting of device names of all assigned IO devices	False
Limit data infeed into the network	False		Use IEC V2.2 LLDP mode	False	Keep-Alive connection monitoring:	30s
PROFINET interface [X2]\Advanced options\Real time settings\IO communication						
Send clock:	1.000ms					
PROFINET interface [X2]\Advanced options\Real time settings\Real time options						
Calculated bandwidth for cyclic IO data:	0.000ms		Calculated bandwidth for cyclic IO data:	0.000%		
PROFINET interface [X2]\Advanced options\Port [X2 P1]\General						
Name	Port_1		Author	192072	Comment	

Totally Integrated Automation Portal						
PROFINET interface [X2]\Advanced options\Port [X2 P1]\Port interconnection\Local port:						
Local port:	PLC_1\PROFINET interface_2 [X2]\Port_1 [X2 P1]		Medium:	Copper	Cable name:	---
						
PROFINET interface [X2]\Advanced options\Port [X2 P1]\Port interconnection\Partner port:						
	Monitoring of partner port is not possible		Alternative partners	False	Partner port:	Any partner
PROFINET interface [X2]\Advanced options\Port [X2 P1]\Port options\Activate						
Activate this port for use	True					
PROFINET interface [X2]\Advanced options\Port [X2 P1]\Port options\Connection						
Transmission rate / duplex:	Automatic		Monitor	False	Enable autonegotiation	True
PROFINET interface [X2]\Advanced options\Port [X2 P1]\Port options\Boundaries						
End of detection of accessible devices	False		End of topology discovery	False	End of the sync domain	False
PROFINET interface [X2]\Web server access						
Note	The Web server must also be activated in the properties of the PLC.		Enable Web server using this interface	False		
DP interface [X3]\General						
Name	DP interface_1		Author	192072	Comment	
DP interface [X3]\PROFIBUS address\Interface networked with						
Subnet:	Not networked					
DP interface [X3]\PROFIBUS address\Parameters						
Address:	2		Highest address:		Transmission speed:	
DP interface [X3]\Operating mode\						
Operating mode	DP master		DP master system:	Not created		
DP interface [X3]\Time synchronization\SIMATIC mode						
Synchronization type	None		Time interval	None		
DP interface [X3]\SYNC/FREEZE\						
Group	SYNC		FREEZE		Comment	
1	True		True			
2	True		True			
3	True		True			
4	True		True			
5	True		True			
6	True		True			
7	True		True			
8	True		True			
Startup						
Startup after POWER ON	Warm restart - Operating mode before POWER OFF		Comparison preset to actual configuration	Startup CPU even if mismatch	Configuration time	60000ms
Cycle						
Maximum cycle time	150ms				Enable minimum cycle time for cyclic OBs	True
Minimum cycle time	1ms					
Communication load						
Cycle load due to communication	50%					
System and clock memory\System memory bits						
Enable the use of system memory byte	False		Address of system memory byte (MBx)	1	First cycle	
Diagnostic status changed			Always 1 (high)		Always 0 (low)	
System and clock memory\Clock memory bits						
Enable the use of clock memory byte	False		Address of clock memory byte (MBx)	0	10 Hz clock	
5 Hz clock			2.5 Hz clock		2 Hz clock	
1.25 Hz clock			1 Hz clock		0.625 Hz clock	
0.5 Hz clock						
SIMATIC Memory Card\Diagnostics						
Aging of the SIMATIC memory card	False		Threshold value	80%		
System diagnostics\General						
Activate system diagnostics for this device	True		Report network faults as maintenance instead of fault	False		
PLC alarms\General						
Central alarm management in the PLC	True					
Web server\General						
Activate web server on this module	False		Permit access only with HTTPS	True		
Web server\Automatic update						
Enable automatic update	True		Update interval	0s		
Web server\User management						
User name				User rights		
Everybody						

Totally Integrated Automation Portal						
Web server\						
User-defined web pages						
Application name		HTML source path	Default HTML page	Files with dynamic content	Web DB number	Fragment DB number
			index.htm	.htm;.html	333	334
Web server\						
Overview of interfaces						
Device		Interface			Enabled web server access	
PLC_1		PROFINET interface_1			False	
PLC_1		PROFINET interface_2			False	
DNS configuration						
No DNS server address is configured.						
Display\General\						
Display standby mode						
Time to standby mode	30 minutes					
Display\General\						
Energy saving mode						
Time to energy saving mode	15 minutes					
Display\General\						
Display language						
Default language on display	English					
Display\						
Automatic update						
Time to update	5 seconds					
Display\Password\						
Display protection						
Enable write access	True	Enable display protection	False			
Display\						
User-defined logo\						
User logo activated	True	Adapt logo	True	Resolution	240x260	
Company logo	---					
User interface languages						
Assign project language			User interface languages			
English (United States)			German			
English (United States)			English			
English (United States)			French			
English (United States)			Spanish			
English (United States)			Italian			
English (United States)			Japanese			
English (United States)			Chinese (simplified)			
English (United States)			Korean			
English (United States)			Russian			
English (United States)			Turkish			
English (United States)			Portuguese (Brazil)			
Time of day\						
Local time						
Time zone	(UTC) Dublin, Edinburgh, Lisbon, London					
Time of day\						
Daylight saving time						
Activate daylight saving time	True	Difference between standard and daylight saving time	60mins			
Time of day\						
Daylight saving time\						
Start of daylight saving time						
Selection of the week	Last	Selection of the weekday	Sunday	of	March	
at	01:00 a.m.					
Time of day\						
Daylight saving time\						
Start of standard time						
Selection of the week	Last	Selection of the weekday	Sunday	of	October	
at	02:00 a.m.					
Protection						
Level of protection	Full access (no protection)					
Protection\						
Connection mechanisms						
Permit access with PUT/GET communication from remote partner	True					
Protection\						
Security event						
Summarize security events in case of high message volume	True	Length of an interval	20	Unit	seconds	
OPC UA\						
Accessibility of the server						
Activate OPC UA server	False					
OPC UA\						
Accessibility of the client						
Activate OPC UA client	False					

Totally Integrated Automation Portal

System power supply\General

General

Connection to supply voltage L+

System power supply\Power segment overview

Module

Slot

Supply/consumption

PLC_1

1

12.00W

AI 8xU/I/RTD/TC ST_1

2

-0.70W

AQ 4xU/I ST_1

3

-0.60W

DI 32x24VDC HF_1

4

-1.10W

DQ 32x24VDC/0.5A HF_1

5

-1.10W

Summary

8.50W

Configuration control\Configuration control for central configuration

Allow reconfiguration of device via the user program

False

Connection resources\

Station resources - Reserved - Maximum

Station resources - Reserved - Configured

Station resources - Dynamic - Configured

Module resources - PLC_1 [CPU 1516-3 PN/DP] - Configured

Maximum number of resources:

10

118

128

Maximum

Configured

Configured

Configured

PG communication:

4

-

-

-

HMI communication:

4

1

0

1

S7 communication:

0

-

0

0

Open user communication:

0

-

0

0

Web communication:

2

-

-

-

Other communication:

-

-

0

0

Total resources used:

1

0

1

Available resources:

9

118

127

Overview of addresses\Overview of addresses\Overview of addresses

Inputs

True

Outputs

True

Address gaps

False

Slot

True

Type

Addr. from

Addr. to

Module

PIP

OB

Device name

Device number

Size

Master / IO system

Rack

Slot

I

0

15

AI 8xU/I/RTD/TC ST_1

Automatic update

-

PLC_1 [CPU 1516-3 PN/DP]

-

16 Bytes

-

0

2

O

0

7

AQ 4xU/I ST_1

Automatic update

-

PLC_1 [CPU 1516-3 PN/DP]

-

8 Bytes

-

0

3

I

16

19

DI 32x24VDC HF_1

Automatic update

-

PLC_1 [CPU 1516-3 PN/DP]

-

4 Bytes

-

0

4

O

8

11

DQ 32x24VDC/0.5A HF_1

Automatic update

-

PLC_1 [CPU 1516-3 PN/DP]

-

4 Bytes

-

0

5

Runtime licenses\OPC UA\Runtime licenses

Type of required license

None

Type of purchased license

No license

Runtime licenses\ProDiag\Supervisions

Number of used supervisions

0

Runtime licenses\ProDiag\Runtime licenses

Number of required licenses

None (<= 25 supervisions)

Used ProDiag licenses

No license

Runtime licenses\Energy Suite\Energy objects

Number of configured energy objects

0

Runtime licenses\Energy Suite\Runtime licenses

Total number of licensed energy objects

0

Runtime licenses\Energy Suite\Runtime licenses\Number of purchased licenses

License type '5 energy objects'

No license

License type '10 energy objects'

No license

Totally Integrated Automation Portal																																																																																																																																																																																																																																																																																																				
<div>Proyecto_final / PLC_1 [CPU 1516-3 PN/DP] / Local modules</div> <div>AI 8xU//RTD/TC ST_1</div> <div><div>AI 8xU//RTD/TC ST_1</div><div><div>General\Project information</div><table><tr><td>Name</td><td>AI 8xU//RTD/TC ST_1</td><td>Author</td><td>192072</td><td>Comment</td><td></td></tr><tr><td>Rack</td><td>0</td><td>Slot</td><td>2</td><td colspan="2"></td></tr></table><div>General\Catalog information</div><table><tr><td>Short designation</td><td>AI 8xU//RTD/TC ST</td><td>Description</td><td colspan="2">Analog input module AI8 x U//RTD/TC 16-bit; grouping 8; 4 channels with RTD measurement; common mode voltage 10 V; configurable diagnostics; hardware interrupts</td><td>Article number</td><td>6ES7 531-7KF00-0AB0</td></tr><tr><td>Firmware version</td><td>V2.2</td><td colspan="5"></td></tr></table><div>General\Identification & Maintenance</div><table><tr><td>Plant designation</td><td></td><td>Location identifier</td><td></td><td>Installation date</td><td colspan="2">2025-05-01 19:28:00.438</td></tr><tr><td>Additional information</td><td></td><td colspan="5"></td></tr></table><div>Module parameters\General\Startup</div><table><tr><td>Comparison preset to actual module</td><td>From CPU</td><td colspan="6"></td></tr></table><div>Module parameters\Channel template\Inputs\Apply to all channels that use the template\Diagnostics</div><table><tr><td>No supply voltage L+</td><td>False</td><td>Overflow</td><td>False</td><td>Underflow</td><td colspan="2">False</td></tr><tr><td>Common mode error</td><td>False</td><td>Reference junction</td><td>False</td><td>Wire break</td><td colspan="2">False</td></tr><tr><td>Current limit for wire break diagnostics</td><td></td><td colspan="5"></td></tr></table><div>Module parameters\Channel template\Inputs\Apply to all channels that use the template\Measuring</div><table><tr><td>Measurement type</td><td>Voltage</td><td>Measuring range</td><td>+/- 10V</td><td>Temperature coefficient</td><td colspan="2"></td></tr><tr><td>Temperature unit</td><td></td><td>Reference junction</td><td></td><td>Fixed reference temperature</td><td colspan="2"></td></tr><tr><td>Interference frequency suppression</td><td>50Hz</td><td>Smoothing</td><td>None</td><td colspan="3"></td></tr></table><div>Module parameters\AI configuration\Configuration of submodules</div><table><tr><td>Module distribution</td><td>None</td><td colspan="6"></td></tr></table><div>Module parameters\AI configuration\Value status (Quality Information)</div><table><tr><td>Value status</td><td>False</td><td colspan="6"></td></tr></table><div>Module parameters\AI configuration\Copy of module for Shared Device (MSI)</div><table><tr><td>Copy of module:</td><td>None</td><td colspan="6"></td></tr></table><div>Input 0 - 7\General</div><table><tr><td>Name</td><td>AI 8xU//RTD/TC ST_1</td><td>Comment</td><td></td><td colspan="4"></td></tr></table><div>Input 0 - 7\Inputs\Channel 0</div><table><tr><td>Parameter settings</td><td>From template</td><td colspan="6"></td></tr></table><div>Input 0 - 7\Inputs\Channel 0\Diagnostics</div><table><tr><td>No supply voltage L+</td><td>False</td><td>Overflow</td><td>False</td><td>Underflow</td><td colspan="2">False</td></tr><tr><td>Common mode error</td><td>False</td><td>Reference junction</td><td>False</td><td>Wire break</td><td colspan="2">False</td></tr><tr><td>Current limit for wire break diagnostics</td><td></td><td colspan="5"></td></tr></table><div>Input 0 - 7\Inputs\Channel 0\Measuring</div><table><tr><td>Measurement type</td><td>Voltage</td><td>Measuring range</td><td>+/- 10V</td><td>Temperature coefficient</td><td colspan="2"></td></tr><tr><td>Temperature unit</td><td></td><td>Reference junction</td><td></td><td>Fixed reference temperature</td><td colspan="2"></td></tr><tr><td>Interference frequency suppression</td><td>50Hz</td><td>Smoothing</td><td>None</td><td colspan="3"></td></tr></table><div>Input 0 - 7\Inputs\Channel 0\Hardware interrupts</div><table><tr><td>High limit 1</td><td></td><td>Low limit 1</td><td></td><td>High limit 2</td><td colspan="2"></td></tr><tr><td>Low limit 2</td><td></td><td colspan="5"></td></tr></table><div>Input 0 - 7\Inputs\Channel 0\Hardware interrupts\</div><table><tr><td>Hardware interrupt high limit 1</td><td>0</td><td>RidPrefixFallingEdgeEvent</td><td>49272</td><td>Event name:</td><td colspan="2"></td></tr><tr><td>Hardware interrupt:</td><td>0</td><td>UpperLimitOne0</td><td>UpperLimitOne0</td><td>Channel number</td><td colspan="2">0</td></tr><tr><td>HwEventTypeLimit1Overrun</td><td>4</td><td colspan="5"></td></tr></table><div>Input 0 - 7\Inputs\Channel 0\Hardware interrupts\</div><table><tr><td>Hardware interrupt low limit 1</td><td>0</td><td>RidPrefixFallingEdgeEvent</td><td>49288</td><td>Event name:</td><td colspan="2"></td></tr><tr><td>Hardware interrupt:</td><td>0</td><td>LowerLimitOne0</td><td>LowerLimitOne0</td><td>Channel number</td><td colspan="2">0</td></tr><tr><td>HwEventTypeLimit1Underrun</td><td>3</td><td colspan="5"></td></tr></table><div>Input 0 - 7\Inputs\Channel 0\Hardware interrupts\</div><table><tr><td>Hardware interrupt high limit 2</td><td>0</td><td>RidPrefixFallingEdgeEvent</td><td>49264</td><td>Event name:</td><td colspan="2"></td></tr><tr><td>Hardware interrupt:</td><td>0</td><td>UpperLimitTwo0</td><td>UpperLimitTwo0</td><td>Channel number</td><td colspan="2">0</td></tr><tr><td>HwEventTypeLimit2Overrun</td><td>6</td><td colspan="5"></td></tr></table><div>Input 0 - 7\Inputs\Channel 0\Hardware interrupts\</div><table><tr><td>Hardware interrupt low limit 2</td><td>0</td><td>RidPrefixFallingEdgeEvent</td><td>49280</td><td>Event name:</td><td colspan="2"></td></tr><tr><td>Hardware interrupt:</td><td>0</td><td>LowerLimitTwo0</td><td>LowerLimitTwo0</td><td>Channel number</td><td colspan="2">0</td></tr><tr><td>HwEventTypeLimit2Underrun</td><td>5</td><td colspan="5"></td></tr></table><div>Input 0 - 7\Inputs\Channel 1</div><table><tr><td>Parameter settings</td><td>From template</td><td colspan="6"></td></tr></table><div>Input 0 - 7\Inputs\Channel 1\Diagnostics</div><table><tr><td>No supply voltage L+</td><td>False</td><td>Overflow</td><td>False</td><td>Underflow</td><td colspan="2">False</td></tr></table></div></div>								Name	AI 8xU//RTD/TC ST_1	Author	192072	Comment		Rack	0	Slot	2			Short designation	AI 8xU//RTD/TC ST	Description	Analog input module AI8 x U//RTD/TC 16-bit; grouping 8; 4 channels with RTD measurement; common mode voltage 10 V; configurable diagnostics; hardware interrupts		Article number	6ES7 531-7KF00-0AB0	Firmware version	V2.2						Plant designation		Location identifier		Installation date	2025-05-01 19:28:00.438		Additional information							Comparison preset to actual module	From CPU							No supply voltage L+	False	Overflow	False	Underflow	False		Common mode error	False	Reference junction	False	Wire break	False		Current limit for wire break diagnostics							Measurement type	Voltage	Measuring range	+/- 10V	Temperature coefficient			Temperature unit		Reference junction		Fixed reference temperature			Interference frequency suppression	50Hz	Smoothing	None				Module distribution	None							Value status	False							Copy of module:	None							Name	AI 8xU//RTD/TC ST_1	Comment						Parameter settings	From template							No supply voltage L+	False	Overflow	False	Underflow	False		Common mode error	False	Reference junction	False	Wire break	False		Current limit for wire break diagnostics							Measurement type	Voltage	Measuring range	+/- 10V	Temperature coefficient			Temperature unit		Reference junction		Fixed reference temperature			Interference frequency suppression	50Hz	Smoothing	None				High limit 1		Low limit 1		High limit 2			Low limit 2							Hardware interrupt high limit 1	0	RidPrefixFallingEdgeEvent	49272	Event name:			Hardware interrupt:	0	UpperLimitOne0	UpperLimitOne0	Channel number	0		HwEventTypeLimit1Overrun	4						Hardware interrupt low limit 1	0	RidPrefixFallingEdgeEvent	49288	Event name:			Hardware interrupt:	0	LowerLimitOne0	LowerLimitOne0	Channel number	0		HwEventTypeLimit1Underrun	3						Hardware interrupt high limit 2	0	RidPrefixFallingEdgeEvent	49264	Event name:			Hardware interrupt:	0	UpperLimitTwo0	UpperLimitTwo0	Channel number	0		HwEventTypeLimit2Overrun	6						Hardware interrupt low limit 2	0	RidPrefixFallingEdgeEvent	49280	Event name:			Hardware interrupt:	0	LowerLimitTwo0	LowerLimitTwo0	Channel number	0		HwEventTypeLimit2Underrun	5						Parameter settings	From template							No supply voltage L+	False	Overflow	False	Underflow	False	
Name	AI 8xU//RTD/TC ST_1	Author	192072	Comment																																																																																																																																																																																																																																																																																																
Rack	0	Slot	2																																																																																																																																																																																																																																																																																																	
Short designation	AI 8xU//RTD/TC ST	Description	Analog input module AI8 x U//RTD/TC 16-bit; grouping 8; 4 channels with RTD measurement; common mode voltage 10 V; configurable diagnostics; hardware interrupts		Article number	6ES7 531-7KF00-0AB0																																																																																																																																																																																																																																																																																														
Firmware version	V2.2																																																																																																																																																																																																																																																																																																			
Plant designation		Location identifier		Installation date	2025-05-01 19:28:00.438																																																																																																																																																																																																																																																																																															
Additional information																																																																																																																																																																																																																																																																																																				
Comparison preset to actual module	From CPU																																																																																																																																																																																																																																																																																																			
No supply voltage L+	False	Overflow	False	Underflow	False																																																																																																																																																																																																																																																																																															
Common mode error	False	Reference junction	False	Wire break	False																																																																																																																																																																																																																																																																																															
Current limit for wire break diagnostics																																																																																																																																																																																																																																																																																																				
Measurement type	Voltage	Measuring range	+/- 10V	Temperature coefficient																																																																																																																																																																																																																																																																																																
Temperature unit		Reference junction		Fixed reference temperature																																																																																																																																																																																																																																																																																																
Interference frequency suppression	50Hz	Smoothing	None																																																																																																																																																																																																																																																																																																	
Module distribution	None																																																																																																																																																																																																																																																																																																			
Value status	False																																																																																																																																																																																																																																																																																																			
Copy of module:	None																																																																																																																																																																																																																																																																																																			
Name	AI 8xU//RTD/TC ST_1	Comment																																																																																																																																																																																																																																																																																																		
Parameter settings	From template																																																																																																																																																																																																																																																																																																			
No supply voltage L+	False	Overflow	False	Underflow	False																																																																																																																																																																																																																																																																																															
Common mode error	False	Reference junction	False	Wire break	False																																																																																																																																																																																																																																																																																															
Current limit for wire break diagnostics																																																																																																																																																																																																																																																																																																				
Measurement type	Voltage	Measuring range	+/- 10V	Temperature coefficient																																																																																																																																																																																																																																																																																																
Temperature unit		Reference junction		Fixed reference temperature																																																																																																																																																																																																																																																																																																
Interference frequency suppression	50Hz	Smoothing	None																																																																																																																																																																																																																																																																																																	
High limit 1		Low limit 1		High limit 2																																																																																																																																																																																																																																																																																																
Low limit 2																																																																																																																																																																																																																																																																																																				
Hardware interrupt high limit 1	0	RidPrefixFallingEdgeEvent	49272	Event name:																																																																																																																																																																																																																																																																																																
Hardware interrupt:	0	UpperLimitOne0	UpperLimitOne0	Channel number	0																																																																																																																																																																																																																																																																																															
HwEventTypeLimit1Overrun	4																																																																																																																																																																																																																																																																																																			
Hardware interrupt low limit 1	0	RidPrefixFallingEdgeEvent	49288	Event name:																																																																																																																																																																																																																																																																																																
Hardware interrupt:	0	LowerLimitOne0	LowerLimitOne0	Channel number	0																																																																																																																																																																																																																																																																																															
HwEventTypeLimit1Underrun	3																																																																																																																																																																																																																																																																																																			
Hardware interrupt high limit 2	0	RidPrefixFallingEdgeEvent	49264	Event name:																																																																																																																																																																																																																																																																																																
Hardware interrupt:	0	UpperLimitTwo0	UpperLimitTwo0	Channel number	0																																																																																																																																																																																																																																																																																															
HwEventTypeLimit2Overrun	6																																																																																																																																																																																																																																																																																																			
Hardware interrupt low limit 2	0	RidPrefixFallingEdgeEvent	49280	Event name:																																																																																																																																																																																																																																																																																																
Hardware interrupt:	0	LowerLimitTwo0	LowerLimitTwo0	Channel number	0																																																																																																																																																																																																																																																																																															
HwEventTypeLimit2Underrun	5																																																																																																																																																																																																																																																																																																			
Parameter settings	From template																																																																																																																																																																																																																																																																																																			
No supply voltage L+	False	Overflow	False	Underflow	False																																																																																																																																																																																																																																																																																															

Totally Integrated Automation Portal						
--------------------------------------	--	--	--	--	--	--

Common mode error	False	Reference junction	False	Wire break	False
Current limit for wire break diagnostics					
Input 0 - 7\Inputs\Channel 1\Measuring					
Measurement type	Voltage	Measuring range	+/- 10V	Temperature coefficient	
Temperature unit		Reference junction		Fixed reference temperature	
Interference frequency suppression	50Hz	Smoothing	None		
Input 0 - 7\Inputs\Channel 1\Hardware interrupts					
High limit 1		Low limit 1		High limit 2	
Low limit 2					
Input 0 - 7\Inputs\Channel 1\Hardware interrupts\					
Hardware interrupt high limit 1	0	RidPrefixFallingEdgeEvent	49273	Event name:	
Hardware interrupt:	0	UpperLimitOne1	UpperLimitOne1	Channel number	1
HwEventTypeLimit1Overrun	4				
Input 0 - 7\Inputs\Channel 1\Hardware interrupts\					
Hardware interrupt low limit 1	0	RidPrefixFallingEdgeEvent	49289	Event name:	
Hardware interrupt:	0	LowerLimitOne1	LowerLimitOne1	Channel number	1
HwEventTypeLimit1Underrun	3				
Input 0 - 7\Inputs\Channel 1\Hardware interrupts\					
Hardware interrupt high limit 2	0	RidPrefixFallingEdgeEvent	49265	Event name:	
Hardware interrupt:	0	UpperLimitTwo1	UpperLimitTwo1	Channel number	1
HwEventTypeLimit2Overrun	6				
Input 0 - 7\Inputs\Channel 1\Hardware interrupts\					
Hardware interrupt low limit 2	0	RidPrefixFallingEdgeEvent	49281	Event name:	
Hardware interrupt:	0	LowerLimitTwo1	LowerLimitTwo1	Channel number	1
HwEventTypeLimit2Underrun	5				
Input 0 - 7\Inputs\Channel 2					
Parameter settings	From template				
Input 0 - 7\Inputs\Channel 2\Diagnostics					
No supply voltage L+	False	Overflow	False	Underflow	False
Common mode error	False	Reference junction	False	Wire break	False
Current limit for wire break diagnostics					
Input 0 - 7\Inputs\Channel 2\Measuring					
Measurement type	Voltage	Measuring range	+/- 10V	Temperature coefficient	
Temperature unit		Reference junction		Fixed reference temperature	
Interference frequency suppression	50Hz	Smoothing	None		
Input 0 - 7\Inputs\Channel 2\Hardware interrupts					
High limit 1		Low limit 1		High limit 2	
Low limit 2					
Input 0 - 7\Inputs\Channel 2\Hardware interrupts\					
Hardware interrupt high limit 1	0	RidPrefixFallingEdgeEvent	49274	Event name:	
Hardware interrupt:	0	UpperLimitOne2	UpperLimitOne2	Channel number	2
HwEventTypeLimit1Overrun	4				
Input 0 - 7\Inputs\Channel 2\Hardware interrupts\					
Hardware interrupt low limit 1	0	RidPrefixFallingEdgeEvent	49290	Event name:	
Hardware interrupt:	0	LowerLimitOne2	LowerLimitOne2	Channel number	2
HwEventTypeLimit1Underrun	3				
Input 0 - 7\Inputs\Channel 2\Hardware interrupts\					
Hardware interrupt high limit 2	0	RidPrefixFallingEdgeEvent	49266	Event name:	
Hardware interrupt:	0	UpperLimitTwo2	UpperLimitTwo2	Channel number	2
HwEventTypeLimit2Overrun	6				
Input 0 - 7\Inputs\Channel 2\Hardware interrupts\					
Hardware interrupt low limit 2	0	RidPrefixFallingEdgeEvent	49282	Event name:	
Hardware interrupt:	0	LowerLimitTwo2	LowerLimitTwo2	Channel number	2
HwEventTypeLimit2Underrun	5				
Input 0 - 7\Inputs\Channel 3					
Parameter settings	From template				
Input 0 - 7\Inputs\Channel 3\Diagnostics					
No supply voltage L+	False	Overflow	False	Underflow	False
Common mode error	False	Reference junction	False	Wire break	False
Current limit for wire break diagnostics					
Input 0 - 7\Inputs\Channel 3\Measuring					
Measurement type	Voltage	Measuring range	+/- 10V	Temperature coefficient	

--	--	--

Totally Integrated Automation Portal						
--------------------------------------	--	--	--	--	--	--

Temperature unit		Reference junction		Fixed reference temperature	
Interference frequency suppression	50Hz	Smoothing	None		
Input 0 - 7\Inputs\Channel 3\Hardware interrupts					
High limit 1		Low limit 1		High limit 2	
Low limit 2					
Input 0 - 7\Inputs\Channel 3\Hardware interrupts\					
Hardware interrupt high limit 1	0	RidPrefixFallingEdgeEvent	49275	Event name:	
Hardware interrupt:	0	UpperLimitOne3	UpperLimitOne3	Channel number	3
HwEventTypeLimit1Overrun	4				
Input 0 - 7\Inputs\Channel 3\Hardware interrupts\					
Hardware interrupt low limit 1	0	RidPrefixFallingEdgeEvent	49291	Event name:	
Hardware interrupt:	0	LowerLimitOne3	LowerLimitOne3	Channel number	3
HwEventTypeLimit1Underrun	3				
Input 0 - 7\Inputs\Channel 3\Hardware interrupts\					
Hardware interrupt high limit 2	0	RidPrefixFallingEdgeEvent	49267	Event name:	
Hardware interrupt:	0	UpperLimitTwo3	UpperLimitTwo3	Channel number	3
HwEventTypeLimit2Overrun	6				
Input 0 - 7\Inputs\Channel 3\Hardware interrupts\					
Hardware interrupt low limit 2	0	RidPrefixFallingEdgeEvent	49283	Event name:	
Hardware interrupt:	0	LowerLimitTwo3	LowerLimitTwo3	Channel number	3
HwEventTypeLimit2Underrun	5				
Input 0 - 7\Inputs\Channel 4					
Parameter settings	From template				
Input 0 - 7\Inputs\Channel 4\Diagnostics					
No supply voltage L+	False	Overflow	False	Underflow	False
Common mode error	False	Reference junction	False	Wire break	False
Current limit for wire break diagnostics					
Input 0 - 7\Inputs\Channel 4\Measuring					
Measurement type	Voltage	Measuring range	+/- 10V	Temperature coefficient	
Temperature unit		Reference junction		Fixed reference temperature	
Interference frequency suppression	50Hz	Smoothing	None		
Input 0 - 7\Inputs\Channel 4\Hardware interrupts					
High limit 1		Low limit 1		High limit 2	
Low limit 2					
Input 0 - 7\Inputs\Channel 4\Hardware interrupts\					
Hardware interrupt high limit 1	0	RidPrefixFallingEdgeEvent	49276	Event name:	
Hardware interrupt:	0	UpperLimitOne4	UpperLimitOne4	Channel number	4
HwEventTypeLimit1Overrun	4				
Input 0 - 7\Inputs\Channel 4\Hardware interrupts\					
Hardware interrupt low limit 1	0	RidPrefixFallingEdgeEvent	49292	Event name:	
Hardware interrupt:	0	LowerLimitOne4	LowerLimitOne4	Channel number	4
HwEventTypeLimit1Underrun	3				
Input 0 - 7\Inputs\Channel 4\Hardware interrupts\					
Hardware interrupt high limit 2	0	RidPrefixFallingEdgeEvent	49268	Event name:	
Hardware interrupt:	0	UpperLimitTwo4	UpperLimitTwo4	Channel number	4
HwEventTypeLimit2Overrun	6				
Input 0 - 7\Inputs\Channel 4\Hardware interrupts\					
Hardware interrupt low limit 2	0	RidPrefixFallingEdgeEvent	49284	Event name:	
Hardware interrupt:	0	LowerLimitTwo4	LowerLimitTwo4	Channel number	4
HwEventTypeLimit2Underrun	5				
Input 0 - 7\Inputs\Channel 5					
Parameter settings	From template				
Input 0 - 7\Inputs\Channel 5\Diagnostics					
No supply voltage L+	False	Overflow	False	Underflow	False
Common mode error	False	Reference junction	False	Wire break	False
Current limit for wire break diagnostics					
Input 0 - 7\Inputs\Channel 5\Measuring					
Measurement type	Voltage	Measuring range	+/- 10V	Temperature coefficient	
Temperature unit		Reference junction		Fixed reference temperature	
Interference frequency suppression	50Hz	Smoothing	None		
Input 0 - 7\Inputs\Channel 5\Hardware interrupts					
High limit 1		Low limit 1		High limit 2	
Low limit 2					

--	--	--

Totally Integrated Automation Portal						
Input 0 - 7\Inputs\Channel 5\Hardware interrupts\						
Hardware interrupt high limit 1	0	RidPrefixFallingEdgeEvent	49277	Event name:		
Hardware interrupt:	0	UpperLimitOne5	UpperLimitOne5	Channel number	5	
HwEventTypeLimit1Overrun	4					
Input 0 - 7\Inputs\Channel 5\Hardware interrupts\						
Hardware interrupt low limit 1	0	RidPrefixFallingEdgeEvent	49293	Event name:		
Hardware interrupt:	0	LowerLimitOne5	LowerLimitOne5	Channel number	5	
HwEventTypeLimit1Underrun	3					
Input 0 - 7\Inputs\Channel 5\Hardware interrupts\						
Hardware interrupt high limit 2	0	RidPrefixFallingEdgeEvent	49269	Event name:		
Hardware interrupt:	0	UpperLimitTwo5	UpperLimitTwo5	Channel number	5	
HwEventTypeLimit2Overrun	6					
Input 0 - 7\Inputs\Channel 5\Hardware interrupts\						
Hardware interrupt low limit 2	0	RidPrefixFallingEdgeEvent	49285	Event name:		
Hardware interrupt:	0	LowerLimitTwo5	LowerLimitTwo5	Channel number	5	
HwEventTypeLimit2Underrun	5					
Input 0 - 7\Inputs\Channel 6						
Parameter settings	From template					
Input 0 - 7\Inputs\Channel 6\Diagnostics						
No supply voltage L+	False	Overflow	False	Underflow	False	
Common mode error	False	Reference junction	False	Wire break	False	
Current limit for wire break diagnostics						
Input 0 - 7\Inputs\Channel 6\Measuring						
Measurement type	Voltage	Measuring range	+/- 10V	Temperature coefficient		
Temperature unit		Reference junction		Fixed reference temperature		
Interference frequency suppression	50Hz	Smoothing	None			
Input 0 - 7\Inputs\Channel 6\Hardware interrupts						
High limit 1		Low limit 1		High limit 2		
Low limit 2						
Input 0 - 7\Inputs\Channel 6\Hardware interrupts\						
Hardware interrupt high limit 1	0	RidPrefixFallingEdgeEvent	49278	Event name:		
Hardware interrupt:	0	UpperLimitOne6	UpperLimitOne6	Channel number	6	
HwEventTypeLimit1Overrun	4					
Input 0 - 7\Inputs\Channel 6\Hardware interrupts\						
Hardware interrupt low limit 1	0	RidPrefixFallingEdgeEvent	49294	Event name:		
Hardware interrupt:	0	LowerLimitOne6	LowerLimitOne6	Channel number	6	
HwEventTypeLimit1Underrun	3					
Input 0 - 7\Inputs\Channel 6\Hardware interrupts\						
Hardware interrupt high limit 2	0	RidPrefixFallingEdgeEvent	49270	Event name:		
Hardware interrupt:	0	UpperLimitTwo6	UpperLimitTwo6	Channel number	6	
HwEventTypeLimit2Overrun	6					
Input 0 - 7\Inputs\Channel 6\Hardware interrupts\						
Hardware interrupt low limit 2	0	RidPrefixFallingEdgeEvent	49286	Event name:		
Hardware interrupt:	0	LowerLimitTwo6	LowerLimitTwo6	Channel number	6	
HwEventTypeLimit2Underrun	5					
Input 0 - 7\Inputs\Channel 7						
Parameter settings	From template					
Input 0 - 7\Inputs\Channel 7\Diagnostics						
No supply voltage L+	False	Overflow	False	Underflow	False	
Common mode error	False	Reference junction	False	Wire break	False	
Current limit for wire break diagnostics						
Input 0 - 7\Inputs\Channel 7\Measuring						
Measurement type	Voltage	Measuring range	+/- 10V	Temperature coefficient		
Temperature unit		Reference junction		Fixed reference temperature		
Interference frequency suppression	50Hz	Smoothing	None			
Input 0 - 7\Inputs\Channel 7\Hardware interrupts						
High limit 1		Low limit 1		High limit 2		
Low limit 2						
Input 0 - 7\Inputs\Channel 7\Hardware interrupts\						
Hardware interrupt high limit 1	0	RidPrefixFallingEdgeEvent	49279	Event name:		
Hardware interrupt:	0	UpperLimitOne7	UpperLimitOne7	Channel number	7	
HwEventTypeLimit1Overrun	4					

Totally Integrated Automation Portal						
Input 0 - 7\Inputs\Channel 7\Hardware interrupts\						
Hardware interrupt low limit 1	0	RidPrefixFallingEdgeEvent	49295	Event name:		
Hardware interrupt:	0	LowerLimitOne7	LowerLimitOne7	Channel number	7	
HwEventTypeLimit1Underrun	3					
Input 0 - 7\Inputs\Channel 7\Hardware interrupts\						
Hardware interrupt high limit 2	0	RidPrefixFallingEdgeEvent	49271	Event name:		
Hardware interrupt:	0	UpperLimitTwo7	UpperLimitTwo7	Channel number	7	
HwEventTypeLimit2Overrun	6					
Input 0 - 7\Inputs\Channel 7\Hardware interrupts\						
Hardware interrupt low limit 2	0	RidPrefixFallingEdgeEvent	49287	Event name:		
Hardware interrupt:	0	LowerLimitTwo7	LowerLimitTwo7	Channel number	7	
HwEventTypeLimit2Underrun	5					
Input 0 - 7\Inputs\Channel reference temperature\Diagnostics						
No supply voltage L+	False	Overflow	False	Underflow	False	
Wire break	False					
Input 0 - 7\Inputs\Channel reference temperature\Measure						
Measurement type	Deactivated	Measuring range		Temperature coefficient		
Interference frequency suppression		Smoothing				
Input 0 - 7\I/O addresses\Input addresses						
Start address	0	End address	15	Organization block	0	
Process image	0					

Totally Integrated Automation Portal					
--------------------------------------	--	--	--	--	--

Proyecto_final / PLC_1 [CPU 1516-3 PN/DP] / Local modules

DI 32x24VDC HF_1

DI 32x24VDC HF_1

General\Project information

Name	DI 32x24VDC HF_1	Author	192072	Comment	
Rack	0	Slot	4		

General\Catalog information

Short designation	DI 32x24VDC HF	Description	Digital input module DI32 x DC24V; grouping 16; input delay 0.05..20ms; input type 3 (IEC 61131); configurable diagnostics; hardware interrupts; value status; integrated counter for channel 0 and 1; isochronous mode		Article number	6ES7 521-1BL00-0AB0
Firmware version	V2.1					

General\Identification & Maintenance

Plant designation		Location identifier		Installation date	2025-05-01 19:28:00.438	
Additional information						

Module parameters\General\Startup

Comparison preset to actual module	From CPU				
------------------------------------	----------	--	--	--	--

Module parameters\Channel template\Inputs\Apply to all channels that use the template\Diagnostics

No supply voltage L+	False	Wire break	False			
----------------------	-------	------------	-------	--	--	--

Module parameters\Channel template\Inputs\Apply to all channels that use the template\Input parameters

Input delay	3.2ms				
-------------	-------	--	--	--	--

Module parameters\DI Configuration\Configuration of submodules

Module distribution	None				
---------------------	------	--	--	--	--

Module parameters\DI Configuration\Value status (Quality Information)

Value status	False				
--------------	-------	--	--	--	--

Module parameters\DI Configuration\Copy of module for Shared Device (MSI)

Copy of module:	None				
-----------------	------	--	--	--	--

Module parameters\DI Configuration\Counter configuration\Counter configuration on channel 0 and channel 1 enabled

Counter configuration on channel 0 and channel 1 enabled	False				
--	-------	--	--	--	--

Input 0 - 31\General

Name	DI 32x24VDC HF_1	Comment				
------	------------------	---------	--	--	--	--

Input 0 - 31\Inputs\General\Module failure

Input values with module failure	Input value 0				
----------------------------------	---------------	--	--	--	--

Input 0 - 31\Inputs\Channel 0-7\Channel 0

Parameter settings	From template				
--------------------	---------------	--	--	--	--

Input 0 - 31\Inputs\Channel 0-7\Channel 0\Diagnostics

No supply voltage L+	False	Wire break	False			
----------------------	-------	------------	-------	--	--	--

Input 0 - 31\Inputs\Channel 0-7\Channel 0\Input parameters

Input delay	3.2ms				
-------------	-------	--	--	--	--

Input 0 - 31\Inputs\Channel 0-7\Channel 0\Counter configuration

Reaction to violation of a counting limit		Edge selection		Set output DQ	
High counting limit		Low counting limit		Start value	
Comparison value					

Input 0 - 31\Inputs\Channel 0-7\Channel 0\Hardware interrupts\

Comparison event for DQ has occurred	0	CountRidPrefixEvent	49248	Event name:	
Hardware interrupt CountHwEventType	0	Rising edge0	Count0	Channel number	0

Input 0 - 31\Inputs\Channel 0-7\Channel 0\Hardware interrupts\

Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49152	Event name:	
Hardware interrupt HwEventTypeRisingEdge	0	Rising edge0	Rising edge0	Channel number	0

Input 0 - 31\Inputs\Channel 0-7\Channel 0\Hardware interrupts\

Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49280	Event name:	
Hardware interrupt HwEventTypeFallingEdge	0	Falling edge0	Falling edge0	Channel number	0

Input 0 - 31\Inputs\Channel 0-7\Channel 1

Parameter settings	From template				
--------------------	---------------	--	--	--	--

Input 0 - 31\Inputs\Channel 0-7\Channel 1\Diagnostics

No supply voltage L+	False	Wire break	False			
----------------------	-------	------------	-------	--	--	--

Input 0 - 31\Inputs\Channel 0-7\Channel 1\Input parameters

Input delay	3.2ms				
-------------	-------	--	--	--	--

Input 0 - 31\Inputs\Channel 0-7\Channel 1\Counter configuration

Reaction to violation of a counting limit		Edge selection		Set output DQ	
High counting limit		Low counting limit		Start value	
Comparison value					

Input 0 - 31\Inputs\Channel 0-7\Channel 1\Hardware interrupts\

Comparison event for DQ has occurred	0	CountRidPrefixEvent	49249	Event name:	
Hardware interrupt CountHwEventType	0	Rising edge1	Count1	Channel number	1

Totally Integrated Automation Portal						
Input 0 - 31\Inputs\Channel 0-7\Channel 1\Hardware interrupts\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49153	Event name:		
Hardware interrupt	0	Rising edge1	Rising edge1	Channel number	1	
HwEventTypeRisingEdge	1					
Input 0 - 31\Inputs\Channel 0-7\Channel 1\Hardware interrupts\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49281	Event name:		
Hardware interrupt	0	Falling edge1	Falling edge1	Channel number	1	
HwEventTypeFallingEdge	2					
Input 0 - 31\Inputs\Channel 0-7\Channel 2						
Parameter settings	From template					
Input 0 - 31\Inputs\Channel 0-7\Channel 2\Diagnostics						
No supply voltage L+	False	Wire break	False			
Input 0 - 31\Inputs\Channel 0-7\Channel 2\Input parameters						
Input delay	3.2ms					
Input 0 - 31\Inputs\Channel 0-7\Channel 2\Hardware interrupts\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49154	Event name:		
Hardware interrupt	0	Rising edge2	Rising edge2	Channel number	2	
HwEventTypeRisingEdge	1					
Input 0 - 31\Inputs\Channel 0-7\Channel 2\Hardware interrupts\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49282	Event name:		
Hardware interrupt	0	Falling edge2	Falling edge2	Channel number	2	
HwEventTypeFallingEdge	2					
Input 0 - 31\Inputs\Channel 0-7\Channel 3						
Parameter settings	From template					
Input 0 - 31\Inputs\Channel 0-7\Channel 3\Diagnostics						
No supply voltage L+	False	Wire break	False			
Input 0 - 31\Inputs\Channel 0-7\Channel 3\Input parameters						
Input delay	3.2ms					
Input 0 - 31\Inputs\Channel 0-7\Channel 3\Hardware interrupts\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49155	Event name:		
Hardware interrupt	0	Rising edge3	Rising edge3	Channel number	3	
HwEventTypeRisingEdge	1					
Input 0 - 31\Inputs\Channel 0-7\Channel 3\Hardware interrupts\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49283	Event name:		
Hardware interrupt	0	Falling edge3	Falling edge3	Channel number	3	
HwEventTypeFallingEdge	2					
Input 0 - 31\Inputs\Channel 0-7\Channel 4						
Parameter settings	From template					
Input 0 - 31\Inputs\Channel 0-7\Channel 4\Diagnostics						
No supply voltage L+	False	Wire break	False			
Input 0 - 31\Inputs\Channel 0-7\Channel 4\Input parameters						
Input delay	3.2ms					
Input 0 - 31\Inputs\Channel 0-7\Channel 4\Hardware interrupts\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49156	Event name:		
Hardware interrupt	0	Rising edge4	Rising edge4	Channel number	4	
HwEventTypeRisingEdge	1					
Input 0 - 31\Inputs\Channel 0-7\Channel 4\Hardware interrupts\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49284	Event name:		
Hardware interrupt	0	Falling edge4	Falling edge4	Channel number	4	
HwEventTypeFallingEdge	2					
Input 0 - 31\Inputs\Channel 0-7\Channel 5						
Parameter settings	From template					
Input 0 - 31\Inputs\Channel 0-7\Channel 5\Diagnostics						
No supply voltage L+	False	Wire break	False			
Input 0 - 31\Inputs\Channel 0-7\Channel 5\Input parameters						
Input delay	3.2ms					
Input 0 - 31\Inputs\Channel 0-7\Channel 5\Hardware interrupts\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49157	Event name:		
Hardware interrupt	0	Rising edge5	Rising edge5	Channel number	5	
HwEventTypeRisingEdge	1					
Input 0 - 31\Inputs\Channel 0-7\Channel 5\Hardware interrupts\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49285	Event name:		
Hardware interrupt	0	Falling edge5	Falling edge5	Channel number	5	
HwEventTypeFallingEdge	2					
Input 0 - 31\Inputs\Channel 0-7\Channel 6						
Parameter settings	From template					
Input 0 - 31\Inputs\Channel 0-7\Channel 6\Diagnostics						
No supply voltage L+	False	Wire break	False			

Totally Integrated Automation Portal						
Input 0 - 31\Inputs\Channel 0-7\Channel 6\Input parameters						
Input delay	3.2ms					
Input 0 - 31\Inputs\Channel 0-7\Channel 6\Hardware interrupts\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49158	Event name:		
Hardware interrupt	0	Rising edge6	Rising edge6	Channel number	6	
HwEventTypeRisingEdge	1					
Input 0 - 31\Inputs\Channel 0-7\Channel 6\Hardware interrupts\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49286	Event name:		
Hardware interrupt	0	Falling edge6	Falling edge6	Channel number	6	
HwEventTypeFallingEdge	2					
Input 0 - 31\Inputs\Channel 0-7\Channel 7						
Parameter settings	From template					
Input 0 - 31\Inputs\Channel 0-7\Channel 7\Diagnostics						
No supply voltage L+	False	Wire break	False			
Input 0 - 31\Inputs\Channel 0-7\Channel 7\Input parameters						
Input delay	3.2ms					
Input 0 - 31\Inputs\Channel 0-7\Channel 7\Hardware interrupts\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49159	Event name:		
Hardware interrupt	0	Rising edge7	Rising edge7	Channel number	7	
HwEventTypeRisingEdge	1					
Input 0 - 31\Inputs\Channel 0-7\Channel 7\Hardware interrupts\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49287	Event name:		
Hardware interrupt	0	Falling edge7	Falling edge7	Channel number	7	
HwEventTypeFallingEdge	2					
Input 0 - 31\Inputs\Channel 8-15\Channel 8						
Parameter settings	From template					
Input 0 - 31\Inputs\Channel 8-15\Channel 8\Diagnostics						
No supply voltage L+	False	Wire break	False			
Input 0 - 31\Inputs\Channel 8-15\Channel 8\Input parameters						
Input delay	3.2ms					
Input 0 - 31\Inputs\Channel 8-15\Channel 8\Hardware interrupts\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49160	Event name:		
Hardware interrupt	0	Rising edge8	Rising edge8	Channel number	8	
HwEventTypeRisingEdge	1					
Input 0 - 31\Inputs\Channel 8-15\Channel 8\Hardware interrupts\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49288	Event name:		
Hardware interrupt	0	Falling edge8	Falling edge8	Channel number	8	
HwEventTypeFallingEdge	2					
Input 0 - 31\Inputs\Channel 8-15\Channel 9						
Parameter settings	From template					
Input 0 - 31\Inputs\Channel 8-15\Channel 9\Diagnostics						
No supply voltage L+	False	Wire break	False			
Input 0 - 31\Inputs\Channel 8-15\Channel 9\Input parameters						
Input delay	3.2ms					
Input 0 - 31\Inputs\Channel 8-15\Channel 9\Hardware interrupts\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49161	Event name:		
Hardware interrupt	0	Rising edge9	Rising edge9	Channel number	9	
HwEventTypeRisingEdge	1					
Input 0 - 31\Inputs\Channel 8-15\Channel 9\Hardware interrupts\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49289	Event name:		
Hardware interrupt	0	Falling edge9	Falling edge9	Channel number	9	
HwEventTypeFallingEdge	2					
Input 0 - 31\Inputs\Channel 8-15\Channel 10						
Parameter settings	From template					
Input 0 - 31\Inputs\Channel 8-15\Channel 10\Diagnostics						
No supply voltage L+	False	Wire break	False			
Input 0 - 31\Inputs\Channel 8-15\Channel 10\Input parameters						
Input delay	3.2ms					
Input 0 - 31\Inputs\Channel 8-15\Channel 10\Hardware interrupts\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49162	Event name:		
Hardware interrupt	0	Rising edge10	Rising edge10	Channel number	10	
HwEventTypeRisingEdge	1					
Input 0 - 31\Inputs\Channel 8-15\Channel 10\Hardware interrupts\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49290	Event name:		
Hardware interrupt	0	Falling edge10	Falling edge10	Channel number	10	
HwEventTypeFallingEdge	2					
Input 0 - 31\Inputs\Channel 8-15\Channel 11						
Parameter settings	From template					

Totally Integrated Automation Portal		
Input 0 - 31\Inputs\Channel 8-15\Channel 11\Diagnostics		
No supply voltage L+	False	Wire breakFalse
Input 0 - 31\Inputs\Channel 8-15\Channel 11\Input parameters		
Input delay	3.2ms	
Input 0 - 31\Inputs\Channel 8-15\Channel 11\Hardware interrupts\		
Enable rising edge detection	0	RidPrefixRisingEdgeEvent49163Event name:
Hardware interrupt	0	Rising edge11Rising edge11Channel number11
HwEventTypeRisingEdge	1	
Input 0 - 31\Inputs\Channel 8-15\Channel 11\Hardware interrupts\		
Enable falling edge detection	0	RidPrefixFallingEdgeEvent49291Event name:
Hardware interrupt	0	Falling edge11Falling edge11Channel number11
HwEventTypeFallingEdge	2	
Input 0 - 31\Inputs\Channel 8-15\Channel 12		
Parameter settings	From template	
Input 0 - 31\Inputs\Channel 8-15\Channel 12\Diagnostics		
No supply voltage L+	False	Wire breakFalse
Input 0 - 31\Inputs\Channel 8-15\Channel 12\Input parameters		
Input delay	3.2ms	
Input 0 - 31\Inputs\Channel 8-15\Channel 12\Hardware interrupts\		
Enable rising edge detection	0	RidPrefixRisingEdgeEvent49164Event name:
Hardware interrupt	0	Rising edge12Rising edge12Channel number12
HwEventTypeRisingEdge	1	
Input 0 - 31\Inputs\Channel 8-15\Channel 12\Hardware interrupts\		
Enable falling edge detection	0	RidPrefixFallingEdgeEvent49292Event name:
Hardware interrupt	0	Falling edge12Falling edge12Channel number12
HwEventTypeFallingEdge	2	
Input 0 - 31\Inputs\Channel 8-15\Channel 13		
Parameter settings	From template	
Input 0 - 31\Inputs\Channel 8-15\Channel 13\Diagnostics		
No supply voltage L+	False	Wire breakFalse
Input 0 - 31\Inputs\Channel 8-15\Channel 13\Input parameters		
Input delay	3.2ms	
Input 0 - 31\Inputs\Channel 8-15\Channel 13\Hardware interrupts\		
Enable rising edge detection	0	RidPrefixRisingEdgeEvent49165Event name:
Hardware interrupt	0	Rising edge13Rising edge13Channel number13
HwEventTypeRisingEdge	1	
Input 0 - 31\Inputs\Channel 8-15\Channel 13\Hardware interrupts\		
Enable falling edge detection	0	RidPrefixFallingEdgeEvent49293Event name:
Hardware interrupt	0	Falling edge13Falling edge13Channel number13
HwEventTypeFallingEdge	2	
Input 0 - 31\Inputs\Channel 8-15\Channel 14		
Parameter settings	From template	
Input 0 - 31\Inputs\Channel 8-15\Channel 14\Diagnostics		
No supply voltage L+	False	Wire breakFalse
Input 0 - 31\Inputs\Channel 8-15\Channel 14\Input parameters		
Input delay	3.2ms	
Input 0 - 31\Inputs\Channel 8-15\Channel 14\Hardware interrupts\		
Enable rising edge detection	0	RidPrefixRisingEdgeEvent49166Event name:
Hardware interrupt	0	Rising edge14Rising edge14Channel number14
HwEventTypeRisingEdge	1	
Input 0 - 31\Inputs\Channel 8-15\Channel 14\Hardware interrupts\		
Enable falling edge detection	0	RidPrefixFallingEdgeEvent49294Event name:
Hardware interrupt	0	Falling edge14Falling edge14Channel number14
HwEventTypeFallingEdge	2	
Input 0 - 31\Inputs\Channel 8-15\Channel 15		
Parameter settings	From template	
Input 0 - 31\Inputs\Channel 8-15\Channel 15\Diagnostics		
No supply voltage L+	False	Wire breakFalse
Input 0 - 31\Inputs\Channel 8-15\Channel 15\Input parameters		
Input delay	3.2ms	
Input 0 - 31\Inputs\Channel 8-15\Channel 15\Hardware interrupts\		
Enable rising edge detection	0	RidPrefixRisingEdgeEvent49167Event name:
Hardware interrupt	0	Rising edge15Rising edge15Channel number15
HwEventTypeRisingEdge	1	
Input 0 - 31\Inputs\Channel 8-15\Channel 15\Hardware interrupts\		
Enable falling edge detection	0	RidPrefixFallingEdgeEvent49295Event name:
Hardware interrupt	0	Falling edge15Falling edge15Channel number15
HwEventTypeFallingEdge	2	

Totally Integrated Automation Portal									
Input 0 - 31\Inputs\Channel 16-23\Channel 16									
Parameter settings		From template							
Input 0 - 31\Inputs\Channel 16-23\Channel 16\Diagnostics									
No supply voltage L+		False		Wire break		False			
Input 0 - 31\Inputs\Channel 16-23\Channel 16\Input parameters									
Input delay		3.2ms							
Input 0 - 31\Inputs\Channel 16-23\Channel 16\Hardware interrupts\									
Enable rising edge detection		0		RidPrefixRisingEdgeEvent		49168		Event name:	
Hardware interrupt		0		Rising edge16		Rising edge16		Channel number	
HwEventTypeRisingEdge		1							
Input 0 - 31\Inputs\Channel 16-23\Channel 16\Hardware interrupts\									
Enable falling edge detection		0		RidPrefixFallingEdgeEvent		49296		Event name:	
Hardware interrupt		0		Falling edge16		Falling edge16		Channel number	
HwEventTypeFallingEdge		2							
Input 0 - 31\Inputs\Channel 16-23\Channel 17									
Parameter settings		From template							
Input 0 - 31\Inputs\Channel 16-23\Channel 17\Diagnostics									
No supply voltage L+		False		Wire break		False			
Input 0 - 31\Inputs\Channel 16-23\Channel 17\Input parameters									
Input delay		3.2ms							
Input 0 - 31\Inputs\Channel 16-23\Channel 17\Hardware interrupts\									
Enable rising edge detection		0		RidPrefixRisingEdgeEvent		49169		Event name:	
Hardware interrupt		0		Rising edge17		Rising edge17		Channel number	
HwEventTypeRisingEdge		1							
Input 0 - 31\Inputs\Channel 16-23\Channel 17\Hardware interrupts\									
Enable falling edge detection		0		RidPrefixFallingEdgeEvent		49297		Event name:	
Hardware interrupt		0		Falling edge17		Falling edge17		Channel number	
HwEventTypeFallingEdge		2							
Input 0 - 31\Inputs\Channel 16-23\Channel 18									
Parameter settings		From template							
Input 0 - 31\Inputs\Channel 16-23\Channel 18\Diagnostics									
No supply voltage L+		False		Wire break		False			
Input 0 - 31\Inputs\Channel 16-23\Channel 18\Input parameters									
Input delay		3.2ms							
Input 0 - 31\Inputs\Channel 16-23\Channel 18\Hardware interrupts\									
Enable rising edge detection		0		RidPrefixRisingEdgeEvent		49170		Event name:	
Hardware interrupt		0		Rising edge18		Rising edge18		Channel number	
HwEventTypeRisingEdge		1							
Input 0 - 31\Inputs\Channel 16-23\Channel 18\Hardware interrupts\									
Enable falling edge detection		0		RidPrefixFallingEdgeEvent		49298		Event name:	
Hardware interrupt		0		Falling edge18		Falling edge18		Channel number	
HwEventTypeFallingEdge		2							
Input 0 - 31\Inputs\Channel 16-23\Channel 19									
Parameter settings		From template							
Input 0 - 31\Inputs\Channel 16-23\Channel 19\Diagnostics									
No supply voltage L+		False		Wire break		False			
Input 0 - 31\Inputs\Channel 16-23\Channel 19\Input parameters									
Input delay		3.2ms							
Input 0 - 31\Inputs\Channel 16-23\Channel 19\Hardware interrupts\									
Enable rising edge detection		0		RidPrefixRisingEdgeEvent		49171		Event name:	
Hardware interrupt		0		Rising edge19		Rising edge19		Channel number	
HwEventTypeRisingEdge		1							
Input 0 - 31\Inputs\Channel 16-23\Channel 19\Hardware interrupts\									
Enable falling edge detection		0		RidPrefixFallingEdgeEvent		49299		Event name:	
Hardware interrupt		0		Falling edge19		Falling edge19		Channel number	
HwEventTypeFallingEdge		2							
Input 0 - 31\Inputs\Channel 16-23\Channel 20									
Parameter settings		From template							
Input 0 - 31\Inputs\Channel 16-23\Channel 20\Diagnostics									
No supply voltage L+		False		Wire break		False			
Input 0 - 31\Inputs\Channel 16-23\Channel 20\Input parameters									
Input delay		3.2ms							
Input 0 - 31\Inputs\Channel 16-23\Channel 20\Hardware interrupts\									
Enable rising edge detection		0		RidPrefixRisingEdgeEvent		49172		Event name:	
Hardware interrupt		0		Rising edge20		Rising edge20		Channel number	
HwEventTypeRisingEdge		1							
Input 0 - 31\Inputs\Channel 16-23\Channel 20\Hardware interrupts\									
Enable falling edge detection		0		RidPrefixFallingEdgeEvent		49300		Event name:	
Hardware interrupt		0		Falling edge20		Falling edge20		Channel number	

Totally Integrated Automation Portal									
HwEventTypeFallingEdge	2								
Input 0 - 31\Inputs\Channel 16-23\Channel 21									
Parameter settings	From template								
Input 0 - 31\Inputs\Channel 16-23\Channel 21\Diagnostics									
No supply voltage L+	False		Wire break	False					
Input 0 - 31\Inputs\Channel 16-23\Channel 21\Input parameters									
Input delay	3.2ms								
Input 0 - 31\Inputs\Channel 16-23\Channel 21\Hardware interrupts\									
Enable rising edge detection	0		RidPrefixRisingEdgeEvent	49173		Event name:			
Hardware interrupt	0		Rising edge21	Rising edge21		Channel number	21		
HwEventTypeRisingEdge	1								
Input 0 - 31\Inputs\Channel 16-23\Channel 21\Hardware interrupts\									
Enable falling edge detection	0		RidPrefixFallingEdgeEvent	49301		Event name:			
Hardware interrupt	0		Falling edge21	Falling edge21		Channel number	21		
HwEventTypeFallingEdge	2								
Input 0 - 31\Inputs\Channel 16-23\Channel 22									
Parameter settings	From template								
Input 0 - 31\Inputs\Channel 16-23\Channel 22\Diagnostics									
No supply voltage L+	False		Wire break	False					
Input 0 - 31\Inputs\Channel 16-23\Channel 22\Input parameters									
Input delay	3.2ms								
Input 0 - 31\Inputs\Channel 16-23\Channel 22\Hardware interrupts\									
Enable rising edge detection	0		RidPrefixRisingEdgeEvent	49174		Event name:			
Hardware interrupt	0		Rising edge22	Rising edge22		Channel number	22		
HwEventTypeRisingEdge	1								
Input 0 - 31\Inputs\Channel 16-23\Channel 22\Hardware interrupts\									
Enable falling edge detection	0		RidPrefixFallingEdgeEvent	49302		Event name:			
Hardware interrupt	0		Falling edge22	Falling edge22		Channel number	22		
HwEventTypeFallingEdge	2								
Input 0 - 31\Inputs\Channel 16-23\Channel 23									
Parameter settings	From template								
Input 0 - 31\Inputs\Channel 16-23\Channel 23\Diagnostics									
No supply voltage L+	False		Wire break	False					
Input 0 - 31\Inputs\Channel 16-23\Channel 23\Input parameters									
Input delay	3.2ms								
Input 0 - 31\Inputs\Channel 16-23\Channel 23\Hardware interrupts\									
Enable rising edge detection	0		RidPrefixRisingEdgeEvent	49175		Event name:			
Hardware interrupt	0		Rising edge23	Rising edge23		Channel number	23		
HwEventTypeRisingEdge	1								
Input 0 - 31\Inputs\Channel 16-23\Channel 23\Hardware interrupts\									
Enable falling edge detection	0		RidPrefixFallingEdgeEvent	49303		Event name:			
Hardware interrupt	0		Falling edge23	Falling edge23		Channel number	23		
HwEventTypeFallingEdge	2								
Input 0 - 31\Inputs\Channel 24-31\Channel 24									
Parameter settings	From template								
Input 0 - 31\Inputs\Channel 24-31\Channel 24\Diagnostics									
No supply voltage L+	False		Wire break	False					
Input 0 - 31\Inputs\Channel 24-31\Channel 24\Input parameters									
Input delay	3.2ms								
Input 0 - 31\Inputs\Channel 24-31\Channel 24\Hardware interrupts\									
Enable rising edge detection	0		RidPrefixRisingEdgeEvent	49176		Event name:			
Hardware interrupt	0		Rising edge24	Rising edge24		Channel number	24		
HwEventTypeRisingEdge	1								
Input 0 - 31\Inputs\Channel 24-31\Channel 24\Hardware interrupts\									
Enable falling edge detection	0		RidPrefixFallingEdgeEvent	49304		Event name:			
Hardware interrupt	0		Falling edge24	Falling edge24		Channel number	24		
HwEventTypeFallingEdge	2								
Input 0 - 31\Inputs\Channel 24-31\Channel 25									
Parameter settings	From template								
Input 0 - 31\Inputs\Channel 24-31\Channel 25\Diagnostics									
No supply voltage L+	False		Wire break	False					
Input 0 - 31\Inputs\Channel 24-31\Channel 25\Input parameters									
Input delay	3.2ms								
Input 0 - 31\Inputs\Channel 24-31\Channel 25\Hardware interrupts\									
Enable rising edge detection	0		RidPrefixRisingEdgeEvent	49177		Event name:			
Hardware interrupt	0		Rising edge25	Rising edge25		Channel number	25		
HwEventTypeRisingEdge	1								
Input 0 - 31\Inputs\Channel 24-31\Channel 25\Hardware interrupts\									
Enable falling edge detection	0		RidPrefixFallingEdgeEvent	49305		Event name:			

Totally Integrated Automation Portal									
Hardware interrupt	0	Falling edge25	Falling edge25	Channel number	25				
HwEventTypeFallingEdge	2								
Input 0 - 31\Inputs\Channel 24-31\Channel 26									
Parameter settings	From template								
Input 0 - 31\Inputs\Channel 24-31\Channel 26\Diagnostics									
No supply voltage L+	False	Wire break	False						
Input 0 - 31\Inputs\Channel 24-31\Channel 26\Input parameters									
Input delay	3.2ms								
Input 0 - 31\Inputs\Channel 24-31\Channel 26\Hardware interrupts\									
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49178	Event name:					
Hardware interrupt	0	Rising edge26	Rising edge26	Channel number	26				
HwEventTypeRisingEdge	1								
Input 0 - 31\Inputs\Channel 24-31\Channel 26\Hardware interrupts\									
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49306	Event name:					
Hardware interrupt	0	Falling edge26	Falling edge26	Channel number	26				
HwEventTypeFallingEdge	2								
Input 0 - 31\Inputs\Channel 24-31\Channel 27									
Parameter settings	From template								
Input 0 - 31\Inputs\Channel 24-31\Channel 27\Diagnostics									
No supply voltage L+	False	Wire break	False						
Input 0 - 31\Inputs\Channel 24-31\Channel 27\Input parameters									
Input delay	3.2ms								
Input 0 - 31\Inputs\Channel 24-31\Channel 27\Hardware interrupts\									
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49179	Event name:					
Hardware interrupt	0	Rising edge27	Rising edge27	Channel number	27				
HwEventTypeRisingEdge	1								
Input 0 - 31\Inputs\Channel 24-31\Channel 27\Hardware interrupts\									
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49307	Event name:					
Hardware interrupt	0	Falling edge27	Falling edge27	Channel number	27				
HwEventTypeFallingEdge	2								
Input 0 - 31\Inputs\Channel 24-31\Channel 28									
Parameter settings	From template								
Input 0 - 31\Inputs\Channel 24-31\Channel 28\Diagnostics									
No supply voltage L+	False	Wire break	False						
Input 0 - 31\Inputs\Channel 24-31\Channel 28\Input parameters									
Input delay	3.2ms								
Input 0 - 31\Inputs\Channel 24-31\Channel 28\Hardware interrupts\									
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49180	Event name:					
Hardware interrupt	0	Rising edge28	Rising edge28	Channel number	28				
HwEventTypeRisingEdge	1								
Input 0 - 31\Inputs\Channel 24-31\Channel 28\Hardware interrupts\									
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49308	Event name:					
Hardware interrupt	0	Falling edge28	Falling edge28	Channel number	28				
HwEventTypeFallingEdge	2								
Input 0 - 31\Inputs\Channel 24-31\Channel 29									
Parameter settings	From template								
Input 0 - 31\Inputs\Channel 24-31\Channel 29\Diagnostics									
No supply voltage L+	False	Wire break	False						
Input 0 - 31\Inputs\Channel 24-31\Channel 29\Input parameters									
Input delay	3.2ms								
Input 0 - 31\Inputs\Channel 24-31\Channel 29\Hardware interrupts\									
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49181	Event name:					
Hardware interrupt	0	Rising edge29	Rising edge29	Channel number	29				
HwEventTypeRisingEdge	1								
Input 0 - 31\Inputs\Channel 24-31\Channel 29\Hardware interrupts\									
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49309	Event name:					
Hardware interrupt	0	Falling edge29	Falling edge29	Channel number	29				
HwEventTypeFallingEdge	2								
Input 0 - 31\Inputs\Channel 24-31\Channel 30									
Parameter settings	From template								
Input 0 - 31\Inputs\Channel 24-31\Channel 30\Diagnostics									
No supply voltage L+	False	Wire break	False						
Input 0 - 31\Inputs\Channel 24-31\Channel 30\Input parameters									
Input delay	3.2ms								
Input 0 - 31\Inputs\Channel 24-31\Channel 30\Hardware interrupts\									
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49182	Event name:					
Hardware interrupt	0	Rising edge30	Rising edge30	Channel number	30				
HwEventTypeRisingEdge	1								

Totally Integrated Automation Portal						
Input 0 - 31\Inputs\Channel 24-31\Channel 30\Hardware interrupts\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49310	Event name:		
Hardware interrupt	0	Falling edge30	Falling edge30	Channel number	30	
HwEventTypeFallingEdge	2					
Input 0 - 31\Inputs\Channel 24-31\Channel 31						
Parameter settings	From template					
Input 0 - 31\Inputs\Channel 24-31\Channel 31\Diagnostics						
No supply voltage L+	False	Wire break	False			
Input 0 - 31\Inputs\Channel 24-31\Channel 31\Input parameters						
Input delay	3.2ms					
Input 0 - 31\Inputs\Channel 24-31\Channel 31\Hardware interrupts\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49183	Event name:		
Hardware interrupt	0	Rising edge31	Rising edge31	Channel number	31	
HwEventTypeRisingEdge	1					
Input 0 - 31\Inputs\Channel 24-31\Channel 31\Hardware interrupts\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49311	Event name:		
Hardware interrupt	0	Falling edge31	Falling edge31	Channel number	31	
HwEventTypeFallingEdge	2					
Input 0 - 31\I/O addresses\Input addresses						
Start address	16.0	End address	19.7	Isochronous mode	False	
Organization block	0	Process image	0			

Totally Integrated Automation Portal																																																																																																																																																																																																																																																																														
<div>Proyecto_final / PLC_1 [CPU 1516-3 PN/DP] / Local modules</div> <div>DQ 32x24VDC/0.5A HF_1</div> <div><div>DQ 32x24VDC/0.5A HF_1</div><div><div>General\Project information</div><table><tr><td>Name</td><td>DQ 32x24VDC/0.5A HF_1</td><td>Author</td><td>192072</td><td>Comment</td><td></td></tr><tr><td>Rack</td><td>0</td><td>Slot</td><td>5</td><td colspan="2"></td></tr></table><div>General\Catalog information</div><table><tr><td>Short designation</td><td>DQ 32x24VDC/0.5A HF</td><td>Description</td><td>Digital output module DQ32 x DC24V / 0,5A; grouping 8; 4A per group; configurable diagnostics; configurable substitute value for output; isochronous mode; switching cycle counter</td><td>Article number</td><td>6ES7 522-1BL01-0AB0</td></tr><tr><td>Firmware version</td><td>V1.1</td><td colspan="4"></td></tr></table><div>General\Identification & Maintenance</div><table><tr><td>Plant designation</td><td></td><td>Location identifier</td><td></td><td>Installation date</td><td>2025-05-01 19:28:00.438</td></tr><tr><td>Additional information</td><td></td><td colspan="4"></td></tr></table><div>Module parameters\General\Startup</div><table><tr><td>Comparison preset to actual module</td><td>From CPU</td><td colspan="4"></td></tr></table><div>Module parameters\Channel template\Outputs\Apply to all channels that use the template\Diagnostics</div><table><tr><td>No supply voltage L+</td><td>False</td><td>Wire break</td><td>False</td><td>Short circuit to ground</td><td>False</td></tr><tr><td>Maintenance switching cycles</td><td>False</td><td colspan="4"></td></tr></table><div>Module parameters\Channel template\Outputs\Apply to all channels that use the template\Output parameters</div><table><tr><td>Reaction to CPU STOP</td><td>Shutdown</td><td>Switching cycle counter</td><td>False</td><td>Switching cycle limit</td><td></td></tr></table><div>Module parameters\DQ configuration\Configuration of submodules</div><table><tr><td>Module distribution</td><td>None</td><td colspan="4"></td></tr></table><div>Module parameters\DQ configuration\Value status (Quality Information)</div><table><tr><td>Value status</td><td>False</td><td colspan="4"></td></tr></table><div>Module parameters\DQ configuration\Copy of module for shared device (MSO)</div><table><tr><td>Copy of module:</td><td>None</td><td colspan="4"></td></tr></table><div>Output 0 - 31\General</div><table><tr><td>Name</td><td>DQ 32x24VDC/0.5A HF_1</td><td>Comment</td><td></td><td colspan="2"></td></tr></table><div>Output 0 - 31\Outputs\Channel 0 - 7\Channel 0</div><table><tr><td>Parameter settings</td><td>From template</td><td colspan="4"></td></tr><tr><td colspan="6">Output 0 - 31\Outputs\Channel 0 - 7\Channel 0\Diagnostics</td></tr><tr><td>No supply voltage L+</td><td>False</td><td>Wire break</td><td>False</td><td>Short circuit to ground</td><td>False</td></tr><tr><td>Maintenance switching cycles</td><td>False</td><td colspan="4"></td></tr><tr><td colspan="6">Output 0 - 31\Outputs\Channel 0 - 7\Channel 0\Output parameters</td></tr><tr><td>Reaction to CPU STOP</td><td>Shutdown</td><td>Switching cycle counter</td><td>False</td><td>Switching cycle limit</td><td></td></tr></table><div>Output 0 - 31\Outputs\Channel 0 - 7\Channel 1</div><table><tr><td>Parameter settings</td><td>From template</td><td colspan="4"></td></tr><tr><td colspan="6">Output 0 - 31\Outputs\Channel 0 - 7\Channel 1\Diagnostics</td></tr><tr><td>No supply voltage L+</td><td>False</td><td>Wire break</td><td>False</td><td>Short circuit to ground</td><td>False</td></tr><tr><td>Maintenance switching cycles</td><td>False</td><td colspan="4"></td></tr><tr><td colspan="6">Output 0 - 31\Outputs\Channel 0 - 7\Channel 1\Output parameters</td></tr><tr><td>Reaction to CPU STOP</td><td>Shutdown</td><td>Switching cycle counter</td><td>False</td><td>Switching cycle limit</td><td></td></tr></table><div>Output 0 - 31\Outputs\Channel 0 - 7\Channel 2</div><table><tr><td>Parameter settings</td><td>From template</td><td colspan="4"></td></tr><tr><td colspan="6">Output 0 - 31\Outputs\Channel 0 - 7\Channel 2\Diagnostics</td></tr><tr><td>No supply voltage L+</td><td>False</td><td>Wire break</td><td>False</td><td>Short circuit to ground</td><td>False</td></tr><tr><td>Maintenance switching cycles</td><td>False</td><td colspan="4"></td></tr><tr><td colspan="6">Output 0 - 31\Outputs\Channel 0 - 7\Channel 2\Output parameters</td></tr><tr><td>Reaction to CPU STOP</td><td>Shutdown</td><td>Switching cycle counter</td><td>False</td><td>Switching cycle limit</td><td></td></tr></table><div>Output 0 - 31\Outputs\Channel 0 - 7\Channel 3</div><table><tr><td>Parameter settings</td><td>From template</td><td colspan="4"></td></tr><tr><td colspan="6">Output 0 - 31\Outputs\Channel 0 - 7\Channel 3\Diagnostics</td></tr><tr><td>No supply voltage L+</td><td>False</td><td>Wire break</td><td>False</td><td>Short circuit to ground</td><td>False</td></tr><tr><td>Maintenance switching cycles</td><td>False</td><td colspan="4"></td></tr><tr><td colspan="6">Output 0 - 31\Outputs\Channel 0 - 7\Channel 3\Output parameters</td></tr><tr><td>Reaction to CPU STOP</td><td>Shutdown</td><td>Switching cycle counter</td><td>False</td><td>Switching cycle limit</td><td></td></tr></table><div>Output 0 - 31\Outputs\Channel 0 - 7\Channel 4</div><table><tr><td>Parameter settings</td><td>From template</td><td colspan="4"></td></tr><tr><td colspan="6">Output 0 - 31\Outputs\Channel 0 - 7\Channel 4\Diagnostics</td></tr><tr><td>No supply voltage L+</td><td>False</td><td>Wire break</td><td>False</td><td>Short circuit to ground</td><td>False</td></tr><tr><td>Maintenance switching cycles</td><td>False</td><td colspan="4"></td></tr><tr><td colspan="6">Output 0 - 31\Outputs\Channel 0 - 7\Channel 4\Output parameters</td></tr><tr><td>Reaction to CPU STOP</td><td>Shutdown</td><td>Switching cycle counter</td><td>False</td><td>Switching cycle limit</td><td></td></tr></table></div></div>							Name	DQ 32x24VDC/0.5A HF_1	Author	192072	Comment		Rack	0	Slot	5			Short designation	DQ 32x24VDC/0.5A HF	Description	Digital output module DQ32 x DC24V / 0,5A; grouping 8; 4A per group; configurable diagnostics; configurable substitute value for output; isochronous mode; switching cycle counter	Article number	6ES7 522-1BL01-0AB0	Firmware version	V1.1					Plant designation		Location identifier		Installation date	2025-05-01 19:28:00.438	Additional information						Comparison preset to actual module	From CPU					No supply voltage L+	False	Wire break	False	Short circuit to ground	False	Maintenance switching cycles	False					Reaction to CPU STOP	Shutdown	Switching cycle counter	False	Switching cycle limit		Module distribution	None					Value status	False					Copy of module:	None					Name	DQ 32x24VDC/0.5A HF_1	Comment				Parameter settings	From template					Output 0 - 31\Outputs\Channel 0 - 7\Channel 0\Diagnostics						No supply voltage L+	False	Wire break	False	Short circuit to ground	False	Maintenance switching cycles	False					Output 0 - 31\Outputs\Channel 0 - 7\Channel 0\Output parameters						Reaction to CPU STOP	Shutdown	Switching cycle counter	False	Switching cycle limit		Parameter settings	From template					Output 0 - 31\Outputs\Channel 0 - 7\Channel 1\Diagnostics						No supply voltage L+	False	Wire break	False	Short circuit to ground	False	Maintenance switching cycles	False					Output 0 - 31\Outputs\Channel 0 - 7\Channel 1\Output parameters						Reaction to CPU STOP	Shutdown	Switching cycle counter	False	Switching cycle limit		Parameter settings	From template					Output 0 - 31\Outputs\Channel 0 - 7\Channel 2\Diagnostics						No supply voltage L+	False	Wire break	False	Short circuit to ground	False	Maintenance switching cycles	False					Output 0 - 31\Outputs\Channel 0 - 7\Channel 2\Output parameters						Reaction to CPU STOP	Shutdown	Switching cycle counter	False	Switching cycle limit		Parameter settings	From template					Output 0 - 31\Outputs\Channel 0 - 7\Channel 3\Diagnostics						No supply voltage L+	False	Wire break	False	Short circuit to ground	False	Maintenance switching cycles	False					Output 0 - 31\Outputs\Channel 0 - 7\Channel 3\Output parameters						Reaction to CPU STOP	Shutdown	Switching cycle counter	False	Switching cycle limit		Parameter settings	From template					Output 0 - 31\Outputs\Channel 0 - 7\Channel 4\Diagnostics						No supply voltage L+	False	Wire break	False	Short circuit to ground	False	Maintenance switching cycles	False					Output 0 - 31\Outputs\Channel 0 - 7\Channel 4\Output parameters						Reaction to CPU STOP	Shutdown	Switching cycle counter	False	Switching cycle limit	
Name	DQ 32x24VDC/0.5A HF_1	Author	192072	Comment																																																																																																																																																																																																																																																																										
Rack	0	Slot	5																																																																																																																																																																																																																																																																											
Short designation	DQ 32x24VDC/0.5A HF	Description	Digital output module DQ32 x DC24V / 0,5A; grouping 8; 4A per group; configurable diagnostics; configurable substitute value for output; isochronous mode; switching cycle counter	Article number	6ES7 522-1BL01-0AB0																																																																																																																																																																																																																																																																									
Firmware version	V1.1																																																																																																																																																																																																																																																																													
Plant designation		Location identifier		Installation date	2025-05-01 19:28:00.438																																																																																																																																																																																																																																																																									
Additional information																																																																																																																																																																																																																																																																														
Comparison preset to actual module	From CPU																																																																																																																																																																																																																																																																													
No supply voltage L+	False	Wire break	False	Short circuit to ground	False																																																																																																																																																																																																																																																																									
Maintenance switching cycles	False																																																																																																																																																																																																																																																																													
Reaction to CPU STOP	Shutdown	Switching cycle counter	False	Switching cycle limit																																																																																																																																																																																																																																																																										
Module distribution	None																																																																																																																																																																																																																																																																													
Value status	False																																																																																																																																																																																																																																																																													
Copy of module:	None																																																																																																																																																																																																																																																																													
Name	DQ 32x24VDC/0.5A HF_1	Comment																																																																																																																																																																																																																																																																												
Parameter settings	From template																																																																																																																																																																																																																																																																													
Output 0 - 31\Outputs\Channel 0 - 7\Channel 0\Diagnostics																																																																																																																																																																																																																																																																														
No supply voltage L+	False	Wire break	False	Short circuit to ground	False																																																																																																																																																																																																																																																																									
Maintenance switching cycles	False																																																																																																																																																																																																																																																																													
Output 0 - 31\Outputs\Channel 0 - 7\Channel 0\Output parameters																																																																																																																																																																																																																																																																														
Reaction to CPU STOP	Shutdown	Switching cycle counter	False	Switching cycle limit																																																																																																																																																																																																																																																																										
Parameter settings	From template																																																																																																																																																																																																																																																																													
Output 0 - 31\Outputs\Channel 0 - 7\Channel 1\Diagnostics																																																																																																																																																																																																																																																																														
No supply voltage L+	False	Wire break	False	Short circuit to ground	False																																																																																																																																																																																																																																																																									
Maintenance switching cycles	False																																																																																																																																																																																																																																																																													
Output 0 - 31\Outputs\Channel 0 - 7\Channel 1\Output parameters																																																																																																																																																																																																																																																																														
Reaction to CPU STOP	Shutdown	Switching cycle counter	False	Switching cycle limit																																																																																																																																																																																																																																																																										
Parameter settings	From template																																																																																																																																																																																																																																																																													
Output 0 - 31\Outputs\Channel 0 - 7\Channel 2\Diagnostics																																																																																																																																																																																																																																																																														
No supply voltage L+	False	Wire break	False	Short circuit to ground	False																																																																																																																																																																																																																																																																									
Maintenance switching cycles	False																																																																																																																																																																																																																																																																													
Output 0 - 31\Outputs\Channel 0 - 7\Channel 2\Output parameters																																																																																																																																																																																																																																																																														
Reaction to CPU STOP	Shutdown	Switching cycle counter	False	Switching cycle limit																																																																																																																																																																																																																																																																										
Parameter settings	From template																																																																																																																																																																																																																																																																													
Output 0 - 31\Outputs\Channel 0 - 7\Channel 3\Diagnostics																																																																																																																																																																																																																																																																														
No supply voltage L+	False	Wire break	False	Short circuit to ground	False																																																																																																																																																																																																																																																																									
Maintenance switching cycles	False																																																																																																																																																																																																																																																																													
Output 0 - 31\Outputs\Channel 0 - 7\Channel 3\Output parameters																																																																																																																																																																																																																																																																														
Reaction to CPU STOP	Shutdown	Switching cycle counter	False	Switching cycle limit																																																																																																																																																																																																																																																																										
Parameter settings	From template																																																																																																																																																																																																																																																																													
Output 0 - 31\Outputs\Channel 0 - 7\Channel 4\Diagnostics																																																																																																																																																																																																																																																																														
No supply voltage L+	False	Wire break	False	Short circuit to ground	False																																																																																																																																																																																																																																																																									
Maintenance switching cycles	False																																																																																																																																																																																																																																																																													
Output 0 - 31\Outputs\Channel 0 - 7\Channel 4\Output parameters																																																																																																																																																																																																																																																																														
Reaction to CPU STOP	Shutdown	Switching cycle counter	False	Switching cycle limit																																																																																																																																																																																																																																																																										

Totally Integrated Automation Portal						
Output 0 - 31\Outputs\Channel 0 - 7\Channel 5						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 0 - 7\Channel 5\Diagnostics						
No supply voltage L+	False		Wire break	False	Short circuit to ground	False
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 0 - 7\Channel 5\Output parameters						
Reaction to CPU STOP	Shutdown		Switching cycle counter	False	Switching cycle limit	
Output 0 - 31\Outputs\Channel 0 - 7\Channel 6						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 0 - 7\Channel 6\Diagnostics						
No supply voltage L+	False		Wire break	False	Short circuit to ground	False
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 0 - 7\Channel 6\Output parameters						
Reaction to CPU STOP	Shutdown		Switching cycle counter	False	Switching cycle limit	
Output 0 - 31\Outputs\Channel 0 - 7\Channel 7						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 0 - 7\Channel 7\Diagnostics						
No supply voltage L+	False		Wire break	False	Short circuit to ground	False
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 0 - 7\Channel 7\Output parameters						
Reaction to CPU STOP	Shutdown		Switching cycle counter	False	Switching cycle limit	
Output 0 - 31\Outputs\Channel 8 - 15\Channel 8						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 8 - 15\Channel 8\Diagnostics						
No supply voltage L+	False		Wire break	False	Short circuit to ground	False
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 8 - 15\Channel 8\Output parameters						
Reaction to CPU STOP	Shutdown		Switching cycle counter	False	Switching cycle limit	
Output 0 - 31\Outputs\Channel 8 - 15\Channel 9						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 8 - 15\Channel 9\Diagnostics						
No supply voltage L+	False		Wire break	False	Short circuit to ground	False
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 8 - 15\Channel 9\Output parameters						
Reaction to CPU STOP	Shutdown		Switching cycle counter	False	Switching cycle limit	
Output 0 - 31\Outputs\Channel 8 - 15\Channel 10						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 8 - 15\Channel 10\Diagnostics						
No supply voltage L+	False		Wire break	False	Short circuit to ground	False
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 8 - 15\Channel 10\Output parameters						
Reaction to CPU STOP	Shutdown		Switching cycle counter	False	Switching cycle limit	
Output 0 - 31\Outputs\Channel 8 - 15\Channel 11						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 8 - 15\Channel 11\Diagnostics						
No supply voltage L+	False		Wire break	False	Short circuit to ground	False
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 8 - 15\Channel 11\Output parameters						
Reaction to CPU STOP	Shutdown		Switching cycle counter	False	Switching cycle limit	
Output 0 - 31\Outputs\Channel 8 - 15\Channel 12						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 8 - 15\Channel 12\Diagnostics						
No supply voltage L+	False		Wire break	False	Short circuit to ground	False
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 8 - 15\Channel 12\Output parameters						
Reaction to CPU STOP	Shutdown		Switching cycle counter	False	Switching cycle limit	
Output 0 - 31\Outputs\Channel 8 - 15\Channel 13						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 8 - 15\Channel 13\Diagnostics						
No supply voltage L+	False		Wire break	False	Short circuit to ground	False
Maintenance switching cycles	False					

Totally Integrated Automation Portal						
Output 0 - 31\Outputs\Channel 8 - 15\Channel 13\Output parameters						
Reaction to CPU STOP	Shutdown		Switching cycle counter	False	Switching cycle limit	
Output 0 - 31\Outputs\Channel 8 - 15\Channel 14						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 8 - 15\Channel 14\Diagnostics						
No supply voltage L+	False		Wire break	False	Short circuit to ground	False
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 8 - 15\Channel 14\Output parameters						
Reaction to CPU STOP	Shutdown		Switching cycle counter	False	Switching cycle limit	
Output 0 - 31\Outputs\Channel 8 - 15\Channel 15						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 8 - 15\Channel 15\Diagnostics						
No supply voltage L+	False		Wire break	False	Short circuit to ground	False
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 8 - 15\Channel 15\Output parameters						
Reaction to CPU STOP	Shutdown		Switching cycle counter	False	Switching cycle limit	
Output 0 - 31\Outputs\Channel 16 - 23\Channel 16						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 16 - 23\Channel 16\Diagnostics						
No supply voltage L+	False		Wire break	False	Short circuit to ground	False
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 16 - 23\Channel 16\Output parameters						
Reaction to CPU STOP	Shutdown		Switching cycle counter	False	Switching cycle limit	
Output 0 - 31\Outputs\Channel 16 - 23\Channel 17						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 16 - 23\Channel 17\Diagnostics						
No supply voltage L+	False		Wire break	False	Short circuit to ground	False
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 16 - 23\Channel 17\Output parameters						
Reaction to CPU STOP	Shutdown		Switching cycle counter	False	Switching cycle limit	
Output 0 - 31\Outputs\Channel 16 - 23\Channel 18						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 16 - 23\Channel 18\Diagnostics						
No supply voltage L+	False		Wire break	False	Short circuit to ground	False
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 16 - 23\Channel 18\Output parameters						
Reaction to CPU STOP	Shutdown		Switching cycle counter	False	Switching cycle limit	
Output 0 - 31\Outputs\Channel 16 - 23\Channel 19						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 16 - 23\Channel 19\Diagnostics						
No supply voltage L+	False		Wire break	False	Short circuit to ground	False
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 16 - 23\Channel 19\Output parameters						
Reaction to CPU STOP	Shutdown		Switching cycle counter	False	Switching cycle limit	
Output 0 - 31\Outputs\Channel 16 - 23\Channel 20						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 16 - 23\Channel 20\Diagnostics						
No supply voltage L+	False		Wire break	False	Short circuit to ground	False
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 16 - 23\Channel 20\Output parameters						
Reaction to CPU STOP	Shutdown		Switching cycle counter	False	Switching cycle limit	
Output 0 - 31\Outputs\Channel 16 - 23\Channel 21						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 16 - 23\Channel 21\Diagnostics						
No supply voltage L+	False		Wire break	False	Short circuit to ground	False
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 16 - 23\Channel 21\Output parameters						
Reaction to CPU STOP	Shutdown		Switching cycle counter	False	Switching cycle limit	
Output 0 - 31\Outputs\Channel 16 - 23\Channel 22						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 16 - 23\Channel 22\Diagnostics						
No supply voltage L+	False		Wire break	False	Short circuit to ground	False

Totally Integrated Automation Portal						
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 16 - 23\Channel 22\Output parameters						
Reaction to CPU STOP	Shutdown	Switching cycle counter	False	Switching cycle limit		
Output 0 - 31\Outputs\Channel 16 - 23\Channel 23						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 16 - 23\Channel 23\Diagnostics						
No supply voltage L+	False	Wire break	False	Short circuit to ground	False	
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 16 - 23\Channel 23\Output parameters						
Reaction to CPU STOP	Shutdown	Switching cycle counter	False	Switching cycle limit		
Output 0 - 31\Outputs\Channel 24 - 31\Channel 24						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 24 - 31\Channel 24\Diagnostics						
No supply voltage L+	False	Wire break	False	Short circuit to ground	False	
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 24 - 31\Channel 24\Output parameters						
Reaction to CPU STOP	Shutdown	Switching cycle counter	False	Switching cycle limit		
Output 0 - 31\Outputs\Channel 24 - 31\Channel 25						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 24 - 31\Channel 25\Diagnostics						
No supply voltage L+	False	Wire break	False	Short circuit to ground	False	
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 24 - 31\Channel 25\Output parameters						
Reaction to CPU STOP	Shutdown	Switching cycle counter	False	Switching cycle limit		
Output 0 - 31\Outputs\Channel 24 - 31\Channel 26						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 24 - 31\Channel 26\Diagnostics						
No supply voltage L+	False	Wire break	False	Short circuit to ground	False	
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 24 - 31\Channel 26\Output parameters						
Reaction to CPU STOP	Shutdown	Switching cycle counter	False	Switching cycle limit		
Output 0 - 31\Outputs\Channel 24 - 31\Channel 27						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 24 - 31\Channel 27\Diagnostics						
No supply voltage L+	False	Wire break	False	Short circuit to ground	False	
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 24 - 31\Channel 27\Output parameters						
Reaction to CPU STOP	Shutdown	Switching cycle counter	False	Switching cycle limit		
Output 0 - 31\Outputs\Channel 24 - 31\Channel 28						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 24 - 31\Channel 28\Diagnostics						
No supply voltage L+	False	Wire break	False	Short circuit to ground	False	
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 24 - 31\Channel 28\Output parameters						
Reaction to CPU STOP	Shutdown	Switching cycle counter	False	Switching cycle limit		
Output 0 - 31\Outputs\Channel 24 - 31\Channel 29						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 24 - 31\Channel 29\Diagnostics						
No supply voltage L+	False	Wire break	False	Short circuit to ground	False	
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 24 - 31\Channel 29\Output parameters						
Reaction to CPU STOP	Shutdown	Switching cycle counter	False	Switching cycle limit		
Output 0 - 31\Outputs\Channel 24 - 31\Channel 30						
Parameter settings	From template					
Output 0 - 31\Outputs\Channel 24 - 31\Channel 30\Diagnostics						
No supply voltage L+	False	Wire break	False	Short circuit to ground	False	
Maintenance switching cycles	False					
Output 0 - 31\Outputs\Channel 24 - 31\Channel 30\Output parameters						
Reaction to CPU STOP	Shutdown	Switching cycle counter	False	Switching cycle limit		
Output 0 - 31\Outputs\Channel 24 - 31\Channel 31						
Parameter settings	From template					

Totally Integrated Automation Portal							
Output 0 - 31\OutputsChannel 24 - 31\Channel 31\Diagnostics							
No supply voltage L+	False		Wire break	False		Short circuit to ground	False
Maintenance switching cycles	False						
Output 0 - 31\OutputsChannel 24 - 31\Channel 31\Output parameters							
Reaction to CPU STOP	Shutdown		Switching cycle counter	False		Switching cycle limit	
Output 0 - 31\I/O addresses\Output addresses							
Start address	8.0		End address	11.7		Isochronous mode	False
Organization block	0		Process image	0			

Totally Integrated Automation Portal						
--------------------------------------	--	--	--	--	--	--

Proyecto_final



PLC_2 [CPU 1215C DC/DC/DC]

PLC_2					
General\Project information					
Name	PLC_2	Author	192072	Comment	
Slot	1	Rack	0		
General\Catalog information					
Short designation	CPU 1215C DC/DC/DC	Description	Work memory 125 KB; 24VDC power supply with DI14 x 24VDC SINK/ SOURCE, DQ10 x 24VDC and AI2 and AQ2 on board; 6 high-speed counters and 4 pulse outputs on board; signal board expands on-board I/O; up to 3 communication modules for serial communication; up to 8 signal modules for I/O expansion; 0.04 ms/1000 instructions; 2 PROFINET ports for programming, HMI and PLC-to-PLC communication	Article number	6ES7 215-1AG40-0XB0
Firmware version	V4.2				
General\Identification & Maintenance					
Plant designation		Location identifier		Installation date	2025-05-01 19:29:36.425
Additional information					
General\Checksums					
Text lists	FA 70 E8 75 1D 5A 8E 29	Software	11 2B 3B 85 C7 CB 83 E7		
PROFINET interface [X1]\General					
Name	PROFINET interface_1	Author	192072	Comment	
PROFINET interface [X1]\General\Project information					
Name	DI 14/DQ 10_1	Comment		Name	AI 2/AQ 2_1
Comment					
PROFINET interface [X1]\Ethernet addresses\Interface networked with					
Subnet:	PN/IE_1				
PROFINET interface [X1]\Ethernet addresses\IP protocol					
IP configuration	Set IP address in the project	IP address:	192.168.0.2	Subnet mask:	255.255.255.0
Use router	False				
PROFINET interface [X1]\Ethernet addresses\PROFINET					
PROFINET device name is set directly at the device	False	Generate PROFINET device name automatically	True	PROFINET device name:	plc_2
Converted name:	plcxb2d1ad	Device number:	0		
PROFINET interface [X1]\Time synchronization					
Enable time synchronization via NTP server	Enable time synchronization via NTP server		IP addresses	Server 1	0.0.0.0
Server 2	0.0.0.0	Server 3	0.0.0.0	Server 4	0.0.0.0
Update interval	10sec	Empty		CPU synchronizes the modules of the device.	No synchronization
PROFINET interface [X1]\Digital inputs\Channel0					
Channel address	I0.0	Input filters	6.4 millisec	Enable pulse catch	0
PROFINET interface [X1]\Digital inputs\Channel0\					
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49152	Event name:	0
Hardware interrupt:	0	Rising edge0	Rising edge0		
PROFINET interface [X1]\Digital inputs\Channel0\					
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49280	Event name:	0
Hardware interrupt:	0	Falling edge0	Falling edge0		
PROFINET interface [X1]\Digital inputs\Channel1					
Channel address	I0.1	Input filters	6.4 millisec	Enable pulse catch	0
PROFINET interface [X1]\Digital inputs\Channel1\					
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49153	Event name:	0
Hardware interrupt:	0	Rising edge1	Rising edge1		
PROFINET interface [X1]\Digital inputs\Channel1\					
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49281	Event name:	0
Hardware interrupt:	0	Falling edge1	Falling edge1		
PROFINET interface [X1]\Digital inputs\Channel2					
Channel address	I0.2	Input filters	6.4 millisec	Enable pulse catch	0
PROFINET interface [X1]\Digital inputs\Channel2\					
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49154	Event name:	0
Hardware interrupt:	0	Rising edge2	Rising edge2		
PROFINET interface [X1]\Digital inputs\Channel2\					
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49282	Event name:	0
Hardware interrupt:	0	Falling edge2	Falling edge2		
PROFINET interface [X1]\Digital inputs\Channel3					
Channel address	I0.3	Input filters	6.4 millisec	Enable pulse catch	0
PROFINET interface [X1]\Digital inputs\Channel3\					
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49155	Event name:	0
Hardware interrupt:	0	Rising edge3	Rising edge3		

--	--	--

Totally Integrated Automation Portal							
PROFINET interface [X1]\Digital inputs\Channel3\							
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49283	Event name:	0		
Hardware interrupt:	0	Falling edge3	Falling edge3				
PROFINET interface [X1]\Digital inputs\Channel4							
Channel address	I0.4	Input filters	6.4 millisec	Enable pulse catch	0		
PROFINET interface [X1]\Digital inputs\Channel4\							
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49156	Event name:	0		
Hardware interrupt:	0	Rising edge4	Rising edge4				
PROFINET interface [X1]\Digital inputs\Channel4\							
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49284	Event name:	0		
Hardware interrupt:	0	Falling edge4	Falling edge4				
PROFINET interface [X1]\Digital inputs\Channel5							
Channel address	I0.5	Input filters	6.4 millisec	Enable pulse catch	0		
PROFINET interface [X1]\Digital inputs\Channel5\							
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49157	Event name:	0		
Hardware interrupt:	0	Rising edge5	Rising edge5				
PROFINET interface [X1]\Digital inputs\Channel5\							
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49285	Event name:	0		
Hardware interrupt:	0	Falling edge5	Falling edge5				
PROFINET interface [X1]\Digital inputs\Channel6							
Channel address	I0.6	Input filters	6.4 millisec	Enable pulse catch	0		
PROFINET interface [X1]\Digital inputs\Channel6\							
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49158	Event name:	0		
Hardware interrupt:	0	Rising edge6	Rising edge6				
PROFINET interface [X1]\Digital inputs\Channel6\							
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49286	Event name:	0		
Hardware interrupt:	0	Falling edge6	Falling edge6				
PROFINET interface [X1]\Digital inputs\Channel7							
Channel address	I0.7	Input filters	6.4 millisec	Enable pulse catch	0		
PROFINET interface [X1]\Digital inputs\Channel7\							
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49159	Event name:	0		
Hardware interrupt:	0	Rising edge7	Rising edge7				
PROFINET interface [X1]\Digital inputs\Channel7\							
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49287	Event name:	0		
Hardware interrupt:	0	Falling edge7	Falling edge7				
PROFINET interface [X1]\Digital inputs\Channel8							
Channel address	I1.0	Input filters	6.4 millisec	Enable pulse catch	0		
PROFINET interface [X1]\Digital inputs\Channel8\							
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49160	Event name:	0		
Hardware interrupt:	0	Rising edge8	Rising edge8				
PROFINET interface [X1]\Digital inputs\Channel8\							
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49288	Event name:	0		
Hardware interrupt:	0	Falling edge8	Falling edge8				
PROFINET interface [X1]\Digital inputs\Channel9							
Channel address	I1.1	Input filters	6.4 millisec	Enable pulse catch	0		
PROFINET interface [X1]\Digital inputs\Channel9\							
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49161	Event name:	0		
Hardware interrupt:	0	Rising edge9	Rising edge9				
PROFINET interface [X1]\Digital inputs\Channel9\							
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49289	Event name:	0		
Hardware interrupt:	0	Falling edge9	Falling edge9				
PROFINET interface [X1]\Digital inputs\Channel10							
Channel address	I1.2	Input filters	6.4 millisec	Enable pulse catch	0		
PROFINET interface [X1]\Digital inputs\Channel10\							
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49162	Event name:	0		
Hardware interrupt:	0	Rising edge10	Rising edge10				
PROFINET interface [X1]\Digital inputs\Channel10\							
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49290	Event name:	0		
Hardware interrupt:	0	Falling edge10	Falling edge10				
PROFINET interface [X1]\Digital inputs\Channel11							
Channel address	I1.3	Input filters	6.4 millisec	Enable pulse catch	0		
PROFINET interface [X1]\Digital inputs\Channel11\							
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49163	Event name:	0		
Hardware interrupt:	0	Rising edge11	Rising edge11				
PROFINET interface [X1]\Digital inputs\Channel11\							
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49291	Event name:	0		
Hardware interrupt:	0	Falling edge11	Falling edge11				
PROFINET interface [X1]\Digital inputs\Channel12							
Channel address	I1.4	Input filters	6.4 millisec	Enable pulse catch	0		
PROFINET interface [X1]\Digital inputs\Channel13							
Channel address	I1.5	Input filters	6.4 millisec	Enable pulse catch	0		

Totally Integrated Automation Portal						
PROFINET interface [X1]\Analog inputs\Noise reduction						
Integration time	50 Hz (20 ms)					
PROFINET interface [X1]\Analog inputs\Channel0						
Channel address	IW64	Measurement type	Voltage	Voltage range	0..10 V	
Smoothing	Weak (4 cycles)	Empty		Enable overflow diagnostics	1	
PROFINET interface [X1]\Analog inputs\Channel1						
Channel address	IW66	Measurement type	Voltage	Voltage range	0..10 V	
Smoothing	Weak (4 cycles)	Empty		Enable overflow diagnostics	1	
PROFINET interface [X1]\Digital outputs						
Reaction to CPU STOP	Use substitute value					
PROFINET interface [X1]\Digital outputs\Channel0						
Channel address	Q0.0	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel1						
Channel address	Q0.1	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel2						
Channel address	Q0.2	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel3						
Channel address	Q0.3	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel4						
Channel address	Q0.4	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel5						
Channel address	Q0.5	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel6						
Channel address	Q0.6	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel7						
Channel address	Q0.7	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel8						
Channel address	Q1.0	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel9						
Channel address	Q1.1	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Operating mode						
IO controller	True	IO system		Device number	0	
IO device	False					
PROFINET interface [X1]\Analog outputs						
Reaction to CPU STOP	Use substitute value					
PROFINET interface [X1]\Analog outputs\Channel0						
Channel address	QW64	Analog output type	Current	Current range	0..20 mA	
Substitute value for channel on a change from RUN to STOP	0.000mA	Empty		Enable overflow diagnostics	1	
Enable underflow diagnostics	1					
PROFINET interface [X1]\Analog outputs\Channel1						
Channel address	QW66	Analog output type	Current	Current range	0..20 mA	
Substitute value for channel on a change from RUN to STOP	0.000mA	Empty		Enable overflow diagnostics	1	
Enable underflow diagnostics	1					
PROFINET interface [X1]\I/O addresses\Input addresses						
Start address	0.0	End address	1.7	Organization block	0	
Process image	0					
PROFINET interface [X1]\I/O addresses\Input addresses						
Start address	64	End address	67	Organization block	0	
Process image	0					
PROFINET interface [X1]\I/O addresses\Output addresses						
Start address	0.0	End address	1.7	Organization block	0	
Process image	0					
PROFINET interface [X1]\I/O addresses\Output addresses						
Start address	64	End address	67	Organization block	0	
Process image	0					
PROFINET interface [X1]\Advanced options\Interface options						
Support device replacement without exchangeable medium	True	Permit overwriting of device names of all assigned IO devices	False	Use IEC V2.2 LLDP mode	False	
Keep-Alive connection monitoring:	30s					

Totally Integrated Automation Portal						
PROFINET interface [X1]\Advanced options\Real time settings\IO communication						
Send clock:	1.000ms					
PROFINET interface [X1]\Advanced options\Real time settings\Real time options						
Calculated bandwidth for cyclic IO data:	0.000ms		Calculated bandwidth for cyclic IO data:	0.000%		
PROFINET interface [X1]\Advanced options\Port [X1 P1]\General						
Name	Port_1		Author	192072		Comment
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port interconnection\Local port:						
Local port:	PLC_2\PROFINET interface_1 [X1]\Port_1 [X1 P1 R]		Medium:	Copper		Cable name: ---
						
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port interconnection\Partner port:						
	Monitoring of partner port is executed		Partner port:	HMI_2.IE_CP_1\PROFINET Interface_1 [X1]\Port_1 [X1 P1]		Medium: Copper
Cable length:						
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port options\Activate						
Activate this port for use	True					
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port options\Connection						
Transmission rate / duplex:	Automatic		Monitor	False		Enable autonegotiation True
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port options\Boundaries						
End of detection of accessible devices	False		End of topology discovery	False		End of the sync domain False
PROFINET interface [X1]\Advanced options\Port [X1 P2]\General						
Name	Port_2		Author	192072		Comment
PROFINET interface [X1]\Advanced options\Port [X1 P2]\Port interconnection\Local port:						
Local port:	PLC_2\PROFINET interface_1 [X1]\Port_2 [X1 P2 R]		Medium:	Copper		Cable name: ---
						
PROFINET interface [X1]\Advanced options\Port [X1 P2]\Port interconnection\Partner port:						
	Monitoring of partner port is not possible		Partner port:	Switch_1\SCALANCE interface_1 [X1]\Port_3 [X1 P3]		Medium: Copper
Cable length:						
PROFINET interface [X1]\Advanced options\Port [X1 P2]\Port options\Activate						
Activate this port for use	True					
PROFINET interface [X1]\Advanced options\Port [X1 P2]\Port options\Connection						
Transmission rate / duplex:	Automatic		Monitor	False		Enable autonegotiation True
PROFINET interface [X1]\Advanced options\Port [X1 P2]\Port options\Boundaries						
End of detection of accessible devices	False		End of topology discovery	False		End of the sync domain False
PROFINET interface [X1]\Web server access						
Enable Web server using this interface	False		The Web server must also be activated in the properties of the PLC.			
High speed counters (HSC)\HSC1\General\Enable						
Enable this high speed counter	0		Enable this high speed counter	0		Enable this high speed counter 0
Enable this high speed counter	0		Enable this high speed counter	0		Enable this high speed counter 0
High speed counters (HSC)\HSC1\General\Project information						
Name	HSC_1		Comment			
Comment			Name	HSC_3		
Name	HSC_4		Comment			
Comment			Name	HSC_6		
High speed counters (HSC)\HSC1\I/O addresses\Input addresses						
Start address	1000.0		End address	1003.7		Start address 1004.0
End address	1007.7		Organization block	0		Start address 1008.0
End address	1011.7		Organization block	0		Process image 0
Start address	1012.0		End address	1015.7		Organization block 0
Process image	0		Start address	1016.0		End address 1019.7
Organization block	0		Process image	0		Start address 1020.0
End address	1023.7		Organization block	0		Process image 0
Organization block	0		Process image	0		Process image 0
Pulse generators (PTO/PWM)\PTO1/PWM1\General\Enable						
Enable this pulse generator	0		Enable this pulse generator	0		
Pulse generators (PTO/PWM)\PTO1/PWM1\General\Project information						
Name	Pulse_1		Comment			
Comment			Name	Pulse_2		

Totally Integrated Automation Portal

Pulse generators (PTO/PWM)\PTO1/PWM1\I/O addresses\Output addresses

Start address1000.0End address1001.7Start address1002.0

End address1003.7Organization block0Organization block0

Process image0Process image0

Startup

Startup after POWER ONWarm restart - mode before POWER OFFComparison preset to actual configurationStartup CPU even if mismatchConfiguration time60000ms

OBS should be interruptible1

Cycle

Cycle monitoring time150msEnable minimum cycle time for cyclic OBs0

Minimum cycle time1ms

Communication load

Cycle load due to communication20%

System and clock memory\System memory bits

Enable the use of system memory byte0Address of system memory byte (MBx)1First cycle

Diagnostic status changedAlways 1 (high)Always 0 (low)

System and clock memory\Clock memory bits

Enable the use of clock memory byte0Address of clock memory byte (MBx)010 Hz clock

5 Hz clock2.5 Hz clock2 Hz clock

1.25 Hz clock1 Hz clock0.625 Hz clock

0.5 Hz clock

Web server\General

Activate Web server on all modules of this deviceFalsePermit access only with HTTPSTrue

Web server\Automatic update

Enable automatic updateTrueUpdate interval5s

Web server\User interface languages

Assign project languageUser interface languages

English (United States)German

English (United States)English

English (United States)French

English (United States)Spanish

English (United States)Italian

English (United States)Chinese (simplified)

Web server\User management

User nameUser rights

EverybodyQuery diagnostics ,Read tags ,Write tags ,Read tag status ,Write tag status ,Open user-defined pages ,Write in user-defined web pages ,Read files ,Write/delete files ,Change operating mode ,Let LED flash ,Perform firmware update ,create a backup of the PLC ,restore the PLC by a backup file

JPHAQuery diagnostics ,Read tags ,Write tags ,Read tag status ,Write tag status ,Open user-defined pages ,Write in user-defined web pages ,Read files ,Write/delete files ,Change operating mode ,Let LED flash ,Perform firmware update ,create a backup of the PLC ,restore the PLC by a backup file

Web server\User-defined web pages

Application nameHTML source pathDefault HTML pageFiles with dynamic contentWeb DB numberFragment DB number

WEBPLC2C:\Users\192072\Desktop\WEBindex.htm.htm;.html333334

Web server\Overview of interfaces

DeviceInterfaceEnabled web server access

PLC_2PROFINET interface_1False

User interface languages

Assign project languageUser interface languages

English (United States)German

English (United States)English

English (United States)French

English (United States)Spanish

English (United States)Italian

English (United States)Chinese (simplified)

Time of day\Local time

Time zone(UTC +01:00) Berlin, Bern, Brussels, Rome, Stockholm, Vienna

Time of day\Daylight saving time

Activate daylight saving time1Difference between standard and daylight saving time60mins

Time of day\Daylight saving time\Start of daylight saving time

Starting week of the month:LastSundayofMarch

at01:00 a.m.

Time of day\Daylight saving time\Start of standard time

atLastSundayofOctober

at02:00 a.m.

Protection & Security

Level of protectionNo protection

Protection & Security\Connection mechanisms

Permit access with PUT/GET communication from remote partnerTrue

Totally Integrated Automation Portal

Protection & Security

Security event

Summarize security events in case of high message volume

True

Length of an interval

20

Unit

seconds

Protection & Security

External load memory

Disable copying from internal load memory to external load memory

False

Configuration control

Configuration control for central configuration

Allow to reconfigure the device via the user program

0

Connection resources

	Station resources - Reserved - Maximum	Station resources - Reserved - Configured	Station resources - Dynamic - Configured	Module resources - PLC_2 [CPU 1215C DC/DC/DC] - Configured
Maximum number of resources:		62	6	68
	Maximum	Configured	Configured	Configured
PG communication:	4	-	-	-
HMI communication:	12	1	0	1
S7 communication:	8	0	0	0
Open user communication:	8	0	0	0
Web communication:	30	-	-	-
Other communication:	-	-	0	0
Total resources used:		1	0	1
Available resources:		61	6	67

Overview of addresses

Overview of addresses

Overview of addresses

Inputs

True

Outputs

True

Address gaps

False

Slot

True

Type	Addr. from	Addr. to	Module	PIP	Device name	Device number	Size	Master / IO system	Rack	Slot
I	0	1	DI 14/DQ 10_1	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	2 Bytes	-	0	1 1
O	0	1	DI 14/DQ 10_1	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	2 Bytes	-	0	1 1
I	64	67	AI 2/AQ 2_1	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 2
O	64	67	AI 2/AQ 2_1	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 2
I	1000	1003	HSC_1	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 16
I	1004	1007	HSC_2	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 17
I	1008	1011	HSC_3	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 18
I	1012	1015	HSC_4	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 19
I	1016	1019	HSC_5	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 20
I	1020	1023	HSC_6	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 21
O	1000	1001	Pulse_1	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	2 Bytes	-	0	1 32
O	1002	1003	Pulse_2	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	2 Bytes	-	0	1 33
O	1004	1005	Pulse_3	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	2 Bytes	-	0	1 34
O	1006	1007	Pulse_4	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	2 Bytes	-	0	1 35

Proyecto_final / PLC_2 [CPU 1215C DC/DC/DC] / Program blocks

Main [OB1]

Main Properties

General


Name	Main	Number	1	Type	OB	Language	LAD
Numbering	Automatic						

Information


Title	Revolvedora	Author		Comment		Family	
Version	0.1	User-defined ID					

Name	Data type	Default value	Comment
▼ Input			
Initial_Call	Bool		Initial call of this OB
Remanence	Bool		=True, if remanent data are available
Temp			
Constant			


Network 1:




Network 2: Ciclo main



Network 3: Fin



Network 4: DB_control



Totally Integrated Automation Portal

Proyecto_final / PLC_2 [CPU 1215C DC/DC/DC] / Program blocks

PLC2_Rev [DB5]

PLC2_Rev Properties

General

Name	PLC2_Rev	Number	5	Type	DB	Language	DB
Numbering	Automatic						

Information

Title		Author		Comment		Family	
Version	0.1	User-defined ID					

Name	Data type	Offset	Start value	Retain	Accessi-ble from HMI/OPC UA	Writ-able from HMI/OPC UA	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Static										
Rev_Detección	Bool	0.0	false	False	True	True	True	False		
Rev_especial	UInt	2.0	0	False	True	True	True	False		
Rev_estado	Bool	4.0	false	False	True	True	True	False		
Rev_progreso	Int	6.0	0	False	True	True	True	False		

Totally Integrated Automation Portal

Proyecto_final / PLC_2 [CPU 1215C DC/DC/DC] / Program blocks / System blocks / Program resources

IEC_Timer_0_DB [DB1]

IEC_Timer_0_DB Properties

General

Name	IEC_Timer_0_DB	Number	1	Type	DB	Language	DB
Numbering	Automatic						

Information

Title		Author	Simatic	Comment		Family	IEC
Version	1.0	User-defined ID	IEC_TMR				

Name	Data type	Start value	Retain	Accessible from HMI/OPC UA	Writ-able from HMI/OPC UA	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Static									
PT	Time	T#0ms	False	True	True	True	False		
ET	Time	T#0ms	False	True	False	True	False		
IN	Bool	false	False	True	True	True	False		
Q	Bool	false	False	True	False	True	False		

Totally Integrated Automation Portal

Proyecto_final / PLC_2 [CPU 1215C DC/DC/DC] / Program blocks / System blocks / Program resources

IEC_Timer_0_DB_2 [DB3]

IEC_Timer_0_DB_2 Properties

General

Name	IEC_Timer_0_DB_2	Number	3	Type	DB	Language	DB
Numbering	Automatic						

Information

Title		Author	Simatic	Comment		Family	IEC
Version	1.0	User-defined ID	IEC_TMR				

Name	Data type	Start value	Retain	Accessible from HMI/OPC UA	Writ-able from HMI/OPC UA	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Static									
PT	Time	T#0ms	False	True	True	True	False		
ET	Time	T#0ms	False	True	False	True	False		
IN	Bool	false	False	True	True	True	False		
Q	Bool	false	False	True	False	True	False		

Totally Integrated Automation Portal

Proyecto_final / PLC_2 [CPU 1215C DC/DC/DC] / Program blocks / System blocks / Program resources

IEC_Counter_0_DB [DB2]

IEC_Counter_0_DB Properties

General

Name	IEC_Counter_0_DB	Number	2	Type	DB	Language	DB
Numbering	Automatic						

Information

Title		Author	Simatic	Comment		Family	IEC
Version	1.0	User-defined ID	CNTR				

Name	Data type	Start value	Retain	Accessible from HMI/OPC UA	Writ-able from HMI/ OPC UA	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Static									
CU	Bool	false	True	True	True	True	False		
CD	Bool	false	True	True	True	True	False		
R	Bool	false	True	True	True	True	False		
LD	Bool	false	True	True	True	True	False		
QU	Bool	false	True	True	True	True	False		
QD	Bool	false	True	True	True	True	False		
PV	Int	0	True	True	True	True	False		
CV	Int	0	True	True	True	True	False		

Totally Integrated Automation Portal

Proyecto_final / PLC_2 [CPU 1215C DC/DC/DC] / Program blocks / System blocks / Program resources

IEC_Timer_0_DB_1 [DB4]

IEC_Timer_0_DB_1 Properties

General

Name	IEC_Timer_0_DB_1	Number	4	Type	DB	Language	DB
Numbering	Automatic						

Information

Title		Author	Simatic	Comment		Family	IEC
Version	1.0	User-defined ID	IEC_TMR				

Name	Data type	Start value	Retain	Accessible from HMI/OPC UA	Writ-able from HMI/OPC UA	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Static									
PT	Time	T#0ms	False	True	True	True	False		
ET	Time	T#0ms	False	True	False	True	False		
IN	Bool	false	False	True	True	True	False		
Q	Bool	false	False	True	False	True	False		

Totally Integrated Automation Portal

Proyecto_final / PLC_2 [CPU 1215C DC/DC/DC] / Program blocks / System blocks / Program resources

IEC_Timer_0_DB_3 [DB6]

IEC_Timer_0_DB_3 Properties

General

Name	IEC_Timer_0_DB_3	Number	6	Type	DB	Language	DB
Numbering	Automatic						

Information

Title		Author	Simatic	Comment		Family	IEC
Version	1.0	User-defined ID	IEC_TMR				

Name	Data type	Start value	Retain	Accessible from HMI/OPC UA	Writ-able from HMI/OPC UA	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Static									
PT	Time	T#0ms	False	True	True	True	False		
ET	Time	T#0ms	False	True	False	True	False		
IN	Bool	false	False	True	True	True	False		
Q	Bool	false	False	True	False	True	False		

Totally Integrated Automation Portal

Proyecto_final / PLC_2 [CPU 1215C DC/DC/DC] / Program blocks / System blocks / Program resources

IEC_Timer_0_DB_4 [DB7]

IEC_Timer_0_DB_4 Properties

General

Name	IEC_Timer_0_DB_4	Number	7	Type	DB	Language	DB
Numbering	Automatic						

Information

Title		Author	Simatic	Comment		Family	IEC
Version	1.0	User-defined ID	IEC_TMR				

Name	Data type	Start value	Retain	Accessible from HMI/OPC UA	Writ-able from HMI/OPC UA	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Static									
PT	Time	T#0ms	False	True	True	True	False		
ET	Time	T#0ms	False	True	False	True	False		
IN	Bool	false	False	True	True	True	False		
Q	Bool	false	False	True	False	True	False		

Totally Integrated Automation Portal

Proyecto_final / PLC_2 [CPU 1215C DC/DC/DC] / Program blocks / System blocks / Program resources

IEC_Timer_0_DB_5 [DB8]

IEC_Timer_0_DB_5 Properties

General

Name	IEC_Timer_0_DB_5	Number	8	Type	DB	Language	DB
Numbering	Automatic						

Information

Title		Author	Simatic	Comment		Family	IEC
Version	1.0	User-defined ID	IEC_TMR				

Name	Data type	Start value	Retain	Accessible from HMI/OPC UA	Writ-able from HMI/OPC UA	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Static									
PT	Time	T#0ms	False	True	True	True	False		
ET	Time	T#0ms	False	True	False	True	False		
IN	Bool	false	False	True	True	True	False		
Q	Bool	false	False	True	False	True	False		

























DB 333 [DB333]

Name	Data type	Offset	Start value	Retain	Accessi- ble from HMI/OPC UA	Writ- able from HMI/ OPC UA	Visible in HMI engi- neering	Setpoint	Supervi- sion	Comment
▼ Static										
magic	DWord	0.0	DW#16#41575043	False	False	False	False	False		
consistency_tag	DWord	4.0	DW#16#79EB8D95	False	False	False	False	False		
db_version	Word	8.0	W#16#0001	False	False	False	False	False		
length	UInt	10.0	124	False	False	False	False	False		
pagetab_of	UInt	12.0	92	False	False	False	False	False		
pagetab_count	UInt	14.0	0	False	False	False	False	False		
excludetab_of	UInt	16.0	92	False	False	False	False	False		
excludetab_count	UInt	18.0	0	False	False	False	False	False		
fragmentlist_of	UInt	20.0	92	False	False	False	False	False		
fragmentlist_count	UInt	22.0	0	False	False	False	False	False		
fragmenttab_of	UInt	24.0	98	False	False	False	False	False		
fragmenttab_count	UInt	26.0	0	False	False	False	False	False		
datatab_of	UInt	28.0	98	False	False	False	False	False		
datatab_count	UInt	30.0	0	False	False	False	False	False		
usenameatab_of	UInt	32.0	98	False	False	False	False	False		
usenameatab_count	UInt	34.0	0	False	False	False	False	False		
enumreftab_of	UInt	36.0	98	False	False	False	False	False		
enumreftab_count	UInt	38.0	0	False	False	False	False	False		
enumtab_of	UInt	40.0	98	False	False	False	False	False		
enumtab_count	UInt	42.0	0	False	False	False	False	False		
textlist_of	UInt	44.0	98	False	False	False	False	False		
textlist_count	UInt	46.0	26	False	False	False	False	False		
language_frag_tab_of	UInt	48.0	92	False	False	False	False	False		
language_frag_tab_count	UInt	50.0	6	False	False	False	False	False		
application_name	UInt	52.0	1	False	False	False	False	False		
application_url	UInt	54.0	9	False	False	False	False	False		
application_desc	UInt	56.0	19	False	False	False	False	False		
enum_defs_fragment_start	UInt	58.0	0	False	False	False	False	False		
enum_defs_fragment_count	UInt	60.0	0	False	False	False	False	False		
▼ commandstate	Struct	62.0		False	False	False	False	False		
last_error	Int	62.0	0	False	False	False	False	False		
debug_mode	Int	64.0	0	False	False	False	False	False		
init	Bool	66.0	True	False	False	False	False	False		
deactivate	Bool	66.1	False	False	False	False	False	False		
initializing	Bool	66.2	False	False	False	False	False	False		
error	Bool	66.3	False	False	False	False	False	False		
deactivating	Bool	66.4	False	False	False	False	False	False		
deactivated	Bool	66.5	False	False	False	False	False	False		
initialized	Bool	66.6	False	False	False	False	False	False		
reserved1	Bool	66.7	False	False	False	False	False	False		
reserved2	Byte	67.0	B#16#00	False	False	False	False	False		
▼ requesttab	Array[1..4] of Struct	68.0		False	False	False	False	False		
▼ requesttab[1]	Struct	68.0		False	False	False	False	False		
page_index	UInt	68.0	0	False	False	False	False	False		
fragment_index	UInt	70.0	0	False	False	False	False	False		
continue	Bool	72.0	False	False	False	False	False	False		
repeat	Bool	72.1	False	False	False	False	False	False		
abort	Bool	72.2	False	False	False	False	False	False		
finish	Bool	72.3	False	False	False	False	False	False		
idle	Bool	72.4	False	False	False	False	False	False		
waiting	Bool	72.5	False	False	False	False	False	False		
sending	Bool	72.6	False	False	False	False	False	False		
aborting	Bool	72.7	False	False	False	False	False	False		
reserved3	Byte	73.0	B#16#00	False	False	False	False	False		
▼ requesttab[2]	Struct	74.0		False	False	False	False	False		
page_index	UInt	74.0	0	False	False	False	False	False		
fragment_index	UInt	76.0	0	False	False	False	False	False		
continue	Bool	78.0	False	False	False	False	False	False		
repeat	Bool	78.1	False	False	False	False	False	False		
abort	Bool	78.2	False	False	False	False	False	False		

Totally Integrated Automation Portal		
<div>Proyecto_final / PLC_2 [CPU 1215C DC/DC/DC]</div> <div>Technology objects</div> <div>This folder is empty.</div>		

Proyecto_final / PLC_2 [CPU 1215C DC/DC/DC] / PLC tags / Default tag table [54]

PLC tags

PLC tags									
	Name	Data type	Address	Retain	Accessi-ble from HMI/OPC UA	Writable from HMI/OPC UA	Visible in HMI engi-neering	Supervision	Comment
	Rev_Detección	Bool	%M0.1	False	True	True	True		
	Rev_especial	UInt	%MW4	False	True	True	True		
	Rev_estado	Bool	%M0.0	False	True	True	True		
	Rev_progreso	Int	%MW2	False	True	True	True		
	B4	Bool	%I0.0	False	True	True	True		
	F3	Bool	%Q0.0	False	True	True	True		
	F2	Bool	%Q0.1	False	True	True	True		
	F1	Bool	%Q0.2	False	True	True	True		
	Piston_arriba	Bool	%Q0.3	False	True	True	True		
	Piston_abajo	Bool	%Q0.4	False	True	True	True		
	PE	Bool	%I0.4	False	True	True	True		
	Sens_abajo	Bool	%I0.5	False	True	True	True		
	Sens_arriba	Bool	%I0.6	False	True	True	True		
	B3	Bool	%I0.1	False	True	True	True		
	B2	Bool	%I0.2	False	True	True	True		
	B1	Bool	%I0.3	False	True	True	True		
	Encendido	Bool	%M0.2	False	True	True	True		
	Fin	Bool	%M0.3	False	True	True	True		
	Ciclo	Bool	%M0.4	False	True	True	True		
	Mem_pos	Bool	%M0.5	False	True	True	True		
	Cuenta_add	Int	%MW6	False	True	True	True		
	Reset	Bool	%M0.6	False	True	True	True		
	Skip	Bool	%M0.7	False	True	True	True		
	Tag_1	Bool	%M8.0	False	True	True	True		

Totally Integrated Automation Portal																
<div>Proyecto_final / PLC_2 [CPU 1215C DC/DC/DC] / PLC tags / Default tag table [54]</div> <div>User constants</div> <table><tr><th colspan="4">User constants</th></tr><tr><th></th><th>Name</th><th>Data type</th><th>Value</th><th>Comment</th></tr><tr><td colspan="5"></td></tr></table>			User constants					Name	Data type	Value	Comment					
User constants																
	Name	Data type	Value	Comment												

Totally Integrated Automation Portal		
<div>Proyecto_final / PLC_2 [CPU 1215C DC/DC/DC] / PLC data types</div> <div>System data types</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal							
<div>Proyecto_final / PLC_2 [CPU 1215C DC/DC/DC] / Watch and force tables</div> <div>Force table</div> <table><thead><tr><th>Name</th><th>Address</th><th>Display format</th><th>Force value</th><th>Comment</th></tr></thead><tbody></tbody></table>			Name	Address	Display format	Force value	Comment
Name	Address	Display format	Force value	Comment			

Totally Integrated Automation Portal		
<div>Proyecto_final / PLC_2 [CPU 1215C DC/DC/DC]</div> <div>Traces</div> <div><div>Name</div></div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / PLC_2 [CPU 1215C DC/DC/DC] / Traces</div> <div>Measurements</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / PLC_2 [CPU 1215C DC/DC/DC] / Traces</div> <div>Combined measurements</div> <div><div>Name</div></div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / PLC_2 [CPU 1215C DC/DC/DC]</div> <div>PLC alarm text lists</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal						
--------------------------------------	--	--	--	--	--	--

Proyecto_final / PLC_2 [CPU 1215C DC/DC/DC] / Local modules



PLC_2 [CPU 1215C DC/DC/DC]

PLC_2					
General\Project information					
Name	PLC_2	Author	192072	Comment	
Slot	1	Rack	0		
General\Catalog information					
Short designation	CPU 1215C DC/DC/DC	Description	Work memory 125 KB; 24VDC power supply with DI14 x 24VDC SINK/ SOURCE, DQ10 x 24VDC and AI2 and AQ2 on board; 6 high-speed counters and 4 pulse outputs on board; signal board expands on-board I/O; up to 3 communication modules for serial communication; up to 8 signal modules for I/O expansion; 0.04 ms/1000 instructions; 2 PROFINET ports for programming, HMI and PLC-to-PLC communication	Article number	6ES7 215-1AG40-0XB0
Firmware version	V4.2				
General\Identification & Maintenance					
Plant designation		Location identifier		Installation date	2025-05-01 19:29:36.425
Additional information					
General\Checksums					
Text lists	FA 70 E8 75 1D 5A 8E 29	Software	11 2B 3B 85 C7 CB 83 E7		
PROFINET interface [X1]\General					
Name	PROFINET interface_1	Author	192072	Comment	
PROFINET interface [X1]\General\Project information					
Name	DI 14/DQ 10_1	Comment		Name	AI 2/AQ 2_1
Comment					
PROFINET interface [X1]\Ethernet addresses\Interface networked with					
Subnet:	PN/IE_1				
PROFINET interface [X1]\Ethernet addresses\IP protocol					
IP configuration	Set IP address in the project	IP address:	192.168.0.2	Subnet mask:	255.255.255.0
Use router	False				
PROFINET interface [X1]\Ethernet addresses\PROFINET					
PROFINET device name is set directly at the device	False	Generate PROFINET device name automatically	True	PROFINET device name:	plc_2
Converted name:	plcxb2d1ad	Device number:	0		
PROFINET interface [X1]\Time synchronization					
Enable time synchronization via NTP server	Enable time synchronization via NTP server		IP addresses	Server 1	0.0.0.0
Server 2	0.0.0.0	Server 3	0.0.0.0	Server 4	0.0.0.0
Update interval	10sec	Empty		CPU synchronizes the modules of the device.	No synchronization
PROFINET interface [X1]\Digital inputs\Channel0					
Channel address	I0.0	Input filters	6.4 millisec	Enable pulse catch	0
PROFINET interface [X1]\Digital inputs\Channel0\					
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49152	Event name:	0
Hardware interrupt:	0	Rising edge0	Rising edge0		
PROFINET interface [X1]\Digital inputs\Channel0\					
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49280	Event name:	0
Hardware interrupt:	0	Falling edge0	Falling edge0		
PROFINET interface [X1]\Digital inputs\Channel1					
Channel address	I0.1	Input filters	6.4 millisec	Enable pulse catch	0
PROFINET interface [X1]\Digital inputs\Channel1\					
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49153	Event name:	0
Hardware interrupt:	0	Rising edge1	Rising edge1		
PROFINET interface [X1]\Digital inputs\Channel1\					
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49281	Event name:	0
Hardware interrupt:	0	Falling edge1	Falling edge1		
PROFINET interface [X1]\Digital inputs\Channel2					
Channel address	I0.2	Input filters	6.4 millisec	Enable pulse catch	0
PROFINET interface [X1]\Digital inputs\Channel2\					
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49154	Event name:	0
Hardware interrupt:	0	Rising edge2	Rising edge2		
PROFINET interface [X1]\Digital inputs\Channel2\					
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49282	Event name:	0
Hardware interrupt:	0	Falling edge2	Falling edge2		
PROFINET interface [X1]\Digital inputs\Channel3					
Channel address	I0.3	Input filters	6.4 millisec	Enable pulse catch	0
PROFINET interface [X1]\Digital inputs\Channel3\					
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49155	Event name:	0
Hardware interrupt:	0	Rising edge3	Rising edge3		

--	--	--

Totally Integrated Automation Portal						
PROFINET interface [X1]\Digital inputs\Channel3\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49283	Event name:	0	
Hardware interrupt:	0	Falling edge3	Falling edge3			
PROFINET interface [X1]\Digital inputs\Channel4						
Channel address	I0.4	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel4\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49156	Event name:	0	
Hardware interrupt:	0	Rising edge4	Rising edge4			
PROFINET interface [X1]\Digital inputs\Channel4\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49284	Event name:	0	
Hardware interrupt:	0	Falling edge4	Falling edge4			
PROFINET interface [X1]\Digital inputs\Channel5						
Channel address	I0.5	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel5\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49157	Event name:	0	
Hardware interrupt:	0	Rising edge5	Rising edge5			
PROFINET interface [X1]\Digital inputs\Channel5\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49285	Event name:	0	
Hardware interrupt:	0	Falling edge5	Falling edge5			
PROFINET interface [X1]\Digital inputs\Channel6						
Channel address	I0.6	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel6\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49158	Event name:	0	
Hardware interrupt:	0	Rising edge6	Rising edge6			
PROFINET interface [X1]\Digital inputs\Channel6\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49286	Event name:	0	
Hardware interrupt:	0	Falling edge6	Falling edge6			
PROFINET interface [X1]\Digital inputs\Channel7						
Channel address	I0.7	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel7\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49159	Event name:	0	
Hardware interrupt:	0	Rising edge7	Rising edge7			
PROFINET interface [X1]\Digital inputs\Channel7\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49287	Event name:	0	
Hardware interrupt:	0	Falling edge7	Falling edge7			
PROFINET interface [X1]\Digital inputs\Channel8						
Channel address	I1.0	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel8\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49160	Event name:	0	
Hardware interrupt:	0	Rising edge8	Rising edge8			
PROFINET interface [X1]\Digital inputs\Channel8\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49288	Event name:	0	
Hardware interrupt:	0	Falling edge8	Falling edge8			
PROFINET interface [X1]\Digital inputs\Channel9						
Channel address	I1.1	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel9\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49161	Event name:	0	
Hardware interrupt:	0	Rising edge9	Rising edge9			
PROFINET interface [X1]\Digital inputs\Channel9\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49289	Event name:	0	
Hardware interrupt:	0	Falling edge9	Falling edge9			
PROFINET interface [X1]\Digital inputs\Channel10						
Channel address	I1.2	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel10\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49162	Event name:	0	
Hardware interrupt:	0	Rising edge10	Rising edge10			
PROFINET interface [X1]\Digital inputs\Channel10\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49290	Event name:	0	
Hardware interrupt:	0	Falling edge10	Falling edge10			
PROFINET interface [X1]\Digital inputs\Channel11						
Channel address	I1.3	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel11\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49163	Event name:	0	
Hardware interrupt:	0	Rising edge11	Rising edge11			
PROFINET interface [X1]\Digital inputs\Channel11\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49291	Event name:	0	
Hardware interrupt:	0	Falling edge11	Falling edge11			
PROFINET interface [X1]\Digital inputs\Channel12						
Channel address	I1.4	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel13						
Channel address	I1.5	Input filters	6.4 millisec	Enable pulse catch	0	

Totally Integrated Automation Portal						
PROFINET interface [X1]\Analog inputs\Noise reduction						
Integration time	50 Hz (20 ms)					
PROFINET interface [X1]\Analog inputs\Channel0						
Channel address	IW64	Measurement type	Voltage	Voltage range	0..10 V	
Smoothing	Weak (4 cycles)	Empty		Enable overflow diagnostics	1	
PROFINET interface [X1]\Analog inputs\Channel1						
Channel address	IW66	Measurement type	Voltage	Voltage range	0..10 V	
Smoothing	Weak (4 cycles)	Empty		Enable overflow diagnostics	1	
PROFINET interface [X1]\Digital outputs						
Reaction to CPU STOP	Use substitute value					
PROFINET interface [X1]\Digital outputs\Channel0						
Channel address	Q0.0	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel1						
Channel address	Q0.1	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel2						
Channel address	Q0.2	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel3						
Channel address	Q0.3	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel4						
Channel address	Q0.4	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel5						
Channel address	Q0.5	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel6						
Channel address	Q0.6	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel7						
Channel address	Q0.7	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel8						
Channel address	Q1.0	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel9						
Channel address	Q1.1	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Operating mode						
IO controller	True	IO system		Device number	0	
IO device	False					
PROFINET interface [X1]\Analog outputs						
Reaction to CPU STOP	Use substitute value					
PROFINET interface [X1]\Analog outputs\Channel0						
Channel address	QW64	Analog output type	Current	Current range	0..20 mA	
Substitute value for channel on a change from RUN to STOP	0.000mA	Empty		Enable overflow diagnostics	1	
Enable underflow diagnostics	1					
PROFINET interface [X1]\Analog outputs\Channel1						
Channel address	QW66	Analog output type	Current	Current range	0..20 mA	
Substitute value for channel on a change from RUN to STOP	0.000mA	Empty		Enable overflow diagnostics	1	
Enable underflow diagnostics	1					
PROFINET interface [X1]\I/O addresses\Input addresses						
Start address	0.0	End address	1.7	Organization block	0	
Process image	0					
PROFINET interface [X1]\I/O addresses\Input addresses						
Start address	64	End address	67	Organization block	0	
Process image	0					
PROFINET interface [X1]\I/O addresses\Output addresses						
Start address	0.0	End address	1.7	Organization block	0	
Process image	0					
PROFINET interface [X1]\I/O addresses\Output addresses						
Start address	64	End address	67	Organization block	0	
Process image	0					
PROFINET interface [X1]\Advanced options\Interface options						
Support device replacement without exchangeable medium	True	Permit overwriting of device names of all assigned IO devices	False	Use IEC V2.2 LLDP mode	False	
Keep-Alive connection monitoring:	30s					

Totally Integrated Automation Portal						
PROFINET interface [X1]\Advanced options\Real time settings\IO communication						
Send clock:	1.000ms					
PROFINET interface [X1]\Advanced options\Real time settings\Real time options						
Calculated bandwidth for cyclic IO data:	0.000ms		Calculated bandwidth for cyclic IO data:	0.000%		
PROFINET interface [X1]\Advanced options\Port [X1 P1]\General						
Name	Port_1		Author	192072		Comment
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port interconnection\Local port:						
Local port:	PLC_2\PROFINET interface_1 [X1]\Port_1 [X1 P1 R]		Medium:	Copper		Cable name: ---
						
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port interconnection\Partner port:						
	Monitoring of partner port is executed		Partner port:	HMI_2.IE_CP_1\PROFINET Interface_1 [X1]\Port_1 [X1 P1]		Medium: Copper
Cable length:						
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port options\Activate						
Activate this port for use	True					
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port options\Connection						
Transmission rate / duplex:	Automatic		Monitor	False		Enable autonegotiation True
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port options\Boundaries						
End of detection of accessible devices	False		End of topology discovery	False		End of the sync domain False
PROFINET interface [X1]\Advanced options\Port [X1 P2]\General						
Name	Port_2		Author	192072		Comment
PROFINET interface [X1]\Advanced options\Port [X1 P2]\Port interconnection\Local port:						
Local port:	PLC_2\PROFINET interface_1 [X1]\Port_2 [X1 P2 R]		Medium:	Copper		Cable name: ---
						
PROFINET interface [X1]\Advanced options\Port [X1 P2]\Port interconnection\Partner port:						
	Monitoring of partner port is not possible		Partner port:	Switch_1\SCALANCE interface_1 [X1]\Port_3 [X1 P3]		Medium: Copper
Cable length:						
PROFINET interface [X1]\Advanced options\Port [X1 P2]\Port options\Activate						
Activate this port for use	True					
PROFINET interface [X1]\Advanced options\Port [X1 P2]\Port options\Connection						
Transmission rate / duplex:	Automatic		Monitor	False		Enable autonegotiation True
PROFINET interface [X1]\Advanced options\Port [X1 P2]\Port options\Boundaries						
End of detection of accessible devices	False		End of topology discovery	False		End of the sync domain False
PROFINET interface [X1]\Web server access						
Enable Web server using this interface	False		The Web server must also be activated in the properties of the PLC.			
High speed counters (HSC)\HSC1\General\Enable						
Enable this high speed counter	0		Enable this high speed counter	0		Enable this high speed counter 0
Enable this high speed counter	0		Enable this high speed counter	0		Enable this high speed counter 0
High speed counters (HSC)\HSC1\General\Project information						
Name	HSC_1		Comment			
Comment			Name	HSC_3		
Name	HSC_4		Comment			
Comment			Name	HSC_6		
High speed counters (HSC)\HSC1\I/O addresses\Input addresses						
Start address	1000.0		End address	1003.7		Start address 1004.0
End address	1007.7		Organization block	0		Start address 1008.0
End address	1011.7		Organization block	0		Process image 0
Start address	1012.0		End address	1015.7		Organization block 0
Process image	0		Start address	1016.0		End address 1019.7
Organization block	0		Process image	0		Start address 1020.0
End address	1023.7		Organization block	0		Process image 0
Organization block	0		Process image	0		Process image 0
Pulse generators (PTO/PWM)\PTO1/PWM1\General\Enable						
Enable this pulse generator	0		Enable this pulse generator	0		
Pulse generators (PTO/PWM)\PTO1/PWM1\General\Project information						
Name	Pulse_1		Comment			
Comment			Name	Pulse_2		

Totally Integrated Automation Portal						
Pulse generators (PTO/PWM)\PTO1/PWM1\I/O addresses\Output addresses						
Start address	1000.0	End address	1001.7	Start address	1002.0	
End address	1003.7	Organization block	0	Organization block	0	
Process image	0	Process image	0			
Startup						
Startup after POWER ON	Warm restart - mode before POWER OFF	Comparison preset to actual configuration	Startup CPU even if mismatch	Configuration time	60000ms	
OBs should be interruptible	1					
Cycle						
Cycle monitoring time	150ms			Enable minimum cycle time for cyclic OBs	0	
Minimum cycle time	1ms					
Communication load						
Cycle load due to communication	20%					
System and clock memory\System memory bits						
Enable the use of system memory byte	0	Address of system memory byte (MBx)	1	First cycle		
Diagnostic status changed		Always 1 (high)		Always 0 (low)		
System and clock memory\Clock memory bits						
Enable the use of clock memory byte	0	Address of clock memory byte (MBx)	0	10 Hz clock		
5 Hz clock		2.5 Hz clock		2 Hz clock		
1.25 Hz clock		1 Hz clock		0.625 Hz clock		
0.5 Hz clock						
Web server\General						
Activate Web server on all modules of this device	False	Permit access only with HTTPS	True			
Web server\Automatic update						
Enable automatic update	True	Update interval	5s			
Web server\User interface languages						
Assign project language			User interface languages			
English (United States)			German			
English (United States)			English			
English (United States)			French			
English (United States)			Spanish			
English (United States)			Italian			
English (United States)			Chinese (simplified)			
Web server\User management						
User name			User rights			
Everybody			Query diagnostics ,Read tags ,Write tags ,Read tag status ,Write tag status ,Open user-defined pages ,Write in user-defined web pages ,Read files ,Write/delete files ,Change operating mode ,Let LED flash ,Perform firmware update ,create a backup of the PLC ,restore the PLC by a backup file			
JPHA			Query diagnostics ,Read tags ,Write tags ,Read tag status ,Write tag status ,Open user-defined pages ,Write in user-defined web pages ,Read files ,Write/delete files ,Change operating mode ,Let LED flash ,Perform firmware update ,create a backup of the PLC ,restore the PLC by a backup file			
Web server\User-defined web pages						
Application name	HTML source path	Default HTML page	Files with dynamic content	Web DB number	Fragment DB number	
WEBPLC2	C:\Users\192072\Desktop\WEB	index.htm	.htm;.html	333	334	
Web server\Overview of interfaces						
Device		Interface		Enabled web server access		
PLC_2		PROFINET interface_1		False		
User interface languages						
Assign project language			User interface languages			
English (United States)			German			
English (United States)			English			
English (United States)			French			
English (United States)			Spanish			
English (United States)			Italian			
English (United States)			Chinese (simplified)			
Time of day\Local time						
Time zone	(UTC +01:00) Berlin, Bern, Brussels, Rome, Stockholm, Vienna					
Time of day\Daylight saving time						
Activate daylight saving time	1	Difference between standard and daylight saving time	60mins			
Time of day\Daylight saving time\Start of daylight saving time						
Starting week of the month:	Last		Sunday	of	March	
at	01:00 a.m.					
Time of day\Daylight saving time\Start of standard time						
	Last		Sunday	of	October	
at	02:00 a.m.					
Protection & Security						
Level of protection	No protection					
Protection & Security\Connection mechanisms						
Permit access with PUT/GET communication from remote partner	True					

Totally Integrated Automation Portal

Protection & Security

Security event

Summarize security events in case of high message volume

True

Length of an interval

20

Unit

seconds

Protection & Security

External load memory

Disable copying from internal load memory to external load memory

False

Configuration control

Configuration control for central configuration

Allow to reconfigure the device via the user program

0

Connection resources

	Station resources - Reserved - Maximum	Station resources - Reserved - Configured	Station resources - Dynamic - Configured	Module resources - PLC_2 [CPU 1215C DC/DC/DC] - Configured
Maximum number of resources:		62	6	68
	Maximum	Configured	Configured	Configured
PG communication:	4	-	-	-
HMI communication:	12	1	0	1
S7 communication:	8	0	0	0
Open user communication:	8	0	0	0
Web communication:	30	-	-	-
Other communication:	-	-	0	0
Total resources used:		1	0	1
Available resources:		61	6	67

Overview of addresses

Overview of addresses

Overview of addresses

Inputs

True

Outputs

True

Address gaps

False

Slot

True

Type	Addr. from	Addr. to	Module	PIP	Device name	Device number	Size	Master / IO system	Rack	Slot
I	0	1	DI 14/DQ 10_1	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	2 Bytes	-	0	1 1
O	0	1	DI 14/DQ 10_1	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	2 Bytes	-	0	1 1
I	64	67	AI 2/AQ 2_1	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 2
O	64	67	AI 2/AQ 2_1	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 2
I	1000	1003	HSC_1	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 16
I	1004	1007	HSC_2	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 17
I	1008	1011	HSC_3	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 18
I	1012	1015	HSC_4	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 19
I	1016	1019	HSC_5	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 20
I	1020	1023	HSC_6	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 21
O	1000	1001	Pulse_1	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	2 Bytes	-	0	1 32
O	1002	1003	Pulse_2	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	2 Bytes	-	0	1 33
O	1004	1005	Pulse_3	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	2 Bytes	-	0	1 34
O	1006	1007	Pulse_4	Automatic update	PLC_2 [CPU 1215C DC/DC/DC]	-	2 Bytes	-	0	1 35

Totally Integrated Automation Portal						
--------------------------------------	--	--	--	--	--	--

Proyecto_final



PLC_3 [CPU 1215C DC/DC/DC]

PLC_3					
General\Project information					
Name	PLC_3	Author	192072	Comment	
Slot	1	Rack	0		
General\Catalog information					
Short designation	CPU 1215C DC/DC/DC	Description	Work memory 125 KB; 24VDC power supply with DI14 x 24VDC SINK/ SOURCE, DQ10 x 24VDC and AI2 and AQ2 on board; 6 high-speed counters and 4 pulse outputs on board; signal board expands on-board I/O; up to 3 communication modules for serial communication; up to 8 signal modules for I/O expansion; 0.04 ms/1000 instructions; 2 PROFINET ports for programming, HMI and PLC-to-PLC communication	Article number	6ES7 215-1AG40-0XB0
Firmware version	V4.2				
General\Identification & Maintenance					
Plant designation		Location identifier		Installation date	2025-05-01 19:30:34.594
Additional information					
General\Checksums					
Text lists	FA 70 E8 75 1D 5A 8E 29	Software	42 96 C8 30 73 B2 47 3E		
PROFINET interface [X1]\General					
Name	PROFINET interface_1	Author	192072	Comment	
PROFINET interface [X1]\General\Project information					
Name	DI 14/DQ 10_1	Comment		Name	AI 2/AQ 2_1
Comment					
PROFINET interface [X1]\Ethernet addresses\Interface networked with					
Subnet:	PN/IE_3				
PROFINET interface [X1]\Ethernet addresses\IP protocol					
IP configuration	Set IP address in the project	IP address:	192.168.0.4	Subnet mask:	255.255.255.0
Use router	False				
PROFINET interface [X1]\Ethernet addresses\PROFINET					
PROFINET device name is set directly at the device	False	Generate PROFINET device name automatically	True	PROFINET device name:	plc_3
Converted name:	plcxb3116c	Device number:	0		
PROFINET interface [X1]\Time synchronization					
Enable time synchronization via NTP server	Enable time synchronization via NTP server		IP addresses	Server 1	0.0.0.0
Server 2	0.0.0.0	Server 3	0.0.0.0	Server 4	0.0.0.0
Update interval	10sec	Empty		CPU synchronizes the modules of the device.	No synchronization
PROFINET interface [X1]\Digital inputs\Channel0					
Channel address	I0.0	Input filters	6.4 millisec	Enable pulse catch	0
PROFINET interface [X1]\Digital inputs\Channel0\					
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49152	Event name:	0
Hardware interrupt:	0	Rising edge0	Rising edge0		
PROFINET interface [X1]\Digital inputs\Channel0\					
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49280	Event name:	0
Hardware interrupt:	0	Falling edge0	Falling edge0		
PROFINET interface [X1]\Digital inputs\Channel1					
Channel address	I0.1	Input filters	6.4 millisec	Enable pulse catch	0
PROFINET interface [X1]\Digital inputs\Channel1\					
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49153	Event name:	0
Hardware interrupt:	0	Rising edge1	Rising edge1		
PROFINET interface [X1]\Digital inputs\Channel1\					
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49281	Event name:	0
Hardware interrupt:	0	Falling edge1	Falling edge1		
PROFINET interface [X1]\Digital inputs\Channel2					
Channel address	I0.2	Input filters	6.4 millisec	Enable pulse catch	0
PROFINET interface [X1]\Digital inputs\Channel2\					
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49154	Event name:	0
Hardware interrupt:	0	Rising edge2	Rising edge2		
PROFINET interface [X1]\Digital inputs\Channel2\					
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49282	Event name:	0
Hardware interrupt:	0	Falling edge2	Falling edge2		
PROFINET interface [X1]\Digital inputs\Channel3					
Channel address	I0.3	Input filters	6.4 millisec	Enable pulse catch	0
PROFINET interface [X1]\Digital inputs\Channel3\					
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49155	Event name:	0
Hardware interrupt:	0	Rising edge3	Rising edge3		

--	--	--

Totally Integrated Automation Portal						
PROFINET interface [X1]\Digital inputs\Channel3\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49283	Event name:	0	
Hardware interrupt:	0	Falling edge3	Falling edge3			
PROFINET interface [X1]\Digital inputs\Channel4						
Channel address	I0.4	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel4\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49156	Event name:	0	
Hardware interrupt:	0	Rising edge4	Rising edge4			
PROFINET interface [X1]\Digital inputs\Channel4\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49284	Event name:	0	
Hardware interrupt:	0	Falling edge4	Falling edge4			
PROFINET interface [X1]\Digital inputs\Channel5						
Channel address	I0.5	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel5\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49157	Event name:	0	
Hardware interrupt:	0	Rising edge5	Rising edge5			
PROFINET interface [X1]\Digital inputs\Channel5\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49285	Event name:	0	
Hardware interrupt:	0	Falling edge5	Falling edge5			
PROFINET interface [X1]\Digital inputs\Channel6						
Channel address	I0.6	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel6\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49158	Event name:	0	
Hardware interrupt:	0	Rising edge6	Rising edge6			
PROFINET interface [X1]\Digital inputs\Channel6\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49286	Event name:	0	
Hardware interrupt:	0	Falling edge6	Falling edge6			
PROFINET interface [X1]\Digital inputs\Channel7						
Channel address	I0.7	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel7\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49159	Event name:	0	
Hardware interrupt:	0	Rising edge7	Rising edge7			
PROFINET interface [X1]\Digital inputs\Channel7\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49287	Event name:	0	
Hardware interrupt:	0	Falling edge7	Falling edge7			
PROFINET interface [X1]\Digital inputs\Channel8						
Channel address	I1.0	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel8\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49160	Event name:	0	
Hardware interrupt:	0	Rising edge8	Rising edge8			
PROFINET interface [X1]\Digital inputs\Channel8\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49288	Event name:	0	
Hardware interrupt:	0	Falling edge8	Falling edge8			
PROFINET interface [X1]\Digital inputs\Channel9						
Channel address	I1.1	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel9\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49161	Event name:	0	
Hardware interrupt:	0	Rising edge9	Rising edge9			
PROFINET interface [X1]\Digital inputs\Channel9\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49289	Event name:	0	
Hardware interrupt:	0	Falling edge9	Falling edge9			
PROFINET interface [X1]\Digital inputs\Channel10						
Channel address	I1.2	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel10\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49162	Event name:	0	
Hardware interrupt:	0	Rising edge10	Rising edge10			
PROFINET interface [X1]\Digital inputs\Channel10\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49290	Event name:	0	
Hardware interrupt:	0	Falling edge10	Falling edge10			
PROFINET interface [X1]\Digital inputs\Channel11						
Channel address	I1.3	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel11\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49163	Event name:	0	
Hardware interrupt:	0	Rising edge11	Rising edge11			
PROFINET interface [X1]\Digital inputs\Channel11\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49291	Event name:	0	
Hardware interrupt:	0	Falling edge11	Falling edge11			
PROFINET interface [X1]\Digital inputs\Channel12						
Channel address	I1.4	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel13						
Channel address	I1.5	Input filters	6.4 millisec	Enable pulse catch	0	

Totally Integrated Automation Portal						
PROFINET interface [X1]\Analog inputs\Noise reduction						
Integration time	50 Hz (20 ms)					
PROFINET interface [X1]\Analog inputs\Channel0						
Channel address	IW64	Measurement type	Voltage	Voltage range	0..10 V	
Smoothing	Weak (4 cycles)	Empty		Enable overflow diagnostics	1	
PROFINET interface [X1]\Analog inputs\Channel1						
Channel address	IW66	Measurement type	Voltage	Voltage range	0..10 V	
Smoothing	Weak (4 cycles)	Empty		Enable overflow diagnostics	1	
PROFINET interface [X1]\Digital outputs						
Reaction to CPU STOP	Use substitute value					
PROFINET interface [X1]\Digital outputs\Channel0						
Channel address	Q0.0	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel1						
Channel address	Q0.1	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel2						
Channel address	Q0.2	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel3						
Channel address	Q0.3	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel4						
Channel address	Q0.4	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel5						
Channel address	Q0.5	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel6						
Channel address	Q0.6	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel7						
Channel address	Q0.7	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel8						
Channel address	Q1.0	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel9						
Channel address	Q1.1	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Operating mode						
IO controller	True	IO system		Device number	0	
IO device	False					
PROFINET interface [X1]\Analog outputs						
Reaction to CPU STOP	Use substitute value					
PROFINET interface [X1]\Analog outputs\Channel0						
Channel address	QW64	Analog output type	Current	Current range	0..20 mA	
Substitute value for channel on a change from RUN to STOP	0.000mA	Empty		Enable overflow diagnostics	1	
Enable underflow diagnostics	1					
PROFINET interface [X1]\Analog outputs\Channel1						
Channel address	QW66	Analog output type	Current	Current range	0..20 mA	
Substitute value for channel on a change from RUN to STOP	0.000mA	Empty		Enable overflow diagnostics	1	
Enable underflow diagnostics	1					
PROFINET interface [X1]\I/O addresses\Input addresses						
Start address	0.0	End address	1.7	Organization block	0	
Process image	0					
PROFINET interface [X1]\I/O addresses\Input addresses						
Start address	64	End address	67	Organization block	0	
Process image	0					
PROFINET interface [X1]\I/O addresses\Output addresses						
Start address	0.0	End address	1.7	Organization block	0	
Process image	0					
PROFINET interface [X1]\I/O addresses\Output addresses						
Start address	64	End address	67	Organization block	0	
Process image	0					
PROFINET interface [X1]\Advanced options\Interface options						
Support device replacement without exchangeable medium	True	Permit overwriting of device names of all assigned IO devices	False	Use IEC V2.2 LLDP mode	False	
Keep-Alive connection monitoring:	30s					

Totally Integrated Automation Portal						
PROFINET interface [X1]\Advanced options\Real time settings\IO communication						
Send clock:	1.000ms					
PROFINET interface [X1]\Advanced options\Real time settings\Real time options						
Calculated bandwidth for cyclic IO data:	0.000ms		Calculated bandwidth for cyclic IO data:	0.000%		
PROFINET interface [X1]\Advanced options\Port [X1 P1]\General						
Name	Port_1		Author	192072		Comment
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port interconnection\Local port:						
Local port:	PLC_3\PROFINET interface_1 [X1]\Port_1 [X1 P1 R]		Medium:	Copper		Cable name: ---
						
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port interconnection\Partner port:						
	Monitoring of partner port is executed		Partner port:	HMI_3.IE_CP_1\PROFINET Interface_1 [X1]\Port_1 [X1 P1]		Medium: Copper
Cable length:						
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port options\Activate						
Activate this port for use	True					
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port options\Connection						
Transmission rate / duplex:	Automatic		Monitor	False		Enable autonegotiation True
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port options\Boundaries						
End of detection of accessible devices	False		End of topology discovery	False		End of the sync domain False
PROFINET interface [X1]\Advanced options\Port [X1 P2]\General						
Name	Port_2		Author	192072		Comment
PROFINET interface [X1]\Advanced options\Port [X1 P2]\Port interconnection\Local port:						
Local port:	PLC_3\PROFINET interface_1 [X1]\Port_2 [X1 P2 R]		Medium:	Copper		Cable name: ---
						
PROFINET interface [X1]\Advanced options\Port [X1 P2]\Port interconnection\Partner port:						
	Monitoring of partner port is not possible		Partner port:	Switch_1\SCALANCE interface_1 [X1]\Port_4 [X1 P4]		Medium: Copper
Cable length:						
PROFINET interface [X1]\Advanced options\Port [X1 P2]\Port options\Activate						
Activate this port for use	True					
PROFINET interface [X1]\Advanced options\Port [X1 P2]\Port options\Connection						
Transmission rate / duplex:	Automatic		Monitor	False		Enable autonegotiation True
PROFINET interface [X1]\Advanced options\Port [X1 P2]\Port options\Boundaries						
End of detection of accessible devices	False		End of topology discovery	False		End of the sync domain False
PROFINET interface [X1]\Web server access						
Enable Web server using this interface	False		The Web server must also be activated in the properties of the PLC.			
High speed counters (HSC)\HSC1\General\Enable						
Enable this high speed counter	0		Enable this high speed counter	0		Enable this high speed counter 0
Enable this high speed counter	0		Enable this high speed counter	0		Enable this high speed counter 0
High speed counters (HSC)\HSC1\General\Project information						
Name	HSC_1		Comment			
Comment			Name	HSC_3		
Name	HSC_4		Comment			
Comment			Name	HSC_6		
High speed counters (HSC)\HSC1\I/O addresses\Input addresses						
Start address	1000.0		End address	1003.7		Start address 1004.0
End address	1007.7		Organization block	0		Start address 1008.0
End address	1011.7		Organization block	0		Process image 0
Start address	1012.0		End address	1015.7		Organization block 0
Process image	0		Start address	1016.0		End address 1019.7
Organization block	0		Process image	0		Start address 1020.0
End address	1023.7		Organization block	0		Process image 0
Organization block	0		Process image	0		Process image 0
Pulse generators (PTO/PWM)\PTO1/PWM1\General\Enable						
Enable this pulse generator	0		Enable this pulse generator	0		
Pulse generators (PTO/PWM)\PTO1/PWM1\General\Project information						
Name	Pulse_1		Comment			
Comment			Name	Pulse_2		

Totally Integrated Automation Portal						
Pulse generators (PTO/PWM)\PTO1/PWM1\I/O addresses\Output addresses						
Start address	1000.0	End address	1001.7	Start address	1002.0	
End address	1003.7	Organization block	0	Organization block	0	
Process image	0	Process image	0			
Startup						
Startup after POWER ON	Warm restart - mode before POWER OFF	Comparison preset to actual configuration	Startup CPU even if mismatch	Configuration time	60000ms	
OBs should be interruptible	1					
Cycle						
Cycle monitoring time	150ms			Enable minimum cycle time for cyclic OBs	0	
Minimum cycle time	1ms					
Communication load						
Cycle load due to communication	20%					
System and clock memory\System memory bits						
Enable the use of system memory byte	0	Address of system memory byte (MBx)	1	First cycle		
Diagnostic status changed		Always 1 (high)		Always 0 (low)		
System and clock memory\Clock memory bits						
Enable the use of clock memory byte	0	Address of clock memory byte (MBx)	0	10 Hz clock		
5 Hz clock		2.5 Hz clock		2 Hz clock		
1.25 Hz clock		1 Hz clock		0.625 Hz clock		
0.5 Hz clock						
Web server\General						
Activate Web server on all modules of this device	False	Permit access only with HTTPS	True			
Web server\Automatic update						
Enable automatic update	True	Update interval	0s			
Web server\User interface languages						
Assign project language			User interface languages			
English (United States)			German			
English (United States)			English			
English (United States)			French			
English (United States)			Spanish			
English (United States)			Italian			
English (United States)			Chinese (simplified)			
Web server\User management						
User name			User rights			
Everybody						
Web server\User-defined web pages						
Application name	HTML source path	Default HTML page	Files with dynamic content	Web DB number	Fragment DB number	
		index.htm	.htm;.html	333	334	
Web server\Overview of interfaces						
Device		Interface		Enabled web server access		
PLC_3		PROFINET interface_1		False		
User interface languages						
Assign project language			User interface languages			
English (United States)			German			
English (United States)			English			
English (United States)			French			
English (United States)			Spanish			
English (United States)			Italian			
English (United States)			Chinese (simplified)			
Time of day\Local time						
Time zone	(UTC +01:00) Berlin, Bern, Brussels, Rome, Stockholm, Vienna					
Time of day\Daylight saving time						
Activate daylight saving time	1	Difference between standard and daylight saving time	60mins			
Time of day\Daylight saving time\Start of daylight saving time						
Starting week of the month:	Last		Sunday	of	March	
at	01:00 a.m.					
Time of day\Daylight saving time\Start of standard time						
	Last		Sunday	of	October	
at	02:00 a.m.					
Protection & Security						
Level of protection	No protection					
Protection & Security\Connection mechanisms						
Permit access with PUT/GET communication from remote partner	True					
Protection & Security\Security event						
Summarize security events in case of high message volume	True		Length of an interval	20	Unit	seconds

Totally Integrated Automation Portal

Protection & Security

External load memory

Disable copying from internal load memory to external load memory

False

Configuration control

Configuration control for central configuration

Allow to reconfigure the device via the user program

0

Connection resources

	Station resources - Reserved - Maximum	Station resources - Reserved - Configured	Station resources - Dynamic - Configured	Module resources - PLC_3 [CPU 1215C DC/DC/DC] - Configured
Maximum number of resources:		62	6	68
	Maximum	Configured	Configured	Configured
PG communication:	4	-	-	-
HMI communication:	12	1	0	1
S7 communication:	8	0	0	0
Open user communication:	8	0	0	0
Web communication:	30	-	-	-
Other communication:	-	-	0	0
Total resources used:		1	0	1
Available resources:		61	6	67

Overview of addresses

Overview of addresses

Overview of addresses

Inputs	True	Outputs	True	Address gaps	False					
Slot	True									
Type	Addr. from	Addr. to	Module	PIP	Device name	Device number	Size	Master / IO system	Rack	Slot
I	0	1	DI 14/DQ 10_1	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	2 Bytes	-	0	1 1
O	0	1	DI 14/DQ 10_1	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	2 Bytes	-	0	1 1
I	64	67	AI 2/AQ 2_1	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 2
O	64	67	AI 2/AQ 2_1	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 2
I	1000	1003	HSC_1	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 16
I	1004	1007	HSC_2	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 17
I	1008	1011	HSC_3	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 18
I	1012	1015	HSC_4	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 19
I	1016	1019	HSC_5	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 20
I	1020	1023	HSC_6	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 21
O	1000	1001	Pulse_1	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	2 Bytes	-	0	1 32
O	1002	1003	Pulse_2	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	2 Bytes	-	0	1 33
O	1004	1005	Pulse_3	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	2 Bytes	-	0	1 34
O	1006	1007	Pulse_4	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	2 Bytes	-	0	1 35

Proyecto_final / PLC_3 [CPU 1215C DC/DC/DC] / Program blocks

Main [OB1]


Main Properties							
General							
Name	Main	Number	1	Type	OB	Language	LAD
Numbering	Automatic						
Information							
Title	Empacadora circular	Author		Comment		Family	
Version	0.1	User-defined ID					


Name	Data type	Default value	Comment
▼ Input			
Initial_Call	Bool		Initial call of this OB
Remanence	Bool		=True, if remanent data are available
Temp			
Constant			

Network 1: Control Motor




Network 2: Botones físicos

[illegible]



Network 4: Robot_UR



Totally Integrated Automation Portal

Proyecto_final / PLC_3 [CPU 1215C DC/DC/DC] / Program blocks

PLC3_emp [DB3]

PLC3_emp Properties

General

Name	PLC3_emp	Number	3	Type	DB	Language	DB
Numbering	Automatic						

Information

Title		Author		Comment		Family	
Version	0.1	User-defined ID					

Name	Data type	Offset	Start value	Retain	Accessi-ble from HMI/OPC UA	Writ-able from HMI/OPC UA	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Static										
Emp_estado	Bool	0.0	false	False	True	True	True	False		
Emp_especial	UInt	2.0	0	False	True	True	True	False		
Emp_detección	Bool	4.0	false	False	True	True	True	False		
Emp_progreso	Int	6.0	0	False	True	True	True	False		
UR_Estado	Bool	8.0	false	False	True	True	True	False		
UR_Progreso	Int	10.0	0	False	True	True	True	False		
UR_especial	UInt	12.0	0	False	True	True	True	False		

Totally Integrated Automation Portal

Proyecto_final / PLC_3 [CPU 1215C DC/DC/DC] / Program blocks / System blocks / Program resources

IEC_Timer_0_DB [DB1]

IEC_Timer_0_DB Properties

General

Name	IEC_Timer_0_DB	Number	1	Type	DB	Language	DB
Numbering	Automatic						

Information

Title		Author	Simatic	Comment		Family	IEC
Version	1.0	User-defined ID	IEC_TMR				

Name	Data type	Start value	Retain	Accessible from HMI/OPC UA	Writ-able from HMI/OPC UA	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Static									
PT	Time	T#0ms	False	True	True	True	False		
ET	Time	T#0ms	False	True	False	True	False		
IN	Bool	false	False	True	True	True	False		
Q	Bool	false	False	True	False	True	False		

Totally Integrated Automation Portal

Proyecto_final / PLC_3 [CPU 1215C DC/DC/DC] / Program blocks / System blocks / Program resources

IEC_Counter_0_DB [DB2]

IEC_Counter_0_DB Properties

General

Name	IEC_Counter_0_DB	Number	2	Type	DB	Language	DB
Numbering	Automatic						

Information

Title		Author	Simatic	Comment		Family	IEC
Version	1.0	User-defined ID	CNTR				

Name	Data type	Start value	Retain	Accessible from HMI/OPC UA	Writ-able from HMI/OPC UA	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Static									
CU	Bool	false	True	True	True	True	False		
CD	Bool	false	True	True	True	True	False		
R	Bool	false	True	True	True	True	False		
LD	Bool	false	True	True	True	True	False		
QU	Bool	false	True	True	True	True	False		
QD	Bool	false	True	True	True	True	False		
PV	Int	0	True	True	True	True	False		
CV	Int	0	True	True	True	True	False		

Totally Integrated Automation Portal

Proyecto_final / PLC_3 [CPU 1215C DC/DC/DC] / Program blocks / System blocks / Program resources

IEC_Timer_0_DB_1 [DB4]

IEC_Timer_0_DB_1 Properties

General

Name	IEC_Timer_0_DB_1	Number	4	Type	DB	Language	DB
Numbering	Automatic						

Information

Title		Author	Simatic	Comment		Family	IEC
Version	1.0	User-defined ID	IEC_TMR				

Name	Data type	Start value	Retain	Accessible from HMI/OPC UA	Writ-able from HMI/OPC UA	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Static									
PT	Time	T#0ms	False	True	True	True	False		
ET	Time	T#0ms	False	True	False	True	False		
IN	Bool	false	False	True	True	True	False		
Q	Bool	false	False	True	False	True	False		

Totally Integrated Automation Portal

Proyecto_final / PLC_3 [CPU 1215C DC/DC/DC] / Program blocks / System blocks / Program resources

IEC_Counter_0_DB_1 [DB5]

IEC_Counter_0_DB_1 Properties

General

Name	IEC_Counter_0_DB_1	Number	5	Type	DB	Language	DB
Numbering	Automatic						

Information

Title		Author	Simatic	Comment		Family	IEC
Version	1.0	User-defined ID	CNTR				

Name	Data type	Start value	Retain	Accessible from HMI/OPC UA	Writ-able from HMI/OPC UA	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Static									
CU	Bool	false	True	True	True	True	False		
CD	Bool	false	True	True	True	True	False		
R	Bool	false	True	True	True	True	False		
LD	Bool	false	True	True	True	True	False		
QU	Bool	false	True	True	True	True	False		
QD	Bool	false	True	True	True	True	False		
PV	Int	0	True	True	True	True	False		
CV	Int	0	True	True	True	True	False		

Totally Integrated Automation Portal

Proyecto_final / PLC_3 [CPU 1215C DC/DC/DC] / Program blocks / System blocks / Program resources

IEC_Timer_0_DB_2 [DB6]

IEC_Timer_0_DB_2 Properties

General


















Name	IEC_Timer_0_DB_2	Number	6	Type	DB	Language	DB
Numbering	Automatic						

Information

Title		Author	Simatic	Comment		Family	IEC
Version	1.0	User-defined ID	IEC_TMR				

Name	Data type	Start value	Retain	Accessible from HMI/OPC UA	Writ-able from HMI/OPC UA	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Static									
PT	Time	T#0ms	False	True	True	True	False		
ET	Time	T#0ms	False	True	False	True	False		
IN	Bool	false	False	True	True	True	False		
Q	Bool	false	False	True	False	True	False		

Totally Integrated Automation Portal		
<div>Proyecto_final / PLC_3 [CPU 1215C DC/DC/DC]</div> <div>Technology objects</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal									
Proyecto_final / PLC_3 [CPU 1215C DC/DC/DC] / PLC tags / Default tag table [46]									
PLC tags									
PLC tags									
	Name	Data type	Address	Retain	Accessi-ble from HMI/OPC UA	Writable from HMI/OPC UA	Visible in HMI engi-neering	Supervision	Comment
	Emp_Estado	Bool	%M4.0	False	True	True	True		
	Emp_Especial	UInt	%MW0	False	True	True	True		
	Emp_Detección	Bool	%M4.1	False	True	True	True		
	Emp_Progreso	Int	%MW2	False	True	True	True		
	Start	Bool	%I1.3	False	True	True	True		
	Reiniciar	Bool	%I1.4	False	True	True	True		
	Skip	Bool	%I1.5	False	True	True	True		
	Encendido	Bool	%M4.2	False	True	True	True		
	Motor	Bool	%Q0.2	False	True	True	True		
	Fin	Bool	%M4.3	False	True	True	True		
	Reset	Bool	%M4.4	False	True	True	True		
	Detector	Bool	%I0.0	False	True	True	True		
	Emp_progreso_trans	Int	%MW5	False	True	True	True		
	UR_Q0	Bool	%Q0.4	False	True	True	True		
	UR_pulsos	Bool	%I0.4	False	True	True	True		
	Reset_UR	Bool	%M8.0	False	True	True	True		
	Progress_ur_trans	Int	%MW9	False	True	True	True		

User constants

User constants			
Name	Data type	Value	Comment

Totally Integrated Automation Portal		
<div>Proyecto_final / PLC_3 [CPU 1215C DC/DC/DC] / PLC data types</div> <div>System data types</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal							
<div>Proyecto_final / PLC_3 [CPU 1215C DC/DC/DC] / Watch and force tables</div> <div>Force table</div> <table><thead><tr><th>Name</th><th>Address</th><th>Display format</th><th>Force value</th><th>Comment</th></tr></thead><tbody></tbody></table>			Name	Address	Display format	Force value	Comment
Name	Address	Display format	Force value	Comment			

Totally Integrated Automation Portal			
<div>Proyecto_final / PLC_3 [CPU 1215C DC/DC/DC]</div> <div>Traces</div> <table><tr><th>Name</th></tr></table>			Name
Name			

Totally Integrated Automation Portal		
<div>Proyecto_final / PLC_3 [CPU 1215C DC/DC/DC] / Traces</div> <div>Measurements</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / PLC_3 [CPU 1215C DC/DC/DC] / Traces</div> <div>Combined measurements</div> <div><div>Name</div></div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / PLC_3 [CPU 1215C DC/DC/DC]</div> <div>PLC alarm text lists</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal						
--------------------------------------	--	--	--	--	--	--

Proyecto_final / PLC_3 [CPU 1215C DC/DC/DC] / Local modules

PLC_3 [CPU 1215C DC/DC/DC]

PLC_3

General\Project information

Name	PLC_3	Author	192072	Comment	
Slot	1	Rack	0		

General\Catalog information

Short designation	CPU 1215C DC/DC/DC	Description	Work memory 125 KB; 24VDC power supply with DI14 x 24VDC SINK/ SOURCE, DQ10 x 24VDC and AI2 and AQ2 on board; 6 high-speed counters and 4 pulse outputs on board; signal board expands on-board I/O; up to 3 communication modules for serial communication; up to 8 signal modules for I/O expansion; 0.04 ms/1000 instructions; 2 PROFINET ports for programming, HMI and PLC-to-PLC communication	Article number	6ES7 215-1AG40-0XB0
Firmware version	V4.2				

General\Identification & Maintenance

Plant designation		Location identifier		Installation date	2025-05-01 19:30:34.594
Additional information					

General\Checksums

Text lists	FA 70 E8 75 1D 5A 8E 29	Software	42 96 C8 30 73 B2 47 3E		
------------	-------------------------	----------	-------------------------	--	--

PROFINET interface [X1]\General

Name	PROFINET interface_1	Author	192072	Comment	
------	----------------------	--------	--------	---------	--

PROFINET interface [X1]\General\Project information

Name	DI 14/DQ 10_1	Comment		Name	AI 2/AQ 2_1
Comment					

PROFINET interface [X1]\Ethernet addresses\Interface networked with

Subnet:	PN/IE_3				
---------	---------	--	--	--	--

PROFINET interface [X1]\Ethernet addresses\IP protocol

IP configuration	Set IP address in the project	IP address:	192.168.0.4	Subnet mask:	255.255.255.0
Use router	False				

PROFINET interface [X1]\Ethernet addresses\PROFINET

PROFINET device name is set directly at the device	False	Generate PROFINET device name automatically	True	PROFINET device name:	plc_3
Converted name:	plcxb3116c	Device number:	0		

PROFINET interface [X1]\Time synchronization

Enable time synchronization via NTP server	Enable time synchronization via NTP server		IP addresses	Server 1	0.0.0.0
Server 2	0.0.0.0	Server 3	0.0.0.0	Server 4	0.0.0.0
Update interval	10sec	Empty		CPU synchronizes the modules of the device.	No synchronization

PROFINET interface [X1]\Digital inputs\Channel0

Channel address	I0.0	Input filters	6.4 millisec	Enable pulse catch	0
-----------------	------	---------------	--------------	--------------------	---

PROFINET interface [X1]\Digital inputs\Channel0\

Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49152	Event name:	0
Hardware interrupt:	0	Rising edge0	Rising edge0		

PROFINET interface [X1]\Digital inputs\Channel0\

Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49280	Event name:	0
Hardware interrupt:	0	Falling edge0	Falling edge0		

PROFINET interface [X1]\Digital inputs\Channel1

Channel address	I0.1	Input filters	6.4 millisec	Enable pulse catch	0
-----------------	------	---------------	--------------	--------------------	---

PROFINET interface [X1]\Digital inputs\Channel1\

Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49153	Event name:	0
Hardware interrupt:	0	Rising edge1	Rising edge1		

PROFINET interface [X1]\Digital inputs\Channel1\

Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49281	Event name:	0
Hardware interrupt:	0	Falling edge1	Falling edge1		

PROFINET interface [X1]\Digital inputs\Channel2

Channel address	I0.2	Input filters	6.4 millisec	Enable pulse catch	0
-----------------	------	---------------	--------------	--------------------	---

PROFINET interface [X1]\Digital inputs\Channel2\

Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49154	Event name:	0
Hardware interrupt:	0	Rising edge2	Rising edge2		

PROFINET interface [X1]\Digital inputs\Channel2\

Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49282	Event name:	0
Hardware interrupt:	0	Falling edge2	Falling edge2		

PROFINET interface [X1]\Digital inputs\Channel3



Channel address	I0.3	Input filters	6.4 millisec	Enable pulse catch	0
-----------------	------	---------------	--------------	--------------------	---

PROFINET interface [X1]\Digital inputs\Channel3\

Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49155	Event name:	0
Hardware interrupt:	0	Rising edge3	Rising edge3		

Totally Integrated Automation Portal						
PROFINET interface [X1]\Digital inputs\Channel3\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49283	Event name:	0	
Hardware interrupt:	0	Falling edge3	Falling edge3			
PROFINET interface [X1]\Digital inputs\Channel4						
Channel address	I0.4	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel4\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49156	Event name:	0	
Hardware interrupt:	0	Rising edge4	Rising edge4			
PROFINET interface [X1]\Digital inputs\Channel4\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49284	Event name:	0	
Hardware interrupt:	0	Falling edge4	Falling edge4			
PROFINET interface [X1]\Digital inputs\Channel5						
Channel address	I0.5	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel5\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49157	Event name:	0	
Hardware interrupt:	0	Rising edge5	Rising edge5			
PROFINET interface [X1]\Digital inputs\Channel5\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49285	Event name:	0	
Hardware interrupt:	0	Falling edge5	Falling edge5			
PROFINET interface [X1]\Digital inputs\Channel6						
Channel address	I0.6	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel6\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49158	Event name:	0	
Hardware interrupt:	0	Rising edge6	Rising edge6			
PROFINET interface [X1]\Digital inputs\Channel6\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49286	Event name:	0	
Hardware interrupt:	0	Falling edge6	Falling edge6			
PROFINET interface [X1]\Digital inputs\Channel7						
Channel address	I0.7	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel7\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49159	Event name:	0	
Hardware interrupt:	0	Rising edge7	Rising edge7			
PROFINET interface [X1]\Digital inputs\Channel7\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49287	Event name:	0	
Hardware interrupt:	0	Falling edge7	Falling edge7			
PROFINET interface [X1]\Digital inputs\Channel8						
Channel address	I1.0	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel8\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49160	Event name:	0	
Hardware interrupt:	0	Rising edge8	Rising edge8			
PROFINET interface [X1]\Digital inputs\Channel8\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49288	Event name:	0	
Hardware interrupt:	0	Falling edge8	Falling edge8			
PROFINET interface [X1]\Digital inputs\Channel9						
Channel address	I1.1	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel9\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49161	Event name:	0	
Hardware interrupt:	0	Rising edge9	Rising edge9			
PROFINET interface [X1]\Digital inputs\Channel9\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49289	Event name:	0	
Hardware interrupt:	0	Falling edge9	Falling edge9			
PROFINET interface [X1]\Digital inputs\Channel10						
Channel address	I1.2	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel10\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49162	Event name:	0	
Hardware interrupt:	0	Rising edge10	Rising edge10			
PROFINET interface [X1]\Digital inputs\Channel10\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49290	Event name:	0	
Hardware interrupt:	0	Falling edge10	Falling edge10			
PROFINET interface [X1]\Digital inputs\Channel11						
Channel address	I1.3	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel11\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49163	Event name:	0	
Hardware interrupt:	0	Rising edge11	Rising edge11			
PROFINET interface [X1]\Digital inputs\Channel11\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49291	Event name:	0	
Hardware interrupt:	0	Falling edge11	Falling edge11			
PROFINET interface [X1]\Digital inputs\Channel12						
Channel address	I1.4	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel13						
Channel address	I1.5	Input filters	6.4 millisec	Enable pulse catch	0	

Totally Integrated Automation Portal						
PROFINET interface [X1]\Analog inputs\Noise reduction						
Integration time	50 Hz (20 ms)					
PROFINET interface [X1]\Analog inputs\Channel0						
Channel address	IW64	Measurement type	Voltage	Voltage range	0..10 V	
Smoothing	Weak (4 cycles)	Empty		Enable overflow diagnostics	1	
PROFINET interface [X1]\Analog inputs\Channel1						
Channel address	IW66	Measurement type	Voltage	Voltage range	0..10 V	
Smoothing	Weak (4 cycles)	Empty		Enable overflow diagnostics	1	
PROFINET interface [X1]\Digital outputs						
Reaction to CPU STOP	Use substitute value					
PROFINET interface [X1]\Digital outputs\Channel0						
Channel address	Q0.0	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel1						
Channel address	Q0.1	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel2						
Channel address	Q0.2	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel3						
Channel address	Q0.3	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel4						
Channel address	Q0.4	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel5						
Channel address	Q0.5	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel6						
Channel address	Q0.6	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel7						
Channel address	Q0.7	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel8						
Channel address	Q1.0	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel9						
Channel address	Q1.1	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Operating mode						
IO controller	True	IO system		Device number	0	
IO device	False					
PROFINET interface [X1]\Analog outputs						
Reaction to CPU STOP	Use substitute value					
PROFINET interface [X1]\Analog outputs\Channel0						
Channel address	QW64	Analog output type	Current	Current range	0..20 mA	
Substitute value for channel on a change from RUN to STOP	0.000mA	Empty		Enable overflow diagnostics	1	
Enable underflow diagnostics	1					
PROFINET interface [X1]\Analog outputs\Channel1						
Channel address	QW66	Analog output type	Current	Current range	0..20 mA	
Substitute value for channel on a change from RUN to STOP	0.000mA	Empty		Enable overflow diagnostics	1	
Enable underflow diagnostics	1					
PROFINET interface [X1]\I/O addresses\Input addresses						
Start address	0.0	End address	1.7	Organization block	0	
Process image	0					
PROFINET interface [X1]\I/O addresses\Input addresses						
Start address	64	End address	67	Organization block	0	
Process image	0					
PROFINET interface [X1]\I/O addresses\Output addresses						
Start address	0.0	End address	1.7	Organization block	0	
Process image	0					
PROFINET interface [X1]\I/O addresses\Output addresses						
Start address	64	End address	67	Organization block	0	
Process image	0					
PROFINET interface [X1]\Advanced options\Interface options						
Support device replacement without exchangeable medium	True	Permit overwriting of device names of all assigned IO devices	False	Use IEC V2.2 LLDP mode	False	
Keep-Alive connection monitoring:	30s					

Totally Integrated Automation Portal						
PROFINET interface [X1]\Advanced options\Real time settings\IO communication						
Send clock:	1.000ms					
PROFINET interface [X1]\Advanced options\Real time settings\Real time options						
Calculated bandwidth for cyclic IO data:	0.000ms		Calculated bandwidth for cyclic IO data:	0.000%		
PROFINET interface [X1]\Advanced options\Port [X1 P1]\General						
Name	Port_1		Author	192072		Comment
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port interconnection\Local port:						
Local port:	PLC_3\PROFINET interface_1 [X1]\Port_1 [X1 P1 R]		Medium:	Copper		Cable name: ---
						
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port interconnection\Partner port:						
	Monitoring of partner port is executed		Partner port:	HMI_3.IE_CP_1\PROFINET Interface_1 [X1]\Port_1 [X1 P1]		Medium: Copper
Cable length:						
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port options\Activate						
Activate this port for use	True					
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port options\Connection						
Transmission rate / duplex:	Automatic		Monitor	False		Enable autonegotiation True
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port options\Boundaries						
End of detection of accessible devices	False		End of topology discovery	False		End of the sync domain False
PROFINET interface [X1]\Advanced options\Port [X1 P2]\General						
Name	Port_2		Author	192072		Comment
PROFINET interface [X1]\Advanced options\Port [X1 P2]\Port interconnection\Local port:						
Local port:	PLC_3\PROFINET interface_1 [X1]\Port_2 [X1 P2 R]		Medium:	Copper		Cable name: ---
						
PROFINET interface [X1]\Advanced options\Port [X1 P2]\Port interconnection\Partner port:						
	Monitoring of partner port is not possible		Partner port:	Switch_1\SCALANCE interface_1 [X1]\Port_4 [X1 P4]		Medium: Copper
Cable length:						
PROFINET interface [X1]\Advanced options\Port [X1 P2]\Port options\Activate						
Activate this port for use	True					
PROFINET interface [X1]\Advanced options\Port [X1 P2]\Port options\Connection						
Transmission rate / duplex:	Automatic		Monitor	False		Enable autonegotiation True
PROFINET interface [X1]\Advanced options\Port [X1 P2]\Port options\Boundaries						
End of detection of accessible devices	False		End of topology discovery	False		End of the sync domain False
PROFINET interface [X1]\Web server access						
Enable Web server using this interface	False		The Web server must also be activated in the properties of the PLC.			
High speed counters (HSC)\HSC1\General\Enable						
Enable this high speed counter	0		Enable this high speed counter	0		Enable this high speed counter 0
Enable this high speed counter	0		Enable this high speed counter	0		Enable this high speed counter 0
High speed counters (HSC)\HSC1\General\Project information						
Name	HSC_1		Comment			
Comment			Name	HSC_3		
Name	HSC_4		Comment			
Comment			Name	HSC_6		
High speed counters (HSC)\HSC1\I/O addresses\Input addresses						
Start address	1000.0		End address	1003.7		Start address 1004.0
End address	1007.7		Organization block	0		Start address 1008.0
End address	1011.7		Organization block	0		Process image 0
Start address	1012.0		End address	1015.7		Organization block 0
Process image	0		Start address	1016.0		End address 1019.7
Organization block	0		Process image	0		Start address 1020.0
End address	1023.7		Organization block	0		Process image 0
Organization block	0		Process image	0		Process image 0
Pulse generators (PTO/PWM)\PTO1/PWM1\General\Enable						
Enable this pulse generator	0		Enable this pulse generator	0		
Pulse generators (PTO/PWM)\PTO1/PWM1\General\Project information						
Name	Pulse_1		Comment			
Comment			Name	Pulse_2		

Totally Integrated Automation Portal						
Pulse generators (PTO/PWM)\PTO1/PWM1\I/O addresses\Output addresses						
Start address	1000.0	End address	1001.7	Start address	1002.0	
End address	1003.7	Organization block	0	Organization block	0	
Process image	0	Process image	0			
Startup						
Startup after POWER ON	Warm restart - mode before POWER OFF	Comparison preset to actual configuration	Startup CPU even if mismatch	Configuration time	60000ms	
OBs should be interruptible	1					
Cycle						
Cycle monitoring time	150ms			Enable minimum cycle time for cyclic OBs	0	
Minimum cycle time	1ms					
Communication load						
Cycle load due to communication	20%					
System and clock memory\System memory bits						
Enable the use of system memory byte	0	Address of system memory byte (MBx)	1	First cycle		
Diagnostic status changed		Always 1 (high)		Always 0 (low)		
System and clock memory\Clock memory bits						
Enable the use of clock memory byte	0	Address of clock memory byte (MBx)	0	10 Hz clock		
5 Hz clock		2.5 Hz clock		2 Hz clock		
1.25 Hz clock		1 Hz clock		0.625 Hz clock		
0.5 Hz clock						
Web server\General						
Activate Web server on all modules of this device	False	Permit access only with HTTPS	True			
Web server\Automatic update						
Enable automatic update	True	Update interval	0s			
Web server\User interface languages						
Assign project language			User interface languages			
English (United States)			German			
English (United States)			English			
English (United States)			French			
English (United States)			Spanish			
English (United States)			Italian			
English (United States)			Chinese (simplified)			
Web server\User management						
User name			User rights			
Everybody						
Web server\User-defined web pages						
Application name	HTML source path	Default HTML page	Files with dynamic content	Web DB number	Fragment DB number	
		index.htm	.htm;.html	333	334	
Web server\Overview of interfaces						
Device		Interface		Enabled web server access		
PLC_3		PROFINET interface_1		False		
User interface languages						
Assign project language			User interface languages			
English (United States)			German			
English (United States)			English			
English (United States)			French			
English (United States)			Spanish			
English (United States)			Italian			
English (United States)			Chinese (simplified)			
Time of day\Local time						
Time zone	(UTC +01:00) Berlin, Bern, Brussels, Rome, Stockholm, Vienna					
Time of day\Daylight saving time						
Activate daylight saving time	1	Difference between standard and daylight saving time	60mins			
Time of day\Daylight saving time\Start of daylight saving time						
Starting week of the month:	Last		Sunday	of	March	
at	01:00 a.m.					
Time of day\Daylight saving time\Start of standard time						
	Last		Sunday	of	October	
at	02:00 a.m.					
Protection & Security						
Level of protection	No protection					
Protection & Security\Connection mechanisms						
Permit access with PUT/GET communication from remote partner	True					
Protection & Security\Security event						
Summarize security events in case of high message volume	True		Length of an interval	20	Unit	seconds

Totally Integrated Automation Portal

Protection & Security

External load memory

Disable copying from internal load memory to external load memory

False

Configuration control

Configuration control for central configuration

Allow to reconfigure the device via the user program

0

Connection resources

	Station resources - Reserved - Maximum	Station resources - Reserved - Configured	Station resources - Dynamic - Configured	Module resources - PLC_3 [CPU 1215C DC/DC/DC] - Configured
Maximum number of resources:		62	6	68
	Maximum	Configured	Configured	Configured
PG communication:	4	-	-	-
HMI communication:	12	1	0	1
S7 communication:	8	0	0	0
Open user communication:	8	0	0	0
Web communication:	30	-	-	-
Other communication:	-	-	0	0
Total resources used:		1	0	1
Available resources:		61	6	67

Overview of addresses

Overview of addresses

Overview of addresses

Inputs	True	Outputs	True	Address gaps	False
Slot	True				

Type	Addr. from	Addr. to	Module	PIP	Device name	Device number	Size	Master / IO system	Rack	Slot
I	0	1	DI 14/DQ 10_1	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	2 Bytes	-	0	1 1
O	0	1	DI 14/DQ 10_1	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	2 Bytes	-	0	1 1
I	64	67	AI 2/AQ 2_1	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 2
O	64	67	AI 2/AQ 2_1	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 2
I	1000	1003	HSC_1	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 16
I	1004	1007	HSC_2	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 17
I	1008	1011	HSC_3	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 18
I	1012	1015	HSC_4	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 19
I	1016	1019	HSC_5	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 20
I	1020	1023	HSC_6	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	4 Bytes	-	0	1 21
O	1000	1001	Pulse_1	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	2 Bytes	-	0	1 32
O	1002	1003	Pulse_2	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	2 Bytes	-	0	1 33
O	1004	1005	Pulse_3	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	2 Bytes	-	0	1 34
O	1006	1007	Pulse_4	Automatic update	PLC_3 [CPU 1215C DC/DC/DC]	-	2 Bytes	-	0	1 35

Totally Integrated Automation Portal				
<div>Proyecto_final</div> <div>HMI_1 [KTP400 Basic PN]</div> <div><div>HMI_1</div><div>General</div><div><table><tr><td>Name</td><td>HMI_1</td></tr></table></div></div>			Name	HMI_1
Name	HMI_1			

Totally Integrated Automation Portal

Proyecto_final / HMI_1 [KTP400 Basic PN]

Runtime settings

General

Start screen	Banda transportadora	Default template		Default style of the project	Enabled
Style of the HMI device	WinCC Dark V 1.0.1	Adapt font size to style	Enabled	Screen resolution	480, 272
Project ID	0	Logging language	Startup language		

Services

Sm@rtAccess or service: start Sm@rtServer	Disabled
---	----------

Screens

Bit selection for text and graphic lists	Off	User-defined pictogram size	Disabled	X,Y:	64, 45
Scrolling mode	Scroll bar				

Keyboard

Use screen keyboard	Enabled	Release button on exit	Disabled	Disable dialog window function keys	Disabled
---------------------	---------	------------------------	----------	-------------------------------------	----------

Alarms

Controller alarms

Buffer overflow	10 %	Acknowledgment group text	QGR	Use alarm class color	Disabled
Use help texts for system diagnostics	Enabled	System event duration	2 Seconds	PersistentAlarmBuffer	Enabled
Connection	HMI_Connection_1				

User administration

Enable limit for logon attempts	Enabled	Invalid logon attempts	3	Logon with password	Disabled
Group-specific rights	Disabled	Password aging	Disabled	Validity period	90
Warning period	7	Password generations	3	At least one special character	Disabled
At least one number	Disabled	Minimum password length	3		

Language & font

Preset runtime language	English (United States)
-------------------------	-------------------------

English (United States)

Runtime language	Enabled	Fixed font 1	Tahoma	Default font	Tahoma, 11 Pixel
Configured font 1					

Tag settings

Replace the separators on each sub-level of the path of the PLC tag:	Enabled	Compatibility mode: Set '_' between the PLC tags and the first-level element.	Disabled	Replace the '.' character if the name of the HMI tag is created from the PLC tag name	Enabled
Use '_' as the replacement character	Enabled	Use ';' as the replacement character	Disabled	Replace the characters '[' and ']' if the name of the HMI tag is created from the PLC tag name	Enabled
Use '{' and '}' as replacement characters	Enabled	Use '(' and ')' as replacement characters	Disabled		

Settings for the prefix 'PLC' in the HMI tag name

Connection	HMI_Connection_1	PLC name as prefix in the HMI tag name	Disabled
------------	------------------	--	----------

Banda transportadora

Hardcopy of Banda transportadora



General					
Name	Banda transportadora	Background color	0, 0, 0	Grid color	0, 0, 0
Number	2	Template		Tooltip	
Layers					
Active layer	0				

Layer_0	Enabled
Layer_1	Enabled
Layer_2	Enabled
Layer_3	Enabled
Layer_4	Enabled
Layer_5	Enabled
Layer_6	Enabled
Layer_7	Enabled
Layer_8	Enabled
Layer_9	Enabled
Layer_10	Enabled
Layer_11	Enabled
Layer_12	Enabled
Layer_13	Enabled
Layer_14	Enabled
Layer_15	Enabled
Layer_16	Enabled
Layer_17	Enabled
Layer_18	Enabled
Layer_19	Enabled
Layer_20	Enabled
Layer_21	Enabled
Layer_22	Enabled
Layer_23	Enabled
Layer_24	Enabled
Layer_25	Enabled
Layer_26	Enabled
Layer_27	Enabled
Layer_28	Enabled
Layer_29	Enabled
Layer_30	Enabled
Layer_31	Enabled

Text field_2

Type	Text field				
General					
Text	Estado:				
Appearance					
Background color	255, 255, 255	Background fill pattern	Transparent	Corner radius (border)	3
Foreground color	255, 255, 255	Border width	0	Line style	Double line
Border color	66, 73, 82	Border background color	99, 101, 115		
Layout					
X position	89	Y position	81	Width	79
Height	28	Left margin	3	Top margin	2
Right margin	2	Bottom margin	2	Fit object to contents	Enabled
Text format					
Font	Tahoma, 20px, style=Bold	Orientation	Horizontal	Horizontal alignment	Right
Vertical alignment	Middle	Line break	Disabled		
Flashing					
Flashing	Disabled				
Styles/Designs					
Use style/design	Disabled	Style item appearance			

Totally Integrated Automation Portal						
Miscellaneous						
Name	Text field_2	Layer	0 - Layer_0			
Text field_3						
Type	Text field					
General						
Text	Dirección:					
Appearance						
Background color	255, 255, 255	Background fill pattern	Transparent	Corner radius (border)	3	
Foreground color	255, 255, 255	Border width	0	Line style	Double line	
Border color	66, 73, 82	Border background color	99, 101, 115			
Layout						
X position	61	Y position	129	Width	107	
Height	28	Left margin	3	Top margin	2	
Right margin	2	Bottom margin	2	Fit object to contents	Enabled	
Text format						
Font	Tahoma, 20px, style=Bold	Orientation	Horizontal	Horizontal alignment	Right	
Vertical alignment	Middle	Line break	Disabled			
Flashing						
Flashing	Disabled					
Styles/Designs						
Use style/design	Disabled	Style item appearance				
Miscellaneous						
Name	Text field_3	Layer	0 - Layer_0			
Button_2						
Type	Button					
General						
Mode	Text	Hotkey	None	Text OFF	Adelante	
Text ON	Text	Text list		Graphic OFF		
Graphic ON		Graphic list		Process value		
Bit number	0					
Appearance						
Background color	99, 101, 115	Background fill pattern	Vertical gradient	Corner radius (border)	3	
Foreground color	255, 255, 255	Border width	2	Line style	Solid	
Border color	66, 73, 82	Border background color	107, 105, 107			
Fill pattern						
Background color gradient (fill pattern)	99, 101, 115	Gradient 1 (fill pattern)	Enabled	Color gradient 1 (fill pattern)	132, 134, 140	
Offset gradient 1 (fill pattern)	15	Gradient 2 (fill pattern)	Enabled	Color gradient 2 (fill pattern)	90, 89, 99	
Offset gradient 2 (fill pattern)	15					
Design						
Focus width	2	Focus color	148, 182, 231			
Layout						
X position	214	Y position	193	Width	96	
Height	55	Fit graphic to size	Stretch graphic	Horizontal alignment of the graphic	Centered	
Vertical alignment of the graphic	Middle	Fit object to contents	Disabled	Margin left text (layout)	0	
Margin top text (layout)	0	Margin right text (layout)	0	Margin bottom text (layout)	0	
Margin left graphic (layout)	0	Margin top graphic (layout)	0	Margin right graphic (layout)	0	
Margin bottom graphic (layout)	0					
Text format						
Font	Tahoma, 13px, style=Bold	Orientation	Horizontal	Horizontal alignment of the text	Centered	
Vertical alignment of the text	Middle					
Styles/Designs						
Use style/design	Disabled	Style item appearance				
Miscellaneous						
Name	Button_2	Layer	0 - Layer_0	Tooltip		
Security						
Authorization		Allow operator control	Enabled			
Dynamizations\Event						
Event name		Click				
Function list\SetTag						
Tag	Dirección		Value	1		
Button_3						
Type	Button					
General						
Mode	Text	Hotkey	None	Text OFF	Reversa	

Totally Integrated Automation Portal						
--------------------------------------	--	--	--	--	--	--

Text ON	Text	Text list		Graphic OFF	
Graphic ON		Graphic list		Process value	
Bit number	0				
Appearance					
Background color	99, 101, 115	Background fill pattern	Vertical gradient	Corner radius (border)	3
Foreground color	255, 255, 255	Border width	2	Line style	Solid
Border color	66, 73, 82	Border background color	107, 105, 107		
Fill pattern					
Background color gradient (fill pattern)	99, 101, 115	Gradient 1 (fill pattern)	Enabled	Color gradient 1 (fill pattern)	132, 134, 140
Offset gradient 1 (fill pattern)	15	Gradient 2 (fill pattern)	Enabled	Color gradient 2 (fill pattern)	90, 89, 99
Offset gradient 2 (fill pattern)	15				
Design					
Focus width	2	Focus color	148, 182, 231		
Layout					
X position	348	Y position	192	Width	96
Height	55	Fit graphic to size	Stretch graphic	Horizontal alignment of the graphic	Centered
Vertical alignment of the graphic	Middle	Fit object to contents	Disabled	Margin left text (layout)	0
Margin top text (layout)	0	Margin right text (layout)	0	Margin bottom text (layout)	0
Margin left graphic (layout)	0	Margin top graphic (layout)	0	Margin right graphic (layout)	0
Margin bottom graphic (layout)	0				
Text format					
Font	Tahoma, 13px, style=Bold	Orientation	Horizontal	Horizontal alignment of the text	Centered
Vertical alignment of the text	Middle				
Styles/Designs					
Use style/design	Disabled	Style item appearance			
Miscellaneous					
Name	Button_3	Layer	0 - Layer_0	Tooltip	
Security					
Authorization		Allow operator control	Enabled		

Dynamizations\Event

Event name	Click
------------	-------

Function list\SetTag

Tag	Dirección	Value	2
-----	-----------	-------	---

Graphic view_1

Type	Graphic view				
General					
Graphic	Logo of HMI_1				
Appearance					
Background color	173, 174, 181	Background fill pattern	Solid	Border width	0
Line style	Solid	Border color	0, 0, 0		
Layout					
X position	0	Y position	3	Width	176
Height	48	Fit embedded graphic object to screen size	Fit graphic to object size	Fit graphic to size	Stretch graphic
Fit object to contents	Disabled				
Miscellaneous					
Name	Graphic view_1	Layer	0 - Layer_0		

Text field_6

Type	Text field				
General					
Text	Banda transportadora				
Appearance					
Background color	255, 255, 255	Background fill pattern	Transparent	Corner radius (border)	3
Foreground color	255, 255, 255	Border width	0	Line style	Double line
Border color	66, 73, 82	Border background color	99, 101, 115		
Layout					
X position	179	Y position	6	Width	265
Height	33	Left margin	3	Top margin	2
Right margin	2	Bottom margin	2	Fit object to contents	Enabled
Text format					
Font	Tahoma, 24px, style=Bold	Orientation	Horizontal	Horizontal alignment	Left
Vertical alignment	Middle	Line break	Disabled		
Flashing					
Flashing	Disabled				

--	--	--


Totally Integrated Automation Portal						
Styles/Designs						
Use style/design	Disabled	Style item appearance				
Miscellaneous						
Name	Text field_6	Layer	0 - Layer_0			
Switch_1						
Type	Switch					
General						
Process value		Value status ON	1	Mode	Switch	
Text ON	Encendio	Text OFF	Apagado	Graphic ON		
Graphic OFF						
Appearance						
Foreground color	255, 255, 255	Background color	99, 101, 115	Inner background color ON	0, 255, 0	
Inner background color OFF	255, 0, 0	Border width	2	Line style	Solid	
Border color	66, 73, 82	Border background color	107, 105, 107	Corner radius	3	
Fill pattern						
Background fill pattern	Vertical gradient	Background color gradient (fill pattern)	99, 101, 115	Gradient 1 (fill pattern)	Enabled	
Color gradient 1 (fill pattern)	132, 134, 140	Offset gradient 1 (fill pattern)	15	Gradient 2 (fill pattern)	Enabled	
Color gradient 2 (fill pattern)	90, 89, 99	Offset gradient 2 (fill pattern)	15			
Design						
Focus width	2	Focus color	148, 182, 231			
Layout						
X position	22	Y position	196	Width	147	
Height	51	Fit graphic to size	Stretch graphic	Horizontal alignment of the graphic	Centered	
Vertical alignment of the graphic	Middle	Switch orientation	Left to right	Fit object to contents	Disabled	
Margin left text (layout)	0	Margin top text (layout)	0	Margin right text (layout)	0	
Margin bottom text (layout)	0	Margin left graphic (layout)	0	Margin top graphic (layout)	0	
Margin right graphic (layout)	0	Margin bottom graphic (layout)	0			
Text format						
Font	Tahoma, 15px, style=Bold	Orientation	Horizontal	Horizontal alignment of the text	Centered	
Vertical alignment of the text	Middle					
Limits						
Color for High limit violated	239, 97, 99	Color for Low limit violated	255, 219, 41			
Styles/Designs						
Use style/design	Disabled	Style item appearance				
Miscellaneous						
Name	Switch_1	Layer	0 - Layer_0	Tooltip		
Security						
Authorization		Allow operator control	Enabled			
Dynamizations\Tag connection						
Property name	Process value	Tag	Estado			
Dynamizations\Event						
Event name		Switch OFF				
Function list\SetTag						
Tag	Estado		Value	0		
Dynamizations\Event						
Event name		Switch ON				
Function list\SetTag						
Tag	Estado		Value	1		
Symbolic I/O field_1						
Type	Symbolic I/O field					
General						
Process value	0	Bit number	0	Mode	Output	
Value status ON	1	Text OFF	0	Text ON	1	
Text list	Estado	Number of visible items	3			
Appearance						
Background color	255, 255, 255	Background fill pattern	Solid	Corner radius (border)	3	
Foreground color	255, 0, 0	Border width	4	Line style	Double line	
Border color	66, 73, 82	Border background color	99, 101, 115			
Design						
Foreground color of selection	255, 255, 255	Background color of selection	0, 0, 0	Alternative color	231, 231, 239	

Totally Integrated Automation Portal						
Layout						
X position	198	Y position	72	Width	155	
Height	46	Left margin	3	Top margin	2	
Right margin	2	Bottom margin	2	Fit object to contents	Disabled	
Display selection list	Disabled	Show selection field	Disabled			
Text format						
Font	Tahoma, 20px, style=Bold	Orientation	Horizontal	Horizontal alignment	Centered	
Vertical alignment	Middle					
Limits						
Color for High limit violated	239, 89, 99	Color for Low limit violated	247, 162, 41			
Styles/Designs						
Use style/design	Disabled	Style item appearance				
Miscellaneous						
Name	Symbolic I/O field_1	Layer	0 - Layer_0	Tooltip		
Security						
Authorization		Allow operator control	Enabled			
Dynamizations\Tag connection						
Property name	Process value	Tag	Estado			
Symbolic I/O field_2						
Type	Symbolic I/O field					
General						
Process value	0	Bit number	0	Mode	Output	
Value status ON	1	Text OFF	0	Text ON	1	
Text list	Dirección	Number of visible items	3			
Appearance						
Background color	255, 255, 255	Background fill pattern	Solid	Corner radius (border)	3	
Foreground color	255, 0, 0	Border width	4	Line style	Double line	
Border color	66, 73, 82	Border background color	99, 101, 115			
Design						
Foreground color of selection	255, 255, 255	Background color of selection	0, 0, 0	Alternative color	231, 231, 239	
Layout						
X position	198	Y position	121	Width	155	
Height	46	Left margin	3	Top margin	2	
Right margin	2	Bottom margin	2	Fit object to contents	Disabled	
Display selection list	Disabled	Show selection field	Disabled			
Text format						
Font	Tahoma, 20px, style=Bold	Orientation	Horizontal	Horizontal alignment	Centered	
Vertical alignment	Middle					
Limits						
Color for High limit violated	239, 89, 99	Color for Low limit violated	247, 162, 41			
Styles/Designs						
Use style/design	Disabled	Style item appearance				
Miscellaneous						
Name	Symbolic I/O field_2	Layer	0 - Layer_0	Tooltip		
Security						
Authorization		Allow operator control	Enabled			
Dynamizations\Tag connection						
Property name	Process value	Tag	Dirección			

Proyecto_final / HMI_1 [KTP400 Basic PN] / Screen management / Templates

Template_1

Hardcopy of Template_1



General					
Name	Template_1	Background color	181, 182, 181	Grid color	0, 0, 0
Tab sequence in foreground	Enabled				
Layers					
Active layer	0				
Layer_0			Enabled		
Layer_1			Enabled		
Layer_2			Enabled		
Layer_3			Enabled		
Layer_4			Enabled		
Layer_5			Enabled		
Layer_6			Enabled		
Layer_7			Enabled		
Layer_8			Enabled		
Layer_9			Enabled		
Layer_10			Enabled		
Layer_11			Enabled		
Layer_12			Enabled		
Layer_13			Enabled		
Layer_14			Enabled		
Layer_15			Enabled		
Layer_16			Enabled		
Layer_17			Enabled		
Layer_18			Enabled		
Layer_19			Enabled		
Layer_20			Enabled		
Layer_21			Enabled		
Layer_22			Enabled		
Layer_23			Enabled		
Layer_24			Enabled		
Layer_25			Enabled		
Layer_26			Enabled		
Layer_27			Enabled		
Layer_28			Enabled		
Layer_29			Enabled		
Layer_30			Enabled		
Layer_31			Enabled		
Exit					
Type	Button				
General					
Mode	Graphic	Hotkey	None	Text OFF	Exit
Text ON	Exit	Text list		Graphic OFF	ExitRuntime_KTP400_Basic_PN_TR
Graphic ON	ExitRuntime_KTP400_Basic_PN_TR	Graphic list		Process value	
Bit number	0				
Appearance					
Background color	239, 235, 239	Background fill pattern	Vertical gradient	Corner radius (border)	3
Foreground color	49, 52, 74	Border width	1	Line style	Solid
Border color	156, 154, 165	Border background color	107, 105, 107		
Fill pattern					
Background color gradient (fill pattern)	231, 227, 231	Gradient 1 (fill pattern)	Enabled	Color gradient 1 (fill pattern)	247, 247, 247
Offset gradient 1 (fill pattern)	15	Gradient 2 (fill pattern)	Enabled	Color gradient 2 (fill pattern)	222, 215, 214
Offset gradient 2 (fill pattern)	15				
Design					
Focus width	2	Focus color	148, 182, 231		

--	--	--

Totally Integrated Automation Portal		
--------------------------------------	--	--

Proyecto_final / HMI_1 [KTP400 Basic PN] / Screen management

Global screen

Hardcopy of Global screen

General					
Name	Global screen	Background color	181, 182, 181	Grid color	0, 0, 0

Totally Integrated Automation Portal

Proyecto_final / HMI_1 [KTP400 Basic PN] / HMI tags

Default tag table [3]

Tag_ScreenNumber

General					
Name	Tag_ScreenNumber	Connection	<Internal tag>	Data type	UInt
Array elements	0	Length	2	Address	
Access mode	<symbolic access>	PLC tag		Coding	Binary
PLC name					
Settings					
Acquisition cycle	1 s	Acquisition mode	Cyclic in operation		
Limits					
Upper 2		Lower 2			
Linear scaling					
Linear scaling	Disabled	PLC value range end value	10	PLC value range start value	0
HMI device value range end value	100	HMI device value range start value	0		
Values					
ID tag		Start value			
Comment					
Comment		Source comment			
Multiplexing					
Multiplexing	Disabled	Index tag			

Estado

General					
Name	Estado	Connection	HMI_Connection_1	Data type	Bool
Array elements	0	Length	1	Address	
Access mode	<symbolic access>	PLC tag	PLC1_Ban.Ban_estado	Coding	Binary
PLC name		PLC_1			
Settings					
Acquisition cycle	500 ms	Acquisition mode	Cyclic in operation		
Limits					
Upper 2		Lower 2			
Linear scaling					
Linear scaling	Disabled	PLC value range end value	10	PLC value range start value	0
HMI device value range end value	100	HMI device value range start value	0		
Values					
ID tag		Start value			
Comment					
Comment		Source comment			
Multiplexing					
Multiplexing	Disabled	Index tag			

Dirección

General					
Name	Dirección	Connection	HMI_Connection_1	Data type	UInt
Array elements	0	Length	2	Address	
Access mode	<symbolic access>	PLC tag	PLC1_Ban.Ban_dirección	Coding	Binary
PLC name		PLC_1			
Settings					
Acquisition cycle	500 ms	Acquisition mode	Cyclic in operation		
Limits					
Upper 2		Lower 2			
Linear scaling					
Linear scaling	Disabled	PLC value range end value	10	PLC value range start value	0
HMI device value range end value	100	HMI device value range start value	0		
Values					
ID tag		Start value			
Comment					
Comment		Source comment			
Multiplexing					
Multiplexing	Disabled	Index tag			

Totally Integrated Automation Portal

Proyecto_final / HMI_1 [KTP400 Basic PN]

Connections

Connection_1

Name	Connection_1	Communication driver	SIMATIC S7 1200	Comment	
Online	Enabled	Station		Partner	
Node		HMI time synchronization mode	None		

Parameter

HMI device					
Interface	PROFINET (X1)	Address	192.168.0.11	Access point	S7ONLINE
PLC					
Address	192.168.0.1				

HMI_Connection_1

Name	HMI_Connection_1	Communication driver	SIMATIC S7 1500	Comment	
Online	Enabled	Station	S71500/ET200MP station_1	Partner	PLC_1
Node	CPU 1516-3 PN/DP, PROFINET interface (R0/S1)	HMI time synchronization mode	None		

Parameter

HMI device					
Interface	PROFINET (X1)	Address	192.168.0.11	Access point	S7ONLINE
PLC					
Address	192.168.0.1				

Totally Integrated Automation Portal		
<div>Proyecto_final / HMI_1 [KTP400 Basic PN] / HMI alarms</div> <div>Discrete alarms</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / HMI_1 [KTP400 Basic PN] / HMI alarms</div> <div>Analog alarms</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
--------------------------------------	--	--

Proyecto_final / HMI_1 [KTP400 Basic PN] / HMI alarms

Alarm groups

Alarm_group_1

General			
Name	Alarm_group_1	ID	1

Alarm_group_10

General			
Name	Alarm_group_10	ID	10

Alarm_group_11

General			
Name	Alarm_group_11	ID	11

Alarm_group_12

General			
Name	Alarm_group_12	ID	12

Alarm_group_13

General			
Name	Alarm_group_13	ID	13

Alarm_group_14

General			
Name	Alarm_group_14	ID	14

Alarm_group_15

General			
Name	Alarm_group_15	ID	15

Alarm_group_16

General			
Name	Alarm_group_16	ID	16

Alarm_group_2

General			
Name	Alarm_group_2	ID	2

Alarm_group_3

General			
Name	Alarm_group_3	ID	3

Alarm_group_4

General			
Name	Alarm_group_4	ID	4

Alarm_group_5

General			
Name	Alarm_group_5	ID	5

Alarm_group_6

General			
Name	Alarm_group_6	ID	6

Alarm_group_7

General			
Name	Alarm_group_7	ID	7

Alarm_group_8

General			
Name	Alarm_group_8	ID	8

Alarm_group_9

General			
Name	Alarm_group_9	ID	9

--	--	--

Totally Integrated Automation Portal

Proyecto_final / HMI_1 [KTP400 Basic PN] / HMI alarms

Alarm classes

Acknowledgement

General					
Name	Acknowledgement	Display name	A	ID	33
Common alarm class	Acknowledgement	Alarm log	<No log>		
Acknowledgment					
State machine	Alarm with single-mode acknowledg-ment				
State texts					
Text for "Incoming"	I	Text for "Outgoing"	O	Text for "Acknowl-edged"	A
Colors					
Background "Incom-ing/Acknowledged"	255, 255, 255	Background "Incom-ing"	255, 0, 0	Background "Incom-ing/Outgoing/Acknowledged"	255, 255, 255
Background "Incom-ing/Outgoing"	255, 0, 0				

Errors

General					
Name	Errors	Display name	!	ID	1
Common alarm class	<No alarm class>	Alarm log	<No log>		
Acknowledgment					
State machine	Alarm with single-mode acknowledg-ment				
State texts					
Text for "Incoming"	I	Text for "Outgoing"	O	Text for "Acknowl-edged"	A
Colors					
Background "Incom-ing/Acknowledged"	255, 255, 255	Background "Incom-ing"	255, 0, 0	Background "Incom-ing/Outgoing/Acknowledged"	255, 255, 255
Background "Incom-ing/Outgoing"	255, 0, 0				

No Acknowledgement

General					
Name	No Acknowledgement	Display name	NA	ID	34
Common alarm class	No Acknowledgement	Alarm log	<No log>		
Acknowledgment					
State machine	Alarm without acknowledgment				
State texts					
Text for "Incoming"	I	Text for "Outgoing"	O	Text for "Acknowl-edged"	A
Colors					
Background "Incom-ing/Acknowledged"	255, 255, 255	Background "Incom-ing"	255, 0, 0	Background "Incom-ing/Outgoing/Acknowledged"	255, 255, 255
Background "Incom-ing/Outgoing"	255, 0, 0				

System

General					
Name	System	Display name	\$	ID	3
Common alarm class	<No alarm class>	Alarm log	<No log>		
Acknowledgment					
State machine	Alarm without acknowledgment				
State texts					
Text for "Incoming"	I	Text for "Outgoing"	O	Text for "Acknowl-edged"	A
Colors					
Background "Incom-ing/Acknowledged"	255, 255, 255	Background "Incom-ing"	255, 255, 255	Background "Incom-ing/Outgoing/Acknowledged"	255, 255, 255
Background "Incom-ing/Outgoing"	255, 255, 255				

Warnings

General					
Name	Warnings	Display name		ID	2
Common alarm class	<No alarm class>	Alarm log	<No log>		
Acknowledgment					
State machine	Alarm without acknowledgment				
State texts					
Text for "Incoming"	I	Text for "Outgoing"	O	Text for "Acknowl-edged"	A
Colors					
Background "Incom-ing/Acknowledged"	255, 255, 255	Background "Incom-ing"	255, 255, 255	Background "Incom-ing/Outgoing/Acknowledged"	255, 255, 255

Totally Integrated Automation Portal		
Background "Incoming/Outgoing"	255, 255, 255	

Totally Integrated Automation Portal		
<div>Proyecto_final / HMI_1 [KTP400 Basic PN] / HMI alarms</div> <div>System events</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / HMI_1 [KTP400 Basic PN]</div> <div>Recipes</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / HMI_1 [KTP400 Basic PN] / Historical data</div> <div>Datalogs</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / HMI_1 [KTP400 Basic PN] / Historical data</div> <div>AlarmLogs</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / HMI_1 [KTP400 Basic PN]</div> <div>Scheduled tasks</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
--------------------------------------	--	--

Proyecto_final / HMI_1 [KTP400 Basic PN] / Text and graphic lists

Text lists

Dirección

Name	Dirección	List range	Value/Range	Comment	
Value: Default entry					
Entry type	Range	Text	Apagado		
Value: 1					
Entry type	Single value	Text	Adelante		
Value: 2					
Entry type	Single value	Text	Reversa		

Estado

Name	Estado	List range	Value/Range	Comment	
Value: Default entry					
Entry type	Range	Text	Apagado		
Value: 1					
Entry type	Single value	Text	Encendido		

TextList_OriginalScreenNames

Name	TextList_OriginalScreenNames	List range	Value/Range	Comment	
Value: 1					
Entry type	Single value	Text	Root screen		

TextList_ScreenNames

Name	TextList_ScreenNames	List range	Value/Range	Comment	
------	----------------------	------------	-------------	---------	--

Totally Integrated Automation Portal		
<div>Proyecto_final / HMI_1 [KTP400 Basic PN] / Text and graphic lists</div> <div>Graphic lists</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
--------------------------------------	--	--

Proyecto_final / HMI_1 [KTP400 Basic PN] / User administration

User

Administrator

General			
Name	Administrator	Number	1
Automatic logoff			
Automatic logoff	Enabled	Logoff time	5
Comment			
Comment	The user 'Administrator' is assigned to the 'Administrator' group.		
Groups			
Groups	Administrator group;		

--	--	--

Totally Integrated Automation Portal		
--------------------------------------	--	--

Proyecto_final / HMI_1 [KTP400 Basic PN] / User administration

Groups

Administrator group

General					
Name	Administrator group	Display name	Administrator group	Number	1
Password aging	Disabled				
Comment					
Comment	The 'Administrator' group is initially granted all rights.				
Authorizations					
Authorizations	User administration; Monitor; Oper-ate;				

Users

General					
Name	Users	Display name	Users	Number	2
Password aging	Disabled				
Comment					
Comment	The 'Users' group is initially granted 'Operating' rights.				
Authorizations					
Authorizations	Operate;				

--	--	--

Totally Integrated Automation Portal		
--------------------------------------	--	--

Proyecto_final / HMI_1 [KTP400 Basic PN] / User administration

Authorizations

Monitor

General					
Name	Monitor	Authorization	Monitor	Authorization number	2
Comment					
Comment	'Monitor' authorization.				

Operate

General					
Name	Operate	Authorization	Operate	Authorization number	3
Comment					
Comment	'Operate' authorization.				

User administration

General					
Name	User administration	Authorization	User administration	Authorization number	1
Comment					
Comment	Authorization 'User administration' for managing users in the user view in Runtime.				

--	--	--

Totally Integrated Automation Portal		
--------------------------------------	--	--

Proyecto_final

HMI_2 [KTP400 Basic PN]

HMI_2

General

Name	HMI_2
------	-------

Totally Integrated Automation Portal

Proyecto_final / HMI_2 [KTP400 Basic PN]

Runtime settings

General

Start screen	Revolvedora	Default template		Default style of the project	Enabled
Style of the HMI device	WinCC Dark V 1.0.1	Adapt font size to style	Enabled	Screen resolution	480, 272
Project ID	0	Logging language	Startup language		

Services

Sm@rtAccess or service: start Sm@rtServer	Disabled
---	----------

Screens

Bit selection for text and graphic lists	Off	User-defined pictogram size	Disabled	X,Y:	64, 45
Scrolling mode	Scroll bar				

Keyboard

Use screen keyboard	Enabled	Release button on exit	Disabled	Disable dialog window function keys	Disabled
---------------------	---------	------------------------	----------	-------------------------------------	----------

Alarms

Controller alarms

Buffer overflow	10 %	Acknowledgment group text	QGR	Use alarm class color	Disabled
Use help texts for system diagnostics	Enabled	System event duration	2 Seconds	PersistentAlarmBuffer	Enabled
Connection	HMI_Connection_3				

User administration

Enable limit for logon attempts	Enabled	Invalid logon attempts	3	Logon with password	Disabled
Group-specific rights	Disabled	Password aging	Disabled	Validity period	90
Warning period	7	Password generations	3	At least one special character	Disabled
At least one number	Disabled	Minimum password length	3		

Language & font

Preset runtime language	English (United States)
-------------------------	-------------------------

English (United States)

Runtime language	Enabled	Fixed font 1	Tahoma	Default font	Tahoma, 11 Pixel
Configured font 1					

Tag settings

Replace the separators on each sub-level of the path of the PLC tag:	Enabled	Compatibility mode: Set '_' between the PLC tags and the first-level element.	Disabled	Replace the '.' character if the name of the HMI tag is created from the PLC tag name	Enabled
Use '_' as the replacement character	Enabled	Use ';' as the replacement character	Disabled	Replace the characters '[' and ']' if the name of the HMI tag is created from the PLC tag name	Enabled
Use '{' and '}' as replacement characters	Enabled	Use '(' and ')' as replacement characters	Disabled		

Settings for the prefix 'PLC' in the HMI tag name

Connection	HMI_Connection_3	PLC name as prefix in the HMI tag name	Disabled
------------	------------------	--	----------

Proyecto_final / HMI_2 [KTP400 Basic PN] / Screens

Revolvedora

Hardcopy of Revolvedora



General					
Name	Revolvedora	Background color	0, 0, 0	Grid color	0, 0, 0
Number	2	Template		Tooltip	
Layers					
Active layer	0				

Layer_0	Enabled
Layer_1	Enabled
Layer_2	Enabled
Layer_3	Enabled
Layer_4	Enabled
Layer_5	Enabled
Layer_6	Enabled
Layer_7	Enabled
Layer_8	Enabled
Layer_9	Enabled
Layer_10	Enabled
Layer_11	Enabled
Layer_12	Enabled
Layer_13	Enabled
Layer_14	Enabled
Layer_15	Enabled
Layer_16	Enabled
Layer_17	Enabled
Layer_18	Enabled
Layer_19	Enabled
Layer_20	Enabled
Layer_21	Enabled
Layer_22	Enabled
Layer_23	Enabled
Layer_24	Enabled
Layer_25	Enabled
Layer_26	Enabled
Layer_27	Enabled
Layer_28	Enabled
Layer_29	Enabled
Layer_30	Enabled
Layer_31	Enabled

Text field_2

Type	Text field				
General					
Text	Estado:				
Appearance					
Background color	255, 255, 255	Background fill pattern	Transparent	Corner radius (border)	3
Foreground color	255, 255, 255	Border width	0	Line style	Double line
Border color	66, 73, 82	Border background color	99, 101, 115		
Layout					
X position	33	Y position	73	Width	79
Height	28	Left margin	3	Top margin	2
Right margin	2	Bottom margin	2	Fit object to contents	Enabled
Text format					
Font	Tahoma, 20px, style=Bold	Orientation	Horizontal	Horizontal alignment	Right
Vertical alignment	Middle	Line break	Disabled		
Flashing					
Flashing	Disabled				
Styles/Designs					
Use style/design	Disabled	Style item appearance			

Totally Integrated Automation Portal						
Miscellaneous						
Name	Text field_2	Layer	0 - Layer_0			
Text field_3						
Type	Text field					
General						
Text	Detección:					
Appearance						
Background color	255, 255, 255	Background fill pattern	Transparent	Corner radius (border)	3	
Foreground color	255, 255, 255	Border width	0	Line style	Double line	
Border color	66, 73, 82	Border background color	99, 101, 115			
Layout						
X position	0	Y position	133	Width	112	
Height	28	Left margin	3	Top margin	2	
Right margin	2	Bottom margin	2	Fit object to contents	Enabled	
Text format						
Font	Tahoma, 20px, style=Bold	Orientation	Horizontal	Horizontal alignment	Right	
Vertical alignment	Middle	Line break	Disabled			
Flashing						
Flashing	Disabled					
Styles/Designs						
Use style/design	Disabled	Style item appearance				
Miscellaneous						
Name	Text field_3	Layer	0 - Layer_0			
Button_2						
Type	Button					
General						
Mode	Text	Hotkey	None	Text OFF	Reiniciar	
Text ON	Text	Text list		Graphic OFF		
Graphic ON		Graphic list		Process value		
Bit number	0					
Appearance						
Background color	99, 101, 115	Background fill pattern	Vertical gradient	Corner radius (border)	3	
Foreground color	255, 255, 255	Border width	2	Line style	Solid	
Border color	66, 73, 82	Border background color	107, 105, 107			
Fill pattern						
Background color gradient (fill pattern)	99, 101, 115	Gradient 1 (fill pattern)	Enabled	Color gradient 1 (fill pattern)	132, 134, 140	
Offset gradient 1 (fill pattern)	15	Gradient 2 (fill pattern)	Enabled	Color gradient 2 (fill pattern)	90, 89, 99	
Offset gradient 2 (fill pattern)	15					
Design						
Focus width	2	Focus color	148, 182, 231			
Layout						
X position	211	Y position	212	Width	96	
Height	55	Fit graphic to size	Stretch graphic	Horizontal alignment of the graphic	Centered	
Vertical alignment of the graphic	Middle	Fit object to contents	Disabled	Margin left text (layout)	0	
Margin top text (layout)	0	Margin right text (layout)	0	Margin bottom text (layout)	0	
Margin left graphic (layout)	0	Margin top graphic (layout)	0	Margin right graphic (layout)	0	
Margin bottom graphic (layout)	0					
Text format						
Font	Tahoma, 13px, style=Bold	Orientation	Horizontal	Horizontal alignment of the text	Centered	
Vertical alignment of the text	Middle					
Styles/Designs						
Use style/design	Disabled	Style item appearance				
Miscellaneous						
Name	Button_2	Layer	0 - Layer_0	Tooltip		
Security						
Authorization		Allow operator control	Enabled			
Dynamizations\Event						
Event name		Click				
Function list\SetTag						
Tag	Estado	Value	0			
Function list\SetTag						
Tag	Especial	Value	1			

Totally Integrated Automation Portal						
--------------------------------------	--	--	--	--	--	--

Button_3

Type	Button				
General					
Mode	Text	Hotkey	None	Text OFF	Skip
Text ON	Text	Text list		Graphic OFF	
Graphic ON		Graphic list		Process value	
Bit number	0				
Appearance					
Background color	99, 101, 115	Background fill pattern	Vertical gradient	Corner radius (border)	3
Foreground color	255, 255, 255	Border width	2	Line style	Solid
Border color	66, 73, 82	Border background color	107, 105, 107		
Fill pattern					
Background color gradient (fill pattern)	99, 101, 115	Gradient 1 (fill pattern)	Enabled	Color gradient 1 (fill pattern)	132, 134, 140
Offset gradient 1 (fill pattern)	15	Gradient 2 (fill pattern)	Enabled	Color gradient 2 (fill pattern)	90, 89, 99
Offset gradient 2 (fill pattern)	15				
Design					
Focus width	2	Focus color	148, 182, 231		
Layout					
X position	348	Y position	212	Width	96
Height	55	Fit graphic to size	Stretch graphic	Horizontal alignment of the graphic	Centered
Vertical alignment of the graphic	Middle	Fit object to contents	Disabled	Margin left text (layout)	0
Margin top text (layout)	0	Margin right text (layout)	0	Margin bottom text (layout)	0
Margin left graphic (layout)	0	Margin top graphic (layout)	0	Margin right graphic (layout)	0
Margin bottom graphic (layout)	0				
Text format					
Font	Tahoma, 13px, style=Bold	Orientation	Horizontal	Horizontal alignment of the text	Centered
Vertical alignment of the text	Middle				
Styles/Designs					
Use style/design	Disabled	Style item appearance			
Miscellaneous					
Name	Button_3	Layer	0 - Layer_0	Tooltip	
Security					
Authorization		Allow operator control	Enabled		

Dynamizations\Event

Event name	Click
------------	-------

Function list\SetTag

Tag	Estado	Value	0
-----	--------	-------	---

Function list\SetTag

Tag	Especial	Value	2
-----	----------	-------	---

Graphic view_1

Type	Graphic view				
General					
Graphic	Logo of HMI_1				
Appearance					
Background color	173, 174, 181	Background fill pattern	Solid	Border width	0
Line style	Solid	Border color	0, 0, 0		
Layout					
X position	0	Y position	3	Width	176
Height	48	Fit embedded graphic object to screen size	Fit graphic to object size	Fit graphic to size	Stretch graphic
Fit object to contents	Disabled				
Miscellaneous					
Name	Graphic view_1	Layer	0 - Layer_0		

Text field_6

Type	Text field				
General					
Text	Revolvedora				
Appearance					
Background color	255, 255, 255	Background fill pattern	Transparent	Corner radius (border)	3
Foreground color	255, 255, 255	Border width	0	Line style	Double line
Border color	66, 73, 82	Border background color	99, 101, 115		
Layout					
X position	179	Y position	6	Width	154

--	--	--

Totally Integrated Automation Portal							
--------------------------------------	--	--	--	--	--	--	--

Height	33	Left margin	3	Top margin	2
Right margin	2	Bottom margin	2	Fit object to contents	Enabled
Text format					
Font	Tahoma, 24px, style=Bold	Orientation	Horizontal	Horizontal alignment	Left
Vertical alignment	Middle	Line break	Disabled		
Flashing					
Flashing	Disabled				
Styles/Designs					
Use style/design	Disabled	Style item appearance			
Miscellaneous					
Name	Text field_6	Layer	0 - Layer_0		

Switch_1

Type	Switch				
General					
Process value		Value status ON	1	Mode	Switch
Text ON	Encendio	Text OFF	Apagado	Graphic ON	
Graphic OFF					
Appearance					
Foreground color	255, 255, 255	Background color	99, 101, 115	Inner background color ON	0, 255, 0
Inner background color OFF	255, 0, 0	Border width	2	Line style	Solid
Border color	66, 73, 82	Border background color	107, 105, 107	Corner radius	3
Fill pattern					
Background fill pattern	Vertical gradient	Background color gradient (fill pattern)	99, 101, 115	Gradient 1 (fill pattern)	Enabled
Color gradient 1 (fill pattern)	132, 134, 140	Offset gradient 1 (fill pattern)	15	Gradient 2 (fill pattern)	Enabled
Color gradient 2 (fill pattern)	90, 89, 99	Offset gradient 2 (fill pattern)	15		
Design					
Focus width	2	Focus color	148, 182, 231		
Layout					
X position	9	Y position	212	Width	147
Height	51	Fit graphic to size	Stretch graphic	Horizontal alignment of the graphic	Centered
Vertical alignment of the graphic	Middle	Switch orientation	Left to right	Fit object to contents	Disabled
Margin left text (layout)	0	Margin top text (layout)	0	Margin right text (layout)	0
Margin bottom text (layout)	0	Margin left graphic (layout)	0	Margin top graphic (layout)	0
Margin right graphic (layout)	0	Margin bottom graphic (layout)	0		
Text format					
Font	Tahoma, 15px, style=Bold	Orientation	Horizontal	Horizontal alignment of the text	Centered
Vertical alignment of the text	Middle				
Limits					
Color for High limit violated	239, 97, 99	Color for Low limit violated	255, 219, 41		
Styles/Designs					
Use style/design	Disabled	Style item appearance			
Miscellaneous					
Name	Switch_1	Layer	0 - Layer_0	Tooltip	
Security					
Authorization		Allow operator control	Enabled		
Dynamizations\Tag connection					
Property name	Process value	Tag	Estado		

Dynamizations\Event

Event name	Switch OFF
------------	------------

Function list\SetTag

Tag	Estado	Value	0
-----	--------	-------	---

Dynamizations\Event

Event name	Switch ON
------------	-----------

Function list\SetTag

Tag	Estado	Value	1
-----	--------	-------	---

Symbolic I/O field_1

Type	Symbolic I/O field				
General					
Process value	0	Bit number	0	Mode	Output
Value status ON	1	Text OFF	0	Text ON	1
Text list	Estado	Number of visible items	3		

Totally Integrated Automation Portal						
--------------------------------------	--	--	--	--	--	--

Appearance

Background color	255, 255, 255	Background fill pattern	Solid	Corner radius (border)	3
Foreground color	255, 0, 0	Border width	4	Line style	Double line
Border color	66, 73, 82	Border background color	99, 101, 115		

Design

Foreground color of selection	255, 255, 255	Background color of selection	0, 0, 0	Alternative color	231, 231, 239
-------------------------------	---------------	-------------------------------	---------	-------------------	---------------

Layout

X position	120	Y position	64	Width	155
Height	46	Left margin	3	Top margin	2
Right margin	2	Bottom margin	2	Fit object to contents	Disabled
Display selection list	Disabled	Show selection field	Disabled		

Text format

Font	Tahoma, 20px, style=Bold	Orientation	Horizontal	Horizontal alignment	Centered
Vertical alignment	Middle				

Limits

Color for High limit violated	239, 89, 99	Color for Low limit violated	247, 162, 41		
-------------------------------	-------------	------------------------------	--------------	--	--

Styles/Designs

Use style/design	Disabled	Style item appearance			
------------------	----------	-----------------------	--	--	--

Miscellaneous

Name	Symbolic I/O field_1	Layer	0 - Layer_0	Tooltip	
------	----------------------	-------	-------------	---------	--

Security

Authorization		Allow operator control	Enabled		
---------------	--	------------------------	---------	--	--

Dynamizations\Tag connection

Property name	Process value	Tag	Estado		
---------------	---------------	-----	--------	--	--

Text field_1

Type	Text field				
------	------------	--	--	--	--

General

Text	Progreso:				
------	-----------	--	--	--	--

Appearance

Background color	255, 255, 255	Background fill pattern	Transparent	Corner radius (border)	3
Foreground color	255, 255, 255	Border width	0	Line style	Double line
Border color	66, 73, 82	Border background color	99, 101, 115		

Layout

X position	342	Y position	45	Width	102
Height	28	Left margin	3	Top margin	2
Right margin	2	Bottom margin	2	Fit object to contents	Enabled

Text format

Font	Tahoma, 20px, style=Bold	Orientation	Horizontal	Horizontal alignment	Right
Vertical alignment	Middle	Line break	Disabled		

Flashing

Flashing	Disabled				
----------	----------	--	--	--	--

Styles/Designs

Use style/design	Disabled	Style item appearance			
------------------	----------	-----------------------	--	--	--

Miscellaneous

Name	Text field_1	Layer	0 - Layer_0		
------	--------------	-------	-------------	--	--

Bar_1

Type	Bar				
------	-----	--	--	--	--

General

Maximum value	20	Minimum value	0	Process value	0
---------------	----	---------------	---	---------------	---

Appearance

Foreground color	255, 0, 0	Segment coloring	Entire bar	Background color	247, 243, 247
Background fill pattern	Solid	Color of scale	49, 52, 74	Limit lines (layout)	Disabled
Limit marking (layout)	Disabled				

Border type

Border width	7	Border color	132, 130, 132	Border background color	99, 101, 115
Line style	Solid	Corner radius (border)	9		

Scales

Show scale	Enabled	Auto-scale	Disabled	Divisions	4
Large mark labeling	1	Scale gradation	5		

Label

Show scale marks	Enabled	Show "+" for positive numbers	Disabled	Use exponential format	Disabled
Double-lined scale label	Disabled	Unit		Integer digits	2
Decimal places	0				

Layout

X position	359	Y position	75	Width	80
Height	120	Scale position	Left/up	Bar orientation	Top

Text format

Font	Tahoma, 8px, style=Bold				
------	-------------------------	--	--	--	--

Limits/Ranges


Color range high 2	239, 89, 99	Color range low 2	247, 162, 41		
--------------------	-------------	-------------------	--------------	--	--

Totally Integrated Automation Portal						
Styles/Designs						
Use style/design	Disabled	Style item appearance				
Miscellaneous						
Name	Bar_1	Layer	0 - Layer_0			
Dynamizations\Tag connection						
Property name	Process value	Tag	Progreso			
Circle_1						
Type	Circle					
Appearance						
Background color	222, 219, 222	Background fill pattern	Solid	Border width	1	
Line style	Solid	Border color	24, 28, 49			
Layout						
X position	176	Y position	123	Width	48	
Height	48	Radius	24			
Styles/Designs						
Use style/design	Disabled	Style item appearance				
Miscellaneous						
Name	Circle_1	Layer	0 - Layer_0			
Dynamizations\Appearance						
Tag - Cycle	Detección -	Data type	Range	Range	0..0	
Foreground color	148, 150, 148	Background color	148, 150, 148	Flashing	No	
Range	1..1	Foreground color	255, 0, 0	Background color	255, 0, 0	
Flashing	No					

Proyecto_final / HMI_2 [KTP400 Basic PN] / Screen management / Templates

Template_1

Hardcopy of Template_1



General

Name	Template_1	Background color	181, 182, 181	Grid color	0, 0, 0
Tab sequence in foreground	Enabled				

Layers

Active layer	0
--------------	---

Layer_0	Enabled
Layer_1	Enabled
Layer_2	Enabled
Layer_3	Enabled
Layer_4	Enabled
Layer_5	Enabled
Layer_6	Enabled
Layer_7	Enabled
Layer_8	Enabled
Layer_9	Enabled
Layer_10	Enabled
Layer_11	Enabled
Layer_12	Enabled
Layer_13	Enabled
Layer_14	Enabled
Layer_15	Enabled
Layer_16	Enabled
Layer_17	Enabled
Layer_18	Enabled
Layer_19	Enabled
Layer_20	Enabled
Layer_21	Enabled
Layer_22	Enabled
Layer_23	Enabled
Layer_24	Enabled
Layer_25	Enabled
Layer_26	Enabled
Layer_27	Enabled
Layer_28	Enabled
Layer_29	Enabled
Layer_30	Enabled
Layer_31	Enabled

Logo

Type	Graphic view
------	--------------

General

Graphic	Logo of HMI_2
---------	---------------

Appearance

Background color	222, 219, 222	Background fill pattern	Transparent	Border width	0
Line style	Solid	Border color	0, 0, 0		

Layout

X position

Height	45	Fit embedded graphic object to screen size	Fit graphic to object size	Fit graphic to size	Stretch graphic
Fit object to contents	Disabled				

Miscellaneous

Name

Totally Integrated Automation Portal		
--------------------------------------	--	--

Proyecto_final / HMI_2 [KTP400 Basic PN] / Screen management

Global screen

Hardcopy of Global screen

General					
Name	Global screen	Background color	181, 182, 181	Grid color	0, 0, 0

Totally Integrated Automation Portal

Proyecto_final / HMI_2 [KTP400 Basic PN] / HMI tags

Default tag table [5]

Tag_ScreenNumber

General					
Name	Tag_ScreenNumber	Connection	<Internal tag>	Data type	UInt
Array elements	0	Length	2	Address	
Access mode	<symbolic access>	PLC tag		Coding	Binary
PLC name					
Settings					
Acquisition cycle	1 s	Acquisition mode	Cyclic in operation		
Limits					
Upper 2		Lower 2			
Linear scaling					
Linear scaling	Disabled	PLC value range end value	10	PLC value range start value	0
HMI device value range end value	100	HMI device value range start value	0		
Values					
ID tag		Start value			
Comment					
Comment		Source comment			
Multiplexing					
Multiplexing	Disabled	Index tag			

Detección

General					
Name	Detección	Connection	HMI_Connection_3	Data type	Bool
Array elements	0	Length	1	Address	
Access mode	<symbolic access>	PLC tag	PLC2_Rev.Rev_Detección	Coding	Binary
PLC name		PLC_2			
Settings					
Acquisition cycle	100 ms	Acquisition mode	Cyclic in operation		
Limits					
Upper 2		Lower 2			
Linear scaling					
Linear scaling	Disabled	PLC value range end value	10	PLC value range start value	0
HMI device value range end value	100	HMI device value range start value	0		
Values					
ID tag		Start value			
Comment					
Comment		Source comment			
Multiplexing					
Multiplexing	Disabled	Index tag			

Especial

General					
Name	Especial	Connection	HMI_Connection_3	Data type	UInt
Array elements	0	Length	2	Address	
Access mode	<symbolic access>	PLC tag	PLC2_Rev.Rev_especial	Coding	Binary
PLC name		PLC_2			
Settings					
Acquisition cycle	100 ms	Acquisition mode	Cyclic in operation		
Limits					
Upper 2		Lower 2			
Linear scaling					
Linear scaling	Disabled	PLC value range end value	10	PLC value range start value	0
HMI device value range end value	100	HMI device value range start value	0		
Values					
ID tag		Start value			
Comment					
Comment		Source comment			
Multiplexing					
Multiplexing	Disabled	Index tag			

Estado

General					
Name	Estado	Connection	HMI_Connection_3	Data type	Bool
Array elements	0	Length	1	Address	
Access mode	<symbolic access>	PLC tag	PLC2_Rev.Rev_estado	Coding	Binary
PLC name		PLC_2			
Settings					
Acquisition cycle	100 ms	Acquisition mode	Cyclic in operation		
Limits					
Upper 2		Lower 2			
Linear scaling					
Linear scaling	Disabled	PLC value range end value	10	PLC value range start value	0

Totally Integrated Automation Portal						
--------------------------------------	--	--	--	--	--	--

HMI device value range end value	100	HMI device value range start value	0		
Values					
ID tag		Start value			
Comment					
Comment		Source comment			
Multiplexing					
Multiplexing	Disabled	Index tag			

Progreso

General					
Name	Progreso	Connection	HMI_Connection_3	Data type	Int
Array elements	0	Length	2	Address	
Access mode	<symbolic access>	PLC tag	PLC2_Rev.Rev_progreso	Coding	Binary
PLC name	PLC_2				
Settings					
Acquisition cycle	100 ms	Acquisition mode	Cyclic in operation		
Limits					
Upper 2		Lower 2			
Linear scaling					
Linear scaling	Disabled	PLC value range end value	10	PLC value range start value	0
HMI device value range end value	100	HMI device value range start value	0		
Values					
ID tag		Start value			
Comment					
Comment		Source comment			
Multiplexing					
Multiplexing	Disabled	Index tag			

Totally Integrated Automation Portal

Proyecto_final / HMI_2 [KTP400 Basic PN]

Connections

Connection_2

Name	Connection_2	Communication driver	SIMATIC S7 1200	Comment	
Online	Enabled	Station		Partner	
Node		HMI time synchronization mode	None		

Parameter

HMI device					
Interface	PROFINET (X1)	Address	192.168.0.21	Access point	S7ONLINE
PLC					
Address	192.168.0.2				

HMI_Connection_3

Name	HMI_Connection_3	Communication driver	SIMATIC S7 1200	Comment	
Online	Enabled	Station	S7-1200 station_1	Partner	PLC_2
Node	CPU 1215C DC/DC/DC, PROFINET interface (R0/S1)	HMI time synchronization mode	None		

Parameter

HMI device					
Interface	PROFINET (X1)	Address	192.168.0.21	Access point	S7ONLINE
PLC					
Address	192.168.0.2				

Totally Integrated Automation Portal		
<div>Proyecto_final / HMI_2 [KTP400 Basic PN] / HMI alarms</div> <div>Discrete alarms</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / HMI_2 [KTP400 Basic PN] / HMI alarms</div> <div>Analog alarms</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
--------------------------------------	--	--

Proyecto_final / HMI_2 [KTP400 Basic PN] / HMI alarms

Alarm groups

Alarm_group_1

General			
Name	Alarm_group_1	ID	1

Alarm_group_10

General			
Name	Alarm_group_10	ID	10

Alarm_group_11

General			
Name	Alarm_group_11	ID	11

Alarm_group_12

General			
Name	Alarm_group_12	ID	12

Alarm_group_13

General			
Name	Alarm_group_13	ID	13

Alarm_group_14

General			
Name	Alarm_group_14	ID	14

Alarm_group_15

General			
Name	Alarm_group_15	ID	15

Alarm_group_16

General			
Name	Alarm_group_16	ID	16

Alarm_group_2

General			
Name	Alarm_group_2	ID	2

Alarm_group_3

General			
Name	Alarm_group_3	ID	3

Alarm_group_4

General			
Name	Alarm_group_4	ID	4

Alarm_group_5

General			
Name	Alarm_group_5	ID	5

Alarm_group_6

General			
Name	Alarm_group_6	ID	6

Alarm_group_7

General			
Name	Alarm_group_7	ID	7

Alarm_group_8

General			
Name	Alarm_group_8	ID	8

Alarm_group_9

General			
Name	Alarm_group_9	ID	9

--	--	--

Totally Integrated Automation Portal

Proyecto_final / HMI_2 [KTP400 Basic PN] / HMI alarms

Alarm classes

Acknowledgement

General					
Name	Acknowledgement	Display name	A	ID	33
Common alarm class	Acknowledgement	Alarm log	<No log>		
Acknowledgment					
State machine	Alarm with single-mode acknowledg-ment				
State texts					
Text for "Incoming"	I	Text for "Outgoing"	O	Text for "Acknowl-edged"	A
Colors					
Background "Incom-ing/Acknowledged"	255, 255, 255	Background "Incom-ing"	255, 0, 0	Background "Incom-ing/Outgoing/Acknowledged"	255, 255, 255
Background "Incom-ing/Outgoing"	255, 0, 0				

Errors

General					
Name	Errors	Display name	!	ID	1
Common alarm class	<No alarm class>	Alarm log	<No log>		
Acknowledgment					
State machine	Alarm with single-mode acknowledg-ment				
State texts					
Text for "Incoming"	I	Text for "Outgoing"	O	Text for "Acknowl-edged"	A
Colors					
Background "Incom-ing/Acknowledged"	255, 255, 255	Background "Incom-ing"	255, 0, 0	Background "Incom-ing/Outgoing/Acknowledged"	255, 255, 255
Background "Incom-ing/Outgoing"	255, 0, 0				

No Acknowledgement

General					
Name	No Acknowledgement	Display name	NA	ID	34
Common alarm class	No Acknowledgement	Alarm log	<No log>		
Acknowledgment					
State machine	Alarm without acknowledgment				
State texts					
Text for "Incoming"	I	Text for "Outgoing"	O	Text for "Acknowl-edged"	A
Colors					
Background "Incom-ing/Acknowledged"	255, 255, 255	Background "Incom-ing"	255, 0, 0	Background "Incom-ing/Outgoing/Acknowledged"	255, 255, 255
Background "Incom-ing/Outgoing"	255, 0, 0				

System

General					
Name	System	Display name	\$	ID	3
Common alarm class	<No alarm class>	Alarm log	<No log>		
Acknowledgment					
State machine	Alarm without acknowledgment				
State texts					
Text for "Incoming"	I	Text for "Outgoing"	O	Text for "Acknowl-edged"	A
Colors					
Background "Incom-ing/Acknowledged"	255, 255, 255	Background "Incom-ing"	255, 255, 255	Background "Incom-ing/Outgoing/Acknowledged"	255, 255, 255
Background "Incom-ing/Outgoing"	255, 255, 255				

Warnings

General					
Name	Warnings	Display name		ID	2
Common alarm class	<No alarm class>	Alarm log	<No log>		
Acknowledgment					
State machine	Alarm without acknowledgment				
State texts					
Text for "Incoming"	I	Text for "Outgoing"	O	Text for "Acknowl-edged"	A
Colors					
Background "Incom-ing/Acknowledged"	255, 255, 255	Background "Incom-ing"	255, 255, 255	Background "Incom-ing/Outgoing/Acknowledged"	255, 255, 255

Totally Integrated Automation Portal		
Background "Incoming/Outgoing"	255, 255, 255	

Totally Integrated Automation Portal		
<div>Proyecto_final / HMI_2 [KTP400 Basic PN] / HMI alarms</div> <div>System events</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / HMI_2 [KTP400 Basic PN]</div> <div>Recipes</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / HMI_2 [KTP400 Basic PN] / Historical data</div> <div>Datalogs</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / HMI_2 [KTP400 Basic PN] / Historical data</div> <div>AlarmLogs</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / HMI_2 [KTP400 Basic PN]</div> <div>Scheduled tasks</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
--------------------------------------	--	--

Proyecto_final / HMI_2 [KTP400 Basic PN] / Text and graphic lists

Text lists

Dirección

Name	Dirección	List range	Value/Range	Comment	
Value: Default entry					
Entry type	Range	Text	Apagado		
Value: 1					
Entry type	Single value	Text	Adelante		
Value: 2					
Entry type	Single value	Text	Reversa		

Estado

Name	Estado	List range	Value/Range	Comment	
Value: Default entry					
Entry type	Range	Text	Apagado		
Value: 1					
Entry type	Single value	Text	Encendido		

TextList_OriginalScreenNames

Name	TextList_OriginalScreenNames	List range	Value/Range	Comment	
Value: 1					
Entry type	Single value	Text	Root screen		

TextList_ScreenNames

Name	TextList_ScreenNames	List range	Value/Range	Comment	
Value: 1					
Entry type	Single value	Text	Root screen		

Totally Integrated Automation Portal		
<div>Proyecto_final / HMI_2 [KTP400 Basic PN] / Text and graphic lists</div> <div>Graphic lists</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
--------------------------------------	--	--

Proyecto_final / HMI_2 [KTP400 Basic PN] / User administration

User

Administrator

General			
Name	Administrator	Number	1
Automatic logoff			
Automatic logoff	Enabled	Logoff time	5
Comment			
Comment	The user 'Administrator' is assigned to the 'Administrator' group.		
Groups			
Groups	Administrator group;		

--	--	--

Totally Integrated Automation Portal

Proyecto_final / HMI_2 [KTP400 Basic PN] / User administration

Groups

Administrator group

General

Name

Administrator group

Display name

Administrator group

Number

1

Password aging

Disabled

Comment

Comment

The 'Administrator' group is initially granted all rights.

Authorizations

Authorizations

User administration; Monitor; Oper-ate;

Users

General

Name

Users

Display name

Users

Number

2

Password aging

Disabled

Comment

Comment

The 'Users' group is initially granted 'Operating' rights.

Authorizations

Authorizations

Operate;

Totally Integrated Automation Portal		
--------------------------------------	--	--

Proyecto_final / HMI_2 [KTP400 Basic PN] / User administration

Authorizations

Monitor

General					
Name	Monitor	Authorization	Monitor	Authorization number	2
Comment					
Comment	'Monitor' authorization.				

Operate

General					
Name	Operate	Authorization	Operate	Authorization number	3
Comment					
Comment	'Operate' authorization.				

User administration

General					
Name	User administration	Authorization	User administration	Authorization number	1
Comment					
Comment	Authorization 'User administration' for managing users in the user view in Runtime.				

--	--	--

Totally Integrated Automation Portal				
<div>Proyecto_final</div> <div>HMI_3 [KTP400 Basic PN]</div> <div><div>HMI_3</div><div>General</div><div><table><tr><td>Name</td><td>HMI_3</td></tr></table></div></div>			Name	HMI_3
Name	HMI_3			

Totally Integrated Automation Portal

Proyecto_final / HMI_3 [KTP400 Basic PN]

Runtime settings

General

Start screen	Empacadora	Default template		Default style of the project	Enabled
Style of the HMI device	WinCC Dark V 1.0.1	Adapt font size to style	Enabled	Screen resolution	480, 272
Project ID	0	Logging language	Startup language		

Services

Sm@rtAccess or service: start Sm@rtServer	Disabled
---	----------

Screens

Bit selection for text and graphic lists	Off	User-defined pictogram size	Disabled	X,Y:	64, 45
Scrolling mode	Scroll bar				

Keyboard

Use screen keyboard	Enabled	Release button on exit	Disabled	Disable dialog window function keys	Disabled
---------------------	---------	------------------------	----------	-------------------------------------	----------

Alarms

Controller alarms

Buffer overflow	10 %	Acknowledgment group text	QGR	Use alarm class color	Disabled
Use help texts for system diagnostics	Enabled	System event duration	2 Seconds	PersistentAlarmBuffer	Enabled
Connection	HMI_Connection_2				

User administration

Enable limit for logon attempts	Enabled	Invalid logon attempts	3	Logon with password	Disabled
Group-specific rights	Disabled	Password aging	Disabled	Validity period	90
Warning period	7	Password generations	3	At least one special character	Disabled
At least one number	Disabled	Minimum password length	3		

Language & font

Preset runtime language	English (United States)				
-------------------------	-------------------------	--	--	--	--

English (United States)

Runtime language	Enabled	Fixed font 1	Tahoma	Default font	Tahoma, 11 Pixel
Configured font 1					

Tag settings

Replace the separators on each sub-level of the path of the PLC tag:	Enabled	Compatibility mode: Set '_' between the PLC tags and the first-level element.	Disabled	Replace the '.' character if the name of the HMI tag is created from the PLC tag name	Enabled
Use '_' as the replacement character	Enabled	Use ';' as the replacement character	Disabled	Replace the characters '[' and ']' if the name of the HMI tag is created from the PLC tag name	Enabled
Use '{' and '}' as replacement characters	Enabled	Use '(' and ')' as replacement characters	Disabled		


Settings for the prefix 'PLC' in the HMI tag name

Connection	HMI_Connection_2	PLC name as prefix in the HMI tag name	Disabled
------------	------------------	--	----------

Proyecto_final / HMI_3 [KTP400 Basic PN] / Screens

Empacadora

Hardcopy of Empacadora



General					
Name	Empacadora	Background color	0, 0, 0	Grid color	0, 0, 0
Number	2	Template		Tooltip	
Layers					
Active layer	0				

Layer_0	Enabled
Layer_1	Enabled
Layer_2	Enabled
Layer_3	Enabled
Layer_4	Enabled
Layer_5	Enabled
Layer_6	Enabled
Layer_7	Enabled
Layer_8	Enabled
Layer_9	Enabled
Layer_10	Enabled
Layer_11	Enabled
Layer_12	Enabled
Layer_13	Enabled
Layer_14	Enabled
Layer_15	Enabled
Layer_16	Enabled
Layer_17	Enabled
Layer_18	Enabled
Layer_19	Enabled
Layer_20	Enabled
Layer_21	Enabled
Layer_22	Enabled
Layer_23	Enabled
Layer_24	Enabled
Layer_25	Enabled
Layer_26	Enabled
Layer_27	Enabled
Layer_28	Enabled
Layer_29	Enabled
Layer_30	Enabled
Layer_31	Enabled

Text field_2

Type	Text field				
General					
Text	Estado:				
Appearance					
Background color	255, 255, 255	Background fill pattern	Transparent	Corner radius (border)	3
Foreground color	255, 255, 255	Border width	0	Line style	Double line
Border color	66, 73, 82	Border background color	99, 101, 115		
Layout					
X position	33	Y position	73	Width	79
Height	28	Left margin	3	Top margin	2
Right margin	2	Bottom margin	2	Fit object to contents	Enabled
Text format					
Font	Tahoma, 20px, style=Bold	Orientation	Horizontal	Horizontal alignment	Right
Vertical alignment	Middle	Line break	Disabled		
Flashing					
Flashing	Disabled				
Styles/Designs					
Use style/design	Disabled	Style item appearance			

Totally Integrated Automation Portal						
Miscellaneous						
Name		Text field_2		Layer		0 - Layer_0
Text field_3						
Type		Text field				
General						
Text		Detección:				
Appearance						
Background color		255, 255, 255		Background fill pattern		Transparent
Corner radius (border)		3		Line style		Double line
Foreground color		255, 255, 255		Border width		0
Border color		66, 73, 82		Border background color		99, 101, 115
Layout						
X position		0		Y position		133
Width		112		Top margin		2
Height		28		Left margin		3
Right margin		2		Bottom margin		2
Fit object to contents		Enabled				
Text format						
Font		Tahoma, 20px, style=Bold		Orientation		Horizontal
Horizontal alignment		Right		Line break		Disabled
Vertical alignment		Middle				
Flashing						
Flashing		Disabled				
Styles/Designs						
Use style/design		Disabled		Style item appearance		
Miscellaneous						
Name		Text field_3		Layer		0 - Layer_0
Button_2						
Type		Button				
General						
Mode		Text		Hotkey		None
Text OFF		Reiniciar		Text list		
Graphic ON				Graphic list		
Process value						
Bit number		0				
Appearance						
Background color		99, 101, 115		Background fill pattern		Vertical gradient
Corner radius (border)		3		Line style		Solid
Foreground color		255, 255, 255		Border width		2
Border color		66, 73, 82		Border background color		107, 105, 107
Fill pattern						
Background color gradient (fill pattern)		99, 101, 115		Gradient 1 (fill pattern)		Enabled
Color gradient 1 (fill pattern)		132, 134, 140		Gradient 2 (fill pattern)		Enabled
Color gradient 2 (fill pattern)		90, 89, 99				
Offset gradient 1 (fill pattern)		15				
Offset gradient 2 (fill pattern)		15				
Design						
Focus width		2		Focus color		148, 182, 231
Layout						
X position		211		Y position		212
Width		96		Fit graphic to size		Stretch graphic
Height		55		Horizontal alignment of the graphic		Centered
Vertical alignment of the graphic		Middle		Fit object to contents		Disabled
Margin left text (layout)		0		Margin right text (layout)		0
Margin top text (layout)		0		Margin bottom text (layout)		0
Margin left graphic (layout)		0		Margin top graphic (layout)		0
Margin right graphic (layout)		0				
Margin bottom graphic (layout)		0				
Text format						
Font		Tahoma, 13px, style=Bold		Orientation		Horizontal
Horizontal alignment of the text		Centered		Vertical alignment of the text		Middle
Styles/Designs						
Use style/design		Disabled		Style item appearance		
Miscellaneous						
Name		Button_2		Layer		0 - Layer_0
Tooltip						
Security						
Authorization				Allow operator control		Enabled
Dynamizations\Event						
Event name		Click				
Function list\SetTag						
Tag		Estado		Value		0
Function list\SetTag						
Tag		Especial		Value		1

Totally Integrated Automation Portal							
Button_3							
Type	Button						
General							
Mode	Text		Hotkey	None		Text OFF	Skip
Text ON	Text		Text list			Graphic OFF	
Graphic ON			Graphic list			Process value	
Bit number	0						
Appearance							
Background color	99, 101, 115		Background fill pattern	Vertical gradient		Corner radius (border)	3
Foreground color	255, 255, 255		Border width	2		Line style	Solid
Border color	66, 73, 82		Border background color	107, 105, 107			
Fill pattern							
Background color gradient (fill pattern)	99, 101, 115		Gradient 1 (fill pattern)	Enabled		Color gradient 1 (fill pattern)	132, 134, 140
Offset gradient 1 (fill pattern)	15		Gradient 2 (fill pattern)	Enabled		Color gradient 2 (fill pattern)	90, 89, 99
Offset gradient 2 (fill pattern)	15						
Design							
Focus width	2		Focus color	148, 182, 231			
Layout							
X position	348		Y position	212		Width	96
Height	55		Fit graphic to size	Stretch graphic		Horizontal alignment of the graphic	Centered
Vertical alignment of the graphic	Middle		Fit object to contents	Disabled		Margin left text (layout)	0
Margin top text (layout)	0		Margin right text (layout)	0		Margin bottom text (layout)	0
Margin left graphic (layout)	0		Margin top graphic (layout)	0		Margin right graphic (layout)	0
Margin bottom graphic (layout)	0						
Text format							
Font	Tahoma, 13px, style=Bold		Orientation	Horizontal		Horizontal alignment of the text	Centered
Vertical alignment of the text	Middle						
Styles/Designs							
Use style/design	Disabled		Style item appearance				
Miscellaneous							
Name	Button_3		Layer	0 - Layer_0		Tooltip	
Security							
Authorization			Allow operator control	Enabled			
Dynamizations\Event							
Event name			Click				
Function list\SetTag							
Tag	Estado			Value	0		
Function list\SetTag							
Tag	Especial			Value	2		
Graphic view_1							
Type	Graphic view						
General							
Graphic	Logo of HMI_1						
Appearance							
Background color	173, 174, 181		Background fill pattern	Solid		Border width	0
Line style	Solid		Border color	0, 0, 0			
Layout							
X position	0		Y position	3		Width	176
Height	48		Fit embedded graphic object to screen size	Fit graphic to object size		Fit graphic to size	Stretch graphic
Fit object to contents	Disabled						
Miscellaneous							
Name	Graphic view_1		Layer	0 - Layer_0			
Text field_6							
Type	Text field						
General							
Text	Empacadora						
Appearance							
Background color	255, 255, 255		Background fill pattern	Transparent		Corner radius (border)	3
Foreground color	255, 255, 255		Border width	0		Line style	Double line
Border color	66, 73, 82		Border background color	99, 101, 115			
Layout							
X position	179		Y position	6		Width	153

Totally Integrated Automation Portal							
--------------------------------------	--	--	--	--	--	--	--

Height	33	Left margin	3	Top margin	2
Right margin	2	Bottom margin	2	Fit object to contents	Enabled
Text format					
Font	Tahoma, 24px, style=Bold	Orientation	Horizontal	Horizontal alignment	Left
Vertical alignment	Middle	Line break	Disabled		
Flashing					
Flashing	Disabled				
Styles/Designs					
Use style/design	Disabled	Style item appearance			
Miscellaneous					
Name	Text field_6	Layer	0 - Layer_0		

Switch_1

Type	Switch				
General					
Process value		Value status ON	1	Mode	Switch
Text ON	Encendio	Text OFF	Apagado	Graphic ON	
Graphic OFF					
Appearance					
Foreground color	255, 255, 255	Background color	99, 101, 115	Inner background color ON	0, 255, 0
Inner background color OFF	255, 0, 0	Border width	2	Line style	Solid
Border color	66, 73, 82	Border background color	107, 105, 107	Corner radius	3
Fill pattern					
Background fill pattern	Vertical gradient	Background color gradient (fill pattern)	99, 101, 115	Gradient 1 (fill pattern)	Enabled
Color gradient 1 (fill pattern)	132, 134, 140	Offset gradient 1 (fill pattern)	15	Gradient 2 (fill pattern)	Enabled
Color gradient 2 (fill pattern)	90, 89, 99	Offset gradient 2 (fill pattern)	15		
Design					
Focus width	2	Focus color	148, 182, 231		
Layout					
X position	9	Y position	212	Width	147
Height	51	Fit graphic to size	Stretch graphic	Horizontal alignment of the graphic	Centered
Vertical alignment of the graphic	Middle	Switch orientation	Left to right	Fit object to contents	Disabled
Margin left text (layout)	0	Margin top text (layout)	0	Margin right text (layout)	0
Margin bottom text (layout)	0	Margin left graphic (layout)	0	Margin top graphic (layout)	0
Margin right graphic (layout)	0	Margin bottom graphic (layout)	0		
Text format					
Font	Tahoma, 15px, style=Bold	Orientation	Horizontal	Horizontal alignment of the text	Centered
Vertical alignment of the text	Middle				
Limits					
Color for High limit violated	239, 97, 99	Color for Low limit violated	255, 219, 41		
Styles/Designs					
Use style/design	Disabled	Style item appearance			
Miscellaneous					
Name	Switch_1	Layer	0 - Layer_0	Tooltip	
Security					
Authorization		Allow operator control	Enabled		
Dynamizations\Tag connection					
Property name	Process value	Tag	Estado		

Dynamizations\Event

Event name	Switch OFF
------------	------------

Function list\SetTag

Tag	Estado	Value	0
-----	--------	-------	---

Dynamizations\Event

Event name	Switch ON
------------	-----------

Function list\SetTag

Tag	Estado	Value	1
-----	--------	-------	---

Symbolic I/O field_1

Type	Symbolic I/O field				
General					
Process value	0	Bit number	0	Mode	Output
Value status ON	1	Text OFF	0	Text ON	1
Text list	Estado	Number of visible items	3		

Totally Integrated Automation Portal						
Appearance						
Background color	255, 255, 255	Background fill pattern	Solid	Corner radius (border)	3	
Foreground color	255, 0, 0	Border width	4	Line style	Double line	
Border color	66, 73, 82	Border background color	99, 101, 115			
Design						
Foreground color of selection	255, 255, 255	Background color of selection	0, 0, 0	Alternative color	231, 231, 239	
Layout						
X position	120	Y position	64	Width	155	
Height	46	Left margin	3	Top margin	2	
Right margin	2	Bottom margin	2	Fit object to contents	Disabled	
Display selection list	Disabled	Show selection field	Disabled			
Text format						
Font	Tahoma, 20px, style=Bold	Orientation	Horizontal	Horizontal alignment	Centered	
Vertical alignment	Middle					
Limits						
Color for High limit violated	239, 89, 99	Color for Low limit violated	247, 162, 41			
Styles/Designs						
Use style/design	Disabled	Style item appearance				
Miscellaneous						
Name	Symbolic I/O field_1	Layer	0 - Layer_0	Tooltip		
Security						
Authorization		Allow operator control	Enabled			
Dynamizations\Tag connection						
Property name	Process value	Tag	Estado			
Text field_1						
Type	Text field					
General						
Text	Progreso:					
Appearance						
Background color	255, 255, 255	Background fill pattern	Transparent	Corner radius (border)	3	
Foreground color	255, 255, 255	Border width	0	Line style	Double line	
Border color	66, 73, 82	Border background color	99, 101, 115			
Layout						
X position	342	Y position	45	Width	102	
Height	28	Left margin	3	Top margin	2	
Right margin	2	Bottom margin	2	Fit object to contents	Enabled	
Text format						
Font	Tahoma, 20px, style=Bold	Orientation	Horizontal	Horizontal alignment	Right	
Vertical alignment	Middle	Line break	Disabled			
Flashing						
Flashing	Disabled					
Styles/Designs						
Use style/design	Disabled	Style item appearance				
Miscellaneous						
Name	Text field_1	Layer	0 - Layer_0			
Bar_1						
Type	Bar					
General						
Maximum value	20	Minimum value	0	Process value	0	
Appearance						
Foreground color	255, 0, 0	Segment coloring	Entire bar	Background color	247, 243, 247	
Background fill pattern	Solid	Color of scale	49, 52, 74	Limit lines (layout)	Disabled	
Limit marking (layout)	Disabled					
Border type						
Border width	7	Border color	132, 130, 132	Border background color	99, 101, 115	
Line style	Solid	Corner radius (border)	9			
Scales						
Show scale	Enabled	Auto-scale	Disabled	Divisions	4	
Large mark labeling	1	Scale gradation	5			
Label						
Show scale marks	Enabled	Show "+" for positive numbers	Disabled	Use exponential format	Disabled	
Double-lined scale label	Disabled	Unit		Integer digits	2	
Decimal places	0					
Layout						
X position	359	Y position	75	Width	80	
Height	120	Scale position	Left/up	Bar orientation	Top	
Text format						
Font	Tahoma, 8px, style=Bold					
Limits/Ranges						
Color range high 2	239, 89, 99	Color range low 2	247, 162, 41			


Totally Integrated Automation Portal							
Styles/Designs							
Use style/design		Disabled		Style item appearance			
Miscellaneous							
Name		Bar_1		Layer		0 - Layer_0	
Dynamizations\Tag connection							
Property name		Process value		Tag		Progreso	
Circle_1							
Type		Circle					
Appearance							
Background color		222, 219, 222		Background fill pattern		Solid	
				Border width		1	
Line style		Solid		Border color		24, 28, 49	
Layout							
X position		176		Y position		123	
Height		48		Radius		24	
Width							
Styles/Designs							
Use style/design		Disabled		Style item appearance			
Miscellaneous							
Name		Circle_1		Layer		0 - Layer_0	
Dynamizations\Appearance							
Tag - Cycle		Detección -		Data type		Range	
				Range		0..0	
Foreground color		148, 150, 148		Background color		148, 150, 148	
Flashing		No		Flashing		No	
Range		1..1		Background color		255, 0, 0	
				Foreground color		255, 0, 0	

Totally Integrated Automation Portal		
--------------------------------------	--	--

Proyecto_final / HMI_3 [KTP400 Basic PN] / Screen management / Templates

Template_1

Hardcopy of Template_1



General					
Name	Template_1	Background color	181, 182, 181	Grid color	0, 0, 0
Tab sequence in foreground	Enabled				
Layers					
Active layer	0				
Layer_0					Enabled
Layer_1					Enabled
Layer_2					Enabled
Layer_3					Enabled
Layer_4					Enabled
Layer_5					Enabled
Layer_6					Enabled
Layer_7					Enabled
Layer_8					Enabled
Layer_9					Enabled
Layer_10					Enabled
Layer_11					Enabled
Layer_12					Enabled
Layer_13					Enabled
Layer_14					Enabled
Layer_15					Enabled
Layer_16					Enabled
Layer_17					Enabled
Layer_18					Enabled
Layer_19					Enabled
Layer_20					Enabled
Layer_21					Enabled
Layer_22					Enabled
Layer_23					Enabled
Layer_24					Enabled
Layer_25					Enabled
Layer_26					Enabled
Layer_27					Enabled
Layer_28					Enabled
Layer_29					Enabled
Layer_30					Enabled
Layer_31					Enabled

Logo					
Type	Graphic view				
General					
Graphic	Logo of HMI_3				
Appearance					
Background color	222, 219, 222	Background fill pattern	Transparent	Border width	0
Line style	Solid	Border color	0, 0, 0		
Layout					
X position	0	Y position	0	Width	160
Height	45	Fit embedded graphic object to screen size	Fit graphic to object size	Fit graphic to size	Stretch graphic
Fit object to contents	Disabled				
Miscellaneous					
Name	Logo	Layer	0 - Layer_0		

Totally Integrated Automation Portal		
--------------------------------------	--	--

Proyecto_final / HMI_3 [KTP400 Basic PN] / Screen management

Global screen

Hardcopy of Global screen

General					
Name	Global screen	Background color	181, 182, 181	Grid color	0, 0, 0

Totally Integrated Automation Portal

Proyecto_final / HMI_3 [KTP400 Basic PN] / HMI tags

Default tag table [5]

Tag_ScreenNumber

General					
Name	Tag_ScreenNumber	Connection	<Internal tag>	Data type	UInt
Array elements	0	Length	2	Address	
Access mode	<symbolic access>	PLC tag		Coding	Binary
PLC name					
Settings					
Acquisition cycle	1 s	Acquisition mode	Cyclic in operation		
Limits					
Upper 2		Lower 2			
Linear scaling					
Linear scaling	Disabled	PLC value range end value	10	PLC value range start value	0
HMI device value range end value	100	HMI device value range start value	0		
Values					
ID tag		Start value			
Comment					
Comment		Source comment			
Multiplexing					
Multiplexing	Disabled	Index tag			

Estado

General					
Name	Estado	Connection	HMI_Connection_2	Data type	Bool
Array elements	0	Length	1	Address	
Access mode	<symbolic access>	PLC tag	PLC3_emp.Emp_estado	Coding	Binary
PLC name	PLC_3				
Settings					
Acquisition cycle	100 ms	Acquisition mode	Cyclic in operation		
Limits					
Upper 2		Lower 2			
Linear scaling					
Linear scaling	Disabled	PLC value range end value	10	PLC value range start value	0
HMI device value range end value	100	HMI device value range start value	0		
Values					
ID tag		Start value			
Comment					
Comment		Source comment			
Multiplexing					
Multiplexing	Disabled	Index tag			

Especial

General					
Name	Especial	Connection	HMI_Connection_2	Data type	UInt
Array elements	0	Length	2	Address	
Access mode	<symbolic access>	PLC tag	PLC3_emp.Emp_especial	Coding	Binary
PLC name	PLC_3				
Settings					
Acquisition cycle	100 ms	Acquisition mode	Cyclic in operation		
Limits					
Upper 2		Lower 2			
Linear scaling					
Linear scaling	Disabled	PLC value range end value	10	PLC value range start value	0
HMI device value range end value	100	HMI device value range start value	0		
Values					
ID tag		Start value			
Comment					
Comment		Source comment			
Multiplexing					
Multiplexing	Disabled	Index tag			

Detección

General					
Name	Detección	Connection	HMI_Connection_2	Data type	Bool
Array elements	0	Length	1	Address	
Access mode	<symbolic access>	PLC tag	PLC3_emp.Emp_detección	Coding	Binary
PLC name	PLC_3				
Settings					
Acquisition cycle	100 ms	Acquisition mode	Cyclic in operation		
Limits					
Upper 2		Lower 2			
Linear scaling					
Linear scaling	Disabled	PLC value range end value	10	PLC value range start value	0

Totally Integrated Automation Portal						
--------------------------------------	--	--	--	--	--	--

HMI device value range end value	100	HMI device value range start value	0		
Values					
ID tag		Start value			
Comment					
Comment		Source comment			
Multiplexing					
Multiplexing	Disabled	Index tag			

Progreso

General					
Name	Progreso	Connection	HMI_Connection_2	Data type	Int
Array elements	0	Length	2	Address	
Access mode	<symbolic access>	PLC tag	PLC3_emp.Emp_progreso	Coding	Binary
PLC name	PLC_3				
Settings					
Acquisition cycle	100 ms	Acquisition mode	Cyclic in operation		
Limits					
Upper 2		Lower 2			
Linear scaling					
Linear scaling	Disabled	PLC value range end value	10	PLC value range start value	0
HMI device value range end value	100	HMI device value range start value	0		
Values					
ID tag		Start value			
Comment					
Comment		Source comment			
Multiplexing					
Multiplexing	Disabled	Index tag			

Totally Integrated Automation Portal

Proyecto_final / HMI_3 [KTP400 Basic PN]

Connections

Connection_3

Name	Connection_3	Communication driver	SIMATIC S7 1200	Comment	
Online	Enabled	Station		Partner	
Node		HMI time synchronization mode	None		

Parameter

HMI device					
Interface	PROFINET (X1)	Address	192.168.0.41	Access point	S7ONLINE
PLC					
Address	192.168.0.4				

HMI_Connection_2

Name	HMI_Connection_2	Communication driver	SIMATIC S7 1200	Comment	
Online	Enabled	Station	S7-1200 station_2	Partner	PLC_3
Node	CPU 1215C DC/DC/DC, PROFINET interface (R0/S1)	HMI time synchronization mode	None		

Parameter

HMI device					
Interface	PROFINET (X1)	Address	192.168.0.41	Access point	S7ONLINE
PLC					
Address	192.168.0.4				

Totally Integrated Automation Portal		
<div>Proyecto_final / HMI_3 [KTP400 Basic PN] / HMI alarms</div> <div>Discrete alarms</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / HMI_3 [KTP400 Basic PN] / HMI alarms</div> <div>Analog alarms</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
--------------------------------------	--	--

Proyecto_final / HMI_3 [KTP400 Basic PN] / HMI alarms

Alarm groups

Alarm_group_1

General			
Name	Alarm_group_1	ID	1

Alarm_group_10

General			
Name	Alarm_group_10	ID	10

Alarm_group_11

General			
Name	Alarm_group_11	ID	11

Alarm_group_12

General			
Name	Alarm_group_12	ID	12

Alarm_group_13

General			
Name	Alarm_group_13	ID	13

Alarm_group_14

General			
Name	Alarm_group_14	ID	14

Alarm_group_15

General			
Name	Alarm_group_15	ID	15

Alarm_group_16

General			
Name	Alarm_group_16	ID	16

Alarm_group_2

General			
Name	Alarm_group_2	ID	2

Alarm_group_3

General			
Name	Alarm_group_3	ID	3

Alarm_group_4

General			
Name	Alarm_group_4	ID	4

Alarm_group_5

General			
Name	Alarm_group_5	ID	5

Alarm_group_6

General			
Name	Alarm_group_6	ID	6

Alarm_group_7

General			
Name	Alarm_group_7	ID	7

Alarm_group_8

General			
Name	Alarm_group_8	ID	8

Alarm_group_9

General			
Name	Alarm_group_9	ID	9

--	--	--

Totally Integrated Automation Portal

Proyecto_final / HMI_3 [KTP400 Basic PN] / HMI alarms

Alarm classes

Acknowledgement

General					
Name	Acknowledgement	Display name	A	ID	33
Common alarm class	Acknowledgement	Alarm log	<No log>		
Acknowledgment					
State machine	Alarm with single-mode acknowledg-ment				
State texts					
Text for "Incoming"	I	Text for "Outgoing"	O	Text for "Acknowl- edged"	A
Colors					
Background "Incom- ing/Acknowledged"	255, 255, 255	Background "Incom- ing"	255, 0, 0	Background "Incom- ing/Outgoing/ Acknowledged"	255, 255, 255
Background "Incom- ing/Outgoing"	255, 0, 0				

Errors

General					
Name	Errors	Display name	!	ID	1
Common alarm class	<No alarm class>	Alarm log	<No log>		
Acknowledgment					
State machine	Alarm with single-mode acknowledg-ment				
State texts					
Text for "Incoming"	I	Text for "Outgoing"	O	Text for "Acknowl- edged"	A
Colors					
Background "Incom- ing/Acknowledged"	255, 255, 255	Background "Incom- ing"	255, 0, 0	Background "Incom- ing/Outgoing/ Acknowledged"	255, 255, 255
Background "Incom- ing/Outgoing"	255, 0, 0				

No Acknowledgement

General					
Name	No Acknowledgement	Display name	NA	ID	34
Common alarm class	No Acknowledgement	Alarm log	<No log>		
Acknowledgment					
State machine	Alarm without acknowledgment				
State texts					
Text for "Incoming"	I	Text for "Outgoing"	O	Text for "Acknowl- edged"	A
Colors					
Background "Incom- ing/Acknowledged"	255, 255, 255	Background "Incom- ing"	255, 0, 0	Background "Incom- ing/Outgoing/ Acknowledged"	255, 255, 255
Background "Incom- ing/Outgoing"	255, 0, 0				

System

General					
Name	System	Display name	\$	ID	3
Common alarm class	<No alarm class>	Alarm log	<No log>		
Acknowledgment					
State machine	Alarm without acknowledgment				
State texts					
Text for "Incoming"	I	Text for "Outgoing"	O	Text for "Acknowl- edged"	A
Colors					
Background "Incom- ing/Acknowledged"	255, 255, 255	Background "Incom- ing"	255, 255, 255	Background "Incom- ing/Outgoing/ Acknowledged"	255, 255, 255
Background "Incom- ing/Outgoing"	255, 255, 255				

Warnings

General					
Name	Warnings	Display name		ID	2
Common alarm class	<No alarm class>	Alarm log	<No log>		
Acknowledgment					
State machine	Alarm without acknowledgment				
State texts					
Text for "Incoming"	I	Text for "Outgoing"	O	Text for "Acknowl- edged"	A
Colors					
Background "Incom- ing/Acknowledged"	255, 255, 255	Background "Incom- ing"	255, 255, 255	Background "Incom- ing/Outgoing/ Acknowledged"	255, 255, 255

Totally Integrated Automation Portal		
Background "Incoming/Outgoing"	255, 255, 255	

Totally Integrated Automation Portal		
<div>Proyecto_final / HMI_3 [KTP400 Basic PN] / HMI alarms</div> <div>System events</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / HMI_3 [KTP400 Basic PN]</div> <div>Recipes</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / HMI_3 [KTP400 Basic PN] / Historical data</div> <div>Datalogs</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / HMI_3 [KTP400 Basic PN] / Historical data</div> <div>AlarmLogs</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / HMI_3 [KTP400 Basic PN]</div> <div>Scheduled tasks</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
--------------------------------------	--	--

Proyecto_final / HMI_3 [KTP400 Basic PN] / Text and graphic lists

Text lists

Estado

Name	Estado	List range	Value/Range	Comment	
Value: Default entry					
Entry type	Range	Text	Apagado		
Value: 1					
Entry type	Single value	Text	Encendido		

TextList_OriginalScreenNames

Name	TextList_OriginalScreenNames	List range	Value/Range	Comment	
Value: 1					
Entry type	Single value	Text	Root screen		

TextList_ScreenNames

Name	TextList_ScreenNames	List range	Value/Range	Comment	
Value: 1					
Entry type	Single value	Text	Root screen		

--	--	--

Totally Integrated Automation Portal		
<div>Proyecto_final / HMI_3 [KTP400 Basic PN] / Text and graphic lists</div> <div>Graphic lists</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
--------------------------------------	--	--

Proyecto_final / HMI_3 [KTP400 Basic PN] / User administration

User

Administrator

General			
Name	Administrator	Number	1
Automatic logoff			
Automatic logoff	Enabled	Logoff time	5
Comment			
Comment	The user 'Administrator' is assigned to the 'Administrator' group.		
Groups			
Groups	Administrator group;		

--	--	--

Totally Integrated Automation Portal

Proyecto_final / HMI_3 [KTP400 Basic PN] / User administration

Groups

Administrator group

General

Name

Administrator group

Display name

Administrator group

Number

1

Password aging

Disabled

Comment

Comment

The 'Administrator' group is initially granted all rights.

Authorizations

Authorizations

User administration; Monitor; Oper-ate;

Users

General

Name

Users

Display name

Users

Number

2

Password aging

Disabled

Comment

Comment

The 'Users' group is initially granted 'Operating' rights.

Authorizations

Authorizations

Operate;

Totally Integrated Automation Portal		
--------------------------------------	--	--

Proyecto_final / HMI_3 [KTP400 Basic PN] / User administration

Authorizations

Monitor

General					
Name	Monitor	Authorization	Monitor	Authorization number	2
Comment					
Comment	'Monitor' authorization.				

Operate

General					
Name	Operate	Authorization	Operate	Authorization number	3
Comment					
Comment	'Operate' authorization.				

User administration

General					
Name	User administration	Authorization	User administration	Authorization number	1
Comment					
Comment	Authorization 'User administration' for managing users in the user view in Runtime.				

--	--	--

Totally Integrated Automation Portal		
<div>Proyecto_final</div> <div>Ungrouped devices</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Proyecto_final</div> <div>Security settings</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal																		
<div>Proyecto_final / Common data</div> <div>Alarm classes</div> <table><thead><tr><th colspan="4">Alarm classes</th></tr><tr><th>Name</th><th>Display name</th><th>Acknowledgment</th><th>Priority</th></tr></thead><tbody><tr><td>Acknowledgement</td><td>A</td><td>True</td><td>0</td></tr><tr><td>No Acknowledgement</td><td>NA</td><td>False</td><td>0</td></tr></tbody></table>			Alarm classes				Name	Display name	Acknowledgment	Priority	Acknowledgement	A	True	0	No Acknowledgement	NA	False	0
Alarm classes																		
Name	Display name	Acknowledgment	Priority															
Acknowledgement	A	True	0															
No Acknowledgement	NA	False	0															

Totally Integrated Automation Portal		
<div>Proyecto_final / Common data</div> <div>Logs</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Proyecto_final / Common data</div> <div>Styles</div> <div>This folder is empty.</div>		









































Totally Integrated Automation Portal		
<div>Proyecto_final / Languages & resources</div> <div>Project languages</div> <div><div>Languages</div><div>Reference language</div><div>English (United States)</div><div>Editing language</div><div>English (United States)</div><div>Other project languages</div><div>Empty</div></div>		

Totally Integrated Automation Portal																																																																																																																																																		
<div>Proyecto_final / Languages & resources / Project texts</div> <div>Project texts</div> <table><tr><th colspan="3">Project texts</th></tr><tr><th>English (United States)</th><th>Category</th><th>Reference</th></tr><tr><td></td><td>Alarm class text</td><td>Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Errors\alarmclass name not set\Short-Name</td></tr><tr><td></td><td>Alarm class text</td><td>Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Warnings\alarmclass name not set_1\ShortName</td></tr><tr><td></td><td>Alarm class text</td><td>Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\System\alarmclass name not set_2\Short-Name</td></tr><tr><td></td><td>Alarm class text</td><td>Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Diagnosis events\alarmclass name not set_3\ShortName</td></tr><tr><td></td><td>Alarm class text</td><td>Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Safety warnings\alarmclass name not set_4\ShortName</td></tr><tr><td></td><td>Alarm class text</td><td>Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Errors\alarmclass name not set_5\Short-Name</td></tr><tr><td></td><td>Alarm class text</td><td>Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Warnings\alarmclass name not set_6\ShortName</td></tr><tr><td></td><td>Alarm class text</td><td>Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\System\alarmclass name not set_7\Short-Name</td></tr><tr><td></td><td>Alarm class text</td><td>Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Diagnosis events\alarmclass name not set_8\ShortName</td></tr><tr><td></td><td>Alarm class text</td><td>Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Safety warnings\alarmclass name not set_9\ShortName</td></tr><tr><td></td><td>Alarm class text</td><td>Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Acknowledgement\ShortName</td></tr><tr><td></td><td>Alarm class text</td><td>Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\ShortName</td></tr><tr><td></td><td>Alarm class text</td><td>Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Errors\alarmclass name not set_10\Short-Name</td></tr><tr><td></td><td>Alarm class text</td><td>Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Warnings\alarmclass name not set_11\ShortName</td></tr><tr><td></td><td>Alarm class text</td><td>Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\System\alarmclass name not set_12\ShortName</td></tr><tr><td></td><td>Alarm class text</td><td>Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Diagnosis events\alarmclass name not set_13\ShortName</td></tr><tr><td></td><td>Alarm class text</td><td>Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Safety warnings\alarmclass name not set_14\ShortName</td></tr><tr><td></td><td>Alarm class text</td><td>Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Acknowledgement\ShortName</td></tr><tr><td></td><td>Alarm class text</td><td>Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\ShortName</td></tr><tr><td></td><td>Alarm class text</td><td>Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Acknowledgement\ShortName</td></tr><tr><td></td><td>Alarm class text</td><td>Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\ShortName</td></tr><tr><td></td><td>Alarm text</td><td>Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Warnings\alarmclass name not set_1\AlarmClassData_IDisplayNaming_DisplayName</td></tr><tr><td></td><td>Alarm text</td><td>Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Warnings\alarmclass name not set_6\AlarmClassData_IDisplayNaming_DisplayName</td></tr><tr><td></td><td>Alarm text</td><td>Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName</td></tr><tr><td></td><td>Alarm text</td><td>Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName</td></tr><tr><td></td><td>Alarm text</td><td>Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Warnings\alarmclass name not set_11\AlarmClassData_IDisplayNaming_DisplayName</td></tr><tr><td></td><td>Alarm text</td><td>Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName</td></tr><tr><td></td><td>Alarm text</td><td>Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName</td></tr><tr><td></td><td>Alarm text</td><td>Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName</td></tr><tr><td></td><td>Alarm text</td><td>Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName</td></tr><tr><td>!</td><td>Alarm text</td><td>Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Errors\alarmclass name not set\Alarm-ClassData_IDisplayNaming_DisplayName</td></tr><tr><td>!</td><td>Alarm text</td><td>Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Errors\alarmclass name not set_5\Alarm-ClassData_IDisplayNaming_DisplayName</td></tr><tr><td>!</td><td>Alarm text</td><td>Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Errors\alarmclass name not set_10\Alarm-ClassData_IDisplayNaming_DisplayName</td></tr><tr><td>!!</td><td>Alarm text</td><td>Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Safety warnings\alarmclass name not set_4\AlarmClassData_IDisplayNaming_DisplayName</td></tr><tr><td>!!</td><td>Alarm text</td><td>Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Safety warnings\alarmclass name not set_9\AlarmClassData_IDisplayNaming_DisplayName</td></tr><tr><td>!!</td><td>Alarm text</td><td>Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Safety warnings\alarmclass name not set_14\AlarmClassData_IDisplayNaming_DisplayName</td></tr><tr><td>\$</td><td>Alarm text</td><td>Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\System\alarmclass name not set_2\Alarm-ClassData_IDisplayNaming_DisplayName</td></tr><tr><td>\$</td><td>Alarm text</td><td>Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\System\alarmclass name not set_7\Alarm-ClassData_IDisplayNaming_DisplayName</td></tr><tr><td>\$</td><td>Alarm text</td><td>Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\System\alarmclass name not set_12\AlarmClassData_IDisplayNaming_DisplayName</td></tr><tr><td>0</td><td>HMI screen</td><td>Proyecto_final\HMI_1 [KTP400 Basic PN]\Screens\Banda transportadora\Symbolic I/O field_1\Text OFF</td></tr><tr><td>0</td><td>HMI screen</td><td>Proyecto_final\HMI_1 [KTP400 Basic PN]\Screens\Banda transportadora\Symbolic I/O field_2\Text OFF</td></tr><tr><td>0</td><td>HMI screen</td><td>Proyecto_final\HMI_3 [KTP400 Basic PN]\Screens\Empacadora\Symbolic I/O field_1\Text OFF</td></tr><tr><td>0</td><td>HMI screen</td><td>Proyecto_final\HMI_2 [KTP400 Basic PN]\Screens\Revolvedora\Symbolic I/O field_1\Text OFF</td></tr><tr><td>1</td><td>HMI screen</td><td>Proyecto_final\HMI_1 [KTP400 Basic PN]\Screens\Banda transportadora\Symbolic I/O field_1\Text ON</td></tr><tr><td>1</td><td>HMI screen</td><td>Proyecto_final\HMI_1 [KTP400 Basic PN]\Screens\Banda transportadora\Symbolic I/O field_2\Text ON</td></tr><tr><td>1</td><td>HMI screen</td><td>Proyecto_final\HMI_3 [KTP400 Basic PN]\Screens\Empacadora\Symbolic I/O field_1\Text ON</td></tr></table>	Project texts			English (United States)	Category	Reference		Alarm class text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Errors\alarmclass name not set\Short-Name		Alarm class text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Warnings\alarmclass name not set_1\ShortName		Alarm class text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\System\alarmclass name not set_2\Short-Name		Alarm class text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Diagnosis events\alarmclass name not set_3\ShortName		Alarm class text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Safety warnings\alarmclass name not set_4\ShortName		Alarm class text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Errors\alarmclass name not set_5\Short-Name		Alarm class text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Warnings\alarmclass name not set_6\ShortName		Alarm class text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\System\alarmclass name not set_7\Short-Name		Alarm class text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Diagnosis events\alarmclass name not set_8\ShortName		Alarm class text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Safety warnings\alarmclass name not set_9\ShortName		Alarm class text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Acknowledgement\ShortName		Alarm class text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\ShortName		Alarm class text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Errors\alarmclass name not set_10\Short-Name		Alarm class text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Warnings\alarmclass name not set_11\ShortName		Alarm class text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\System\alarmclass name not set_12\ShortName		Alarm class text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Diagnosis events\alarmclass name not set_13\ShortName		Alarm class text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Safety warnings\alarmclass name not set_14\ShortName		Alarm class text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Acknowledgement\ShortName		Alarm class text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\ShortName		Alarm class text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Acknowledgement\ShortName		Alarm class text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\ShortName		Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Warnings\alarmclass name not set_1\AlarmClassData_IDisplayNaming_DisplayName		Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Warnings\alarmclass name not set_6\AlarmClassData_IDisplayNaming_DisplayName		Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName		Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName		Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Warnings\alarmclass name not set_11\AlarmClassData_IDisplayNaming_DisplayName		Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName		Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName		Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName		Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName	!	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Errors\alarmclass name not set\Alarm-ClassData_IDisplayNaming_DisplayName	!	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Errors\alarmclass name not set_5\Alarm-ClassData_IDisplayNaming_DisplayName	!	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Errors\alarmclass name not set_10\Alarm-ClassData_IDisplayNaming_DisplayName	!!	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Safety warnings\alarmclass name not set_4\AlarmClassData_IDisplayNaming_DisplayName	!!	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Safety warnings\alarmclass name not set_9\AlarmClassData_IDisplayNaming_DisplayName	!!	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Safety warnings\alarmclass name not set_14\AlarmClassData_IDisplayNaming_DisplayName	\$	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\System\alarmclass name not set_2\Alarm-ClassData_IDisplayNaming_DisplayName	\$	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\System\alarmclass name not set_7\Alarm-ClassData_IDisplayNaming_DisplayName	\$	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\System\alarmclass name not set_12\AlarmClassData_IDisplayNaming_DisplayName	0	HMI screen	Proyecto_final\HMI_1 [KTP400 Basic PN]\Screens\Banda transportadora\Symbolic I/O field_1\Text OFF	0	HMI screen	Proyecto_final\HMI_1 [KTP400 Basic PN]\Screens\Banda transportadora\Symbolic I/O field_2\Text OFF	0	HMI screen	Proyecto_final\HMI_3 [KTP400 Basic PN]\Screens\Empacadora\Symbolic I/O field_1\Text OFF	0	HMI screen	Proyecto_final\HMI_2 [KTP400 Basic PN]\Screens\Revolvedora\Symbolic I/O field_1\Text OFF	1	HMI screen	Proyecto_final\HMI_1 [KTP400 Basic PN]\Screens\Banda transportadora\Symbolic I/O field_1\Text ON	1	HMI screen	Proyecto_final\HMI_1 [KTP400 Basic PN]\Screens\Banda transportadora\Symbolic I/O field_2\Text ON	1	HMI screen	Proyecto_final\HMI_3 [KTP400 Basic PN]\Screens\Empacadora\Symbolic I/O field_1\Text ON		
Project texts																																																																																																																																																		
English (United States)	Category	Reference																																																																																																																																																
	Alarm class text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Errors\alarmclass name not set\Short-Name																																																																																																																																																
	Alarm class text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Warnings\alarmclass name not set_1\ShortName																																																																																																																																																
	Alarm class text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\System\alarmclass name not set_2\Short-Name																																																																																																																																																
	Alarm class text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Diagnosis events\alarmclass name not set_3\ShortName																																																																																																																																																
	Alarm class text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Safety warnings\alarmclass name not set_4\ShortName																																																																																																																																																
	Alarm class text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Errors\alarmclass name not set_5\Short-Name																																																																																																																																																
	Alarm class text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Warnings\alarmclass name not set_6\ShortName																																																																																																																																																
	Alarm class text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\System\alarmclass name not set_7\Short-Name																																																																																																																																																
	Alarm class text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Diagnosis events\alarmclass name not set_8\ShortName																																																																																																																																																
	Alarm class text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Safety warnings\alarmclass name not set_9\ShortName																																																																																																																																																
	Alarm class text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Acknowledgement\ShortName																																																																																																																																																
	Alarm class text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\ShortName																																																																																																																																																
	Alarm class text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Errors\alarmclass name not set_10\Short-Name																																																																																																																																																
	Alarm class text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Warnings\alarmclass name not set_11\ShortName																																																																																																																																																
	Alarm class text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\System\alarmclass name not set_12\ShortName																																																																																																																																																
	Alarm class text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Diagnosis events\alarmclass name not set_13\ShortName																																																																																																																																																
	Alarm class text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Safety warnings\alarmclass name not set_14\ShortName																																																																																																																																																
	Alarm class text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Acknowledgement\ShortName																																																																																																																																																
	Alarm class text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\ShortName																																																																																																																																																
	Alarm class text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Acknowledgement\ShortName																																																																																																																																																
	Alarm class text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\ShortName																																																																																																																																																
	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Warnings\alarmclass name not set_1\AlarmClassData_IDisplayNaming_DisplayName																																																																																																																																																
	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Warnings\alarmclass name not set_6\AlarmClassData_IDisplayNaming_DisplayName																																																																																																																																																
	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName																																																																																																																																																
	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName																																																																																																																																																
	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Warnings\alarmclass name not set_11\AlarmClassData_IDisplayNaming_DisplayName																																																																																																																																																
	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName																																																																																																																																																
	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName																																																																																																																																																
	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName																																																																																																																																																
	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName																																																																																																																																																
!	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Errors\alarmclass name not set\Alarm-ClassData_IDisplayNaming_DisplayName																																																																																																																																																
!	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Errors\alarmclass name not set_5\Alarm-ClassData_IDisplayNaming_DisplayName																																																																																																																																																
!	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Errors\alarmclass name not set_10\Alarm-ClassData_IDisplayNaming_DisplayName																																																																																																																																																
!!	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Safety warnings\alarmclass name not set_4\AlarmClassData_IDisplayNaming_DisplayName																																																																																																																																																
!!	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Safety warnings\alarmclass name not set_9\AlarmClassData_IDisplayNaming_DisplayName																																																																																																																																																
!!	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Safety warnings\alarmclass name not set_14\AlarmClassData_IDisplayNaming_DisplayName																																																																																																																																																
\$	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\System\alarmclass name not set_2\Alarm-ClassData_IDisplayNaming_DisplayName																																																																																																																																																
\$	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\System\alarmclass name not set_7\Alarm-ClassData_IDisplayNaming_DisplayName																																																																																																																																																
\$	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\System\alarmclass name not set_12\AlarmClassData_IDisplayNaming_DisplayName																																																																																																																																																
0	HMI screen	Proyecto_final\HMI_1 [KTP400 Basic PN]\Screens\Banda transportadora\Symbolic I/O field_1\Text OFF																																																																																																																																																
0	HMI screen	Proyecto_final\HMI_1 [KTP400 Basic PN]\Screens\Banda transportadora\Symbolic I/O field_2\Text OFF																																																																																																																																																
0	HMI screen	Proyecto_final\HMI_3 [KTP400 Basic PN]\Screens\Empacadora\Symbolic I/O field_1\Text OFF																																																																																																																																																
0	HMI screen	Proyecto_final\HMI_2 [KTP400 Basic PN]\Screens\Revolvedora\Symbolic I/O field_1\Text OFF																																																																																																																																																
1	HMI screen	Proyecto_final\HMI_1 [KTP400 Basic PN]\Screens\Banda transportadora\Symbolic I/O field_1\Text ON																																																																																																																																																
1	HMI screen	Proyecto_final\HMI_1 [KTP400 Basic PN]\Screens\Banda transportadora\Symbolic I/O field_2\Text ON																																																																																																																																																
1	HMI screen	Proyecto_final\HMI_3 [KTP400 Basic PN]\Screens\Empacadora\Symbolic I/O field_1\Text ON																																																																																																																																																

Totally Integrated Automation Portal		
English (United States)	Category	Reference
1	HMI screen	Proyecto_final\HMI_2 [KTP400 Basic PN]\Screens\Revolvedora\Symbolic I/O field_1\Text ON
A	Alarm class text	Proyecto_final\Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName
A	Alarm class text	Proyecto_final\Acknowledgement\ShortName
A	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Errors\AcknowledgedText
A	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Warnings\AcknowledgedText
A	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\System\AcknowledgedText
A	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Diagnosis events\AcknowledgedText
A	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Safety warnings\AcknowledgedText
A	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Errors\AcknowledgedText
A	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Warnings\AcknowledgedText
A	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\System\AcknowledgedText
A	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Diagnosis events\AcknowledgedText
A	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Safety warnings\AcknowledgedText
A	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Acknowledgement\AcknowledgedText
A	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\Acknowledged-Text
A	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Errors\AcknowledgedText
A	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Warnings\AcknowledgedText
A	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\System\AcknowledgedText
A	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Diagnosis events\AcknowledgedText
A	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Safety warnings\AcknowledgedText
A	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Acknowledgement\AcknowledgedText
A	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\Acknowledged-Text
A	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Acknowledgement\AcknowledgedText
A	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\Acknowledged-Text
Activates remote authorization for the use of client-server scenarios.	HMI comment	Proyecto_final\HMI_1 [KTP400 Basic PN]\User administration\Enable remote control\Comment
Activates remote authorization for the use of client-server scenarios.	HMI comment	Proyecto_final\HMI_2 [KTP400 Basic PN]\User administration\Enable remote control\Comment
Activates remote authorization for the use of client-server scenarios.	HMI comment	Proyecto_final\HMI_3 [KTP400 Basic PN]\User administration\Enable remote control\Comment
Adelante	HMI screen	Proyecto_final\HMI_1 [KTP400 Basic PN]\Screens\Banda transportadora\Button_2\Text OFF
Adelante	HMI runtime	Proyecto_final\HMI_1 [KTP400 Basic PN]\Text and graphic lists\Dirección\Text_list_entry_2\Text
Adelante	HMI runtime	Proyecto_final\HMI_2 [KTP400 Basic PN]\Text and graphic lists\Dirección\Text_list_entry_2\Text
Administrator group	HMI runtime	Proyecto_final\HMI_1 [KTP400 Basic PN]\User administration\Administrator group\Display-Name
Administrator group	HMI runtime	Proyecto_final\HMI_2 [KTP400 Basic PN]\User administration\Administrator group\Display-Name
Administrator group	HMI runtime	Proyecto_final\HMI_3 [KTP400 Basic PN]\User administration\Administrator group\Display-Name
Apagado	HMI screen	Proyecto_final\HMI_1 [KTP400 Basic PN]\Screens\Banda transportadora\Switch_1\Text OFF
Apagado	HMI runtime	Proyecto_final\HMI_1 [KTP400 Basic PN]\Text and graphic lists\Estado\Text_list_entry_1\Text
Apagado	HMI runtime	Proyecto_final\HMI_1 [KTP400 Basic PN]\Text and graphic lists\Dirección\Text_list_entry_1\Text
Apagado	HMI runtime	Proyecto_final\HMI_2 [KTP400 Basic PN]\Text and graphic lists\Estado\Text_list_entry_1\Text
Apagado	HMI runtime	Proyecto_final\HMI_2 [KTP400 Basic PN]\Text and graphic lists\Dirección\Text_list_entry_1\Text
Apagado	HMI screen	Proyecto_final\HMI_3 [KTP400 Basic PN]\Screens\Empacadora\Switch_1\Text OFF
Apagado	HMI runtime	Proyecto_final\HMI_3 [KTP400 Basic PN]\Text and graphic lists\Estado\Text_list_entry_1\Text
Apagado	HMI screen	Proyecto_final\HMI_2 [KTP400 Basic PN]\Screens\Revolvedora\Switch_1\Text OFF
Authorization 'User administration' for managing users in the user view in Runtime.	HMI comment	Proyecto_final\HMI_1 [KTP400 Basic PN]\User administration\User administration\Comment
Authorization 'User administration' for managing users in the user view in Runtime.	HMI comment	Proyecto_final\HMI_2 [KTP400 Basic PN]\User administration\User administration\Comment
Authorization 'User administration' for managing users in the user view in Runtime.	HMI comment	Proyecto_final\HMI_3 [KTP400 Basic PN]\User administration\User administration\Comment
Banda transportadora	HMI screen	Proyecto_final\HMI_1 [KTP400 Basic PN]\Screens\Banda transportadora\Text field_6\Text
Botones físicos	Block comment	Proyecto_final\PLC_1 [CPU 1516-3 PN/DP]\Program blocks\Main [OB1]\Network 2\Title
Botones físicos	Block comment	Proyecto_final\PLC_3 [CPU 1215C DC/DC/DC]\Program blocks\Main [OB1]\Network 2\Title
Ciclo main	Block comment	Proyecto_final\PLC_2 [CPU 1215C DC/DC/DC]\Program blocks\Main [OB1]\Network 2\Title
Control de banda transportadora	Block comment	Proyecto_final\PLC_1 [CPU 1516-3 PN/DP]\Program blocks\Main [OB1]\Block title
Control motor	Block comment	Proyecto_final\PLC_1 [CPU 1516-3 PN/DP]\Program blocks\Main [OB1]\Network 1\Title
Control Motor	Block comment	Proyecto_final\PLC_3 [CPU 1215C DC/DC/DC]\Program blocks\Main [OB1]\Network 1\Title
Cuenta	Block comment	Proyecto_final\PLC_3 [CPU 1215C DC/DC/DC]\Program blocks\Main [OB1]\Network 3\Title
DB_control	Block comment	Proyecto_final\PLC_2 [CPU 1215C DC/DC/DC]\Program blocks\Main [OB1]\Network 4\Title
Detección:	HMI screen	Proyecto_final\HMI_3 [KTP400 Basic PN]\Screens\Empacadora\Text field_3\Text
Detección:	HMI screen	Proyecto_final\HMI_2 [KTP400 Basic PN]\Screens\Revolvedora\Text field_3\Text
Dirección:	HMI screen	Proyecto_final\HMI_1 [KTP400 Basic PN]\Screens\Banda transportadora\Text field_3\Text
Empacadora	HMI screen	Proyecto_final\HMI_3 [KTP400 Basic PN]\Screens\Empacadora\Text field_6\Text
Empacadora circular	Block comment	Proyecto_final\PLC_3 [CPU 1215C DC/DC/DC]\Program blocks\Main [OB1]\Block title
Encendido	HMI runtime	Proyecto_final\HMI_1 [KTP400 Basic PN]\Text and graphic lists\Estado\Text_list_entry_2\Text
Encendido	HMI runtime	Proyecto_final\HMI_2 [KTP400 Basic PN]\Text and graphic lists\Estado\Text_list_entry_2\Text
Encendido	HMI runtime	Proyecto_final\HMI_3 [KTP400 Basic PN]\Text and graphic lists\Estado\Text_list_entry_2\Text
Encendio	HMI screen	Proyecto_final\HMI_1 [KTP400 Basic PN]\Screens\Banda transportadora\Switch_1\Text ON
Encendio	HMI screen	Proyecto_final\HMI_3 [KTP400 Basic PN]\Screens\Empacadora\Switch_1\Text ON
Encendio	HMI screen	Proyecto_final\HMI_2 [KTP400 Basic PN]\Screens\Revolvedora\Switch_1\Text ON
Estado:	HMI screen	Proyecto_final\HMI_1 [KTP400 Basic PN]\Screens\Banda transportadora\Text field_2\Text
Estado:	HMI screen	Proyecto_final\HMI_3 [KTP400 Basic PN]\Screens\Empacadora\Text field_2\Text
Estado:	HMI screen	Proyecto_final\HMI_2 [KTP400 Basic PN]\Screens\Revolvedora\Text field_2\Text
Exit	HMI screen	Proyecto_final\HMI_1 [KTP400 Basic PN]\Screen management\Templates\Template_1\Exit\Text OFF
Exit	HMI screen	Proyecto_final\HMI_1 [KTP400 Basic PN]\Screen management\Templates\Template_1\Exit\Text ON
Fin	Block comment	Proyecto_final\PLC_2 [CPU 1215C DC/DC/DC]\Program blocks\Main [OB1]\Network 3\Title
I	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Errors\ComingText
I	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Warnings\ComingText
I	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\System\ComingText

Totally Integrated Automation Portal		
English (United States)	Category	Reference
I	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Diagnosis events\ComingText
I	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Safety warnings\ComingText
I	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Errors\ComingText
I	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Warnings\ComingText
I	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\System\ComingText
I	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Diagnosis events\ComingText
I	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Safety warnings\ComingText
I	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Acknowledgement\ComingText
I	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\ComingText
I	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Errors\ComingText
I	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Warnings\ComingText
I	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\System\ComingText
I	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Diagnosis events\ComingText
I	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Safety warnings\ComingText
I	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Acknowledgement\ComingText
I	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\ComingText
I	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Acknowledgement\ComingText
I	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\ComingText
IO	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Errors\ComingGoingText
IO	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Warnings\ComingGoingText
IO	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\System\ComingGoingText
IO	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Diagnosis events\ComingGoingText
IO	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Safety warnings\ComingGoingText
IO	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Errors\ComingGoingText
IO	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Warnings\ComingGoingText
IO	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\System\ComingGoingText
IO	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Diagnosis events\ComingGoingText
IO	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Safety warnings\ComingGoingText
IO	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Acknowledgement\ComingGoingText
IO	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\ComingGoingText
IO	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Errors\ComingGoingText
IO	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Warnings\ComingGoingText
IO	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\System\ComingGoingText
IO	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Diagnosis events\ComingGoingText
IO	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Safety warnings\ComingGoingText
IO	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Acknowledgement\ComingGoingText
IO	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\ComingGoingText
IO	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Acknowledgement\ComingGoingText
IO	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\ComingGoingText
Monitor	HMI runtime	Proyecto_final\HMI_1 [KTP400 Basic PN]\User administration\Monitor\ShortName
Monitor	HMI runtime	Proyecto_final\HMI_2 [KTP400 Basic PN]\User administration\Monitor\ShortName
Monitor	HMI runtime	Proyecto_final\HMI_3 [KTP400 Basic PN]\User administration\Monitor\ShortName
'Monitor' authorization.	HMI comment	Proyecto_final\HMI_1 [KTP400 Basic PN]\User administration\Monitor\Comment
'Monitor' authorization.	HMI comment	Proyecto_final\HMI_2 [KTP400 Basic PN]\User administration\Monitor\Comment
'Monitor' authorization.	HMI comment	Proyecto_final\HMI_3 [KTP400 Basic PN]\User administration\Monitor\Comment
NA	Alarm class text	Proyecto_final\No Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName
NA	Alarm class text	Proyecto_final\No Acknowledgement\ShortName
O	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Errors\GoingText
O	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Warnings\GoingText
O	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\System\GoingText
O	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Diagnosis events\GoingText
O	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Safety warnings\GoingText
O	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Errors\GoingText
O	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Warnings\GoingText
O	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\System\GoingText
O	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Diagnosis events\GoingText
O	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Safety warnings\GoingText
O	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Acknowledgement\GoingText
O	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\GoingText
O	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Errors\GoingText
O	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Warnings\GoingText
O	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\System\GoingText
O	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Diagnosis events\GoingText
O	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Safety warnings\GoingText
O	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Acknowledgement\GoingText
O	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\GoingText
O	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Acknowledgement\GoingText
O	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\GoingText
Operate	HMI runtime	Proyecto_final\HMI_1 [KTP400 Basic PN]\User administration\Operate\ShortName
Operate	HMI runtime	Proyecto_final\HMI_2 [KTP400 Basic PN]\User administration\Operate\ShortName
Operate	HMI runtime	Proyecto_final\HMI_3 [KTP400 Basic PN]\User administration\Operate\ShortName
'Operate' authorization.	HMI comment	Proyecto_final\HMI_1 [KTP400 Basic PN]\User administration\Operate\Comment
'Operate' authorization.	HMI comment	Proyecto_final\HMI_2 [KTP400 Basic PN]\User administration\Operate\Comment
'Operate' authorization.	HMI comment	Proyecto_final\HMI_3 [KTP400 Basic PN]\User administration\Operate\Comment
Progreso:	HMI screen	Proyecto_final\HMI_3 [KTP400 Basic PN]\Screens\Empacadora\Text field_1\Text
Progreso:	HMI screen	Proyecto_final\HMI_2 [KTP400 Basic PN]\Screens\Revolvedora\Text field_1\Text
QGR	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\Runtime settings\HmiAlarmSettingsData\AcknowledgementGroupText
QGR	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\Runtime settings\HmiAlarmSettingsData\AcknowledgementGroupText
QGR	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\Runtime settings\HmiAlarmSettingsData\AcknowledgementGroupText
Reiniciar	HMI screen	Proyecto_final\HMI_3 [KTP400 Basic PN]\Screens\Empacadora\Button_2\Text OFF
Reiniciar	HMI screen	Proyecto_final\HMI_2 [KTP400 Basic PN]\Screens\Revolvedora\Button_2\Text OFF
Reversa	HMI screen	Proyecto_final\HMI_1 [KTP400 Basic PN]\Screens\Banda transportadora\Button_3\Text OFF
Reversa	HMI runtime	Proyecto_final\HMI_1 [KTP400 Basic PN]\Text and graphic lists\Dirección\Text_list_entry_3\Text

Totally Integrated Automation Portal		
English (United States)	Category	Reference
Reversa	HMI runtime	Proyecto_final\HMI_2 [KTP400 Basic PN]\Text and graphic lists\Dirección\Text_list_entry_3\Text
Revolvedora	Block comment	Proyecto_final\PLC_2 [CPU 1215C DC/DC/DC]\Program blocks\Main [OB1]\Block title
Revolvedora	HMI screen	Proyecto_final\HMI_2 [KTP400 Basic PN]\Screens\Revolvedora\Text field_6\Text
Robot_UR	Block comment	Proyecto_final\PLC_3 [CPU 1215C DC/DC/DC]\Program blocks\Main [OB1]\Network 4\Title
Root screen	HMI runtime	Proyecto_final\HMI_1 [KTP400 Basic PN]\Text and graphic lists\TextList_OriginalScreenNames\Text_list_entry_1\Text
Root screen	HMI runtime	Proyecto_final\HMI_2 [KTP400 Basic PN]\Text and graphic lists\TextList_ScreenNames\Text_list_entry_1\Text
Root screen	HMI runtime	Proyecto_final\HMI_2 [KTP400 Basic PN]\Text and graphic lists\TextList_OriginalScreenNames\Text_list_entry_1\Text
Root screen	HMI runtime	Proyecto_final\HMI_3 [KTP400 Basic PN]\Text and graphic lists\TextList_ScreenNames\Text_list_entry_1\Text
Root screen	HMI runtime	Proyecto_final\HMI_3 [KTP400 Basic PN]\Text and graphic lists\TextList_OriginalScreenNames\Text_list_entry_1\Text
S7	Alarm text	Proyecto_final\HMI_1 [KTP400 Basic PN]\HMI alarms\Diagnosis events\alarmclass name not set_3\AlarmClassData_IDisplayNaming_DisplayName
S7	Alarm text	Proyecto_final\HMI_2 [KTP400 Basic PN]\HMI alarms\Diagnosis events\alarmclass name not set_8\AlarmClassData_IDisplayNaming_DisplayName
S7	Alarm text	Proyecto_final\HMI_3 [KTP400 Basic PN]\HMI alarms\Diagnosis events\alarmclass name not set_13\AlarmClassData_IDisplayNaming_DisplayName
Skip	HMI screen	Proyecto_final\HMI_3 [KTP400 Basic PN]\Screens\Empacadora\Button_3\Text OFF
Skip	HMI screen	Proyecto_final\HMI_2 [KTP400 Basic PN]\Screens\Revolvedora\Button_3\Text OFF
Switch	HMI screen	Proyecto_final\HMI_1 [KTP400 Basic PN]\Screens\Banda transportadora\Switch_1\Caption text
Switch	HMI screen	Proyecto_final\HMI_3 [KTP400 Basic PN]\Screens\Empacadora\Switch_1\Caption text
Switch	HMI screen	Proyecto_final\HMI_2 [KTP400 Basic PN]\Screens\Revolvedora\Switch_1\Caption text
Text	HMI screen	Proyecto_final\HMI_1 [KTP400 Basic PN]\Screens\Banda transportadora\Button_2\Text ON
Text	HMI screen	Proyecto_final\HMI_1 [KTP400 Basic PN]\Screens\Banda transportadora\Button_3\Text ON
Text	HMI screen	Proyecto_final\HMI_3 [KTP400 Basic PN]\Screens\Empacadora\Button_2\Text ON
Text	HMI screen	Proyecto_final\HMI_3 [KTP400 Basic PN]\Screens\Empacadora\Button_3\Text ON
Text	HMI screen	Proyecto_final\HMI_2 [KTP400 Basic PN]\Screens\Revolvedora\Button_2\Text ON
Text	HMI screen	Proyecto_final\HMI_2 [KTP400 Basic PN]\Screens\Revolvedora\Button_3\Text ON
The 'Administrator' group is initially granted all rights.	HMI comment	Proyecto_final\HMI_1 [KTP400 Basic PN]\User administration\Administrator group\Comment
The 'Administrator' group is initially granted all rights.	HMI comment	Proyecto_final\HMI_2 [KTP400 Basic PN]\User administration\Administrator group\Comment
The 'Administrator' group is initially granted all rights.	HMI comment	Proyecto_final\HMI_3 [KTP400 Basic PN]\User administration\Administrator group\Comment
The user 'Administrator' is assigned to the 'Administrator' group.	HMI comment	Proyecto_final\HMI_1 [KTP400 Basic PN]\User administration\Administrator\Comment
The user 'Administrator' is assigned to the 'Administrator' group.	HMI comment	Proyecto_final\HMI_2 [KTP400 Basic PN]\User administration\Administrator\Comment
The user 'Administrator' is assigned to the 'Administrator' group.	HMI comment	Proyecto_final\HMI_3 [KTP400 Basic PN]\User administration\Administrator\Comment
The 'Users' group is initially granted 'Operating' rights.	HMI comment	Proyecto_final\HMI_1 [KTP400 Basic PN]\User administration\Users\Comment
The 'Users' group is initially granted 'Operating' rights.	HMI comment	Proyecto_final\HMI_2 [KTP400 Basic PN]\User administration\Users\Comment
The 'Users' group is initially granted 'Operating' rights.	HMI comment	Proyecto_final\HMI_3 [KTP400 Basic PN]\User administration\Users\Comment
User administration	HMI runtime	Proyecto_final\HMI_1 [KTP400 Basic PN]\User administration\User administration\ShortName
User administration	HMI runtime	Proyecto_final\HMI_2 [KTP400 Basic PN]\User administration\User administration\ShortName
User administration	HMI runtime	Proyecto_final\HMI_3 [KTP400 Basic PN]\User administration\User administration\ShortName
Users	HMI runtime	Proyecto_final\HMI_1 [KTP400 Basic PN]\User administration\Users\DisplayName
Users	HMI runtime	Proyecto_final\HMI_2 [KTP400 Basic PN]\User administration\Users\DisplayName
Users	HMI runtime	Proyecto_final\HMI_3 [KTP400 Basic PN]\User administration\Users\DisplayName
Web access - view only. Authorization for the use of Web Navigator and for client-server systems.	HMI comment	Proyecto_final\HMI_1 [KTP400 Basic PN]\User administration\Web access - view only\Comment
Web access - view only. Authorization for the use of Web Navigator and for client-server systems.	HMI comment	Proyecto_final\HMI_2 [KTP400 Basic PN]\User administration\Web access - view only\Comment
Web access - view only. Authorization for the use of Web Navigator and for client-server systems.	HMI comment	Proyecto_final\HMI_3 [KTP400 Basic PN]\User administration\Web access - view only\Comment

Totally Integrated Automation Portal																																																																																
<div>Proyecto_final / Languages & resources</div> <div>Project graphics</div> <div>Down_Arrow</div> <table><tr><th>Standard graphic</th><th>English (United States)</th></tr><tr><td></td><td></td></tr><tr><td colspan="2">▶ <i>Dithering mode</i></td></tr><tr><td>Same color</td><td>Same color</td></tr><tr><td colspan="2">▶ <i>Smoothing</i></td></tr><tr><td>Disabled</td><td>Disabled</td></tr></table> <div>ExitRuntime_KTP400_Basic_PN_TR</div> <table><tr><th>Standard graphic</th><th>English (United States)</th></tr><tr><td></td><td></td></tr><tr><td colspan="2">▶ <i>Dithering mode</i></td></tr><tr><td>Same color</td><td>Same color</td></tr><tr><td colspan="2">▶ <i>Smoothing</i></td></tr><tr><td>Disabled</td><td>Disabled</td></tr></table> <div>Home</div> <table><tr><th>Standard graphic</th><th>English (United States)</th></tr><tr><td></td><td></td></tr><tr><td colspan="2">▶ <i>Dithering mode</i></td></tr><tr><td>Same color</td><td>Same color</td></tr><tr><td colspan="2">▶ <i>Smoothing</i></td></tr><tr><td>Disabled</td><td>Disabled</td></tr></table> <div>Left_Arrow</div> <table><tr><th>Standard graphic</th><th>English (United States)</th></tr><tr><td></td><td></td></tr><tr><td colspan="2">▶ <i>Dithering mode</i></td></tr><tr><td>Same color</td><td>Same color</td></tr><tr><td colspan="2">▶ <i>Smoothing</i></td></tr><tr><td>Disabled</td><td>Disabled</td></tr></table> <div>Logo of HMI_1</div> <table><tr><th>Standard graphic</th><th>English (United States)</th></tr><tr><td></td><td></td></tr><tr><td colspan="2">▶ <i>Dithering mode</i></td></tr><tr><td>Same color</td><td>Same color</td></tr><tr><td colspan="2">▶ <i>Smoothing</i></td></tr><tr><td>Disabled</td><td>Disabled</td></tr></table> <div>Logo of HMI_2</div> <table><tr><th>Standard graphic</th><th>English (United States)</th></tr><tr><td></td><td></td></tr><tr><td colspan="2">▶ <i>Dithering mode</i></td></tr><tr><td>Same color</td><td>Same color</td></tr><tr><td colspan="2">▶ <i>Smoothing</i></td></tr><tr><td>Disabled</td><td>Disabled</td></tr></table> <div>Logo of HMI_3</div> <table><tr><th>Standard graphic</th><th>English (United States)</th></tr><tr><td></td><td></td></tr></table>			Standard graphic	English (United States)			▶ <i>Dithering mode</i>		Same color	Same color	▶ <i>Smoothing</i>		Disabled	Disabled	Standard graphic	English (United States)			▶ <i>Dithering mode</i>		Same color	Same color	▶ <i>Smoothing</i>		Disabled	Disabled	Standard graphic	English (United States)			▶ <i>Dithering mode</i>		Same color	Same color	▶ <i>Smoothing</i>		Disabled	Disabled	Standard graphic	English (United States)			▶ <i>Dithering mode</i>		Same color	Same color	▶ <i>Smoothing</i>		Disabled	Disabled	Standard graphic	English (United States)			▶ <i>Dithering mode</i>		Same color	Same color	▶ <i>Smoothing</i>		Disabled	Disabled	Standard graphic	English (United States)			▶ <i>Dithering mode</i>		Same color	Same color	▶ <i>Smoothing</i>		Disabled	Disabled	Standard graphic	English (United States)				
Standard graphic	English (United States)																																																																															
																																																																																
▶ <i>Dithering mode</i>																																																																																
Same color	Same color																																																																															
▶ <i>Smoothing</i>																																																																																
Disabled	Disabled																																																																															
Standard graphic	English (United States)																																																																															
																																																																																
▶ <i>Dithering mode</i>																																																																																
Same color	Same color																																																																															
▶ <i>Smoothing</i>																																																																																
Disabled	Disabled																																																																															
Standard graphic	English (United States)																																																																															
																																																																																
▶ <i>Dithering mode</i>																																																																																
Same color	Same color																																																																															
▶ <i>Smoothing</i>																																																																																
Disabled	Disabled																																																																															
Standard graphic	English (United States)																																																																															
																																																																																
▶ <i>Dithering mode</i>																																																																																
Same color	Same color																																																																															
▶ <i>Smoothing</i>																																																																																
Disabled	Disabled																																																																															
Standard graphic	English (United States)																																																																															
																																																																																
▶ <i>Dithering mode</i>																																																																																
Same color	Same color																																																																															
▶ <i>Smoothing</i>																																																																																
Disabled	Disabled																																																																															
Standard graphic	English (United States)																																																																															
																																																																																
▶ <i>Dithering mode</i>																																																																																
Same color	Same color																																																																															
▶ <i>Smoothing</i>																																																																																
Disabled	Disabled																																																																															
Standard graphic	English (United States)																																																																															
