



GENERAL NOTES

- A. REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT LOCATION OF ALL LIGHTING FIXTURES UNLESS NOTED OTHERWISE.
- B. ALL NORMAL LIGHTING CIRCUITS ORIGINATE FROM PANEL LPA UNLESS OTHERWISE NOTED. ALL EMERGENCY LIGHTING CIRCUITS ORIGINATE FROM PANEL ELP UNLESS OTHERWISE NOTED.
- C. LIGHT SWITCHES SHALL BE GROUPED UNDER ONE COMMON FACEPLATE WHERE MORE THAN ONE LIGHT SWITCH IS INDICATED TO BE INSTALLED AT THE SAME LOCATION.
- D. ALL LIGHTING BRANCH CIRCUIT WIRING ASSOCIATED WITH NEW LIGHTING SHALL BE 2W/2, 1W/2W/2 IN 3/4" UNLESS NOTED OTHERWISE.
- E. ALL NIGHT LIGHT AND EXIT SIGNS SHALL BE UNCONTROLLED AND CONNECTED AHEAD OF THE LOCAL LIGHTING CONTROLS.
- F. ALL CONDUITS INSTALLED IN FINISHED AREAS SHALL BE ROUTED CONCEALED UNLESS NOTED OTHERWISE.
- G. ALL PLAN NOTES WILL APPEAR ON ALL DRAWINGS THAT ARE OF THIS TYPE. NUMBERS WILL ALSO BE THE SAME TO PROMOTE CONSISTENCY.
- H. BUILDING WIRING RUNNING THROUGH TENANTS EXPOSED CEILING SHALL BE ENCASED IN EMT CONDUIT, RUN TIGHT TO THE DECK AND BE EITHER PARALLEL OR PERPENDICULAR TO THE STRUCTURE ABOVE. EXPOSED MC CABLE IS NOT ALLOWED.
- I. ALL ELECTRICAL AND TECHNOLOGY INSTALLATIONS ABOVE THE FLOATING CEILING CLOUD AREA SHALL BE INSTALLED HIGH AS POSSIBLE, HIDDEN FROM VIEW BELOW. COORDINATE PAINTING OF INSTALLATIONS WITH GENERAL CONTRACTOR.

PLAN NOTES

- 1. EMERGENCY LIGHTING THIS ROOM/AREA IS SWITCHED VIA THE NORMAL LIGHTING CIRCUIT. PROVIDE A 20A RATED TRANSFER DEVICE RELAY THIS ROOM TO ALLOW NORMAL LIGHTING SWITCHED CIRCUITS TO TRANSFER FULL ON UNSWITCHED EMERGENCY LIGHTING UPON POWER LOSS. TIE TO THE NEAREST UNSWITCHED EMERGENCY LIGHTING CIRCUIT (EMF).
- 2. SURFACE MOUNT BACKBOX, DEVICE, AND CONDUIT LOCATED ON EXTERIOR WALL OF CLOSED AREA.
- 3. CONNECT EXISTING EXIT SIGNAGE TO NEW LIGHTING CIRCUIT WITH-IN SPACE. FIELD VERIFY EXISTING CONDITIONS PRIOR TO WORK.
- 4. CLOSELY COORDINATE LOCATION OF HIGH BAY LIGHTING WITH CORD REEL INSTALLATION. BOTTOM OF LIGHTING AND CORD REEL SHALL BE SAME ELEVATION WITH CORD DROP FROM REEL EXTENDING MINIMUM 6'-0" FROM FINISH FLOOR. PROVIDE A MINIMUM 5'-0" SEPARATION FROM LIGHTING TO CORD REEL ENCLOSURE.

FUQUA  
& PARTNERS  
ARCHITECTS

MEMBER OF THE AMERICAN  
INSTITUTE OF ARCHITECTS

Architecture

Interior Design

Media Visualization

Master Planning

100 Church Street, Suite 700  
Huntsville, Alabama 35801  
(256) 534 3516  
www.fuquaarchitects.com

CUMMINGS AEROSPACE TENANT IMPROVEMENTS  
7100 REDSTONE GATEWAY, SUITE 100  
HUNTSVILLE, AL 35898  
FLOOR PLAN PHASE II - LIGHTING

PROJECT NO: FPA #018-01308-00  
DRAWN: D. STEVENS  
CHECKED: A. YORK  
ISSUE: 100% CONSTRUCTION DOCUMENTS  
DATE: 08.25.2021

REVISIONS

ALABAMA  
REGISTERED  
ELECTRICAL  
ENGINEER  
No. 24780  
J. B. STEVENS  
8/25/2021

SHEET  
E2.1  
OF