

---

# **NSLS-II CSX Beamline Docs Documentation**

***Release 0.1***

**Stuart B. Wilkins**

November 23, 2015



## CONTENTS

<b>1</b>	<b>CSX-1 (23-ID-1) Beamline Documentation</b>	<b>3</b>
1.1	Fast CCD Detector . . . . .	3
<b>2</b>	<b>Indices and tables</b>	<b>7</b>
<b>3</b>	<b>HELP!! The %\$^\$#@% just crashed</b>	<b>9</b>
3.1	Managing IOCs . . . . .	9
3.2	OLog Glassfish Server . . . . .	10
<b>4</b>	<b>UNIX Account Setup</b>	<b>11</b>
4.1	Bash Shell Setup . . . . .	11
<b>5</b>	<b>Downloads</b>	<b>13</b>
<b>6</b>	<b>Indices and tables</b>	<b>15</b>



Contents:



## CSX-1 (23-ID-1) BEAMLINE DOCUMENTATION

Contents:

### 1.1 Fast CCD Detector

#### 1.1.1 Introduction

The FastCCD installed in the endstation at CSX-1 is of the LBNL Fast CCD design. The sensor contains 1920 x 960 pixels of 30  $\mu\text{m}$  x 30  $\mu\text{m}$  and is arranged into two halves of 960 rows by 960 columns with the columns parallel to the long CCD axis. There is one output for each 10 columns (a “super column”) which results in 192 individual outputs and analogue to digital converters (ADC). The CCD camera can either be used in a traditional CCD with an x-ray shutter exposing the full chip, or in a framestore (frame transfer) mode by covering two quarters of the CCD with a light (x-ray) block effectively exposing half the chip along the column direction.

The analogue CCD signal is digitized by a custom designed fCRIC. Each fCRIC has 16 analogue inputs and digitizes with 13 bit precision and had 16 bit dynamic range. This is accomplished by having 3 gain ranges of 8x, 4x and 1x with an auto gain feature. In order to allow negative charge injection. The ADC is biased at a value of approximately 4096 (0x1000 in hex) with the exact value dependent on the ADC channel. The gain settings are stored in the two most significant bits of each ADC reading. The schematic of a single fCRIC channel is shown in the *LBNL fCRIC Circuit Diagram*.



Fig. 1.1: LBNL fCRIC Circuit Diagram

The specifications of the CCD are summarized below:

- Pixel Size: 30  $\mu\text{m}$  x 30  $\mu\text{m}$
- Active Area: 1920 pixels (column) x 960 pixels (row)
- 192 super columns = 192 outputs (480 rows x 10 columns)
- Back illuminated
- 250  $\mu\text{m}$  - 350  $\mu\text{m}$  thickness
- Full well : ~900k  $e^-$  per pixel
- Sensitivity : 6  $e^-$  / ADU for 8x gain (max gain)
- Pixel readout time: 500  $\mu\text{s}$
- Digitization time: 2  $\mu\text{s}$  at 120 Hz
- 100 Hz maximum data collection

### 1.1.2 Data Format

In treating the raw CCD data from the FastCCD there are a few important considerations related to the multi-gain behaviour of the fCRIC amplifier and digitizer. The raw 16 bit values that are recorded in the data file follow the *16 Bit fCRIC Data Format* shown below with the two gain bits following the *fCRIC Gain Setting*.

Table 1.1: 16 Bit fCRIC Data Format

15	14	13	12	11	10	09	08	07	06	05	04	03	02	01	00
G1	G0	ERR	D12	D11	D10	D09	D08	D07	D06	D05	D04	D03	D02	D01	D00

Table 1.2: fCRIC Gain Setting

G1	G0	Gain	Pre-factor
0	0	x8	x1
1	0	x2	x4
1	1	x1	x8

Here the two most significant bits record the gain setting for the encoded value. The least significant 13 bits hold the measured analogue value. The actual value is therefore related to the measured value by:

$$A_{\text{corr}} = G(A_{\text{meas}} - O)$$

where  $A_{\text{corr}}$  is the corrected intensity,  $A_{\text{meas}}$  is the measured value by the ADC,  $G$  is the gain of the ADC and  $O$  is the bias offset.

### 1.1.3 Dark Image Subtraction

Due to the multi gain nature of the fCRIC it is therefore necessary to take 3 dark images at different gain settings to obtain the different ADC offsets under these modes. As the lower gain settings are not subject to considerable contribution due to dark current it is usually justifiable to measure only the highest gain dark image repeatedly. Given 3 dark images for the different gain settings the images the following python pseudo code can be used to correct for dark current and gain:

```
import numpy as np

def subtract_background(image, dark_image, gain = [1, 4, 8]):
    gain_mask_8 = (image & 0xC000) == 0xC000
    gain_mask_4 = (image & 0xC000) == 0x8000
    gain_mask_1 = (image & 0xC000) == 0x0000
```



```
cor_image = image.astype(np.float16)
cor_image -= gain_mask_8 * dark_image[2]
cor_image -= gain_mask_4 * dark_image[1]
cor_image -= gain_mask_1 * dark_image[0]

gain_image = (gain_mask_8 * gain[2]) + (gain_mask_4 * gain[1]) + (gain_mask_1 * gain[0])

return (cor_image * gain_image), gain_image
```

### 1.1.4 Useful Links

- [LBNL Fast CCD Site](#)
- [csxtools python analysis routines](#)
- [libcin low level c driver](#)
- [areaDetector Driver](#)



## INDICES AND TABLES

- `genindex`
- `modindex`
- `search`



## HELP!! THE %\$^\$#@% JUST CRASHED

### 3.1 Managing IOCs

Soft IOCs are managed through the `manage-iocs` script. To obtain a list of softiocs running on a NSLS-II computer use the command `manage-iocs report` an example is shown below for `xf23id1-ioc3`:

```
[swilkins@xf23id1-ioc3 ~]$ manage-iocs report
```

nBASE	IOC	USER	PORT	EXEC
/epics/iocs	apcupsd	root	5000	/epics/iocs/apcupsd/st.cmd
/epics/iocs	cam-diag1	softioc	4202	/epics/iocs/cam-diag1/st.cmd
/epics/iocs	cam-diag6	softioc	4300	/epics/iocs/cam-diag6/st.cmd
/epics/iocs	cam-dif1	softioc	4204	/epics/iocs/cam-dif1/st.cmd
/epics/iocs	cam-dif2	softioc	4205	/epics/iocs/cam-dif2/st.cmd
/epics/iocs	cam-dif3	softioc	4206	/epics/iocs/cam-dif3/st.cmd
/epics/iocs	cam-dif-beam	softioc	4201	/epics/iocs/cam-dif-beam/st.cmd
/epics/iocs	ct-eps	softioc	4002	/epics/iocs/ct-eps/st.cmd
/epics/iocs	es-dg645	softioc	5013	/epics/iocs/es-dg645/st.cmd
/epics/iocs	es-K2611	softioc	4302	/epics/iocs/es-K2611/st.cmd
/epics/iocs	es-tctrl1	softioc	5010	/epics/iocs/es-tctrl1/st.cmd
/epics/iocs	es-vortex	softioc	4301	/epics/iocs/es-vortex/st.cmd
/epics/iocs	mc11	softioc	5001	/epics/iocs/mc11/st.cmd
/epics/iocs	mc12	softioc	5002	/epics/iocs/mc12/st.cmd
/epics/iocs	mc13	softioc	5003	/epics/iocs/mc13/st.cmd
/epics/iocs	omegaM4061	softioc	5012	/epics/iocs/omegaM4061/st.cmd
/epics/iocs	simdetector	softioc	4203	/epics/iocs/simdetector/st.cmd
/epics/iocs	simmotor	softioc	8001	/epics/iocs/simmotor/st.cmd
/epics/iocs	timestamp	softioc	6001	/epics/iocs/timestamp/st.cmd
/epics/iocs	va-bakeout-01	softioc	4001	/epics/iocs/va-bakeout-01/st.cmd
/epics/iocs	zebra	softioc	5011	/epics/iocs/zebra/st.cmd

To connect to the IOC console, telnet to localhost at the port that is shown in the table. For example to connect to the `mc12` console issue the command:

```
[swilkins@xf23id1-ioc3 ~]$ telnet localhost 5002
Trying ::1...
Trying 127.0.0.1...
Connected to localhost.
Escape character is '^]'.
@@@ Welcome to procServ (procServ Process Server 2.6.0)
@@@ Use ^X to kill the child, auto restart is ON, use ^T to toggle auto restart
@@@ procServ server PID: 10584
@@@ Server startup directory: /epics/iocs/mc12
@@@ Child startup directory: /epics/iocs/mc12
@@@ Child "mc12" started as: /epics/iocs/mc12/st.cmd
@@@ Child "mc12" PID: 28044
```

```
@@@ procServ server started at: Tue Oct 20 17:35:25 2015
@@@ Child "mcl2" started at: Fri Nov 13 12:49:49 2015
@@@ 0 user(s) and 0 logger(s) connected (plus you)
```

In order to reboot the IOC, type [CTRL] + X. To leave the console type [CTRL] + ] and type `close` at the `telnet>` prompt

To start all IOCs configured on the system issue the command `sudo manage-iocs startall` and if needed to stop all IOCs issue the command `sudo manage-iocs stopall`

## 3.2 OLog Glassfish Server

To reboot the glassfish server on `xf23id-ca.cs.nsls2.local` execute:

```
swilkins@xf23id-ca:~$sudo su - glassfish
glassfish@xf23id-ca:~$cd glassfish3/bin/
glassfish@xf23id-ca:~/glassfish3/bin$ ./asadmin stop-domain domain1
glassfish@xf23id-ca:~/glassfish3/bin$ ./asadmin stop-domain domain2
glassfish@xf23id-ca:~/glassfish3/bin$ ./asadmin start-domain domain1
glassfish@xf23id-ca:~/glassfish3/bin$ ./asadmin start-domain domain2
```

## UNIX ACCOUNT SETUP

### 4.1 Bash Shell Setup





## DOWNLOADS

Download the CSX Documentation as a PDF



## INDICES AND TABLES

- `genindex`
- `modindex`
- `search`