PREVENTIVE MAINTENANCE SCHEDULE MONTHLY OF GROUND POWER UNI 409 E CUP A (GP)

GSE NUMBER TLM-GP-		SUBJECT	TASK CARD NO.
		SCHEDULE A	GP-409-E-CUP-A-TLM
CHA NO N/A	ENG NO N/A		W.O. NO.

SER NO	HR METER	INSP. TYPE	INTERVAL	EFFECTIVITY	PAGE :
		SVC	250 H / 3 MO	GPU-409-E-CUP	1 of 3

GENERAL

This task include check list on daily check, basic check, shortest repetitive interval until 250 service hours.

A. References :

Reference	Title
GRS-RM-CK-070	Preventive Maintenance for Ground Power Unit (GP) GPU-409-E-CUP

B. Fixtures, Tools, Test and Support Equipment

REFERENCE	DESCRIPTION

C. Consumables Materials

DESCRIPTION	SPECIFICATION

DATE	REPORTED BY	DATE	VERIFIED BY

Thai Lion air

PREVENTIVE MAINTENANCE SCHEDULE MONTHLY OF GROUND POWER UNI 409 E CUP A (GP)

GSE NUMBER TLM-GP-	SER NO	TASK CARD NO. GP-409-E-CUP-A-TLM	W.O. NO.	PAGE : 2 of 3

ITEM	DESCRIPTION	PERFORMED BY
	250 HOURS CHECK	
	Check battery and lead connections	
	Check cooling system	
	Change engine oil	
	Change oil filter	
	Clean fuel strainer	
	Clean exhaust silencer	
	Check V-belt tension	

Thai Lion air

PREVENTIVE MAINTENANCE SCHEDULE MONTHLY OF GROUND POWER UNI 409 E CUP A (GP)

GSE NUMBER TLM-GP-	SER NO	TASK CARD NO. GP-409-E-CUP-A-TLM	W.O. NO.	PAGE : 3 of 3

GENERAL

DEFECT FOUND : ☐ Yes ☐ No

RECTIFICATION : .....

.....

.....

COMPONENT / MATERIAL REQUIRED				
NO.	DESCRIPTION	PART NO.	QTY	S/N NO. / BATCH NO. / P.O NO.

☐ Time Critical ☐ Time Sensitive ☐ Frequently Used ☑ Reference

☐ Doc. Level 1 ☐ Doc. Level 2 ☐ Doc. Level 3 ☑ Doc. Level 4

Please use "✓" upon ticking the box.