PREVENTIVE MAINTENANCE SCHEDULE MONTHLY OF GROUND POWER UNI 409 E CUP C (GP)

GSE NUMBER TLM-GP-		SUBJECT **SCHEDULE C**			TASK CARD NO. GP-409-E-CUP-C-TLM
CHA NO N/A	ENG NO N/A				W.O. NO.
SER NO	HR METER	INSP. TYPE SVC	INTERVAL 1000 H / 12 MO	EFFECTIVITY GPU-409-E-CUP	PAGE : 1 of 5

GENERAL

This task include check list on daily check, basic check, shortest repetitive interval until 1000 service hours.

A. References :

Reference	Title
GRS-RM-CK-070	Preventive Maintenance for Ground Power Unit (GP) GPU-409-E-CUP

B. Fixtures, Tools, Test and Support Equipment

REFERENCE	DESCRIPTION

C. Consumables Materials

DESCRIPTION	SPECIFICATION

DATE	REPORTED BY	DATE	VERIFIED BY

Thai Lion air

PREVENTIVE MAINTENANCE SCHEDULE MONTHLY OF GROUND POWER UNI 409 E CUP C (GP)

GSE NUMBER TLM-GP-	SER NO	TASK CARD NO. GP-409-E-CUP-C-TLM	W.O. NO.	PAGE : 2 of 5

ITEM	DESCRIPTION	PERFORMED BY
	250 HOURS CHECK	
	Check battery and lead connections	
	Check cooling system	
	Change engine oil	
	Change oil filter	
	Clean fuel strainer	
	Clean exhaust silencer	
	Check V-belt tension	
	500 HOURS CHECK	
	Change fuel filter insert (Pre- filter element)	
	Change fuel filter insert (Micro- filter element)	
	Check/clean ventilation	
	Check/clean contactors	
	Check/clean bearing	

Thai Lion air

PREVENTIVE MAINTENANCE SCHEDULE MONTHLY OF GROUND POWER UNI 409 E CUP C (GP)

GSE NUMBER TLM-GP-	SER NO	TASK CARD NO. GP-409-E-CUP-C-TLM	W.O. NO.	PAGE : 3 of 5

ITEM	DESCRIPTION	PERFORMED BY
	Check connection	
	Check out put power cable condition	
	Clean head cable socket	
	Check out put power cable connector	
	Check connector of control board	
	Check beacon light	
	Check warning lamp	
	Check indicating light	
	Clean generator housing	
	Check the voltage and frequency while engine is runing full speed	
	1000 HOURS CHECK	
	Change coolant	
	Check fastenings	
	Check starter, alternator, regurator	

PREVENTIVE MAINTENANCE SCHEDULE MONTHLY OF GROUND POWER UNI 409 E CUP C (GP)

GSE NUMBER TLM-GP-	SER NO	TASK CARD NO. GP-409-E-CUP-C-TLM	W.O. NO.	PAGE : 4 of 5

ITEM	DESCRIPTION	PERFORMED BY
	Check valve clearance and adjust if necessary	
	Check bearing	
X	**3000 HOURS CHECK**	
	Check injector	

Thai Lion air

PREVENTIVE MAINTENANCE SCHEDULE MONTHLY OF GROUND POWER UNI 409 E CUP C (GP)

GSE NUMBER TLM-GP-	SER NO	TASK CARD NO. GP-409-E-CUP-C-TLM	W.O. NO.	PAGE : 5 of 5

GENERAL

DEFECT FOUND : ☐ Yes ☐ No

RECTIFICATION : .....

.....

.....

COMPONENT / MATERIAL REQUIRED				
NO.	DESCRIPTION	PART NO.	QTY	S/N NO. / BATCH NO. / P.O NO.

☐ Time Critical ☐ Time Sensitive ☐ Frequently Used ☑ Reference

☐ Doc. Level 1 ☐ Doc. Level 2 ☐ Doc. Level 3 ☑ Doc. Level 4

Please use "✓" upon ticking the box.