



Tan Jieqi

Task 1 Using the diagrams given in the presentation calculate how much (%) is the effect of applying different modifications (changing the gas, adding an extra pane, using a low emissivity coating) on the U value with respect to a benchmark case of double layer with air and no coating ? (keep the gap thickness to be 13 mm)



From the diagram we can know that

Gap thickness=13mm

When we are changing the gas,

Argon:U_value:2.8-2.65 Percentage:5.4%

Krypton:U_value:2.8-2.6 Percentage:7.1%

When we add an extra pane,

Air:U_value:2.8-1.8 Percentage:35.7%

Task 2 Consider the house that we analysed in the alst two examples, calculate the heating and cooling load of the other windows which are fixed 14.4 m² on the west, fixed 3.6 m² on the south and an operable 3.6 m² on the south (the same window and frame type). How much does the total value change if I change the frame of the window from wooden one to aluminium ?

PIACENZA, Italy

WMO#: 160840

Lat: 44.92N Long: 9.73E Elev: 138 StdP: 99.68 Time Zone: 1.00 (EUW) Period: 89-10 WBAN: 99999

Annual Heating and Humidification Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest month WS/MCDB				MCWS/PCWD	
			99.6%			99%			0.4%		1%		to 99.6% DB	
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)
1	-6.2	-4.8	-11.6	1.4	3.1	-8.8	1.8	1.8	8.8	5.6	7.7	6.2	2.1	250

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.9	33.1	22.7	31.9	22.4	30.3	21.8	24.6	30.2	23.7	29.2	22.9	28.3	2.4	90

Table 10 Peak Irradiance, W/m²

Exposure		Latitude									
		20°	25°	30°	35°	40°	45°	50°	55°	60°	
North	E_D	125	106	92	84	81	85	96	112	136	
	E_d	128	115	103	93	84	76	69	62	55	
	E_t	253	221	195	177	166	162	164	174	191	
Northeast/Northwest	E_D	460	449	437	425	412	399	386	374	361	
	E_d	177	169	162	156	151	147	143	140	137	
	E_t	637	618	599	581	563	546	529	513	498	
East/West	E_D	530	543	552	558	560	559	555	547	537	
	E_d	200	196	193	190	189	188	187	187	187	
	E_t	730	739	745	748	749	747	742	734	724	
Southeast/Southwest	E_D	282	328	369	405	436	463	485	503	517	
	E_d	204	203	203	204	205	207	210	212	215	
	E_t	485	531	572	609	641	670	695	715	732	
South	E_D	0	60	139	214	283	348	408	464	515	
	E_d	166	193	196	200	204	209	214	219	225	
	E_t	166	253	335	414	487	557	622	683	740	
Horizontal	E_D	845	840	827	806	776	738	691	637	574	
	E_d	170	170	170	170	170	170	170	170	170	
	E_t	1015	1010	997	976	946	908	861	807	744	

Table 13 Fenestration Solar Load Factors FF_s

Exposure	Single Family Detached	Multifamily
North	0.44	0.27
Northeast	0.21	0.43
East	0.31	0.56
Southeast	0.37	0.54
South	0.47	0.53
Southwest	0.58	0.61
West	0.56	0.65
Northwest	0.46	0.57
Horizontal	0.58	0.73

General:

We know that

$$\Delta T_{\text{cooling}} = 7.9K$$

$$\Delta T_{\text{heating}} = 24.8K$$

$$DR = 11.9K$$

Fix Window on the west:

Cooling load-

$$q_{\text{window}_w} = A * CF_{\text{window}_w}; A = 14.4m^2$$

$$CF_{\text{window}_w} (\text{HeatTransfer}) = U_{\text{window}_w} (\Delta T_{\text{cooling}} - 0.46DR) = 6.89W/m^2$$

$$P_{XI} \text{window}_w = E_D + E_d = 747;$$

$$SHGC = 0.54; IAC = 1; Ff_s = 0.56$$

$$CF_{\text{window}_w} (\text{wirradiation}) = P_{XI} * SHGC * IAC * Ff_s = 225.9$$

$$q_{\text{window}_w} = A * CF_{\text{window}_w} = A * (CF_{\text{window}_w} (\text{HeatTransfer}) + CF_{\text{window}_w} (\text{wirradiation})) = 3352.17W$$

$$q'_{\text{window}_w} = A * CF'_{\text{window}_w} = A * (CF'_{\text{window}_w} (\text{HeatTransfer}) + CF'_{\text{window}_w} (\text{wirradiation})) = 3499.49$$

Heating load-

$$q_{\text{window}_w} = A * HF_{\text{window}_w} = 1014.22 W$$

$$U_{\text{window}_w} = 3.61; \text{ HSGC} = 0.56$$

$$CF_{\text{window}_w} (\text{HeatTransfer}) = U_{\text{window}_w} (\Delta T_{\text{heating}} - 0.46DR) = 8.76 W / m^2$$

$$q'_{\text{window}_w} = A * HF'_{\text{window}_w} = A * U'_{\text{window}_w} * \Delta T_{\text{heating}} = 1289.2 W$$

Fix Window on the south:

Cooling load-

$$q_{\text{window}_s} = A * CF_{\text{window}_s}; A = 3.6 m^2$$

$$CF_{\text{window}_w} (\text{HeatTransfer}) = U_{\text{window}_w} (\Delta T_{\text{cooling}} - 0.46DR) = 6.89 W / m^2$$

$$P_{Xl} / \text{window}_w = E_D + E_d = 557;$$

$$SHGC = 0.56; IAC = 1; Ff_s = 0.47$$

$$CF_{\text{window}_s} (\text{wrradiation}) = P_{XI} * SHGC * IAC * Ff_s = 146.6$$

$$q_{\text{window}_w} = A * CF_{\text{window}_s} = A * (CF_{\text{window}_s} (\text{HeatTransfer}) + CF_{\text{window}_s} (\text{wrradiation})) \\ = 552.56 W$$

$$q'_{\text{window}_s} = A * CF'_{\text{window}_s} = A * (CF'_{\text{window}_s} (\text{HeatTransfer}) + CF'_{\text{window}_s} (\text{wrradiation})) \\ = 559.2 W$$

Heating load-

$$q_{\text{window}_s} = A * HF_{\text{window}_s} = 253.56 W$$

$$U_{\text{window}_s} = 3.61; \text{ HSGC} = 0.56$$

$$CF_{\text{window}_s} (\text{HeatTransfer}) = U_{\text{window}_s} (\Delta T_{\text{heating}} - 0.46DR) = 8.76 W / m^2$$

$$q'_{\text{window}_s} = A * HF'_{\text{window}_s} = A * U'_{\text{window}_s} * \Delta T_{\text{heating}} = 322.3 W$$

Operable Window on the south:

Cooling load-

$$q_{\text{window}_s} = A * CF_{\text{window}_s}; A = 3.6\text{m}^2$$

$$CF_{\text{window}_s}(\text{HeatTransfer}) = U_{\text{window}_s}(\Delta T_{\text{cooling}} - 0.46DR) = 6.96\text{W/m}^2$$

$$P_{\text{XI}}_{\text{window}_w} = E_D + E_d = 557;$$

$$SHGC = 0.46; IAC = 1: F_{f_s} = 0.47$$

$$CF_{\text{window}_s}(\text{wrradiation}) = P_{\text{XI}} * SHGC * IAC * F_{f_s} = 120.42$$

$$q_{\text{window}_w} = A * CF_{\text{window}_s} = A * (CF_{\text{window}_s}(\text{HeatTransfer}) + CF_{\text{window}_s}(\text{wrradiation})) \\ = 533.97\text{W}$$

$$q'_{\text{window}_s} = A * CF'_{\text{window}_s} = A * (CF'_{\text{window}_s}(\text{HeatTransfer}) + CF'_{\text{window}_s}(\text{wrradiation})) \\ = 558.7\text{W}$$

Heating load-

$$q_{\text{window}_s} = A * HF_{\text{window}_s} = 253.23\text{W}$$

$$U_{\text{window}_s} = 3.61; HSGC = 0.56$$

$$CF_{\text{window}_s}(\text{HeatTransfer}) = U_{\text{window}_s}(\Delta T_{\text{heating}} - 0.46DR) = 11.21\text{W/m}^2$$

$$q'_{\text{window}_s} = A * HF'_{\text{window}_s} = A * U'_{\text{window}_s} * \Delta T_{\text{heating}} = 412.47\text{W}$$