Efficient Feasibility Checking Algorithm of Photovoltaic Array Reconfiguration

Dafang Zhao, Fukohito Ooshita, *Member, IEEE* and Michiko Inoue, *Member, IEEE*

Abstract—Power generation efficiency of photovoltaic (PV) systems is significantly affected buy partial shading and PV cell damage. Partial shading or PV cell damage induces mismatched power generation among PV panels. Conducted bypass diodes under mismatch conditions result in loss of efficiency in power generation. Mismatched PV array can be recovered by re-configuring electrical connections among PV panels in it. In this paper, a feasibility check problem of PV panel reconfiguration is introduced. This problem identifies whether a connection among PV panels can be configured from a given PV module level solution. Proposed algorithm evaluated by comparison with the exhaustive search through random shading distributed PV array. The experimental results demonstrate that proposed algorithm can identify feasible configurations more than 49,000 times faster than the exhaustive search with around 0.5% errors.

Index Terms—PV reconfiguration, partial-shading, mismatch, feasibility, heuristic

I. Introduction

IN recent years, the use of green and renewable energy sources has been increased with the aim to reduce fossil fuel depletion and environment pollution. Photovoltaic (PV) energy is one of the most promising emerging technologies. PV market growth by improvements of converting unlimited solar energy into electrical energy as well as the cost reductions of PV panels.

The use of PV systems for power generation brings many challenges. Due to the nature of PV cell, which is the basic component of PV array. PV system easily suffers from various forms of system faults, which include physical damage, temperature in-homogeneity, or partial shading. Unlike cell damage or other system faults, partial shading sources from cloud, dust or snow are very hard to prevent and predict. Thus, when PV cell could not uniformly generate power when they experience different irradiance or been damaged. This unbalanced working scenario will lead whole system mismatch. Mismatch condition might accelerate heating or aging of PV cells and furthermore hinder operation of maximum power point tracking (MPPT) algorithm, especially when the PV array output P-V curve becomes non-convex [1].

For several series connected PV cells, shaded or damaged cell causing normal cells to produce higher voltages that may reverse bias of "bad" cells. When a large number of series connected cells cause a huge reverse bias across shaded cells, leading to large dissipation of energy in the "bad" cells. This huge energy dissipation occurring in a small area might get overheating or burning of PV cells, or "hot-spots". To protect PV cells from "hot-spots", bypass diode is used to circumvent concentrated energy dissipation. However, the operation of

bypass diode will cause several stop delivering power and generate multiple local maximum power points or the total PV module current are limited by the one of worst "bad" cell. In both situation, available energy is lost. Furthermore, strand bypass diode can not complete eliminate hot-spotting [2].

In order to improve PV system power generation efficiency and protect PV cells from damage, an efficient and effectively PV system manage method is worth to investigate. The key to improve power generation efficiency is to maintain maximum output power. Thus, different maximum power point tracking (MPPT) algorithms have been proposed in this regard. In different MPPT algorithms, P&O [3]–[6]and hill climbing [7]–[9] methods received many attention due to its low complexity and implement cost. Hill climbing and P&O methods are different ways to implement the same fundamental method. Using the approximate linear relationship between V_{OC},I_{SC} and V_{MPP}, I_{MPP}, fractional voltage-based and current-based MPPT are popular due to their linear dependency of PV panel characteristic and irradiance level [10]–[14]. However, under abnormal working condition such as partial shading, it is very hard for conventional MPPT algorithms to find global maximum power point. Meanwhile, without any PV module level improvement, it is impossible to protect PV panel against hot-spotting [15], [16].

Another attractive direction to improve PV system efficiency under different working condition is the reconfiguration of PV arrays. This concept was first proposed by Salameh *et al.* [17] in 1990. Then in 2002, Sherif and Boutros *et al.* proposed a reconfigurable scheme for PV arrays that using transistors as switch network to improve performance [18]. Nguyen *et al.* proposed a method that divide PV array into two parts as the "fixed" part which is static connected PV modules and "adaptive" part that can be attached to "fixed" part with different configurations [19].

In this type of "fixed" - "adaptive" architecture, the mathematical formulation is not clear. Moreover, if the partial shading part is large enough to cover "adaptive" part, this scheme become ineffective. Velasco *et al.* [20]–[22] proposed an principle of operation is referred as "irradiance equalization". Reconfiguration strategy based on this principle aim to relocate the PV panels on the rows so that "irradiance equalization" is achieved. However, optimal configuration requires differences between "row" irradiance level are minimized as shown in [20] therefore it can only be realized on fully reconfigurable array. They proposed algorithm that calculate all possible configurations and stored as look-up table locally. Then, the "best" configuration for real-time shading scenario will be chosen from look-up table. There is no doubt that the number

of possible configurations will increase from the size of the PV array and it will be more difficult to determine the optimal configuration with limited time. Though there are several reconfiguration methods have been proposed, most works consider reconfiguration in PV cell or PV module level. However, those reconfiguration requires a significantly high computation time or a large number of switches to implement reconfiguration. In addition, they require special PV panels with the capability of switching, and cannot be applied to the system constructed with standard PV panels. Orozco-Gutierrez et al. proposed an efficient and effective reconfiguration method [23] where it first selects candidates of configurations using the product of approximated currents and voltages, then finds the best one with precise power simulation. However, these candidates are specified in a PV module level though PV modules could not be fully reconfigured. Actually, we found that some of configuration candidates are not able to be realized. However, the paper [23] does not show any systematic way to identify such a feasibility.

This paper proposes an optimization algorithm to check possibilities of configurations for reconfiguring PV arrays, which uses an approach that limit and sort possible combinations by the index of "Loss-rate". Proposed feasibility checking algorithm can rapidly check feasibility that a given configuration candidate can be actually formed by given PV panels. The experimental results demonstrate the effectiveness of the proposed method where it can identify the feasibility of configurations with a very small false negative rate of less than 1%.

II. PV Array Reconfiguration

In this paper, we use following definition for PV array. A PV array is formed by several PV panels. A PV panel is formed by three series-connected PV modules. A PV module consists of several series-connected PV cells with reverse biased bypass diode. Figure 1 represent the definition introduced above.


Fig. 1: PV array, string, module and panel

III. Feasibility Problem

A. Problem setting

B. Outline of the algorithm

C. Algorithm

IV. Experiment Results

V. Conclusion

The conclusion goes here.

Acknowledgment

The authors would like to thank...

Temp

It is well known that mismatch due to partial shading, soiling, or ageing causes significant losses in the energy yield of photovoltaic (PV) systems [1,2]. Furthermore, mismatches may hinder operation of maximum power point (MPP) tracking algorithms, especially if the power versus output voltage characteristic becomes nonconvex [3]. It has also been shown that, even with commonly used bypass diodes, mismatched cells may become reverse-biased and dissipate power, producing an undesired cell temperature rise or hot spot [4,5]. This may lead to accelerated ageing and reduced reliability of the PV system

References

[1] H. Islam, S. Mekhilef, N. B. M. Shah, T. K. Soon, M. Seyedmahmousian, B. Horan, and A. Stojcevski, "Performance evaluation of maximum power point tracking approaches and photovoltaic systems," *Energies*, vol. 11, no. 2, p. 365, 2018.

[2] K. A. Kim and P. T. Krein, "Reexamination of photovoltaic hot spotting to show inadequacy of the bypass diode," *IEEE Journal of Photovoltaics*, vol. 5, no. 5, pp. 1435–1441, 2015.

[3] N. Kasa, T. Iida, and H. Iwamoto, "Maximum power point tracking with capacitor identificator for photovoltaic power system," 2000.

[4] S. Jain and V. Agarwal, "A new algorithm for rapid tracking of approximate maximum power point in photovoltaic systems," *IEEE power electronics letters*, vol. 2, no. 1, pp. 16–19, 2004.

[5] K. Chomsuwan, P. Prisuwanna, and V. Monyakul, "Photovoltaic grid-connected inverter using two-switch buck-boost converter," in *Conference Record of the Twenty-Ninth IEEE Photovoltaic Specialists Conference, 2002.*, pp. 1527–1530, IEEE, 2002.

[6] O. Wasynezuk, "Dynamic behavior of a class of photovoltaic power systems," *IEEE transactions on power apparatus and systems*, no. 9, pp. 3031–3037, 1983.

[7] E. Koutroulis, K. Kalaitzakis, and N. C. Voulgaris, "Development of a microcontroller-based, photovoltaic maximum power point tracking control system," *IEEE Transactions on power electronics*, vol. 16, no. 1, pp. 46–54, 2001.

[8] W. Teulings, J. Marpinard, A. Capel, and D. O'sullivan, "A new maximum power point tracking system," in *Proceedings of IEEE Power Electronics Specialist Conference-PESC'93*, pp. 833–838, IEEE, 1993.

[9] W. Xiao and W. G. Dunford, "A modified adaptive hill climbing mppt method for photovoltaic power systems," in *2004 IEEE 35th annual power electronics specialists conference (IEEE Cat. No. 04CH37551)*, vol. 3, pp. 1957–1963, Ieee, 2004.

[10] C. Liu, W. Liu, L. Wang, G. Hu, L. Ma, and B. Ren, "A new method of modeling and state of charge estimation of the battery," *Journal of Power Sources*, vol. 320, pp. 1–12, 2016.

[11] K. Kobayashi, H. Matsuo, and Y. Sekine, "A novel optimum operating point tracker of the solar cell power supply system," in *2004 IEEE 35th Annual Power Electronics Specialists Conference (IEEE Cat. No. 04CH37551)*, vol. 3, pp. 2147–2151, IEEE, 2004.

[12] B. Bekker and H. Beukes, "Finding an optimal pv panel maximum power point tracking method," in *2004 IEEE Africon. 7th Africon Conference in Africa (IEEE Cat. No. 04CH37590)*, vol. 2, pp. 1125–1129, IEEE, 2004.

[13] N. Mutoh, T. Matuo, K. Okada, and M. Sakai, "Prediction-data-based maximum-power-point-tracking method for photovoltaic power generation systems," in *2002 IEEE 33rd Annual IEEE Power Electronics Specialists Conference. Proceedings (Cat. No. 02CH37289)*, vol. 3, pp. 1489–1494, IEEE, 2002.

[14] T. Noguchi, S. Togashi, and R. Nakamoto, "Short-current-pulse based adaptive maximum-power-point tracking for photovoltaic power generation system," *IEEJ Transactions on Industry Applications*, vol. 121, no. 1, pp. 78–83, 2001.

[15] C. Olalla, M. N. Hasan, C. Deline, and D. Maksimović, "Mitigation of hot-spots in photovoltaic systems using distributed power electronics," *Energies*, vol. 11, no. 4, pp. 1–16, 2018.

[16] T. Ghanbari, "Permanent partial shading detection for protection of photovoltaic panels against hot spotting," *IET Renewable Power Generation*, vol. 11, no. 1, pp. 123–131, 2016.

[17] Z. Salameh and F. Dagher, "The effect of electrical array reconfiguration on the performance of a PV-powered volumetric water pump," *IEEE Transactions on Energy Conversion*, vol. 5, no. 4, pp. 653–658, 1990.

[18] R. A. Sherif and K. S. Boutros, "Solar module array with reconfigurable tile," Feb. 26 2002. US Patent 6,350,944.

[19] D. Nguyen and B. Lehman, "An adaptive solar photovoltaic array using model-based reconfiguration algorithm," *IEEE Transactions on Industrial Electronics*, vol. 55, no. 7, pp. 2644–2654, 2008.

[20] G. Velasco-Quesada, F. Guinjoan-Gispert, R. Piqué-López, M. Román-Lumbreras, and A. Conesa-Roca, "Electrical PV array reconfiguration strategy for energy extraction improvement in grid-connected PV systems," *IEEE Transactions on Industrial Electronics*, vol. 56, no. 11, pp. 4319–4331, 2009.

[21] G. Velasco, F. Guinjoan, and R. Pique, "Grid-connected pv systems energy extraction improvement by means of an electric array reconfiguration (ear) strategy: Operating principle and experimental results," in *2008 IEEE Power Electronics Specialists Conference*, pp. 1983–1988, IEEE, 2008.

[22] G. Velasco, J. Negroni, F. Guinjoan, and R. Piqué, "Energy generation in pv grid-connected systems: A comparative study depending on the pv generator configuration," in *IEEE International Symposium on Industrial Electronics*, pp. 1025–1030, 2005.

[23] M. L. Orozco-Gutierrez, G. Spagnuolo, J. M. Ramirez-Scarpetta, G. Petrone, and C. A. Ramos-Paja, "Optimized Configuration of Mismatched Photovoltaic Arrays," *IEEE Journal of Photovoltaics*, vol. 6, no. 5, pp. 1210–1220, 2016.