Certificate

Indoor Air Comfort USA

Novacolor mineral finishes

Certified Product

San Marco Group SpA

Via Alta, 10 30020 Marcon (VE), Italy

Applicant

The product complies with Indoor Air Comfort USA requirements for product type, version 1.0 (2023). These include both inspections of factory production control VOC emission testing according to CDPH/EHLB/Standard Method V1.2 and VOC content testing according to the SCAQMD Rule 1113/1168 at regular interval.

Indoor Air Comfort US certification ensures that low product emission requirements are fulfilled and is a sign of the applicant's focus on quality and contribution to a healthy indoor environment.

Compliance with Indoor Air Comfort USA means compliance with VOC requirements defined by LEED v4 and v4.1.

Certified products are in compliance with following limit values for emission testing after 14 days:

TVOC	0.15 mg/m³
TSVOC	0.1 mg/m³
Formaldehyde	9 µg/m³
Total Aldehydes	40 µg/m³
4-Phenylcyclohexene	6 µg/m³
Individual Carcinogens	1 µg/m³ (Category 1A and 1B)
Individual VOC	½ CREL

Exposure scenarios used to model test results:
open plan and private office, school classroom
Wet applied amount: 2 x 230 g/m²

Issue date: 04 December 2024

Validity date: 04 December 2029

Product type: Wall Plaster

Certificate number: IACUS-442-01-08-2024

This certificate is valid as specified if regular surveillance and testing is done.

Thomas Neuhaus
Head of Certification Body

Eurofins Product Testing A/S
Smedeskovvej 38, Gate 9
8464 Galten
Denmark

DANAK
PROD Reg.no. 7054
Member EA MLA

Appendix to Certificate IACUS-442-01-08-2024

San Marco Group SpA

receives the Indoor Air Comfort USA certificate with validity 04 December 2029

for below product group, including subgroups and individual products as listed:

Product group: Novacolor mineral finishes

Product type: Wall Plaster

Products included:

CALCECRUDA,
ERA A PENNELLO,
FLORENZIA,
MARMORINO KS,
MARMUR MEDIO E FINE,
TEODORICO.

The products in this group are based on identical or similar recipe and are produced under equivalent conditions. Grouping of the products and inspection of the production process is part of the Indoor Air Comfort USA certification. A worst-case product, which is representative for the whole group, is being tested frequently.

Eurofins Product Testing A/S
Smedeskovvej 38, Gate 9
8464 Galten
Denmark

DANAK
PROD Reg.no. 7054
Member EA MLA