SARGENTI

Date: November 4, 2026

Project: 15066-26-Centennial, CO

Address: 8283 S. Akron St., Suite 110, Centennial, CO 80112

City Comments – Rev 2 Response Letter

BUILDING

Comment 1:
Construction Documents (IBC 107.1, 107.3.1). Submit a 100 percent construction document set with the "not for construction" designation removed. Each architectural, mechanical, electrical, plumbing and fire alarm sheet shall bear the seal and signature of the responsible Colorado-licensed architect or engineer.
Response 1:
The construction document set will be 100% complete and the "Not for Construction" designation removed. All applicable sheets will be signed and sealed by the responsible Colorado-licensed design professionals.

Comment 2:
Common Path of Egress Travel (IBC 1006.2.1). Two existing exits serve 43 occupants, which is acceptable. Dimension the common path of egress travel from the back-of-house and office to the point where two exit paths are available; the limit is 75 feet in an unsprinklered Group M.
Response 2:
Sheet G003 has been revised to identify and dimension the common path of egress travel from the Office and Back of House to the point where two separate exit paths become available. The common path distances are 35'-2" and 36'-8", both within the 75'-0" maximum permitted by IBC Section 1006.2.1.

Comment 8:
Restroom (A117.1-2017 Sections 603 through 606; IBC 1109.2). Confirm on A502 the 60-inch turning space, water closet centerline of 16 to 18 inches, grab bars, lavatory knee and toe clearances, and door maneuvering clearance at the closer-equipped door.
Response 8:
Please refer to Sheet A402 for the required restroom accessibility dimensions, including the 60" turning space, water closet centerline, grab bar locations, lavatory knee and toe clearances, and door maneuvering clearances in accordance with ICC A117.1-2017.

Comment 9:
Counters (IBC 1109.12.3; A117.1 Section 904.4). Provide a counter section not more than 36 inches high and not less than 36 inches long at the sales counter and consultation counter.
Response 9:
Accessible sales and back/beverage counter details are provided on sheet G002, Detail 6, indicating a max counter height of 34" A.F.F. The proposed consultation areas consist of freestanding furniture and do not include consultation counters

Comment 10:
Doors (IBC 1010.2). Confirm existing exit door hardware is operable from the egress side without a key, tool or special knowledge.
Response 10:

T. 480.678.1373 5840 Legacy Circle, Suite D230, Plano, TX 75024 www.sargarch.com

The existing exit door hardware will be verified to comply with IBC Section 1010.2. A note has been added to sheet A600 requiring all exit doors to be readily operable from the egress side without the use of a key, tool, or special knowledge.

Comment 11:
Interior Finishes and Partitions (IBC 803, Table 803.13, 2211). Provide flame spread classification for slatwall and wall-mounted panels, and show partition bracing to structure above the ceiling.
Response 11:
Sheet A101 has been updated to include a note specifying a minimum Class B flame spread classification for slatwall and wall-mounted decorative panels in accordance with IBC Section 803. Manufacturer fire-rating documentation is referenced. Partition bracing and attachment to the structure above are provided on Sheet A500. Please refer to Detail 5/A500 for Wall Type A3.

FIRE

G000 – Cover Sheet
- Fire notes have been added to the cover sheet.

G003 – Code Analysis & Egress Plan
- Sheet G003 has been updated to identify the existing 3-hour fire-rated demising wall. A note has been added requiring the existing rated assembly to remain and all openings and penetrations to be protected.

D100 – Demolition Plan
- Revised note 12 for panels to be removed per building/electrical comments.

A100 – Construction Floor Plan
- Sheet A100 has been updated to identify the existing 3-hour fire-rated wall to remain. A note has been added requiring the rated assembly to be maintained, all openings and penetrations to be protected, and permanent wall identification to be provided above the ceiling per Sheet A200.
- Updated note from existing to new electrical panel per building/electrical comments.

A102 – Furniture Plan
- Updated note from existing to new electrical panel per building/electrical comments.

A200 – Reflected Ceiling Plan
- Sheet A200 has been updated to include a note requiring permanent identification of the existing 3-hour fire-rated wall above the ceiling, including signage spacing, lettering requirements, and coordination with existing conditions.

END OF NARRATIVE

Melissa Grieco
Assistant Project Manager 1
mgrieco@sargarch.com

T. 480.678.1373 5840 Legacy Circle, Suite D230, Plano, TX 75024 www.sargarch.com