



Electricity Inspection Report

002135

Area	MAHAMA.	Serial No.	002135
Customer ID (account)		Date / Time	14-03-2017
Name, Surname	79.9 KISS FM		
Address	CHUKS WADDELL AVENUE, MAHAMA.		
National ID (passport)		Business / RC No	
Service Center	MPAME	Tariff Group	C1
Code, name (11kV)		Latitude	
Code, name (11/0.4kV)		Longitude	

Meter Status

Meter Number	14201SD8554	Single fase		Residential	
Meter type (PPM)	✓ Actual Units	-5,145.01	Three fase	✓ Commercial	✓
Meter type (POST)	Seals prev/act			MD	

AEDC authorized staff during official operation at customer premises - electricity confirmed as follow:

By pass of meter	* METER FAULTY AND ON NEGATIVE (-5,145.01) * BUT SHOULD BE RE-ACTIVATED. * CUSTOMER NOW ON DIRECT. * ONLY MONTHLY CALCULATED KWH SHOULD BE CAPTURED PLUS THE NEGATIVE SALE OF (-5,145.01 KWH). * NEW METER NEEDS FOR IMMEDIATE REPLACEMENT.	NOTICE: You are disconnected as result of: Theft Integrity Safety No access Outstanding Others
Tampered meter		
Illegal consumer		
CT different with billing		
Damaged CT		
Active / Vacation		
Active / Cut off		
Different tariff group		
Other:	✓	

Type of customer devices

Type of electrical device	Quantity	Power (Watt)
LAMP	7	26
LAMP	1	105
IRON	1	1200
FAN	1	230
AC	7	1450
TRANSMITTER	2	180
SOLAR SYSTEM	1	75

NOTICE:

Your back bill for "loss of revenues" as result of unauthorized use of electricity will be incorporated into your future bill. Unauthorized use of electricity is criminal offence and punishable.

Customer Name, Surname / Signature	Authorized Persons: Name / Signature
79.9 KISS FM	1 ABU CHUKWENKA
	2 HASSAN ALIYE