

QXZF.EX26863 Fire Pump Motors

If you notice a change to your QXZF Listing Card, click here to learn more.

Page Bottom

Fire Pump Motors

See General Information for Fire Pump Motors

NATIONAL FIRE FIGHTING MFG FZ CO

EX26863

PO BOX 17014 JEBEL ALI FREE ZONE DUBAI, UNITED ARAB EMIRATES

Model No.	Outnut	Hz/DC	Volts	FL Amps	Service Factor	Poles	Number of Speeds	RPM	Phases	Ins Class	Prot. Type	Rated Ambient (°C)
(click on a model nu						1	252003			1 2.200	.,,,,	(0)
NMCM501002PO	100hp	50	400- 415	119.8/124.5	1.15	-	1	2940	3	F	-	50
NMCM501252PO	125hp	50	400- 415	143.5	1.15	-	1	2940	3	F	-	50
NMCM501502PO	150hp	50	400- 415	178.6/182.9	1.15	-	1	2940	3	F	-	50
NMCM50152PO	15hp	50	400- 415	19.7	1.15	2	1	2920	3	F	-	50
NMCM502002PO	200hp	50	400- 415	243	1.15	2	1	2940	3	F	-	50
	200hp	50	400- 415	258.2	1.15	2	1	2945	3	F	-	50
NMCM50202PO	20hp	50	400- 415	25.9	1.15	2	1	2920	3	F	-	50
NMCM502502PO	250hp	50	400- 415	302	1.15	2	1	2940	3	F	-	50
NMCM50252PO	25hp	50	400- 415	31.9	1.15	2	1	2930	3	F	-	50
NMCM503002PO	300hp	50	400- 415	355	1.15	-	1	2945	3	F	-	50
NMCM50302PO	30hp	50	400- 415	38.8	1.15	2	1	2930	3	F	-	50
NMCM503502PO	350hp	50	400- 415	451.5	1.15	-	1	2945	3	F	-	50
NMCM50402PO	40hp	50	400- 415	50.5	1.15	2	1	2925	3	F	-	50
	40hp	50	400- 415	50.6	1.15	2	1	2930	3	F	-	50
NMCM50502PO	50hp	50	400- 415	61.3/63	1.15	-	1	2930	3	F	-	50
NMCM50602PO	60hp	50	400- 415	75.4	1.15	2	1	2930	3	F	-	50
	60hp	50	400- 415	75.8	1.15	2	1	2935	3	F	-	50
				-	-	-	-	-	-		-	

NMCM50752PO	75hp	50	100	92.2	1.15	-	1	2940	3	F	-	50	
			415										ı

Trademark and/or Tradename:

Last Updated on 2017-09-27

Questions? Print this page Terms of Use Page Top

© 2017 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a nonmisleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2017 UL LLC".