



HMRZ.EX6704 Gate Valves

Page Bottom

Gate Valves

[See General Information for Gate Valves](#)

SHIELD FIRE SAFETY & SECURITY LTD

EX6704

REDBURN HOUSE
2A TONBRIDGE ROAD
ROMFORD, ESSEX RM3 8QE UNITED KINGDOM

Pattern	Model	Size, in.	End Configuration	Rated Pressure, psig
NRS	SD-NRS175GV	2-1/2, 3, 4, 6, 8, 10	Flanged and Mechanical	175
OS&Y	SD-OSY175GV	2, 2-1/2, 3, 4, 6, 8, 10, 12	Flanged	175
OS&Y	SDOSY-T	3/4, 1, 1-1/4, 1-1/2, 2	Threaded	175
OS&Y	SD-OSY250GV-D	2-1/2, 3, 4, 6, 6-1/2, 8, 10, 12	Flanged	250
NRS	SD-NRS200FF-D	2.5, 3, 4, 5, 6, 8, 10, 12	F by F (ANSI Flange)	200
NRS	SD-NRS250FF-D	2.5, 3, 4, 5, 6, 8, 10, 12	F by F (ANSI Flange)	250
NRS	SD-NRS300FF-D	2.5, 3, 4, 5, 6, 8, 10, 12	F by F (ANSI Flange)	300
NRS	SD-NRS200GG-D	2.5, 3, 4, 5, 6, 8, 10, 12	G by G	200
NRS	SD-NRS250GG-D	2.5, 3, 4, 5, 6, 8, 10, 12	G by G	250
NRS	SD-NRS300GG-D	2.5, 3, 4, 5, 6, 8, 10, 12	G by G	300
NRS	SD-NRS200FG-D	2.5, 3, 4, 5, 6, 8, 10, 12	F by G (ANSI Flange)	200
NRS	SD-NRS250FG-D	2.5, 3, 4, 5, 6, 8, 10, 12	F by G (ANSI Flange)	250
NRS	SD-NRS300FG-D	2.5, 3, 4, 5, 6, 8, 10, 12	F by G (ANSI Flange)	300
OS&Y	SD-OSY200FF-D	2, 2.5, 3, 4, 5, 6, 8, 10, 12	F by F (ANSI Flange)	200
OS&Y	SD-OSY250FF-D	2, 2.5, 3, 4, 5, 6, 8, 10, 12	F by F (ANSI Flange)	250
OS&Y	SD-OSY300FF-D	2, 2.5, 3, 4, 5, 6, 8, 10, 12	F by F (ANSI Flange)	300
OS&Y	SD-OSY200GG-D	2, 2.5, 3, 4, 5, 6, 8, 10, 12	G by G	200
OS&Y	SD-OSY250GG-D	2, 2.5, 3, 4, 5, 6, 8, 10, 12	G by G	250
OS&Y	SD-OSY300GG-D	2, 2.5, 3, 4, 5, 6, 8, 10, 12	G by G	300
OS&Y	SD-OSY200FG-D	2, 2.5, 3, 4, 5, 6, 8, 10, 12	F by G (ANSI Flange)	200
OS&Y	SD-OSY250FG-D	2, 2.5, 3, 4, 5, 6, 8, 10, 12	F by G (ANSI Flange)	250
OS&Y	SD-OSY300FG-D	2, 2.5, 3, 4, 5, 6, 8, 10, 12	F by G (ANSI Flange)	300
NRS	SD-NRSFF-PN16	2.5, 3, 4, 5, 6, 8	F by F (BS Flange)	300
NRS	SD-NRS250FF-PN16	10, 12	F by F (BS Flange)	250
NRS	SD-NRS200FF-PN16	2.5, 3, 4, 5, 6, 8, 10, 12	F by F (BS Flange)	200
OS&Y	SD-OSYFF-PN16	2, 2.5, 3, 4, 5, 6, 8	F by F (BS Flange)	300
OS&Y	SD-OSY250FF-PN16	10, 12	F by F (BS Flange)	250

OS&Y	SD-OSY200FF-PN16	2, 2.5, 3, 4, 5, 6, 8, 10, 12	F by F (BS Flange)	200
NRS	SD-NRSGG-PN16	2.5, 3, 4, 5, 6, 8	G by G	300
NRS	SD-NRS250GG-PN16	10, 12	G by G	250
NRS	SD-NRS200GG-PN16	2.5, 3, 4, 5, 6, 8, 10, 12	G by G	200
OS&Y	SD-OSYGG-PN16	2, 2.5, 3, 4, 5, 6, 8	G by G	300
OS&Y	SD-OSY250GG-PN16	10, 12	G by G	250
OS&Y	SD-OSY200GG-PN16	2, 2.5, 3, 4, 5, 6, 8, 10, 12	G by G	200
NRS	SD-NRS250FG-PN16	10, 12	F by G (BS Flange)	250
OS&Y	SD-OSY250FG-PN16	10, 12	F by G (BS Flange)	250
NRS	SD-NRSFG-PN16	2.5, 3, 4, 5, 6, 8	F by G (BS Flange)	300
NRS	SD-NRS200FG-PN16	2.5, 3, 4, 5, 6, 8, 10, 12	F by G (BS Flange)	200
OS&Y	SD-OSYFG-PN16	2, 2.5, 3, 4, 5, 6, 8	F by G (BS Flange)	300
OS&Y	SD-OSY200FG-PN16	2, 2.5, 3, 4, 5, 6, 8, 10, 12	F by G (BS Flange)	200
NRS	SD-NRS300GV-D	2-1/2, 3, 4, 6, 8, 10, 12	Flanged	300
NRS	SD-NRS250GV-D	2-1/2, 3, 4, 6, 8, 10, 12	Flanged	250
NRS	SD-NRS200GV-D	2-1/2, 3, 4, 6, 8, 10, 12	Flanged	200
NRS	SD-NRS175GV-D	2-1/2, 3, 4, 6, 8, 10, 12	Flanged	175
OS&Y	SD-OSY300GV-D	2-1/2, 3, 4, 6, 8, 10, 12	Flanged	300
OS&Y	SD-OSY200GV-D	2-1/2, 3, 4, 6, 8, 10, 12	Flanged	200
OS&Y	SD-OSY175GV-D	2-1/2, 3, 4, 6, 8, 10, 12	Flanged	175
NRS	SD-NRS250GG-D1	14, 16	GRV By GRV	250
NRS	SD-NRS250FG-D1	14, 16	FLG By GRV	250
NRS	SD-NRS150FF-D1	16	FLG by FLG	150
NRS	SD-NRS250FF-D1	14, 16	FLG By FLG	250
OS&Y	SD-OSY250GG-D1	14, 16	GRV By GRV	250
OS&Y	SD-OSY250FG-D1	14, 16	FLG By GRV	250
OS&Y	SD-OSY250FF-D1	14, 16	FLG By FLG	250

*NRS valve provided with a Post Indicator Flange.

Last Updated on 2014-08-26

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2014 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2014 UL LLC".