Loss Prevention Certification Board

LPCB This is to certify

NAFFCO FZ Co

PO Box 17014, Jebel Ali, Dubai, UAE

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix.

Inlet breechings for dry riser inlets

(refer to attached appendix for details)

which have complied with the requirements of the following:

BS 5041-3:1975 - Fire hydrant systems equipment — Part 3: Specification for Inlet breechings for dry riser inlets

Certificate No. 463f

Issue No. 02

Date of Issue 4th December 2013

This certificate is valid until withdrawn by LPCB. To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of LPCB

B W Lywood

LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100 Fax +44 (0)1923 664603 www.RedBookLive.com This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board

LPCB

APPENDIX TO CERTIFICATE NO. 463f

NAFFCO FZ Co

Model	Description	LPCB Ref. No.
NDR 095 (1)	4" X 2 way inlet breeching	463f/01
NWR 115 (1)	6" x 4 way inlet breeching	463f/02
NWRX 115 (1)	6" x 4 way inlet breeching	463f/03

Notes:

1) Nominal working pressure is 10 bar

This certificate is valid until withdrawn by LPCB. To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of LPCB

Page 2 of 2

Date of Issue 4th December 2013

B W Lywood

Issue No. 02

LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100 Fax +44 (0)1923 664603 www.RedBookLive.com This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.