

Protocol on piece verification

ČSN EN 61439-1 ed.3; ČSN EN 61439-2 ed.3


Switchboard manufacturer:	AUTEL montáže, a.s. Oldřichovice 790, 73961 Třinec	ID number: 61944360
Model:	R2 – TDI1/13	
Name:	20CJJ01GH001F÷5F, 20CJJ01GH001R÷5R	
Serial number:	125/26	
Order:	26053	

Piece verification:

Test number:	Article from the standard:	Requirement for the above-mentioned standards:	Result: (✓ = yes/passed)
1	11.2	degree of protections against contact with hazardous live parts, ingress of solid foreign bodies and water of enclosures	✓
2	11.3	air distances and surface passages	✓
3	11.4	protection against injury by electric current and integrity of protective circuits	✓
4	11.5	installing built-in components	✓
5	11.6	internal electric circuits and joints	✓
6	11.7	terminals for external conductors	✓
7	11.8	mechanical function	✓
8	11.9	dielectric properties	✓
9	11.10	connection, working characteristics and functions	✓
10	6.2.1	documentation for the switchboard is provided	✓

Measuring device used: MultiServicer MI2170 series number: 14031080

Verified by: PYSZKO PETR

Signature: 

Třinec, date 29.7.2026

AUTEL montáže, a.s.

Oldřichovice 790

739 61 Třinec

5 DIČ: CZ61944360

Production Manager
Tomčala M.