

HORIZONTAL JOINT AT RECESSED WINDOW FACING COURTYARD ON BUILDING F HAS NO SILL FLASHING. SILL FLASHING IS REQUIRED AT ALL HORIZONTAL JOINTS. REMOVE SIDING AND INSTALL FLASHING.

