



All areas noted with arrows have unsealed seam in WRB or WRB to SAM. These are the likely areas of water penetration during water testing