



AS DISCUSSED ON SITE
05/06/2021, FIRE SPRINKLER
SHOULD BE MOVED OVER
SIDEWALK AND OUT OF THE
DOOR SWING.