



FIRE SPRINKLER PIPE IS WAY TO LOW AND NOT INSTALLED PER OUR CONVERSATION ON SITE WITH JET FIRE. LMC TO SCHEDULE A MEETING WITH JET FIRE TO DISCUSS MOVING/REINSTALLING.

PHOTO TAKEN ON GROUND FLOOR OF BUILDING B TUCK-UNDER PARKING