



AS DISCUSSED ON SITE
05/06/2021, FIRE SPRINKLER
SHOULD BE MOVED OVER
SIDEWALK AND OUT OF THE
DOOR SWING.

AS DISCUSSED ON SITE
05/06/2021, FIRE SPRINKLER
SHOULD BE PUSHED UP AS
HIGH AS POSSIBLE SO NO ONE
CAN HANG ON PIPE. INSTALL
DRAIN VALUE IF NECESSARY.
JETFIRE TO CONFIRM CODE
REQUIREMENTS.